



**TETRA TECH**

*Complex World, Clear Solutions*

*Leading with Science*

# **Malfunction Abatement Plan for EU-Incinerator**

## **City of Warren Wastewater Treatment Plant**

**August 2021**

**Prepared for:**



39395 W. Twelve Mile Road, Suite 103  
Farmington Hills, MI 48331  
(877) 633-5520

# Malfunction Abatement Plan For EU-Incinerator

At the  
City of Warren, Michigan  
Wastewater Treatment Plant

**AUGUST 2021**

209-4201861

## **PRESENTED TO**

---

City of Warren Wastewater Treatment Plant  
32360 Warkop Ave  
Warren, Michigan 48093

## **SUBMITTED BY**

---

Tetra Tech  
39395 W Twelve Mile Road  
Farmington Hills, MI

P +1 248 991-9702  
F +1.877.845.1456  
tetrattech.com

## **REPORT CERTIFICATION**

---


The material and data in this document were prepared under the supervision and direction of the undersigned.



---

Edward (Ted) Bishop  
Senior Project Manager

9/16/2021



---

Brian Rubel, P.E.  
Client Manager

9/16/2021

## TABLE OF CONTENTS

---

1.0	INTRODUCTION .....	1
2.0	RESPONSIBLE PERSONNEL .....	3
3.0	KEY MONITORED PROCESS PARAMETERS.....	4
4.0	MALFUNCTION ABATEMENT SUMMARY .....	6
5.0	PREVENTATIVE MAINTENANCE .....	8
6.0	IMPLEMENTATION OF AND UPDATES TO PLAN.....	11

## APPENDICES

---

**Appendix A** Incinerator and Scrubber Spare Parts

**Appendix B** Operational Checklists and Routine Maintenance

## ACRONYMS, ABBREVIATIONS, AND LETTER SYMBOLS

Acronyms/Abbreviations	Definition
AQD	Air Quality Division
EGLE	Michigan Department of <u>E</u> nvironment, <u>G</u> reat <u>L</u> akes, and <u>E</u> nergy
MAERS	Michigan Air Emissions Reporting System
CFR	code of federal regulations
EPA	United States Environmental Protection Agency
HAP	hazardous air pollutant
HHV	higher heating value
LHV	lower heating value
MAP	Malfunction Abatement Plan
MW	molecular weight
NAAQS	National Ambient Air Quality Standards
NESHAP	National Emission Standards for Hazardous Air Pollutants
NSPS	New Source Performance Standards
PSD	Prevention of Significant Deterioration
ROP	Renewable operating permit (Title V operating permit)
SCADA	Supervisory control and data acquisition
SSI	Sewage sludge incinerator
WWTP	Wastewater treatment plant
STP	Standard temperature and pressure
°C	degrees Celsius
acfm	actual cubic feet per minute
atm	atmosphere
atm-ft <sup>3</sup> /lb-mol-R	atmosphere cubic foot per pound mole Rankine
Btu	British thermal unit
cal/s	calorie per second
CO	carbon monoxide
dscfm	dry standard cubic foot, feet per minute
ft	foot, feet
ft/min	foot per minute
ft/s	foot per second
ft <sup>3</sup>	cubic foot
gpm	gallon per minute
g	gram
g/dscm	grams per dry standard cubic meter
hr	hour
in	inch

°K	Kelvin (temperature)
lb/hr	pound(s) per hour
m	meter
m/s	meter(s) per second
m <sup>3</sup>	cubic meter(s)
mg	milligram
Mg	megagram (metric ton)
mi	mile(s)
min	minute (s)
mm	millimeter
MM	million
mol	mole
MT	metric ton (megagram)
NO <sub>2</sub>	nitrogen dioxide
NO <sub>x</sub>	nitrogen oxides
Pb	lead
PM	particulate matter (TSP)
PM <sub>10</sub>	particulate matter ≤ 10 microns
PM <sub>2.5</sub>	particulate matter ≤ 2.5 microns
ppbv	parts per billion by volume
ppbw	parts per billion by weight
ppmv	parts per million by volume
ppmw	parts per million by weight
°R	Rankine (temperature)
R	universal gas constant
scf	standard cubic foot
scfm	standard cubic feet per minute
sec	second
SO <sub>2</sub>	sulfur dioxide
tpd, ton/day	ton(s) per day
tph, ton/hr	ton(s) per hour
tpy, TPY	ton(s) per year
TSP	total suspended particulate (PM)
μg	microgram
μg/dsl	microgram per dry standard liter
μg/m <sup>3</sup>	microgram per cubic meter
VOC	volatile organic compound
yd <sup>3</sup>	cubic yards

## 1.0 INTRODUCTION

The City of Warren, Michigan currently operates a Wastewater Treatment Plant Sewage Sludge Incinerator that combusts waste sludge generated in the water treatment process, the residual of which can then be disposed of as ash. This document contains the Incineration Process Malfunction Abatement Plan to be used at the City of Warren Wastewater Treatment Plant, 32360 Warkop Ave, Warren, Michigan 48093. The plan's purpose is to assure compliance with the EU-Incinerator emission limits in the event of a malfunction or failure of any part of the incineration process that would affect air emissions.

As required by Permit to Install (PTI) No. 23-21, issued on June 15, 2021, Process/Operational Restriction No. III.1:

1. *The permittee shall not operate EU-Incinerator unless a malfunction abatement plan (MAP) as described in Rule 911(2).....and... the MAP shall, at a minimum, specify the following:*

a. *A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.*

b. *An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.*

c. *A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.*

*If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.*

Rule 911 of the State of Michigan Air Pollution Control Rules requires the Warren WWTP to have a Malfunction Abatement Plan (MAP) in place, "to prevent, detect, and correct malfunctions or equipment failures resulting in emissions exceeding any applicable emission limitation."

The MAP is divided into four sections as follows:

**Section 2:** Provides the identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of the incinerator process and control equipment.

**Section 3:** Represented by Table 3-1, Key Monitored Process Parameters, this section relates to R336.1911 (2)(b) and Condition III.1.b and delineates, “the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.”

The Operations personnel at the Warren WWTP have determined, through training and experience, the incineration process parameters whose variance may have an effect on the incinerator emissions. These parameters are shown in column 1 of Table 3-1.

Columns 2 to 7 contain information regarding the device or method used to monitor a given process parameter in column 1, the location of such device, the frequency of monitoring, the normal range of the process parameter and the malfunction range for a given parameter.

The value of a given parameter is indicative of either normal operation or malfunction or failure of the process. Table 3-1 contains fields for both the normal operating range and the malfunction range for each monitored process parameter. If any of these parameter’s values fall within the particular parameter’s malfunction range, remedial action must be taken to prevent a deviation from emission limitations.

**Section 4:** Represented by Table 4-1, Malfunction Abatement Summary, this section relates to the action(s) to be taken, as required under R336.1911(2)(c) and Condition III.1.c., in the event that one or more of the monitored Process Parameters value(s) in Table 3-1 enters its malfunction range.

**Section 5:** Table 5-1, Preventative Maintenance Summary, is a summary of the preventative maintenance to be performed on devices whose failure may potentially contribute to emission deviations. The maintenance program relates to requirement (2)(a) of R 336.1911 and Condition III.1.a.

In addition, a spare parts listing is provided in **Appendix A** for use in the maintenance of devices listed in Table 5-1. The parts listing relates to requirement (2)(a) of R336.1911 and Condition III.1.a. Note that the Warren WWTP reserves the right to purchase spare parts from any company offering acceptable replacement parts. The quantity of parts on hand varies depending on the known frequency of repairs, the lead time to obtain replacement parts, the cost of parts, and whether repairs can be done in-house or need to be done by manufacturer certified technicians. The Warren WWTP reserves the right to have suppliers expedite delivery of parts from their factory or warehouse in lieu of storing onsite.

**Appendix B** provides some of the operational checklists that are used to track operational data on the incinerator and scrubber and other related items for maintenance and daily observations on equipment.

## 2.0 RESPONSIBLE PERSONNEL

The supervisory personnel responsible for overseeing the inspection, maintenance, and repair of the incinerator and control equipment are listed below:

<b>Name</b>	<b>Title</b>	<b>Phone Number</b>
Bryan Clor	Division Manager	586-264-2530 ext. 8103
Bob Dranberg	Chief Operator	586-264-2530 ext. 8106
Gerry Dunne	Mechanical Supervisor	586-264-2530 ext. 8130
Jason Tobolski	IT/Electrical Supervisor	586-264-2530 ext. 8108



## 3.0 KEY MONITORED PROCESS PARAMETERS

The key parameters that are monitored for the process and control of the incinerator at the Warren WWTP are listed below in Table 3-1.

The Warren WWTP facility SCADA system allows the information gathered by detection devices/sensors to be processed, distributed, and displayed so that operators and supervisors can monitor, record, and analyze data necessary for operational and environmental purposes.

**Table 3-1. Key Monitored Process Parameters**

Process Parameter	Monitoring Device	Process/Control Equipment Monitored	Device Location	Frequency of Monitoring	Normal Operating Range	Malfunction or Abnormal Range
Combustion Zone Temp	Thermocouples	Incinerator	Hearths 4, 5, 6	Continuous	1400 – 1600 °F	< 1225 °F
Feed Rate	Weigh Scales	Incinerator	Feed Conveyers	Continuous	4 – 6 wet tph	Below 1; Above 7 tph
Scrubber Differential Pressure	Pressure Gauges/Transmitters	Scrubber	Inlet/Outlet	Continuous	22 – 28 inches WC	< 22.0 in wc
Water Flow Rate	Electromagnetic Flow Measurement System	Scrubber	Various	Continuous	750 – 900 gpm	< 750 gpm
Effluent pH	pH Probe	Scrubber	Effluent Discharge	Continuous	6.2 to 7	< 6.0
Ash Buildup	Level Sensor	Scrubber	Ash Hopper	Continuous	Normal ash level	Buildup or no ash discharging
THC Monitoring	THC CEMS	Scrubber	Scrubber Stack	Continuous	30 – 70 ppm	> 150 ppm
Bypass Stack	Camera / alarm	Incinerator	Incinerator 4 <sup>th</sup> Floor	Continuous	Closed	Open

## 4.0 MALFUNCTION ABATEMENT SUMMARY

This section relates to R 336.1911(2)(c) and Table 4-1 below details the action(s) to be taken in the event that one or more of the monitored Process Parameters value(s) in Table 3-1 enters its malfunction range.

**Table 4-1. Malfunction Abatement Summary**

Process Condition	Possible Cause(s)	Process or Control Equipment Monitored	Means of Detection	Corrective Action
Low Combustion Zone Temp	Feed rate increase or lower cake solids	Incinerator	PLC	Decrease water content of feed; reduce feed rate if necessary
Low Combustion Zone Temp	Low burner use profiles	Incinerator	PLC	Increase number of burners in use and/or firing rates as needed.
Low Combustion Zone Temp	Feed rate increase or lower cake solids	Incinerator	PLC	Increase number of burners in use and/or firing rates as needed; or, if necessary, reduce feed rate
High Combustion Zone Temp	Lost feed, burner use profile, or change in cake solids	Incinerator	PLC	Restore feed or reduce number of burners and/or firing rates
No Feed	Conveyer stopped feeding	Incinerator	PLC or visual inspection	Restart conveyers; check for sensor fouling; repair torn belt
Low Scrubber Differential Pressure	Various process changes	Scrubber	PLC	Increase draft and venturi differential pressure set points
Low Scrubber Water Flow Rate	Incorrect settings or loss in water supply pressure	Scrubber	PLC	Increase flow settings and/or restore water supply pressure; check water filters for fouling and clean if necessary
Low Combustion Air Supply	Air supply system	Incinerator	PLC	Check functionality of variable feed drive (VFD) on fan; bypass fan control until repair made
Low effluent pH	Need more water; possible probe issue	Scrubber	PLC	Take grab sample and analyze; increase water flow settings if possible
Ash Buildup	Ash system not removing ash properly	Scrubber	PLC or visual inspection	Check ash system. If not working, Stop Feed, Stop Shaft and Control Burn Out, and place In Standby Mode Before Corrective Maintenance Begins
THC Monitor Malfunction	Check instrument components	Scrubber	PLC / CEMS	Initiate corrective action to bring system back online; contact Trace Environmental for assistance
Bypass Stack Open	ID fan failure; air compressor failure	Incinerator	Camera / PLC	Manual operation of ID fan; initiate backup compressor

## 5.0 PREVENTATIVE MAINTENANCE

This section relates to R 336.1911(2)(a) and Table 5-1 below is a summary of the preventative maintenance to be performed on devices whose failure may potentially contribute to emission deviations.

Currently, the Division Head of the Warren WWTP requires a weekly operations update of all outstanding and/or recent issues that need to be addressed at the plant or have been addressed. The material in the update is reviewed early in the week in order to assess what actions are necessary and priorities for the week. In addition, the Division Head conducts an in-person meeting once every two weeks with the Supervisors of the following areas to discuss operations, including the incinerator and control devices:

- Electrical / IT Supervisor
- Maintenance Supervisor
- Operations Supervisor
- Laboratory Supervisor
- Engineering Supervisor
- IPP (Industrial Pretreatment Program) Supervisor

In addition, as a requirement under NSPS Subpart M MMM, the incinerator scrubber must undergo a complete inspection on an annual basis to ensure proper operation of all scrubber functions. This inspection report is submitted annually with the Warren WWTP Subpart M MMM Annual Compliance Report.

**Table 5-1. Preventative Maintenance Summary**

Maintained Equipment	Maintenance Task	Frequency	Supervisor Responsible
Cake feed scale	Mechanical inspection / adjustment	Annual	Operations/Contractor
Induced draft fan	Vibration analysis	Semi-annual	Electrical Dept
	Grease bearings	Semi-annual	Electrical Dept
Incinerator gas burner	Mechanical inspection of burners	Annual	Electrical Dept
Bypass damper	Pneumatic system check	Annual	Maintenance Dept
Incinerator center shaft drive	Center shaft drive lubrication	Quarterly	Operations
Venturi nozzle	Nozzle inspection	Annual	Operations
Pre-cooler nozzles	Nozzle inspection	Annual	Operations
Burner combustion air fan	Grease bearings & mechanical inspection	Semi-annual	Electrical Dept
	Vibration analysis	Semi-annual	Electrical Dept
Centershaft bearings	Shaft bearing lube & mechanical check	Semi-annual	Operations and Mechanical Dept
Center shaft cooling air fan	Vibration analysis	Semi-annual	Electrical Dept
	Mechanical inspection – belt drive	Semi-annual	Electrical Dept
	Mechanical inspection – sheave alignment	Semi-annual	Electrical Dept

**Table 5-1 (continued). Preventative Maintenance Summary**

Maintained Equipment	Maintenance Task	Frequency	Supervisor Responsible
Center shaft cooling air fan	Fan lubrication	Semi-annual	Electrical Dept and Operations
	Sensory check of fan	Annual	Electrical/Contractor
Combustion air fan	Vibration analysis	Semi-annual	Electrical Dept
	Mechanical inspection – belt drive	Semi-annual	Electrical Dept
Ash Pumps	Vibration analysis	Semi-annual	Electrical Dept
	Mechanical inspection – belt drive	Semi-annual	Electrical Dept
	Mechanical inspection – sheave alignment	Semi-annual	Electrical Dept
	Pump packing inspection	Annual	Electrical Dept and Operations
Scrubber	Scrubber skid pumps – vibration analysis	Semi-annual	Operations
	Scrubber skid pumps – grease motors	Semi-annual	Operations
	Scrubber skid pumps – inspect filters	Weekly	Operations
Scrubber Lances	Inspect and clean	Annual	Operations
Scrubber Mist Eliminator	Inspect and clean	Annual	Operations

## 6.0 IMPLEMENTATION OF AND UPDATES TO PLAN

The overall goal of this plan is to provide assurance to EGLE-AQD that the incinerator and control equipment are being operated and maintained in a manner consistent with good engineering practice to minimize emissions and prevent malfunctions that can lead to exceedances of limitations, while allowing the Warren WWTP operational flexibility in its operations.

If the plan fails to address or inadequately addresses an event that meets the characteristics of a malfunction at the time the plan is initially developed, the permittee shall revise the plan within 45 days after such an event occurs and submit the revised plan for approval to the EGLE-AQD District Supervisor. Should EGLE-AQD determine the malfunction abatement/preventative maintenance plan to be inadequate, the EGLE-AQD District Supervisor may request modification of the plan to address those inadequacies.



## **APPENDIX A**

### **Incinerator and Scrubber Replacement Parts**

**Appendix A  
INCINERATOR PARTS**

QUANTITY	DESCRIPTION	PART NUMBER	LOCATION
3	RABBLE ARMS 2 SHRINK WRAPPED ONE NOT		Outside Truckwell
12	RABBLE ARM PINS		On Shelf
Numerous	VARIOUS SIZE TEETH SPACERS		On Shelf
5		4083-2BR	Floor
10	ALTERNATE PART NUMBER FOR HEARTH 6,8,10	11400A	Floor
4	HEARTH 2 teeth	4083-4FR	Floor
10	HEARTH 4 teeth	4083-4DR	Floor
11	HEARTH 7,9 teeth	9116-ADR	Floor
1		4083-4ER	Floor
9	HEARTH 2 teeth	4083-4FR	On Shelf
8	HEARTH 5 teeth	4083-2ER	On Shelf
1	END OF ARM HEARTH 7,9	4083-1K	On Shelf
22	HEARTH 7,9 teeth	9116-ADR	On Shelf
1		9116 BE	On Shelf
20	UNIDENTIFIED TEETH		On Shelf
36	HEARTH 6,8,10	9116 BDR	On Order

QUANTITY	DESCRIPTION	PART NUMBER	LOCATION
4	Gas regulators		
1	Honeywell Modutrol IV		
12	Replacement Thermocouples		
10	T/C transmitters		
6	Laurel (thermocouple) transmitters		
1	pH probe assembly		
NOTE:	SCADA parts are on hand, but too numerous to list		

3.3.1 Supplied Spare Parts

Quench Spray Lance (Ref. Drwg. C110-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.110-2	7	3/4"	SPRAY NOZZLE, HM 343, 316-SS	2 WEEKS

Tray Irrigator Spray Lance (Ref. Drwg. C113-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.113-2	4	1/2"	HM 218, SPRAY NOZZLE, 316-SS	2 WEEKS

Venturi Inlet Spray Lance (Ref. Drwg. C115-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.115-2	9	3/8"	HM147 SPRAY NOZZLE, 316-SS	4-5 WEEKS

Venturi Throat Manifold (Ref. Drwg. C116-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.116-2	9	1/4"	SM10 SPRAY NOZZLE, 316-SS	4-5 WEEKS

ME Irrigator Spray Lance (Ref. Drwg. C118-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.118-2	4	3/8"	HM 125 NOZZLE, 316-SS	2 WEEKS

ME Backwash Spray Lance (Ref. Drwg. C119-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.119-2	4	1"	RD 20 SPRAY NOZZLE, 316-SS	2 WEEKS

Booster Pump Skid (Ref. Drwg. C315-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.315-11A	1	CRN15-8	CRN15-8 PUMP END ONLY	8 WEEKS
1115.315-12A	1	CRN15-6	CRN15-6 PUMP END ONLY	8 WEEKS

Venturi Tube Assembly (Ref. Drwg. C545-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.545-0B	1	4"	VENTURI TUBE ASSEMBLY W/THROAT NOZZLE INSTALLED.	4-5 WEEKS

3.3.2 Recommended Spare Parts

Quench Spray Lance (Ref. Drwg. C110-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.110-2	7	3/4"	SPRAY NOZZLE, HM 343, 316-SS	2 WEEKS
1115.110-3	1	1/4"	PRESSURE GAUGE, 0-100 PSIG	3 WEEKS
1115.110-7	1	2"X48"	FLEX HOSE, SS WITH NPT ENDS	2 WEEKS
1115.110-10	3	2"	REPLACEMENT Y-STRAINER SCREEN & GASKET, 0.250" PERF., 316-SS	2 WEEKS

Tray Irrigator Spray Lance (Ref. Drwg. C113-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.113-2	4	1/2"	HM 218, SPRAY NOZZLE, 316-SS	2 WEEKS
1115.113-3	1	1/4"	PRESSURE GAUGE, 0-100 PSIG	3 WEEKS
1115.113-5	1	1"	CAMLOCK PART D, SS	1 WEEK
1115.113-6	1	1"	CAMLOCK PART F, SS	1 WEEK
1115.113-7	1	1"X48"	FLEX HOSE, SS WITH MPT ENDS	2 WEEKS
1115.113-10	2	1"	REPLACEMENT Y-STRAINER SCREEN, .125" PERF., 316-SS	2 WEEKS

Venturi Inlet Spray Lance (Ref. Drwg. C115-1115)

Part No.	Qty	Size	Part Description	Delivery
1115.115-2	9	3/8"	HM147 SPRAY NOZZLE, 316-SS	4-5 WEEKS
1115.115-3	1	1/4"	PRESSURE GAUGE, 0-400 PSIG	3 WEEKS
1115.115-7	1	1 1/2"X48"	FLEX HOSE, SS WITH MPT END/ FIXED X LAP JOINT 300# FLANGED ENDS	2 WEEKS
1115.145-41	3	1 1/2"	REPLACEMENT Y-STRAINER SCREEN, 0.125" PERF., 316-SS	2 WEEKS

Venturi Throat Manifold (Ref. Drwg. C116-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.116-3	1	1/4"	PRESSURE GAUGE, 0-400 PSIG	3 WEEKS
1115.116-7	1	1-1/2" X48"	FLEX HOSE, SS WITH MPT END/ FIXED X LAP JOINT 150# FLANGED ENDS	2 WEEKS
1115.116- 20A	2	48"L	FLEX HOSE, SS, SMOOTH BORE WITH 3/8" MPT END X 1/2" MPT END	2 WEEK
1115.146-65	2	1-1/2"	REPLACEMENT Y-STRAINER SCREEN, 3/32" PERF., 316-SS	2 WEEKS

ME Irrigator Spray Lance (Ref. Drwg. C118-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.118-2	4	3/8"	HM 125 NOZZLE, 316-SS	2 WEEKS
1115.118-3	1	1/4"	PRESSURE GAUGE, 0-100 PSIG	3 WEEKS
1115.118-5	1	1"	CAMLOCK PART D, SS	1 WEEK
1115.118-6	1	1"	CAMLOCK PART F, SS	1 WEEK
1115.118-7	1	1"X48"	FLEX HOSE, SS WITH 1" MPT ENDS	2 WEEKS
1115.118-10	2	1"	REPLACEMENT Y-STRAINER SCREEN, 0.125" PERF., 316-SS	2 WEEKS

ME Backwash Spray Lance (Ref. Drwg. C119-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.119-2	4	1"	RD 20 NOZZLE, 316-SS	2 WEEKS
1115.119-3	1	1/4"	PRESSURE GAUGE, 0-15 PSIG	3 WEEKS
1115.119-5	1	1"	CAMLOCK PART D, SS	1 WEEK
1115.119-6	1	1"	CAMLOCK PART F, SS	1 WEEK
1115.119-7	1	1"X48"	FLEX HOSE, SS WITH 1" MPT ENDS	2 WEEKS
1115.119-10	2	1"	REPLACEMENT Y-STRAINER SCREEN, 0.125" PERF., 316-SS	2 WEEKS

Booster Pump Skid (Ref. Drwg. C315-1115)

Part No.	Qty.	Size	Part Description	Delivery
1115.315-1	2	4"	REPLACEMENT STRAINER BASKET, 1/8" PERF., 316-SS	4 WEEKS
1115.315-1	2	4"	REPLACEMENT STRAINER COVER O- RING	2 WEEKS
1115.315-5B	2	2"	REPAIR KIT, 3-PIECE FULL PORT BALL VALVE	1 WEEK
1115.315-2	1	CRN15-	CRN15-10 PUMP COMPLETE WITH 20HP	8 WEEKS

1115.315-2ASS	1	10 CRN15	MOTOR SHAFT SEAL, KUBE	1 WEEK
1115.315-3	1	CRN15-8	CRN15-8 PUMP COMPLETE WITH 15HP MOTOR	8 WEEKS
1115.315-3ASS	1	CRN15	SHAFT SEAL, KUBE	1 WEEK
1115.315-4	1	2"	CHECK VALVE	4 WEEKS
1115.315-9	1	1/4"	PRESSURE GAUGE, 0-400 PSIG	3 WEEKS
1115.315-8	1	1/4"	PRESSURE GAUGE, 0-100 PSIG	3 WEEKS

Venturi Tube Assembly (Ref. Drwg. C545-1115)

Part No.	Qty	Size	Part Description	
1115.545-0	1	4"	VENTURI TUBE ASSEMBLY COMPLETE, WITHOUT THROAT NOZZLE	4-5 WEEKS
1115.545-1	9	1/4"	SPRAY NOZZLE, SM10-170FHC, 316- SS	5 WEEKS
1115.545-6A	2	4"	REPLACEMENT GASKET, MORRIS CLAMP, SS	2 WEEKS

Mist Eliminator

Part No.	Qty.	Size	Part Description	Delivery
1115.565-1	1	96" Ø	REPLACEMENT MESH PAD MIST ELIMINATOR COMPLETE, CONSISTS OF QTY. 12 SECTIONS	4-5 WEEKS

## **APPENDIX B**

### **Operational and Maintenance Checklists**

HEARTH TEMPERATURES

CHECK SCUBBER CHART AND TRENDING

ALTERNATE ASH PUMPS WEEKLY

SHUT DOWN OPERATIONS IF NOT RECORDING DATA

Date	1	2	3	4	5	6	7	8	9	10	SCRUBBER			P.H.	B.H.	THC ppm	Initial	Percent Solids																					
											TEMPERATURE	I.D.	SCRUBBER																										
<6.75t/24hr												>24.6"		>131/12hrs		<95		>755 /12hr		>6.53hrs		642		648		619		FAN %		Total Flow									
scale	tons											DRAFT	PRES																										
23	.											.	.																										
mid	.											.	.																										
1	.											.	.																										
2	.											.	.																										
3	.											.	.																										
4	.											.	.																										
5	.											.	.																										
6	.											.	.																										

TOTAL TONS-		% SOLIDS-		POLY-		DRY/TON-		GAS READING 2200-		GAS READING 0600-		TOTAL-	
7	.												
8	.												
9	.												
10	.												
11	.												
12	.												
13	.												
14	.												

TOTAL TONS-		% SOLIDS-		POLY-		DRY/TON-		GAS READING 0600 -		GAS READING 1400-		TOTAL-	
15	.												
16	.												
17	.												
18	.												
19	.												
20	.												
21	.												
22	.												

TOTAL TONS-		% SOLIDS-		POLY-		DRY/TON-		GAS READING 1400-		GAS READING 2200-		TOTAL-	
Mid Lrg Gas													
Mid Sm Gas													

Mid Lrg

Mid Sm







Month/Week/Year:

CEMS Log  
Incinerator / Scrubber Systems

Section:		A	B.1.	B.2.	B.3.	B.4.	B.5.	B.6.	B.7.	C	D	E	F
Operating		Dessicant	OIT 101	Atmo Seal	CAI 600	Ametek O2 Wet	Gas Display	Ametek O2 dry	SCS 101	Alarms	THC	Gas Cylinders	Dryer
Condition	Name	purple?	~ 325F ?	10-13 psi?	THC	% O2, Cell Temp.	O2: 10-20PSI	% O2, Cell Temp.	Cool, Dry	Report!	10 to 100 ppm	>300psi?	Dryer
Date / Time	Init.	System ok?	Power?	190-195F?	faults?	~650F, mV?	C-free 10-20psi	~650F, mV?	pos. read?		No Solids:<10 ppm	(in day light)	purge
Monday													1x/week
Tuesday													
Wednesday													
Thursday													
Friday													
Saturday													
Sunday													

Notes:

The system must be monitored and the readings recorded by Solids Process Operators on every shift when the Solids Process is running and before startup. The CEMS logs compliance data. Notify Lead Operator and Engineer or Electricians immediately if readings fall outside the normal operating range. Verify any abnormal condition and take appropriate action.



## Weekly (Weekend) - Maintenance Checklist

	DATE	DATE	DATE	DATE	DATE	DATE
<b>First day Clean - Up</b>						
Long Incline	M	A	D	M	A	D
Short Incline	M	A	D	M	A	D
Clean under Belt #3	M	A	D	M	A	D
Flush Trench behind Belt Presses	M	A	D	M	A	D
Steam Clean BP #	D	M	A	D	M	A
Clean push water screens polymer and ferric	D	M	A	D	M	A
Empty Trash in Solids Bldg	D	M	A	D	M	A
Clean Top of MHF + Penthouse	A	D	M	A	D	M
Check oil level Conveyor drives #3,#4,#6 30 WT Oil.	A	D	M	A	D	M
Steam Clean BP #	A	D	M	A	D	M
<b>Second day Clean - Up</b>						
Clean and Switch Screens for Venturi pumps, circle what side is in service on	L R	L R	L R	L R	L R	L R
Pump Skid (Main Floor of MHF)	A	D	M	A	D	M
Clean Scrubber Water Screens(MHF basemt.) or steam clean GBTs	M	A: steam one GBT#	D	M: steam one GBT#	A	D: steam one GBT#
Empty penthouse wheelbarrow - hose area	D	M	A	D	M	A
Ash hopper	D	M	A	D	M	A
Clean U.V system cone screen	D	A	D	A	D	A
Warm up MHF, do NOT fill BTs yet (for MIDs)	A	A	A	A	A	A
Fill and mix Polymer Tanks	A	A	A	A	A	A
Ensure BFP/ Scrubber/ OCS fan is ready	A	A	A	A	A	A
Check water softener, add salt (# of bags)	A ( )	M ( )	D ( )	A ( )	M ( )	D ( )
All Shifts Dewater Storage Tanks						
Tighten chicanes on GBT's	D	A	M	D	A	M
Grease ID fan bearings (2) - 2 x w. black grease gun (shows ID fan bearings) <b>every 2 weeks</b>	D	A	M	D	A	M