

**MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY  
AIR QUALITY DIVISION**

EFFECTIVE DATE: February 4, 2020  
REVISION DATES: September 3, 2020, July 2, 2021

ISSUED TO

**Consumers Energy, J.H. Campbell Generating Complex**

State Registration Number (SRN): B2835

LOCATED AT

17000 Croswell, West Olive, Ottawa County, Michigan 49460

**RENEWABLE OPERATING PERMIT**

Permit Number: MI-ROP-B2835-2020b

Expiration Date: February 4, 2025

Administratively Complete ROP Renewal Application  
Due Between August 4, 2023 and August 4, 2024

This Renewable Operating Permit (ROP) is issued in accordance with and subject to Section 5506(3) of Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451). Pursuant to Rule 210(1) of the administrative rules promulgated under Act 451, this ROP constitutes the permittee's authority to operate the stationary source identified above in accordance with the general conditions, special conditions and attachments contained herein. Operation of the stationary source and all emission units listed in the permit are subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

**SOURCE-WIDE PERMIT TO INSTALL**

Permit Number: MI-PTI-B2835-2020b

This Permit to Install (PTI) is issued in accordance with and subject to Section 5505(1) of Act 451. Pursuant to Rule 214a of the administrative rules promulgated under Act 451, the terms and conditions herein, identified by the underlying applicable requirement citation of Rule 201(1)(a), constitute a federally enforceable PTI. The PTI terms and conditions do not expire and remain in effect unless the criteria of Rule 201(6) are met. Operation of all emission units identified in the PTI is subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

Michigan Department of Environment, Great Lakes, and Energy

---

Heidi Hollenbach, Grand Rapids District Supervisor

# TABLE OF CONTENTS

<b>AUTHORITY AND ENFORCEABILITY .....</b>	<b>4</b>
<b>A. GENERAL CONDITIONS.....</b>	<b>5</b>
Permit Enforceability .....	5
General Provisions .....	5
Equipment & Design .....	6
Emission Limits .....	6
Testing/Sampling.....	6
Monitoring/Recordkeeping .....	7
Certification & Reporting .....	7
Permit Shield.....	8
Revisions .....	9
Reopenings.....	9
Renewals .....	10
Stratospheric Ozone Protection.....	10
Risk Management Plan.....	10
Emission Trading.....	10
Permit to Install (PTI).....	11
<b>B. SOURCE-WIDE CONDITIONS.....</b>	<b>12</b>
<b>C. EMISSION UNIT SPECIAL CONDITIONS .....</b>	<b>13</b>
EMISSION UNIT SUMMARY TABLE.....	13
EUBOILER1 .....	16
EUBOILER2.....	22
EUBOILER3.....	28
EUCOALHAND .....	35
EUSDA_U3.....	40
EUDSI_U12.....	45
EUACI_U123.....	48
EUBYPRODUCT .....	51
EUAUXBLR12.....	58
EUCAT3DIESEL.....	63
EUCATDIESEL12.....	68
EUGUARDSHK_ENG.....	71
<b>D. FLEXIBLE GROUP SPECIAL CONDITIONS.....</b>	<b>74</b>
FLEXIBLE GROUP SUMMARY TABLE.....	74
FGBOILER12.....	75
FGMATS_U12.....	78
FGMATS_U3.....	87
FGEXISTINGRICE .....	95
FGNEW CIRICE.....	100
FGAUXBLRS3.....	104
FGPARTSCLEANERS.....	108
<b>E. NON-APPLICABLE REQUIREMENTS .....</b>	<b>111</b>
<b>APPENDICES.....</b>	<b>112</b>

Appendix 1-A. Acronyms and Abbreviations..... 112  
Appendix 1-B. Definitions Related to the Consent Agreement..... 113  
Appendix 2. Schedule of Compliance ..... 117  
Appendix 3. Monitoring Requirements ..... 117  
Appendix 3-A. Continuous Opacity Monitoring Systems ..... 117  
Appendix 3-B. Continuous Emissions Monitoring System (Title IV; Gas Flow, SO<sub>2</sub> , CO<sub>2</sub>, NO<sub>x</sub>) ..... 117  
Appendix 3-C. Fuel Oil Sulfur Monitoring ..... 118  
Appendix 3-D. Continuous Emission Monitoring Systems (SO<sub>2</sub>/CO<sub>2</sub>) ..... 118  
Appendix 3-E. PM CEMS..... 118  
Appendix 3-F. Optimization of Baghouses ..... 119  
Appendix 4. Recordkeeping ..... 119  
Appendix 5. Testing Procedures..... 119  
Appendix 6. Permits to Install ..... 120  
Appendix 7. Emission Calculations ..... 123  
Appendix 8. Reporting ..... 125  
Appendix 9. Acid Rain Permit..... 127  
Appendix 10: Cross State Air Pollution Rule (CSAPR) Trading Program Title V Requirements..... 137  
Appendix 11-A. System Wide Tonnage Limitations ..... 148  
Appendix 11-B. Allowance Provisions ..... 148

## AUTHORITY AND ENFORCEABILITY

For the purpose of this permit, the **permittee** is defined as any person who owns or operates an emission unit at a stationary source for which this permit has been issued. The **department** is defined in Rule 104(d) as the Director of the Michigan Department of Environment, Great Lakes, and Energy (EGLE) or his or her designee.

The permittee shall comply with all specific details in the permit terms and conditions and the cited underlying applicable requirements. All terms and conditions in this ROP are both federally enforceable and state enforceable unless otherwise footnoted. Certain terms and conditions are applicable to most stationary sources for which an ROP has been issued. These general conditions are included in Part A of this ROP. Other terms and conditions may apply to a specific emission unit, several emission units which are represented as a flexible group, or the entire stationary source which is represented as a Source-Wide group. Special conditions are identified in Parts B, C, D and/or the appendices.

In accordance with Rule 213(2)(a), all underlying applicable requirements are identified for each ROP term or condition. All terms and conditions that are included in a PTI are streamlined, subsumed and/or is state-only enforceable will be noted as such.

In accordance with Section 5507 of Act 451, the permittee has included in the ROP application a compliance certification, a schedule of compliance, and a compliance plan. For applicable requirements with which the source is in compliance, the source will continue to comply with these requirements. For applicable requirements with which the source is not in compliance, the source will comply with the detailed schedule of compliance requirements that are incorporated as an appendix in this ROP. Furthermore, for any applicable requirements effective after the date of issuance of this ROP, the stationary source will meet the requirements on a timely basis, unless the underlying applicable requirement requires a more detailed schedule of compliance.

Issuance of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.

This permit does not relieve the permittee from any responsibilities or obligations imposed on the permittee, at the source under Consent Decree U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014, entered in 2014 between the USEPA and the permittee.

## A. GENERAL CONDITIONS

### Permit Enforceability

- All conditions in this permit are both federally enforceable and state enforceable unless otherwise noted. **(R 336.1213(5))**
- Those conditions that are hereby incorporated in a state-only enforceable Source-Wide PTI pursuant to Rule 201(2)(d) are designated by footnote one. **(R 336.1213(5)(a), R 336.1214a(5))**
- Those conditions that are hereby incorporated in a federally enforceable Source-Wide PTI pursuant to Rule 201(2)(c) are designated by footnote two. **(R 336.1213(5)(b), R 336.1214a(3))**

### General Provisions

1. The permittee shall comply with all conditions of this ROP. Any ROP noncompliance constitutes a violation of Act 451, and is grounds for enforcement action, for ROP revocation or revision, or for denial of the renewal of the ROP. All terms and conditions of this ROP that are designated as federally enforceable are enforceable by the Administrator of the United States Environmental Protection Agency (USEPA) and by citizens under the provisions of the federal Clean Air Act (CAA). Any terms and conditions based on applicable requirements which are designated as "state-only" are not enforceable by the USEPA or citizens pursuant to the CAA. **(R 336.1213(1)(a))**
2. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this ROP. **(R 336.1213(1)(b))**
3. This ROP may be modified, revised, or revoked for cause. The filing of a request by the permittee for a permit modification, revision, or termination, or a notification of planned changes or anticipated noncompliance does not stay any ROP term or condition. This does not supersede or affect the ability of the permittee to make changes, at the permittee's own risk, pursuant to Rule 215 and Rule 216. **(R 336.1213(1)(c))**
4. The permittee shall allow the department, or an authorized representative of the department, upon presentation of credentials and other documents as may be required by law and upon stating the authority for and purpose of the investigation, to perform any of the following activities: **(R 336.1213(1)(d))**
  - a. Enter, at reasonable times, a stationary source or other premises where emissions-related activity is conducted or where records must be kept under the conditions of the ROP.
  - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the ROP.
  - c. Inspect, at reasonable times, any of the following:
    - i. Any stationary source.
    - ii. Any emission unit.
    - iii. Any equipment, including monitoring and air pollution control equipment.
    - iv. Any work practices or operations regulated or required under the ROP.
  - d. As authorized by Section 5526 of Act 451, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the ROP or applicable requirements.
5. The permittee shall furnish to the department, within a reasonable time, any information the department may request, in writing, to determine whether cause exists for modifying, revising, or revoking the ROP or to determine compliance with this ROP. Upon request, the permittee shall also furnish to the department copies of any records that are required to be kept as a term or condition of this ROP. For information which is claimed by the permittee to be confidential, consistent with the requirements of the 1976 PA 442, MCL §15.231 et seq., and known as the Freedom of Information Act, the person may also be required to furnish the records directly to the USEPA together with a claim of confidentiality. **(R 336.1213(1)(e))**

6. A challenge by any person, the Administrator of the USEPA, or the department to a particular condition or a part of this ROP shall not set aside, delay, stay, or in any way affect the applicability or enforceability of any other condition or part of this ROP. **(R 336.1213(1)(f))**
7. The permittee shall pay fees consistent with the fee schedule and requirements pursuant to Section 5522 of Act 451. **(R 336.1213(1)(g))**
8. This ROP does not convey any property rights or any exclusive privilege. **(R 336.1213(1)(h))**

## Equipment & Design

9. Any collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2).<sup>2</sup> **(R 336.1370)**
10. Any air cleaning device shall be installed, maintained, and operated in a satisfactory manner and in accordance with the Michigan Air Pollution Control rules and existing law. **(R 336.1910)**

## Emission Limits

11. Unless otherwise specified in this ROP, the permittee shall comply with Rule 301, which states, in part, "Except as provided in Subrules 2, 3, and 4 of this rule, a person shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of a density greater than the most stringent of the following:"<sup>2</sup> **(R 336.1301(1))**
  - a. A 6-minute average of 20% opacity, except for one 6-minute average per hour of not more than 27% opacity.
  - b. A limit specified by an applicable federal new source performance standard.

The grading of visible emissions shall be determined in accordance with Rule 303.

12. The permittee shall not cause or permit the emission of an air contaminant or water vapor in quantities that cause, alone or in reaction with other air contaminants, either of the following:
  - a. Injurious effects to human health or safety, animal life, plant life of significant economic value, or property.<sup>1</sup> **(R 336.1901(a))**
  - b. Unreasonable interference with the comfortable enjoyment of life and property.<sup>1</sup> **(R 336.1901(b))**

## Testing/Sampling

13. The department may require the owner or operator of any source of an air contaminant to conduct acceptable performance tests, at the owner's or operator's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001(1).<sup>2</sup> **(R 336.2001)**
14. Any required performance testing shall be conducted in accordance with Rule 1001(2), Rule 1001(3) and Rule 1003. **(R 336.2001(2), R 336.2001(3), R 336.2003(1))**
15. Any required test results shall be submitted to the Air Quality Division (AQD) in the format prescribed by the applicable reference test method within 60 days following the last date of the test. **(R 336.2001(5))**

## Monitoring/Recordkeeping

16. Records of any periodic emission or parametric monitoring required in this ROP shall include the following information specified in Rule 213(3)(b)(i), where appropriate. **(R 336.1213(3)(b))**
  - a. The date, location, time, and method of sampling or measurements.
  - b. The dates the analyses of the samples were performed.
  - c. The company or entity that performed the analyses of the samples.
  - d. The analytical techniques or methods used.
  - e. The results of the analyses.
  - f. The related process operating conditions or parameters that existed at the time of sampling or measurement.
17. All required monitoring data, support information and all reports, including reports of all instances of deviation from permit requirements, shall be kept and furnished to the department upon request for a period of not less than 5 years from the date of the monitoring sample, measurement, report or application. Support information includes all calibration and maintenance records and all original strip-chart recordings, or other original data records, for continuous monitoring instrumentation and copies of all reports required by the ROP. **(R 336.1213(1)(e), R 336.1213(3)(b)(ii))**

## Certification & Reporting

18. Except for the alternate certification schedule provided in Rule 213(3)(c)(iii)(B), any document required to be submitted to the department as a term or condition of this ROP shall contain an original certification by a Responsible Official which state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. **(R 336.1213(3)(c))**
19. A Responsible Official shall certify to the appropriate AQD District Office and to the USEPA that the stationary source is and has been in compliance with all terms and conditions contained in the ROP except for deviations that have been or are being reported to the appropriate AQD District Office pursuant to Rule 213(3)(c). This certification shall include all the information specified in Rule 213(4)(c)(i) through (v) and shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the certification are true, accurate, and complete. The USEPA address is: USEPA, Air Compliance Data - Michigan, Air and Radiation Division, 77 West Jackson Boulevard, Chicago, Illinois 60604-3507. **(R 336.1213(4)(c))**
20. The certification of compliance shall be submitted annually for the term of this ROP as detailed in the special conditions, or more frequently if specified in an applicable requirement or in this ROP. **(R 336.1213(4)(c))**
21. The permittee shall promptly report any deviations from ROP requirements and certify the reports. The prompt reporting of deviations from ROP requirements is defined in Rule 213(3)(c)(ii) as follows, unless otherwise described in this ROP. **(R 336.1213(3)(c))**
  - a. For deviations that exceed the emissions allowed under the ROP, prompt reporting means reporting consistent with the requirements of Rule 912 as detailed in Condition 25. All reports submitted pursuant to this paragraph shall be promptly certified as specified in Rule 213(3)(c)(iii).
  - b. For deviations which exceed the emissions allowed under the ROP and which are not reported pursuant to Rule 912 due to the duration of the deviation, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe reasons for each deviation and the actions taken to minimize or correct each deviation.
  - c. For deviations that do not exceed the emissions allowed under the ROP, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe the reasons for each deviation and the actions taken to minimize or correct each deviation.

22. For reports required pursuant to Rule 213(3)(c)(ii), prompt certification of the reports is described in Rule 213(3)(c)(iii) as either of the following: **(R 336.1213(3)(c))**
  - a. Submitting a certification by a Responsible Official with each report which states that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
  - b. Submitting, within 30 days following the end of a calendar month during which one or more prompt reports of deviations from the emissions allowed under the ROP were submitted to the department pursuant to Rule 213(3)(c)(ii), a certification by a Responsible Official which states that; "based on information and belief formed after reasonable inquiry, the statements and information contained in each of the reports submitted during the previous month were true, accurate, and complete." The certification shall include a listing of the reports that are being certified. Any report submitted pursuant to Rule 213(3)(c)(ii) that will be certified on a monthly basis pursuant to this paragraph shall include a statement that certification of the report will be provided within 30 days following the end of the calendar month.
23. Semiannually for the term of the ROP as detailed in the special conditions, or more frequently if specified, the permittee shall submit certified reports of any required monitoring to the appropriate AQD District Office. All instances of deviations from ROP requirements during the reporting period shall be clearly identified in the reports. **(R 336.1213(3)(c)(i))**
24. On an annual basis, the permittee shall report the actual emissions, or the information necessary to determine the actual emissions, of each regulated air pollutant as defined in Rule 212(6) for each emission unit utilizing the emissions inventory forms provided by the department. **(R 336.1212(6))**
25. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the appropriate AQD District Office. The notice shall be provided not later than two business days after the start-up, shutdown, or discovery of the abnormal conditions or malfunction. Notice shall be by any reasonable means, including electronic, telephonic, or oral communication. Written reports, if required under Rule 912, must be submitted to the appropriate AQD District Supervisor within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal conditions or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5) and shall be certified by a Responsible Official in a manner consistent with the CAA.<sup>2</sup> **(R 336.1912)**

## Permit Shield

26. Compliance with the conditions of the ROP shall be considered compliance with any applicable requirements as of the date of ROP issuance if either of the following provisions is satisfied. **(R 336.1213(6)(a)(i), R 336.1213(6)(a)(ii))**
  - a. The applicable requirements are included and are specifically identified in the ROP.
  - b. The permit includes a determination or concise summary of the determination by the department that other specifically identified requirements are not applicable to the stationary source.

Any requirements identified in Part E of this ROP have been identified as non-applicable to this ROP and are included in the permit shield.

27. Nothing in this ROP shall alter or affect any of the following:
  - a. The provisions of Section 303 of the CAA, emergency orders, including the authority of the USEPA under Section 303 of the CAA. **(R 336.1213(6)(b)(i))**
  - b. The liability of the owner or operator of this source for any violation of applicable requirements prior to or at the time of this ROP issuance. **(R 336.1213(6)(b)(ii))**
  - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the CAA. **(R 336.1213(6)(b)(iii))**



- d. The ability of the USEPA to obtain information from a source pursuant to Section 114 of the CAA. **(R 336.1213(6)(b)(iv))**
28. The permit shield shall not apply to provisions incorporated into this ROP through procedures for any of the following:
- a. Operational flexibility changes made pursuant to Rule 215. **(R 336.1215(5))**
  - b. Administrative Amendments made pursuant to Rule 216(1)(a)(i)-(iv). **(R 336.1216(1)(b)(iii))**
  - c. Administrative Amendments made pursuant to Rule 216(1)(a)(v) until the amendment has been approved by the department. **(R 336.1216(1)(c)(iii))**
  - d. Minor Permit Modifications made pursuant to Rule 216(2). **(R 336.1216(2)(f))**
  - e. State-Only Modifications made pursuant to Rule 216(4) until the changes have been approved by the department. **(R 336.1216(4)(e))**
29. Expiration of this ROP results in the loss of the permit shield. If a timely and administratively complete application for renewal is submitted not more than 18 months, but not less than 6 months, before the expiration date of the ROP, but the department fails to take final action before the end of the ROP term, the existing ROP does not expire until the renewal is issued or denied, and the permit shield shall extend beyond the original ROP term until the department takes final action. **(R 336.1217(1)(c), R 336.1217(1)(a))**

## Revisions

30. For changes to any process or process equipment covered by this ROP that do not require a revision of the ROP pursuant to Rule 216, the permittee must comply with Rule 215. **(R 336.1215, R 336.1216)**
31. A change in ownership or operational control of a stationary source covered by this ROP shall be made pursuant to Rule 216(1). **(R 336.1219(2))**
32. For revisions to this ROP, an administratively complete application shall be considered timely if it is received by the department in accordance with the time frames specified in Rule 216. **(R 336.1210(10))**
33. Pursuant to Rule 216(1)(b)(iii), Rule 216(2)(d) and Rule 216(4)(d), after a change has been made, and until the department takes final action, the permittee shall comply with both the applicable requirements governing the change and the ROP terms and conditions proposed in the application for the modification. During this time period, the permittee may choose to not comply with the existing ROP terms and conditions that the application seeks to change. However, if the permittee fails to comply with the ROP terms and conditions proposed in the application during this time period, the terms and conditions in the ROP are enforceable. **(R 336.1216(1)(c)(iii), R 336.1216(2)(d), R 336.1216(4)(d))**

## Reopenings

34. A ROP shall be reopened by the department prior to the expiration date and revised by the department under any of the following circumstances:
- a. If additional requirements become applicable to this stationary source with three or more years remaining in the term of the ROP, but not if the effective date of the new applicable requirement is later than the ROP expiration date. **(R 336.1217(2)(a)(i))**
  - b. If additional requirements pursuant to Title IV of the CAA become applicable to this stationary source. **(R 336.1217(2)(a)(ii))**
  - c. If the department determines that the ROP contains a material mistake, information required by any applicable requirement was omitted, or inaccurate statements were made in establishing emission limits or the terms or conditions of the ROP. **(R 336.1217(2)(a)(iii))**
  - d. If the department determines that the ROP must be revised to ensure compliance with the applicable requirements. **(R 336.1217(2)(a)(iv))**

## Renewals

35. For renewal of this ROP, an administratively complete application shall be considered timely if it is received by the department not more than 18 months, but not less than 6 months, before the expiration date of the ROP. **(R 336.1210(9))**

## Stratospheric Ozone Protection

36. If the permittee is subject to Title 40 of the Code of Federal Regulations (CFR), Part 82 and services, maintains, or repairs appliances except for motor vehicle air conditioners (MVAC), or disposes of appliances containing refrigerant, including MVAC and small appliances, or if the permittee is a refrigerant reclaimer, appliance owner or a manufacturer of appliances or recycling and recovery equipment, the permittee shall comply with all applicable standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.
37. If the permittee is subject to 40 CFR Part 82 and performs a service on motor (fleet) vehicles when this service involves refrigerant in the MVAC, the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed by the original equipment manufacturer. The term MVAC as used in Subpart B does not include the air-tight sealed refrigeration system used for refrigerated cargo or an air conditioning system on passenger buses using Hydrochlorofluorocarbon-22 refrigerant.

## Risk Management Plan

38. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall register and submit to the USEPA the required data related to the risk management plan for reducing the probability of accidental releases of any regulated substances listed pursuant to Section 112(r)(3) of the CAA as amended in 40 CFR 68.130. The list of substances, threshold quantities, and accident prevention regulations promulgated under 40 CFR Part 68, do not limit in any way the general duty provisions under Section 112(r)(1).
39. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall comply with the requirements of 40 CFR Part 68, no later than the latest of the following dates as provided in 40 CFR 68.10(a):
- June 21, 1999,
  - Three years after the date on which a regulated substance is first listed under 40 CFR 68.130, or
  - The date on which a regulated substance is first present above a threshold quantity in a process.
40. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall submit any additional relevant information requested by any regulatory agency necessary to ensure compliance with the requirements of 40 CFR Part 68.
41. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall annually certify compliance with all applicable requirements of Section 112(r) as detailed in Rule 213(4)(c)). **(40 CFR Part 68)**

## Emission Trading

42. Emission averaging and emission reduction credit trading are allowed pursuant to any applicable interstate or regional emission trading program that has been approved by the Administrator of the USEPA as a part of Michigan's State Implementation Plan. Such activities must comply with Rule 215 and Rule 216. **(R 336.1213(12))**

## Permit to Install (PTI)

43. The process or process equipment included in this permit shall not be reconstructed, relocated, or modified unless a PTI authorizing such action is issued by the department, except to the extent such action is exempt from the PTI requirements by any applicable rule.<sup>2</sup> **(R 336.1201(1))**
44. The department may, after notice and opportunity for a hearing, revoke PTI terms or conditions if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of the PTI or is violating the department's rules or the CAA.<sup>2</sup> **(R 336.1201(8), Section 5510 of Act 451)**
45. The terms and conditions of a PTI shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by the PTI. If a new owner or operator submits a written request to the department pursuant to Rule 219 and the department approves the request, this PTI will be amended to reflect the change of ownership or operational control. The request must include all of the information required by Subrules (1)(a), (b) and (c) of Rule 219. The written request shall be sent to the appropriate AQD District Supervisor, EGLE.<sup>2</sup> **(R 336.1219)**
46. If the installation, reconstruction, relocation, or modification of the equipment for which PTI terms and conditions have been approved has not commenced within 18 months of the original PTI issuance date, or has been interrupted for 18 months, the applicable terms and conditions from that PTI, as incorporated into the ROP, shall become void unless otherwise authorized by the department. Furthermore, the person to whom that PTI was issued, or the designated authorized agent, shall notify the department via the Supervisor, Permit Section, EGLE, AQD, P. O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or modification of the equipment allowed by the terms and conditions from that PTI.<sup>2</sup> **(R 336.1201(4))**

### Footnotes:

<sup>1</sup>This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## **B. SOURCE-WIDE CONDITIONS**

Part B outlines the Source-Wide Terms and Conditions that apply to this stationary source. The permittee is subject to these special conditions for the stationary source in addition to the general conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply to this source, NA (not applicable) has been used in the table. If there are no Source-Wide Conditions, this section will be left blank.

### C. EMISSION UNIT SPECIAL CONDITIONS

Part C outlines terms and conditions that are specific to individual emission units listed in the Emission Unit Summary Table. The permittee is subject to the special conditions for each emission unit in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no conditions specific to individual emission units, this section will be left blank.

#### EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUPARTSCLEANERS	Multiple individual cleaning units that are subject to the same applicable requirements. The cleaning units are used in support of facility operations.	01-01-1994/ NA	FGPARTSCLEANERS
EUBOILER1	A 2490 MMBTU per hour dry bottom, tangential fired boiler with fuel oil startup capabilities. Emissions are currently controlled by low-NOx burners, sorbent injection (ACI) (activated carbon or other sorbent for mercury control), dry sorbent injection (DSI) (hydrated lime or other sorbent), and a pulse-jet fabric filter (PJFF) baghouse.	01-01-1958/ 04 23-2015	FGMATS_U12 FGBOILER12
EUBOILER2	A 3560 MMBTU per hour wall-fired (converted from cell burner) boiler with fuel oil startup capability. Emissions are controlled by low-NOx burners, selective catalytic reduction (SCR), sorbent injection (ACI) (activated carbon or other sorbent for mercury control), DSI (hydrated lime or other sorbent), and a PJFF baghouse.	01-01-1963/ 04-23-2015	FGMATS_U12 FGBOILER12
EUBOILER3	An 8240 MMBTU per hour dry bottom, wall-fired boiler with fuel oil startup capability. Emissions are controlled by low-NOx burners, SCR, sorbent injection (ACI) (activated carbon or other sorbent for mercury control), spray dry absorber (SDA), and PJFF baghouse.	02-01-1974/ 04-23-2015	FGMATS_U3
EUCOALHAND	Coal handling facility. Particulate emissions are controlled by 11 baghouses, enclosures, and dust suppression.	01-01-1958	NA

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUSDA_U3	Lime preparation operations for Boiler 3 that support the SDA including storage silos, vertical ball mills, lime slurry transfer and product tanks. Emissions are controlled by bin vent filters and spray scrubbers (mill scrubbers). SDA operations for Boiler 3 includes lime slurry atomizer head tanks, recycle silos, recycle mix tanks, and recycle slurry storage tanks. Emissions are controlled by bin vent filters and a spray scrubber (recycle mix tank).	04-23-2015	NA
EUDSI_U12	Dry Sorbent Injection Material Handling for Boilers 1 and 2. Includes sorbent silos (hydrated lime or other sorbent) and pneumatic transfer; bin vent filters.	04-23-2015	NA
EUACI_U123	Activated carbon (or other sorbent) material handling including silos for Boiler Units 1, 2 and 3; with bin vent filters.	04-23-2015	NA
EUBYPRODUCT	There are three separate byproduct handling systems (one for each boiler). The system transfers the byproduct from the fabric filters (ash, spent lime, and sorbent) to the disposal silos. The equipment includes conveyance piping and byproduct transfer tanks, filter separator, vacuum exhausters, and conveying blowers from transfer tanks to flyash storage/disposal silos. Dry flyash handling facility is located at the landfill and is common to Boilers 1, 2, and 3 and consists of three flyash storage/disposal silos; with flyash truck dry load outs. Emissions control: The transfer tanks' byproduct vacuum exhauster filter separators exhaust to the boiler pulse-jet fabric filters (except as noted in the emission unit requirements); bin vent filters on the byproduct transfer tanks and flyash silos. Water added for flyash conditioning before flyash truck loading for disposal.	04-23-2015	NA
EUAUXBLR12	A 17 MMBTU/hr fuel oil-fired firetube auxiliary boiler servicing EUBOILER1 and EUBOILER2. This boiler is a limited use boiler.	01-01-1958	NA
EUAUXBLR3B	A 9.8 MMBTU/hr fuel oil fired auxiliary boiler providing heat to Plant 3.	11-2011	FGAUXBLRS3
EUAUXBLR3C	A 9.8 MMBTU/hr fuel oil fired auxiliary boiler providing heat to Plant 3.	11-2011	FGAUXBLRS3
EUCAT3DIESEL	A diesel-powered, stationary internal combustion engine rated at 9.3 MMBTU/hr heat input.	02-01-1974	NA

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUWPDIESEL	Water Pump for EUSDA_U3 emergency flush certified to NSPS IIII Tier 3 requirements. A diesel-powered, stationary internal combustion engine rated at 130 HP (97 kW).	07-2016	FGNEWCIRICE
EUCATFIREPUMP3	A diesel-powered, stationary internal combustion Caterpillar 3406 model engine rated at 2.8 MMBTU/hr heat input; used as a fire pump.	01-2017	FGEXISTINGRICE
EUHPHWP15001	A diesel-powered, stationary internal combustion engine rated at 3.05 MMBTU/hr heat input; Emergency Diesel Generator #1.	01-01-1958	FGEXISTINGRICE
EUHPHWP15002	A diesel-powered, stationary internal combustion engine rated at 3.05 MMBTU/hr heat input; Emergency Diesel Generator #2.	01-01-1958	FGEXISTINGRICE
EUHPHWP3000	A diesel-powered, stationary internal combustion engine rated at 2.58 MMBTU/hr heat input; Emergency Diesel Generator.	01-01-1958	FGEXISTINGRICE
EUCATDIESEL12	A 2,000-kilowatt (kW) diesel-fueled emergency engine manufactured in 2007 or later.	10-12-2012	NA
EUTRNCNTRDIESEL	A diesel-powered, stationary internal combustion engine rated at 1193 BHP; Emergency Diesel Generator.	08-2013	FGNEWCIRICE
EUGUARDSHK_ENG	A natural-gas, stationary internal combustion engine rated at 40 HP; Emergency Generator for the guard shack.	08-2015	NA

**EUBOILER1**  
**EMISSION UNIT CONDITIONS**

**DESCRIPTION**

A 2490 MMBTU/hr dry bottom, tangential fired boiler with fuel oil startup capability. This emission unit is subject to 40 CFR Part 63, Subpart UUUUU (MATS) and 40 CFR Part 64 (CAM). All CAM requirements are in FGBOILER12 and all MATS requirements are in FGMATS\_U12.

**Flexible Group ID:** FGBOILER12 and FGMATS\_U12

**POLLUTION CONTROL EQUIPMENT**

Low-NOx burners,  
 Sorbent injection (ACI) (activated carbon or other sorbent for mercury control),  
 Dry sorbent injection (DSI) (hydrated lime or other sorbent), and  
 Pulse-jet fabric filter (PJFF) baghouse.

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Particulate matter (PM)	0.16 pound per 1,000 pounds exhaust gas, corrected to 50% excess air <sup>2</sup>	Hourly	EUBOILER1	SC V.1  (FGBOILER12, SC VI.1, COMS)	R 336.1331(1)(c)
2. NO <sub>x</sub>	0.220 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 365-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER1	SC VI.1	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 76; Act 451, Section 324.5503(b)
3. SO <sub>2</sub>	0.350 pounds per MMBTU heat input <sup>2,3,4</sup>	Based on a 30-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER1	SC VI.1 SC VI.2	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 113; Act 451, Section 324.5503(b)



Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
4. SO <sub>2</sub>	0.290 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 90-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER1	SC VI.1 SC VI.2	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 113; Act 451, Section 324.5503(b)</b>
5. PM	0.015 pound per MMBTU heat input <sup>2,3,4</sup>	Hourly <sup>2,3,4</sup>	EUBOILER1	SC V.2  (FGBOILER12, SC VI.1, COMS)	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 144; Act 451, Section 324.5503(b)</b>
6. Opacity	20% <sup>2,3,4</sup>	Per 6-minute period except for one 6-minute period per hour of not more than 27% <sup>2,3,4</sup>	EUBOILER1	SC VI.4	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 151; Act 451, Section 324.5503(b)</b>
7. SO <sub>2</sub>	1.67 pounds per MMBTU heat input <sup>2</sup>	Monthly average, based on the average of the 31 previous operating days	EUBOILER1	SC VI.3	<b>R 336.1401(3), Table 41</b>

8. The permittee shall comply with the System-Wide Annual NO<sub>x</sub> Tonnage Limitations and System-Wide Annual SO<sub>2</sub> Tonnage Limitations specified in Appendix 11-A. Emissions from EUBOILER1 shall be counted toward the system-wide total emissions.<sup>2,3,4</sup> (**“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 98 & 129, Act 451, Section 324.5503(b)**)
9. The permittee shall comply with the SO<sub>2</sub> and NO<sub>x</sub> allowance surrender and super-compliance allowance provisions listed in Appendix 11-B: Allowance Provisions.<sup>2,3,4</sup> (**“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 101-109 and 132-140, Act 451, Section 324.5503(b)**)

See Appendices 11-A and 11-B

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Coal – sulfur content	1.0% by weight, at a heat content of 12,000 BTU/lb <sup>2</sup>	Monthly average, based on the average of the 31 previous operating days	EUBOILER1	SC VI.3	R 336.1401(3), Table 41

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate EUBOILER1 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for the emission control equipment (PJFF baghouse, ACI, DSI) is implemented and maintained. The MAP shall, at a minimum, specify the following:
  - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
  - b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
  - c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> (R 336.1910, R 336.1911)

2. The permittee shall continuously operate the PM Control Device for EUBOILER1 and use good air pollution control practices to maximize the PM emission reductions at all times when the unit is in operation. The requirements of Appendix 3-F shall be met.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 141, Act 451, Section 324.5503(b))
3. The permittee shall not operate the boiler, including startup and shutdown, unless the corresponding PJFF baghouse is installed and operating properly, in accordance with safe operating practices.<sup>2</sup> (R 336.1910)
4. The permittee shall not burn freeze conditioning/dust suppression agents unless PJFF baghouses are installed and operating properly, in accordance with safe operating practices.<sup>2</sup> (R 336.1910)

See Appendix 3-F

**IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate EUBOILER1 unless the low-NOx burners, the DSI, the ACI sorbent injection (for mercury control), and PJFF baghouse are installed, maintained, and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approvable MAP for EUBOILER1 control equipment as required in SC III.1.<sup>2</sup> (R 336.1910)

2. The permittee shall not operate EUBOILER1 unless the low-NO<sub>x</sub> burners, including over fire air processes, are Continuously Operated.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 75, Act 451, Section 324.5503(b))
3. The permittee shall not operate EUBOILER1 unless the DSI system is Continuously Operated.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 113, Act 451, Section 324.5503(b))
4. The permittee shall not operate EUBOILER1 unless the PJFF baghouse unit is Continuously Operated.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 144, Act 451, Section 324.5503(b))
5. The permittee shall continuously operate the PM control devices being vented to a combined stack associated with FGBOILER12.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 142, Act 451, Section 324.5503(b))

## **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. Every three (3) years, or more frequently upon request of the AQD, the permittee shall verify PM emission rates from EUBOILER1 by testing at the owner’s expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in 40 CFR Part 60, Appendix A, Reference Method 17 (Determination of Particulate Emissions from Stationary Sources (In-stack Filtration Method)), Reference Method 5 or “MATS” 5, or other acceptable test method(s). An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> (R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)
2. The permittee shall conduct a stack test for PM pursuant to the provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements. Subsequent stack tests for PM shall be conducted pursuant to the schedule and provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 153, Act 451, Section 324.5503(b))
3. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted.<sup>2</sup> (R 336.2001(3))
4. The permittee shall assess opacity using USEPA Reference Method 9 - “Visual Determination of the Opacity of Emissions from Stationary Sources,” upon the request of AQD.<sup>2</sup> (R 336.1301)

See Appendix 5

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. For purposes of determining compliance with the Rolling Average Emission Rates for NO<sub>x</sub> and SO<sub>2</sub> as found in SC I.2, I.3, and I.4, the permittee shall install and operate CEMS in accordance with the procedures of 40 CFR Part 75, except that the NO<sub>x</sub> and SO<sub>2</sub> emissions data need not be bias adjusted and the missing data substitution procedures of 40 CFR Part 75 shall not apply. If applicable, diluent capping (i.e., 5% CO<sub>2</sub>) will be applied to the NO<sub>x</sub> emission rate for any hours where the measured CO<sub>2</sub> concentration is less than 5% following the procedures in 40 CFR Part 75, Appendix F, Section 3.3.4.1.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 99 and 130, Act 451, Section 324.5503(b))

2. The permittee shall monitor unit level SO<sub>2</sub> concentrations and gas flow, using CEMS, as installed, maintained, and operated in accordance with 40 CFR Part 75.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 116, Act 451, Section 324.5503(b))
3. The permittee shall monitor gas flow, SO<sub>2</sub>, CO<sub>2</sub>, and NO<sub>x</sub> emissions using CEMS, as installed, maintained, and operated in accordance with the provisions of 40 CFR Part 75.<sup>2</sup> (R 336.1401, R 336.2101)
4. The permittee shall monitor and record the opacity from each boiler using a Continuous Opacity Monitoring System (COMS), installed, operated and maintained in accordance with 40 CFR Part 60, Appendix B.<sup>2</sup> (R 336.1301, R 336.2101)

See Appendices 3-A, 3-B, and 3-D

**VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. (R 336.1213(3)(c)(ii))
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. (R 336.1213(3)(c)(i))
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. (R 336.1213(4)(c))
4. The permittee shall submit any performance test reports, including RATA reports, to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. (R 336.1213(3)(c), R 336.2001(5))

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVBLR12	228 <sup>2</sup>	400 <sup>2</sup>	R 336.1225 R 336.2803 R 336.2804 40 CFR 52.21 (c) and (d)

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the acid rain permitting provisions of 40 CFR Part 72.1 to 72.94, as outlined in a complete Phase II, Acid Rain Permit issued by the AQD. Phase II, Acid Rain Permit No. MI-AR-1710-2020 is hereby incorporated into this ROP as Appendix 9. **(R 336.1902(1)(q))**
2. The permittee shall not allow the emission of an air pollutant to exceed the amount of any emission allowances that an affected source lawfully holds as of the allowance transfer deadline pursuant to R 336.1902(1)(q) and 40 CFR Part 72.9(c)(1)(i). **(R 336.1213(10))**
3. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Annual Trading Program, as specified in 40 CFR Part 97, Subpart AAAAA, and identified in Appendix 10. **(40 CFR Part 97, Subpart AAAAA)**
4. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Ozone Season Group 2 Trading Program, as specified in 40 CFR Part 97, Subpart EEEEE, and identified in Appendix 10. **(40 CFR Part 97, Subpart EEEEE)**
5. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule SO<sub>2</sub> Group 1 Trading Program, as specified in 40 CFR Part 97, Subpart CCCCC, and identified in Appendix 10. **(40 CFR Part 97, Subpart CCCCC)**
6. The permittee shall comply with applicable provisions of Act 451 Part 15 EMISSION LIMITATIONS AND PROHIBITIONS-MERCURY.<sup>2</sup> **(R 336.2503(1))**
7. The permittee shall comply with all applicable requirements of 40 CFR Part 64 as specified in FGBOILER12. **(40 CFR Part 64)**
8. The permittee shall comply with the applicable requirements of 40 CFR Part 63, Subpart UUUUU - National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-fired Electric Utility Steam Generating Units, as specified in FGMATS\_U12.<sup>2</sup> **(40 CFR Part 63, Subpart UUUUU)**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

<sup>3</sup>This condition is federally enforceable and was originally established in the consent decree settling, "U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014" and also pursuant to Act 451, Section 324.5503(b), and will remain in effect after termination of the consent decree.

<sup>4</sup>Definitions specific to this condition may be found in Appendix 1-B: Definitions Applicable to Specified Permit Conditions.

**EUBOILER2  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

A 3560 MMBTU/hr wall-fired boiler with fuel oil startup capability. This emission unit is subject to 40 CFR Part 64 (CAM) and 40 CFR Part 63, Subpart UUUUU (MATS). All CAM requirements are in FGBOILER12, and all MATS requirements are in FGMATS\_U12.

**Flexible Group ID:** FGBOILER12 and FGMATS\_U12

**POLLUTION CONTROL EQUIPMENT**

Low-NOx burners,  
 Selective catalytic reduction (SCR),  
 Sorbent injection (ACI) (activated carbon or other sorbent for mercury control),  
 Dry sorbent injection (DSI) (hydrated lime or other sorbent), and  
 Pulse-jet fabric filter (PJFF) baghouse.

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Particulate matter (PM)	0.15 pound per 1,000 pounds exhaust gas, corrected to 50% excess air <sup>2</sup>	Hourly	EUBOILER2	SC V.1  (FGBOILER12, SC VI.1, COMS)	R 336.1331(1)(c)
2. NO <sub>x</sub>	0.100 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 30-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER2	SC VI.1	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 78; Act 451, Section 324.5503(b)</b>
3. NO <sub>x</sub>	0.080 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 90-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER2	SC VI.1	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 79; Act 451, Section 324.5503(b)</b>

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
4. SO <sub>2</sub>	0.320 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 365-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER2	SC VI.1 SC VI.2	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 114; Act 451, Section 324.5503(b)</b>
5. PM	0.015 pound per MMBTU heat input <sup>2,3,4</sup>	Hourly <sup>2,3,4</sup>	EUBOILER2	SC V.2  (FGBOILER12, SC VI.1, COMS)	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 145; Act 451, Section 324.5503(b)</b>
6. SO <sub>2</sub>	1.67 pounds per MMBTU heat input <sup>2</sup>	Monthly average, based on the average of the 31 previous operating days	EUBOILER2	SC VI.3	<b>R 336.1401(3), Table 41</b>
7. Opacity	20% <sup>2,3,4</sup>	Per 6-minute period except for one 6-minute period per hour of not more than 27% <sup>2,3,4</sup>	EUBOILER2	SC VI.4	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 151; Act 451, Section 324.5503(b)</b>

8. The permittee shall comply with the System-Wide Annual NO<sub>x</sub> Tonnage Limitations and System-Wide Annual SO<sub>2</sub> Tonnage Limitations specified in Appendix 11-A. Emissions from EUBOILER2 shall be counted toward the system-wide total emissions.<sup>2,3,4</sup> (**“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 98 & 129, Act 451, Section 324.5503(b)**)
9. The permittee shall comply with the SO<sub>2</sub> and NO<sub>x</sub> allowance surrender and super-compliance allowance provisions listed in Appendix 11-B: Allowance Provisions.<sup>2,3,4</sup> (**“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 101-109 and 132-140, Act 451, Section 324.5503(b)**)

See Appendices 11-A and 11-B

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Coal – sulfur content	1.0% by weight, at a heat content of 12,000 BTU/lb <sup>2</sup>	Monthly average, based on the average of the 31 previous operating days	EUBOILER2	SC VI.3	<b>R 336.1401(3), Table 41</b>

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate EUBOILER2 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for the emission control equipment (PJFF baghouse, ACI, DSI, and SCR) is implemented and maintained. The MAP shall, at a minimum, specify the following:
  - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
  - b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
  - c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1910, R 336.1911)**

2. The permittee shall continuously operate the PM Control Device for EUBOILER2 and use good air pollution control practices to maximize the PM emission reductions at all times when the unit is in operation. The requirements of Appendix 3-F shall be met.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 141, Act 451, Section 324.5503(b))**
3. The permittee shall not operate the boiler, including startup and shutdown, unless the corresponding PJFF baghouse is installed and operating properly, in accordance with safe operating practices.<sup>2</sup> **(R 336.1910)**
4. The permittee shall not burn freeze conditioning/dust suppression agents unless PJFF baghouses are installed and operating properly, in accordance with safe operating practices.<sup>2</sup> **(R 336.1910)**

See Appendix 3-F

**IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate EUBOILER2 unless the low-NOx burners, the SCR, DSI, ACI sorbent injection (for mercury control), and PJFF baghouse are installed, maintained, and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approvable MAP for EUBOILER2 as required in SC III.1.<sup>2</sup> **(R 336.1910)**



2. The permittee shall not operate EUBOILER2 unless the SCR and PJFF baghouse are continuously operated.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraphs 77 and 145, Act 451, Section 324.5503(b))
3. The permittee shall not operate EUBOILER2 unless the DSI system is continuously operated.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 114, Act 451, Section 324.5503(b))
4. The permittee shall continuously operate the PM control devices being vented to a combined stack associated with FGBOILER12.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 142, Act 451, Section 324.5503(b))

## **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. Every three (3) years, or more frequently upon request of the AQD, the permittee shall verify PM emission rates from EUBOILER2 by testing at the owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in 40 CFR Part 60, Appendix A Reference Method 17 (Determination of Particulate Emissions from Stationary Sources (In-stack Filtration Method)), Reference Method 5, “MATS” Reference Method 5, or other acceptable test method(s). An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> (R 336.1213(3), R 336.1201(3), R 336.2001, R 336.2003, R 336.2004)
2. The permittee shall conduct a stack test for PM pursuant to the provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements. Subsequent stack tests for PM shall be conducted pursuant to the schedule and provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 153, Act 451, Section 324.5503(b))
3. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor no less than 7 days prior to the anticipated test date.<sup>2</sup> (R 336.2001(3))
4. The permittee shall assess opacity using USEPA Reference Method 9 - “Visual Determination of the Opacity of Emissions from Stationary Sources”, upon the request of AQD.<sup>2</sup> (R 336.1301)

See Appendix 5

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. For purposes of determining compliance with the Rolling Average Emission Rates for NO<sub>x</sub> and SO<sub>2</sub> as found in SC I.2, I.3, and I.4., the permittee shall install and operate CEMS in accordance with the procedures of 40 CFR Part 75, except that the NO<sub>x</sub> and SO<sub>2</sub> emissions data need not be bias adjusted and the missing data substitution procedures of 40 CFR Part 75 shall not apply. If applicable, diluent capping (i.e., 5% CO<sub>2</sub>) will be applied to the NO<sub>x</sub> emission rate for any hours where the measured CO<sub>2</sub> concentration is less than 5% following the procedures in 40 CFR Part 75, Appendix F, Section 3.3.4.1.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 99 and 130, Act 451, Section 324.5503(b))
2. The permittee shall monitor SO<sub>2</sub> concentrations and gas flow using CEMS, as installed, maintained, and operated in accordance with 40 CFR Part 75.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 116, Act 451, Section 324.5503(b))

3. The permittee shall monitor gas flow, SO<sub>2</sub>, CO<sub>2</sub>, and NO<sub>x</sub> emissions using CEMS, as installed, maintained, and operated in accordance with the provisions of 40 CFR Part 75.<sup>2</sup> **(R 336.1401, R 336.2101)**
4. The permittee shall monitor and record the opacity from each boiler using a Continuous Opacity Monitoring System (COMS), installed, operated and maintained in accordance with 40 CFR Part 60, Appendix B.<sup>2</sup> **(R 336.1301, R 336.2101)**

See Appendices 3-A, 3-B, and 3-D

**VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports, including RATA reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVBLR12	228 <sup>2</sup>	400 <sup>2</sup>	<b>R 336.1225</b> <b>R 336.2803</b> <b>R 336.2804</b> <b>40 CFR 52.21 (c) and (d)</b>

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the acid rain permitting provisions of 40 CFR 72.1 to 72.94, as outlined in a complete Phase II, Acid Rain Permit issued by the AQD. Phase II, Acid Rain Permit No. MI-AR-1710-2020 is hereby incorporated into this ROP as Appendix 9. **(R 336.1902(1)(q))**
2. The permittee shall not allow the emission of an air pollutant to exceed the amount of any emission allowances that an affected source lawfully holds as of the allowance transfer deadline pursuant to R 336.1902(1)(q) and 40 CFR 72.9(c)(1)(i). **(R 336.1213(10))**
3. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Annual Trading Program, as specified in 40 CFR Part 97, Subpart AAAAA, and identified in Appendix 10. **(40 CFR Part 97, Subpart AAAAA)**

4. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Ozone Season Group 2 Trading Program, as specified in 40 CFR Part 97, Subpart EEEEE, and identified in Appendix 10. **(40 CFR Part 97, Subpart EEEEE)**
5. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule SO<sub>2</sub> Group 1 Trading Program, as specified in 40 CFR Part 97, Subpart CCCCC, and identified in Appendix 10. **(40 CFR Part 97, Subpart CCCCC)**
6. The permittee shall comply with applicable provisions of Act 451 Part 15 EMISSION LIMITATIONS AND PROHIBITIONS—MERCURY.<sup>2</sup> **(R 336.2503(1))**
7. The permittee shall comply with all applicable requirements of 40 CFR Part 64 as specified in FGBOILER12. **(40 CFR Part 64)**
8. The permittee shall comply with the applicable requirements of 40 CFR Part 63, Subpart UUUUU - National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-fired Electric Utility Steam Generating Units, as specified in FGMATS\_U12.<sup>2</sup> **(40 CFR Part 63, Subpart UUUUU)**

**See Appendices 11-A and 11-B**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

<sup>3</sup>This condition is federally enforceable and was originally established in the consent decree settling, “U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” and also pursuant to Act 451, Section 324.5503(b), and will remain in effect after termination of the consent decree.

<sup>4</sup>Definitions specific to this condition may be found in Appendix 1-B: Definitions Applicable to Specified Permit Conditions.

**EUBOILER3  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

An 8240 MMBTU/hr dry bottom, wall-fired boiler with fuel oil startup capability. This emission unit is subject to 40 CFR Part 63, Subpart UUUUU (MATS). The MATS requirements are in FGMATS\_U3.

**Flexible Group ID:** FGMATS\_U3

**POLLUTION CONTROL EQUIPMENT**

Low-NOx burners,  
 Selective catalytic reduction (SCR),  
 Sorbent injection (ACI) (activated carbon or other sorbent for mercury control),  
 Spray dry absorber (SDA), and  
 Pulse-jet fabric filter (PJFF) baghouse.

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Opacity	20% <sup>2</sup>	Per 6-minute period except for one 6-minute period per hour of not more than 27%	EUBOILER3	SC VI.2	<b>40 CFR 60.42(a)(2), R 336.1301</b>
2. Opacity	20% <sup>2,3,4</sup>	Per 6-minute period except for one 6-minute period per hour of not more than 27%	EUBOILER3	SC VI.2	<b>“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14- 13580, E.D. MICH., 2014” paragraph 151; Act 451, Section 324.5503(b)</b>
3. PM	0.10 pound per MMBTU heat input <sup>2</sup>	Hourly	EUBOILER3	SC V.1 SC VI.2 SC VI. 4	<b>40 CFR 60.42(a)(1)</b>
4. PM	370 pounds per hour <sup>2</sup>	Hourly	EUBOILER3	SC V.1 SC VI.2 SC VI.4	<b>R 336.1205(3)</b>
5. PM	1,080 tons per year <sup>2</sup>	Based on a 12-month rolling time period as determined at the end of each calendar month	EUBOILER3	SC V.1 SC VI.2 SC VI.4	<b>R 336.1205(3)</b>

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
6. PM	0.015 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 3-hr rolling average in accordance with SC V.4 and SC VI.4 <sup>2,3,4</sup>	EUBOILER3	SC V.3, SC V.4 (if applicable) SC VI.4	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 146; Act 451, Section 324.5503(b)
7. SO <sub>2</sub>	1.2 pounds per MMBTU heat input <sup>2</sup>	Continuous	EUBOILER3	SC VI.1	40 CFR 60.43(a)(2)
8. SO <sub>2</sub>	10,500 pounds per hour <sup>2</sup>	Based on a daily average	EUBOILER3	SC VI.1	R 336.1205(3)
9. SO <sub>2</sub>	31,650 tons per year <sup>2</sup>	Based on a 12-month rolling time period as determined at the end of each calendar month	EUBOILER3	SC VI.1	R 336.1205(3)
10. SO <sub>2</sub>	0.085 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 30-day Rolling Average <sup>2,3,4</sup>	EUBOILER3	SC VI.3	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 112; Act 451, Section 324.5503(b)
11. SO <sub>2</sub>	0.070 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 365-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER3	SC VI.3	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraph 112; Act 451, Section 324.5503(b)
12. NO <sub>x</sub>	0.70 pound per MMBTU heat input <sup>2</sup>	Per 3-hour rolling time period, as determined each hour the boiler operates	EUBOILER3	SC VI.1	40 CFR 60.44(a)(3)
13. NO <sub>x</sub>	6,130 pounds per hour <sup>2</sup>	Based on a daily average	EUBOILER3	SC VI.1	R 336.1205(3)
14. NO <sub>x</sub>	18,750 tons per year <sup>2</sup>	Based on a 12-month rolling time period as determined at the end of each calendar month	EUBOILER3	SC VI.1	R 336.1205(3)

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
15. NOx	0.100 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 30-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER3	SC VI.3	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14- 13580, E.D. MICH., 2014” paragraph 81; Act 451, Section 324.5503(b)
16. NOx	0.080 pound per MMBTU heat input <sup>2,3,4</sup>	Based on a 90-day Rolling Average Emission Rate <sup>2,3,4</sup>	EUBOILER3	SC VI.3	“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14- 13580, E.D. MICH., 2014” paragraph 82; Act 451, Section 324.5503(b)

17. The permittee shall comply with the System-Wide Annual NOx Tonnage Limitations and System-Wide Annual SO<sub>2</sub> Tonnage Limitations specified in Appendix 11-A. Emissions from EUBOILER3 shall be counted toward the system-wide total emissions.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 98 & 129, Act 451, Section 324.5503(b))

18. The permittee shall comply with the SO<sub>2</sub> and NO<sub>x</sub> allowance surrender and super-compliance allowance provisions listed in Appendix 11-B: Allowance Provisions.<sup>2,3,4</sup> (“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 101-109 and 132-140, Act 451, Section 324.5503(b))

See Appendix 11-A and Appendix 11-B

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not burn freeze conditioning/dust suppression agents unless the boiler and corresponding particulate control device are operating properly.<sup>2</sup> (R 336.1910)
2. The permittee shall not operate the boiler, including startup and shutdown, unless the corresponding PJFF baghouse is installed and operating properly, in accordance with safe operating practices.<sup>2</sup> (R 336.1910)
3. The permittee shall not operate EUBOILER3 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for emission control equipment (PJFF baghouse, ACI, SDA, and SCR) is implemented and maintained. The MAP shall, at a minimum, specify the following:
  - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.

- b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
- c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1910, R 336.1911)**

4. The permittee shall comply with all provisions of the federal Standards of Performance for Fossil-Fuel-Fired Steam Generators for Which Construction is Commenced after August 17, 1971, as specified in 40 CFR Part 60, Subparts A and D, as they apply to EUBOILER3.<sup>2</sup> **(40 CFR Part 60, Subparts A and D)**
5. The permittee shall continuously operate the PM Control Device for EUBOILER3 and use good air pollution control practices to maximize the PM emission reductions at all times when the unit is in operation. The requirements of Appendix 3-F shall be met.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 141, Act 451, Section 324.5503(b))**

See Appendix 3-F

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate EUBOILER3 unless the low-NOx burners, the SCR, SDA, ACI sorbent injection (for mercury control), and PJFF baghouse are installed, maintained, and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approvable MAP for EUBOILER3 as required in SC III.5.<sup>2</sup> **(R 336.1910)**
2. The permittee shall not operate EUBOILER3 unless the SCR is Continuously Operated.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 80, Act 451, Section 324.5503(b))**
3. The permittee shall not operate EUBOILER3 unless the SDA and PJFF baghouse units are Continuously Operated.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraphs 112 and 146, Act 451, Section 324.5503(b))**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. Every three (3) years, or more frequently upon request of the AQD, the permittee shall verify PM emission rates from EUBOILER3 by testing at the owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in 40 CFR Part 60, Appendix A, Reference Method 17 (Determination of Particulate Emissions from Stationary Sources (in-stack Filtration Method) Reference Method 5, “MATS” Reference Method 5, or other acceptable test method(s). An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> **(R 336.2001, R 336.2003, R 336.2004)**

2. The permittee shall notify the AQD no less than 7 days prior to the anticipated test date.<sup>2</sup> **(R 336.2001(3))**
3. The permittee shall conduct a stack test for PM pursuant to the provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements. Subsequent stack tests for PM shall be conducted pursuant to the schedule and provisions found in Appendix 5: PM Emissions Testing and Monitoring Requirements.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 153, Act 451, Section 324.5503(b))**
4. As an alternative to the requirements of SC V.3 PM stack testing, the permittee may forego stack testing and instead demonstrate continuous compliance with SC I.7 PM filterable emission limit by using the PM CEMS pursuant to conditions contained in Appendix 5: PM Emissions Testing and Monitoring Requirements, and Appendix 3-E: PM CEMS.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” – paragraph 157, Act 451, Section 324.5503(b))**

See Appendices 3-E and 5

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall monitor gas flow, SO<sub>2</sub>, CO<sub>2</sub>, and NO<sub>x</sub> emissions using CEMS, as installed, maintained, and operated in accordance with the provisions of 40 CFR Part 75.<sup>2</sup> **(R 336.1205(3), R 336.2101, 40 CFR Part 60)**
2. The permittee shall monitor and record the opacity from the boiler using a Continuous Opacity Monitoring System (COMS), installed, operated and maintained in accordance with 40 CFR Part 60, Appendix B.<sup>2</sup> **(R 336.1301, R 336.2101, 40 CFR 60.42(a)(2))**
3. For purposes of determining compliance with the Rolling Average Emission Rates for NO<sub>x</sub> and SO<sub>2</sub> as found in SC I.10, I.11, I.15, and I.16, the permittee shall install and operate CEMS in accordance with the procedures of 40 CFR Part 75, except that the NO<sub>x</sub> and SO<sub>2</sub> emissions data need not be bias adjusted and the missing data substitution procedures of 40 CFR Part 75 shall not apply. If applicable, diluent capping (i.e., 5% CO<sub>2</sub>) will be applied to the NO<sub>x</sub> emission rate for any hours where the measured CO<sub>2</sub> concentration is less than 5% following the procedures in 40 CFR Part 75, Appendix F, Section 3.3.4.1.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 99 and 130, Act 451, Section 324.5503(b))**
4. The permittee shall install and continuously operate a PM CEMS pursuant to the conditions contained in Appendix 3-E: PM CEMS.<sup>2,3,4</sup> **(“U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” paragraphs 159, 163, Act 451, Section 324.5503(b))**

See Appendices 3-A through 3-F

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports, including RATA reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**



5. Quarterly reporting of monthly excess sulfur dioxide, and nitrogen oxide emissions (including the nature and cause of the periods of excess emissions), and of the dates and times of the monitoring systems being inoperative. Each quarterly report is due within 30 days of the calendar quarter reporting period. **(R 336.2170)**
6. Quarterly reporting of excess opacity emissions (including the nature and cause of the periods of excess emissions), and of the dates and times of the monitoring systems being inoperative. Each quarterly report is due within 30 days of the calendar quarter reporting period. **(R 336.2170)**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVBLR3	327 <sup>2</sup>	642 <sup>2</sup>	<b>R 336.1201(3)</b>

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the acid rain permitting provisions of 40 CFR 72.1 to 72.94, as outlined in a complete Phase II, Acid Rain Permit issued by the AQD. Phase II, Acid Rain Permit No. MI-AR-1710-2020 is hereby incorporated into this ROP as Appendix 9. **(R 336.1902(1)(q))**
2. The permittee shall not allow the emission of an air pollutant to exceed the amount of any emission allowances that an affected source lawfully holds as of the allowance transfer deadline pursuant to R 336.1902(1)(q) and 40 CFR 72.9(c)(1)(i). **(R 336.1213(10))**
3. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Annual Trading Program, as specified in 40 CFR Part 97, Subpart AAAAA, and identified in Appendix 10. **(40 CFR Part 97, Subpart AAAAA)**
4. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule NO<sub>x</sub> Ozone Season Group 2 Trading Program, as specified in 40 CFR Part 97, Subpart EEEEE, and identified in Appendix 10. **(40 CFR Part 97, Subpart EEEEE)**
5. The permittee shall comply with the provisions of the Cross-State Air Pollution Rule SO<sub>2</sub> Group 1 Trading Program, as specified in 40 CFR Part 97, Subpart CCCCC, and identified in Appendix 10. **(40 CFR Part 97, Subpart CCCCC)**
6. The permittee shall comply with applicable provisions of Act 451 Part 15 EMISSION LIMITATIONS AND PROHIBITIONS—MERCURY.<sup>2</sup> **(R 336.2503(1))**
7. The permittee shall comply with the applicable requirements of 40 CFR Part 63, Subpart UUUUU - National Emission Standards for Hazardous Air Pollutants: Coal- and Oil-fired Electric Utility Steam Generating Units as specified in FGMATS\_U3.<sup>2</sup> **(40 CFR Part 63, Subpart UUUUU)**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

<sup>3</sup>This condition is federally enforceable and was originally established in the consent decree settling, “U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” and also pursuant to Act 451, Section 324.5503(b), and will remain in effect after termination of the consent decree.

<sup>4</sup>Definitions specific to this condition may be found in Appendix 1-B: Definitions Applicable to Specified Permit Conditions.

**EUCOALHAND  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

The coal handling facility consists of: (2) dumper buildings, transfer conveyors, transfer building, breaker house, bunker rooms, and the coal pile storage area itself.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

Enclosures, 11 baghouses, dust suppression, telescopic spouts. The Dust Collectors serving the Unit 1 and 2 (DC10), and Unit 3 (DC1) dumper houses, and Coal yard dust hopper (DC11) are subject to 40 CFR Part 64 (CAM).

Dust collectors serving the breaker house (DC4), bunker houses (DC 5, 6, 7) and the reclaim hopper (DC9) are subject to the New Source Performance Standard 40 CFR Part 60, Subpart Y. (Initial performance testing has been completed.)

Dust collectors serving the reclaim (DC2) and transfer house (DC3A, DC3B) are subject to Michigan Rule 336.1301.

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. PM	0.10 pound per 1,000 pounds exhaust gas, on a dry basis	At all times, as verifiable through any requested stack testing	Each discharge point	SC IV.1 SC VI.1 Through SC VI.8  (Proper maintenance and operation of the baghouses)	<b>R 336.1331(1)(a), Table 31(j)</b>
2. Opacity	20%	6-minute average	Discharge points for dust collectors DC4, DC5, DC6, DC7, and DC9	SC IV.1 SC VI.1 Through SC VI.8  (Proper maintenance and operation of the baghouses)	<b>40 CFR 60.252(c) (NSPS, Subpart Y)</b>
3. Opacity	20%	6-minute average	Discharge points for dust collectors DC1, DC2, DC3A, DC3B, DC10, and DC11,	SC IV.1 SC VI.1 Through SC VI.8  (Proper maintenance and operation of the baghouses)	<b>R 336.1301(1)(a)</b>

## **II. MATERIAL LIMIT(S)**

NA

## **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate a process portion unless the particulate matter control device controlling the portion is installed and operating properly. **(R 336.1910)**
2. The permittee shall operate all coal handling equipment in accordance with the most recent facility Fugitive Dust Control Plan as approvable by the AQD District Supervisor. **(R 336.1213(3))**
3. The permittee shall not operate EUCOALHAND unless a malfunction abatement plan (MAP) as described in Rule 911(2), for emission control equipment is implemented and maintained. The MAP shall, at a minimum, specify the following:
  - a. A complete preventative maintenance program including identification of the supervisory personnel responsible for overseeing the inspection, maintenance, and repair of air-cleaning devices, a description of the items or conditions that shall be inspected, the frequency of the inspections or repairs, and an identification of the major replacement parts that shall be maintained in inventory for quick replacement.
  - b. An identification of the source and air-cleaning device operating variables that shall be monitored to detect a malfunction or failure, the normal operating range of these variables, and a description of the method of monitoring or surveillance procedures.
  - c. A description of the corrective procedures or operational changes that shall be taken in the event of a malfunction or failure to achieve compliance with the applicable emission limits.

If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days if new equipment is installed or upon request from the District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits. **(R 336.1910, R 336.1911)**

## **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. Each particulate matter control device shall be equipped with pressure drop measurement devices and associated alarm system.<sup>2</sup> **(R 336.1201(3), R 336.1213(3))**

## **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall assess opacity using USEPA Reference Method 9 - "Visual Determination of the Opacity of Emissions from Stationary Sources", upon the request of AQD. **(R 336.1213(3))**
2. Upon request of the AQD District Supervisor, the permittee shall verify PM emission rates from EUCOALHAND by testing at the owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in 40 CFR Part 60, Appendix A; Part 10 of the Michigan Air Pollution Control Rules. An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**

3. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. **(R 336.1213(3))**

**See Appendix 5**

**VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall conduct and record non-certified visible emissions observations for the dust collectors servicing EUBOILER 1, EUBOILER2 (DC10) and EUBOILER3 (DC1) dumper houses and Coal Yard dust hopper DC(11) once per day when operating, as the primary indicator of the proper functioning of each fabric filter dust collector. If visible emissions are observed, the permittee shall document the visible emissions, including the duration, and continue to observe the source of the visible emissions until no visible emissions are observed. The permittee shall initiate corrective actions as quickly as possible upon the detection of visible emissions. If there is a break in the visible emissions observations, it will be assumed that visible emissions continue to occur during any break in observations. The appropriate range of visible emissions defining proper functioning of each fabric filter dust collector is no visible emissions. **(40 CFR 64.6(c)(1)(i), (ii), and (iii))**
2. An excursion is the observation of visible emissions for the dust collectors serving EUBOILER1 and EUBOILER2 (DC10) or EUBOILER3 (DC1) dumper house or the coal yard dust hopper (DC11) for a duration exceeding one (1) hour. **(40 CFR 64.6(c)(2))**
3. The permittee shall properly maintain the monitoring system, including keeping necessary parts for routine repair of the monitoring equipment. **(40 CFR 64.7(b))**
4. Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions or other measures as specified in the MAP. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). **(40 CFR 64.7(d))**
5. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. **(40 CFR 64.6(c)(3), 40 CFR 64.7(c))**
6. Any formal compliance determinations with the opacity limit established in 40 CFR 60.252(c) shall utilize Method 9 and the procedures in 40 CFR 60.11. **(40 CFR 60.254(b)(2))**
7. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan and any activities undertaken to implement a quality improvement plan, and other information such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions. **(40 CFR 64.9(b)(1))**

8. The permittee shall perform, and document non-certified visible emissions observations from dust collectors DC4, DC5, DC6, DC7, and DC9 as required in I.2 on a daily basis when EUCOALHAND is operating. If during the observation there are any visible emissions detected from an emission point, then corrective procedures as defined in the MAP shall be implemented. Records of the non-certified visible emissions observations, USEPA Method 9 observations that are performed, the reason for any visible emissions observed, and any corrective actions taken, shall be kept on file and in a format acceptable to the AQD. **(R 336.1213(3))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. Each semiannual report of monitoring deviations shall include summary information on the number, duration, and cause of exceedances/excursions in the reporting period; and the corrective actions taken in response. If there were no excursions and/or exceedances in the reporting period, then this report shall include a statement that there were no excursions and/or exceedances. **(40 CFR 64.9(a)(2)(i))**
5. Each semiannual report of monitoring deviations shall include summary information on monitor downtime. If there were no periods of monitor downtime in the reporting period, then this report shall include a statement that there were no periods of monitor downtime. **(40 CFR 64.9(a)(2)(ii))**
6. Each semiannual report of monitoring deviations shall include a description of the actions taken to implement a Quality Improvement Plan (QIP) during the reporting period, if appropriate. If a QIP has been completed, the report shall include documentation that the QIP has been implemented, and a discussion pertaining to whether the QIP implementation has reduced the likelihood of excursions or exceedances. **(40 CFR 64.9(a)(2)(iii))**
7. The permittee shall submit any performance test reports, except for Method 9, to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

1. The permittee shall otherwise comply with the applicable requirements of 40 CFR Part 60 ("Standards of Performance for New Stationary Sources"), Subparts A ("General Provisions") and Y ("Standards of Performance for Coal Preparation Plants"). **(40 CFR Part 60, Subparts A and Y)**
2. The permittee shall comply with all applicable requirements of 40 CFR Part 64. **(40 CFR Part 64)**

3. If the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the AQD and if necessary, submit a proposed modification of the ROP and CAM Plan to address the necessary monitoring changes. Such a modification may include but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. **(40 CFR 64.7(e))**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUSDA\_U3**  
**EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Lime preparation operations for Boiler 3 that support the SDA including storage silos, vertical ball mills, and lime slurry transfer and product tanks.

SDA operations for Boiler 3 including lime slurry atomizer head tanks, recycle silos, recycle mix tanks, and recycle slurry storage tanks. The two recycle silos are subject to 40 CFR Part 64 Compliance Assurance Monitoring (CAM).

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

Silos are controlled by bin vent filters.  
 Ball mills emissions controlled by spray scrubbers (mill scrubbers).  
 Recycle mix tank emissions controlled by a spray scrubber.

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Opacity	5% <sup>2</sup>	6-Minute average	Each bin vent filter in EUSDA_U3	SC VI.1	<b>R 336.1301(1)(c)</b>
2. Opacity	5% <sup>2</sup>	6-Minute average	Each spray scrubber in EUSDA_U3	SC VI.1	<b>R 336.1301(1)(c)</b>
3. PM	0.004 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Each bin vent filter in EUSDA_U3	SC III.2 SC IV.1 SC V.1	<b>R 336.1331(1)(c)</b>
4. PM	0.01 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Each spray scrubber in EUSDA_U3	SC III.2 SC IV.1 SC V.1	<b>R 336.1331(1)(c)</b>
5. PM10	0.03 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVLSS-BV3A SVLSS-BV3B SVLSS-BV3C	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>
6. PM2.5	0.03 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVLSS-BV3A SVLSS-BV3B SVLSS-BV3C	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>
7. PM10	0.021 pph <sup>2</sup>	Hourly	Each of the following spray scrubber emission points: SVVM-SS3A SVVM-SS3B SVVM-SS3C	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>



Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
8. PM2.5	0.021 pph <sup>2</sup>	Hourly	Each of the following spray scrubber emission points: SVVM-SS3A SVVM-SS3B SVVM-SS3C	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>
9. PM10	0.02 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVRS-BV3A SVRS-BV3B  (CAM Subject)	SC III.2 SC IV.1 SC V.1 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
10. PM2.5	0.02 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVRS-BV3A SVRS-BV3B  (CAM Subject)	SC III.2 SC IV.1 SC V.1 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
11. PM10	0.024 pph <sup>2</sup>	Hourly	Each of the following spray scrubber emission points: SVMT-SS3A1 SVMT-SS3B1 SVMT-SS3A2 SVMT-SS3B2	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>
12. PM2.5	0.024 pph <sup>2</sup>	Hourly	Each of the following spray scrubber emission points: SVMT-SS3A1 SVMT-SS3B1 SVMT-SS3A2 SVMT-SS3B2	SC III.2 SC IV.1 SC V.1	<b>R 336.2803</b> <b>R 336.2804</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The Campbell Complex fugitive dust plan shall be updated as necessary and kept at the facility. If at any time the fugitive dust control program fails to address or inadequately addresses a dusting event, the permittee shall amend the fugitive dust control program within 45 days after such an event occurs. The permittee shall also amend the fugitive dust control program within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the fugitive dust control program and any amendments to the fugitive dust control program to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the fugitive dust control program or amended fugitive dust control program shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1372, R 336.2803, R 336.2804, Act 451, Section 324.5524)**
2. The permittee shall not operate EUSDA\_U3 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for operation of the process and emission control equipment, is implemented updated as necessary, and kept at the facility. If at any time the MAP fails to address or inadequately addresses an event that meets

the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> (R 336.1910, R 336.1911)

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate any portion of EUSDA\_U3 unless the associated enclosures, bin vent filters and spray scrubbers are installed, maintained and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approved MAP for EUSDA\_U3 as required in SC III.2.<sup>2</sup> (R 336.1910, R 336.1911, R 336.2803, R 336.2804)

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. Upon request of the AQD District Supervisor, the permittee shall verify PM, PM10, and PM2.5 emission rates from EUSDA\_U3 by testing at owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in:

<b>Pollutant</b>	<b>Test Method Reference</b>
PM	40 CFR Part 60, Appendix A; Part 10 of the Michigan Air Pollution Control Rules
PM10/PM2.5	40 CFR Part 51, Appendix M

An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. (R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)

The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. (R 336.1213(3))

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. (R 336.1213(3)(b)(ii))

1. The permittee shall perform, and document non-certified visible emissions observations as required in SC I.1 and I.2 on a daily basis when EUSDA\_U3 is operating. If during the observation there are any visible emissions detected from an emission point, then corrective procedures as defined in the MAP shall be implemented. Records of the non-certified visible emissions observations, USEPA Method 9 observations that are performed, the reason for any visible emissions observed, and any corrective actions taken, shall be kept on file and in a format acceptable to the AQD.<sup>2</sup> (R 336.1301(1)(c))
2. The permittee shall conduct and record non-certified visible emissions observations the Recycle Silo bin vent filters (SVRS-BV3A, SVRS-BV3B) once per day when operating, as the primary indicator of the proper functioning of each bin vent filter for EUSDA\_U3. If visible emissions are observed, the permittee shall document the visible emissions, including duration, and continue to observe the source of the visible emissions until no visible emissions are observed. The permittee shall initiate corrective actions as quickly as possible upon the detection of visible emissions. If there is a break in the visible emissions observations, it will be assumed that visible emissions continue to occur during any break in observations. The appropriate range of visible emissions defining proper functioning of each bin vent filter is no visible emissions. (40 CFR 64.6(c)(1)(i), (ii), and (iii))
3. An excursion is the observation of visible emissions for a duration exceeding one (1) hour. (40 CFR 64.6(c)(2))

4. Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions or in accordance with the MAP. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). **(40 CFR 64.7(d))**
5. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. **(40 CFR 64.6(c)(3), 40 CFR 64.7(c))**
6. The permittee shall properly maintain the monitoring system, including keeping necessary parts for routine repair of the monitoring equipment. **(40 CFR 64.7(b))**
7. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan and any activities undertaken to implement a quality improvement plan, and other information such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions. **(40 CFR 64.9(b)(1))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
2. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
3. Each semiannual report of monitoring and deviations shall include summary information on the number, duration and cause of excursions and/or exceedances and the corrective actions taken. If there were no excursions and/or exceedances in the reporting period, then this report shall include a statement that there were no excursions and/or exceedances. **(40 CFR 64.9(a)(2)(i))**
4. Each semiannual report of monitoring and deviations shall include summary information on monitor downtime. If there were no periods of monitor downtime in the reporting period, then this report shall include a statement that there were no periods of monitor downtime. **(40 CFR 64.9(a)(2)(ii))**
5. Each semiannual report shall include a Quality Improvement Plan (QIP) during the reporting period, if appropriate. If a QIP has been completed, the report shall include documentation that the QIP has been implemented, and a discussion pertaining to whether the QIP implementation has reduced the likelihood of excursions or exceedances. **(40 CFR 64.9(a)(2)(iii))**

**See Appendix 8**

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

<b>Stack &amp; Vent ID</b>	<b>Maximum Exhaust Dimensions (inches)</b>	<b>Minimum Height Above Ground (feet)</b>	<b>Underlying Applicable Requirements</b>
1. SVLSS-BV3A	4.3 <sup>2</sup>	135 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
2. SVLSS-BV3B	4.3 <sup>2</sup>	135 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
3. SVLSS-BV3C	4.3 <sup>2</sup>	135 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
4. SVVM-SS3A	11.4 <sup>2</sup>	52 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
5. SVVM-SS3B	11.4 <sup>2</sup>	52 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
6. SVVM-SS3C	11.4 <sup>2</sup>	52 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
7. SVRS-BV3A	6.1 <sup>2</sup>	126 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
8. SVRS-BV3B	6.1 <sup>2</sup>	126 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
9. SVMT-SS3A1	6.1 <sup>2</sup>	58 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
10. SVMT-SS3B1	6.1 <sup>2</sup>	58 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
11. SVMT-SS3A2	6.1 <sup>2</sup>	58 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
12. SVMT-SS3B2	6.1 <sup>2</sup>	58 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with all applicable requirements of 40 CFR Part 64. **(40 CFR Part 64)**
2. If the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the AQD and if necessary, submit a proposed modification of the ROP and CAM Plan to address the necessary monitoring changes. Such a modification may include but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. **(40 CFR 64.7(e))**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUDSI\_U12  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Dry Sorbent Injection (DSI) Material Handling for Boilers 1 and 2. Includes sorbent silos (hydrated lime or other sorbent) and pneumatic transfer.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

Bin vent filters

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period/ Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Opacity	5% <sup>2</sup>	6- Minute Average	Each bin vent filter in EUDSI_U12	SC VI.1	<b>R 336.1301(1)(c)</b>
2. PM	0.004 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Each bin vent filter in EUDSI_U12	SC III.2 SC VI.1	<b>R 336.1331(1)(c)</b>
3. PM10	0.08 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVLSS-BV1A SVLSS-BV1B SVLSS-BV1C SVLSS-BV2A SVLSS-BV2B SVLSS-BV2C	SC III.2 SC VI.1	<b>R 336.2803 R 336.2804</b>
4. PM2.5	0.08 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVLSS-BV1A SVLSS-BV1B SVLSS-BV1C SVLSS-BV2A SVLSS-BV2B SVLSS-BV2C	SC III.2 SC VI.1	<b>R 336.2803 R 336.2804</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The Campbell Complex fugitive dust plan shall be updated as necessary and kept at the facility. If at any time the fugitive dust control program fails to address or inadequately addresses a dusting event, the permittee shall amend the fugitive dust control program within 45 days after such an event occurs. The permittee shall also amend the fugitive dust control program within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the fugitive dust control program and any amendments to the fugitive dust control program to the AQD District Supervisor for review and approval. If the AQD does not

notify the permittee within 90 days of submittal, the fugitive dust control program or amended fugitive dust control program shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1372, R 336.2803, R 336.2804, Act 451, Section 324.5524)**

2. The permittee shall not operate EUDSI\_U12 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for operation of the process and emission control equipment, is implemented updated as necessary, and kept at the facility. If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1910, R 336.1911)**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate any portion of EUDSI\_U12 unless the associated enclosures and bin vent filters are installed, maintained and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approved MAP for EUDSI\_U12 as required in SC III.2.<sup>2</sup> **(R 336.1910, R 336.1911, R 336.2803, R 336.2804)**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall perform, and document non-certified visible emissions observations as required in SC I.1 on a daily basis when EUDSI\_U12 is operating. If during the observation there are any visible emissions detected from an emission point, then corrective procedures as defined in the MAP shall be implemented. Records of the non-certified visible emissions observations, USEPA Method 9 observations that are performed, the reason for any visible emissions observed, and any corrective actions taken, shall be kept on file and in a format acceptable to the AQD.<sup>2</sup> **(R 336.1301(1)(c))**

#### **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

**See Appendix 8**

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

<b>Stack &amp; Vent ID</b>	<b>Maximum Exhaust Dimensions (inches)</b>	<b>Minimum Height Above Ground (feet)</b>	<b>Underlying Applicable Requirements</b>
1. SVLSS-BV1A	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>
2. SVLSS-BV1B	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>
3. SVLSS-BV1C	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>
4. SVLSS-BV2A	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>
5. SVLSS-BV2B	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>
6. SVLSS-BV2C	14 <sup>2</sup>	140 <sup>2</sup>	<b>R 336.2803</b> <b>R 336.2804</b>

**IX. OTHER REQUIREMENT(S)**

NA

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUACI\_U123**  
**EMISSION UNIT CONDITIONS**

**DESCRIPTION**

Activated carbon (or other sorbent) material handling including four (4) silos for Boiler Units 1, 2, and 3.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

Bin vent filters

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Opacity	5% <sup>2</sup>	6- Minute Average	Each bin vent filter in EUACI_U123	SC VI.1	<b>R 336.1301(1)(c)</b>
2. PM	0.004 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Each bin vent filter in EUACI_U123	SC III.2 SC VI.1	<b>R 336.1331(1)(c)</b>
3. PM10	0.045 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVACI-BV1A SVACI-BV2A	SC III.2 SC VI.1	<b>R 336.2803</b> <b>R 336.2804</b>
4. PM2.5	0.045 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVACI-BV1A SVACI-BV2A	SC III.2 SC VI.1	<b>R 336.2803</b> <b>R 336.2804</b>
5. PM10	0.041 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVACI-BV3A SVACI-BV3B	SC III.2 SC VI.1	<b>R 336.2803</b> <b>R 336.2804</b>
6. PM2.5	0.041 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVACI-BV3A SVACI-BV3B	SC III.2 SC VI.1	<b>R 336.2803</b> <b>R 336.2804</b>

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The Campbell Complex fugitive dust plan shall be updated as necessary and kept at the facility. If at any time the fugitive dust control program fails to address or inadequately addresses a dusting event, the permittee shall amend the fugitive dust control program within 45 days after such an event occurs. The permittee shall also amend the fugitive dust control program within 45 days, if new equipment is installed or upon request from the



AQD District Supervisor. The permittee shall submit the fugitive dust control program and any amendments to the fugitive dust control program to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the fugitive dust control program or amended fugitive dust control program shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1372, R 336.2803, R 336.2804, Act 451, Section 324.5524)**

2. The permittee shall not operate EUACI\_U123 unless a malfunction abatement plan (MAP) as described in Rule 911(2), for operation of the process and emission control equipment, is implemented updated as necessary, and kept at the facility. If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1910, R 336.1911)**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate any portion of EUACI\_U123 unless the associated enclosures and bin vent filters are installed, maintained and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approved MAP for EUACI\_U123 as required in SC III.2.<sup>2</sup> **(R 336.1910, R 336.1911, R 336.2803, R 336.2804)**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall perform, and document non-certified visible emissions observations as required in SC I.1 on a daily basis when EUACI\_U123 is operating. If during the observation there are any visible emissions detected from an emission point, then corrective procedures as defined in the MAP shall be implemented. Records of the non-certified visible emissions observations, USEPA Method 9 observations that are performed, the reason for any visible emissions observed, and any corrective actions taken, shall be kept on file and in a format acceptable to the AQD.<sup>2</sup> **(R 336.1301(1)(c))**

#### **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

**See Appendix 8**

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

<b>Stack &amp; Vent ID</b>	<b>Maximum Exhaust Dimensions (inches)</b>	<b>Minimum Height Above Ground (feet)</b>	<b>Underlying Applicable Requirements</b>
1. SVACI-BV1A	14 <sup>2</sup>	60 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
2. SVACI-BV2A	14 <sup>2</sup>	60 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
3. SVACI-BV3A	12 <sup>2</sup>	80 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>
4. SVACI-BV3B	12 <sup>2</sup>	80 <sup>2</sup>	<b>R 336.2803 R 336.2804</b>

**IX. OTHER REQUIREMENT(S)**

NA

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## **EUBYPRODUCT EMISSION UNIT CONDITIONS**

### **DESCRIPTION**

Flyash and byproduct handling system that transports flyash and byproduct from the plant to the disposal silos. The Unit 3 Transfer Tanks A and B (SVTT-BV3A and SVTT-BV3B) as well as Landfill Silo's A, B, and C (SVDCASS-BVA, SVDCASS-BVB, and SVDCASS-BVC) are subject to 40 CFR Part 64 (CAM).

#### Unit 3 System

- A large portion of PJFF flyash/byproduct is recycled back to the SDA via the SDA Recycle Flyash System and the remainder is conveyed to the Unit 3 Dry Flyash Byproduct System (for resale or landfill). The SDA Byproduct System consists of the following major equipment: two transfer towers [TT3A and TT3B], three vacuum exhausters [two in operation and one spare], and three disposal silos [Flyash Silos A, B, and C]. Each transfer tower includes two filter separators (F/S) and a single transfer tank. Each transfer tank and each disposal silo are equipped with a bin vent filter. TT3A, TT3B and the three associated vacuum exhausters located at Boiler 3 are regulated under EUBYPRODUCT.
- The vacuum conveyance system pulls flyash from the PJFF hoppers and transports the flyash in hard piping through a F/S and into a transfer tank where the conveyance air is then discharged through a vacuum exhauster (two F/S's per transfer tank. Transfer tank displacement air is released through a bin vent filter to atmosphere. Flyash and byproduct materials collected in the transfer tanks are periodically conveyed to disposal silos A, B, or C where the material is loaded onto trucks for shipment as either byproduct or waste.

#### Unit 1 and 2 System

- The Dry Flyash Handling System services both Unit 1 and Unit 2 and consists of the following major equipment: three transfer towers [TT1, TT2 and TT3], five vacuum exhausters [three in operation and two spares], and two disposal silos [DSA, DSB]. Each transfer tower includes a filter separator and transfer tank. Each transfer tank and each disposal silo are equipped with a bin vent filter.
- TT1 and TT2 and the three associated vacuum exhausters located at Boiler 1&2 are regulated under EUBYPRODUCT. TT3 and the remaining two associated vacuum exhausters that solely support Unit 2 are not regulated by EUBYPRODUCT and are exempt from permitting under Michigan Rule 284(k).
- The vacuum conveyance system pulls flyash from each Boiler Unit's PJFF hoppers and transports the flyash in hard piping through a filter separator and into a transfer tank where the conveyance air is then discharged through a vacuum exhauster. The three vacuum exhausters that serve TT1 and TT2 normally discharge to the Unit 1 PJFF inlet ductwork. The two vacuum exhausters that serve TT3 can only discharge to the Unit 2 PJFF inlet duct. Transfer tank displacement air is released through a bin vent filter to atmosphere. Flyash and byproduct materials collected in the transfer tanks are periodically conveyed to disposal silos DSA and DSB where the material is loaded onto trucks for shipment as either byproduct or waste.
- When Boiler 1 and its associated PJFF are not in operation, then the vacuum exhausters associated with TT1 and TT2 will be redirected and one vacuum exhauster may intermittently discharge controlled emissions to atmosphere through a dedicated stack (bypassing the Boiler 1 PJFF). The operation of TT3 and its associated vacuum exhausters would remain unchanged; discharging into the Unit 2 inlet PJFF ductwork.

#### Common

- 3 Disposal Silos (A, B, & C) – located at the landfill, and store the byproduct/flyash until disposed in licensed landfill.
- Truck loading – each disposal silo has a loading bay under the silo where trucks are loaded with byproduct/flyash for transport to the landfill or for beneficial re-use. "B" silo also employs an exterior load-out chute.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

Transfer tank: Each tank has as a filter separator that breaks the vacuum of the conveyance air to separate the transported material (the flyash byproduct) from the conveyance air. The filter separator is the fabric filter control for the conveyance air. The displacement air from the byproduct dropping into the tank is controlled by a bin vent filter.

Vacuum exhausters: Although the conveyance air from the vacuum exhausters are already controlled by the filter separator (with 0.004 gr/dscf PM emission guarantee), the normal vacuum exhauster discharge configuration is to the PJFF inlet breeching ducts (for either Unit 1, 2, or 3). There are limited times when the Unit 1 PJFF is offline for maintenance or other purposes, at which time the filter separator serving Unit 2 and/or in-plant dust systems will discharge to atmosphere through a vacuum exhauster. Emissions are still controlled via the filter separator (upgraded in PTI No. 18-15) and will be monitored through bag leak dust detectors and visible emission observations under this limited operating scenario.

Disposal Silos: The Disposal Silos A, B and C are controlled by bin vent filter dust collectors.

Truck Loading: Each disposal silo has a dust collector and/or dust suppressant system in the truck loading bay under the silos to control particulate matter during truck loading. The byproduct headed for landfill disposal is sufficiently wetted/conditioned through a pin-paddle mixer prior to loading and transport. The dry load-out chutes minimize fugitive emissions by proper seating of the telescopic chute to or over the truck hatch. Emissions during transfer activity are vacuumed to discharge back into the storage silo, which is controlled by the bin vent filters.

**I. EMISSION LIMIT(S)**

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period / Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
1. Opacity	5% <sup>2</sup>	6- Minute Average	Each of the following bin vent filter emission points: SVTT12-BV1 SVTT12-BV2 SVTT12-FSVE SVTT3-BV3A SVTT3-BV3B SVDCASS-BVA SVDCASS-BVB SVDCASS-BVC	SC VI.1 SC VI.2	<b>R 336.1301(1)(c)</b>
2. PM	0.004 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVTT12-BV1 SVTT12-BV2 SVTT3-BV3A SVTT3-BV3B SVDCASS-BVA SVDCASS-BVB SVDCASS-BVC	SC III.2 SC VI.2	<b>R 336.1331(1)(c)</b>
3. PM	0.004 gr / dscf of exhaust gases <sup>2</sup>	Hourly	Byproduct transfer tank vacuum exhauster SVTT12-FSVE	SC III.2 SC VI.2	<b>R 336.1331(1)(c)</b>

<b>Pollutant</b>	<b>Limit</b>	<b>Time Period / Operating Scenario</b>	<b>Equipment</b>	<b>Monitoring/ Testing Method</b>	<b>Underlying Applicable Requirements</b>
4. PM10	0.03 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVTT12-BV1 SVTT12-BV2	SC III.2 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
5. PM2.5	0.03 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVTT12-BV1 SVTT12-BV2	SC III.2 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
6. PM10	0.05 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVTT3-BV3A SVTT3-BV2B  (CAM Subject)	SC III.2 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
7. PM2.5	0.05 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVTT3-BV3A SVTT3-BV3B  (CAM Subject)	SC III.2 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
8. PM10	0.55 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVDCASS-BVA SVDCASS-BVB SVDCASS-BVC  (CAM Subject)	SC III.2 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
9. PM2.5	0.55 pph <sup>2</sup>	Hourly	Each of the following bin vent filter emission points: SVDCASS-BVA SVDCASS-BVB SVDCASS-BVC  (CAM Subject)	SC III.2 SC VI.1 SC VI.2	<b>R 336.2803</b> <b>R 336.2804</b>
10. PM10	0.10 pph <sup>2</sup>	Hourly	Byproduct transfer tank vacuum exhauster: SVTT12-FSVE	SC III.2 SC VI.2	<b>40 CFR 52.21(c) and (d)</b>
11. PM2.5	0.10 pph <sup>2</sup>	Hourly	Byproduct transfer tank vacuum exhauster: SVTT12-FSVE	SC III.2 SC VI.2	<b>40 CFR 52.21(c) and (d)</b>
12. PM	0.10 lbs per 1,000 lbs. exhaust gas	Hourly	Unit 2 dry flyash transfer tower – including the transfer tank, hoppers, and vacuum exhauster	SC III.2 SC VI.2	<b>R 336.1331</b>

## **II. MATERIAL LIMIT(S)**

NA

## **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The Campbell Complex fugitive dust plan shall be updated as necessary and kept at the facility. If at any time the fugitive dust control program fails to address or inadequately addresses a dusting event, the permittee shall amend the fugitive dust control program within 45 days after such an event occurs. The permittee shall also amend the fugitive dust control program within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the fugitive dust control program and any amendments to the fugitive dust control program to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the fugitive dust control program or amended fugitive dust control program shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1372, R 336.2803, R 336.2804, Act 451, Section 324.5524)**
2. The permittee shall not operate EUBYPRODUCT unless a malfunction abatement plan (MAP) as described in Rule 911(2), for operation of the process and emission control equipment, is implemented updated as necessary, and kept at the facility. If at any time the MAP fails to address or inadequately addresses an event that meets the characteristics of a malfunction, the permittee shall amend the MAP within 45 days after such an event occurs. The permittee shall also amend the MAP within 45 days, if new equipment is installed or upon request from the AQD District Supervisor. The permittee shall submit the MAP and any amendments to the MAP to the AQD District Supervisor for review and approval. If the AQD does not notify the permittee within 90 days of submittal, the MAP or amended MAP shall be considered approved. Until an amended plan is approved, the permittee shall implement corrective procedures or operational changes to achieve compliance with all applicable emission limits.<sup>2</sup> **(R 336.1910, R 336.1911)**

## **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall not operate any portion of EUBYPRODUCT unless the associated enclosures and bin vent filters and filter separators are installed, maintained and operated in a satisfactory manner. Satisfactory manner includes operating and maintaining each control device in accordance with an approved MAP for EUBYPRODUCT as required in SC III.2.<sup>2</sup> **(R 336.1910, R 336.1911, R 336.2803, R 336.2804)**
2. The permittee shall not operate each byproduct transfer tank vacuum exhaustor unless the associated filter separator exhaust gases discharge to an associated PJFF baghouse on either EUBOILER1, EUBOILER2, or EUBOILER3, except as allowed in SC IV.3.<sup>2</sup> **(R 336.1205, R 336.1331, R 336.2803, R 336.2804)**
3. The exhaust from the filter/separator associated with EUBOILER2 shall be routed back to the PJFF for EUBOILER1, except at times when the PJFF for EUBOILER1 is not operating.<sup>2</sup> **(R 336.1205, R 336.1331, 40 CFR 52.21(c) and (d))**

## **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall perform, and document non-certified visible emissions observations on all exhausts to the atmosphere as required in SC I.1 on a daily basis when EUBYPRODUCT is operating. If during the observation there are any visible emissions detected from an emission point, then corrective procedures as defined in the MAP shall be implemented. Records of the non-certified visible emissions observations, USEPA Method 9

observations that are performed, the reason for any visible emissions observed, and any corrective actions taken, shall be kept on file and in a format acceptable to the AQD.<sup>2</sup> **(R 336.1301(1)(c))**

2. The permittee shall conduct and record non-certified visible emissions observations from the bin vent filters servicing the EUBOILER3 Transfer Tanks (SVTT-BV3A, SVTT-BV3B) and the Landfill Silos (SVDCASS-BVA, SVDCASS-BVB, and SVCASSS-BVC) once per day when operating, as the primary indicator of the proper functioning of each bin vent filter for EUBYPRODUCT. If visible emissions are observed, the permittee shall document the visible emissions, including duration, and continue to observe the source of the visible emissions until no visible emissions are observed. The permittee shall initiate corrective actions as quickly as possible upon the detection of visible emissions. If there is a break in the visible emissions observations, it will be assumed that visible emissions continue to occur during any break in observations. The appropriate range of visible emissions defining proper functioning of each bin vent filter is no visible emissions. **(40 CFR 64.6(c)(1)(i), (ii), and (iii))**
3. The permittee shall utilize visible emissions as the primary indicator of the proper functioning of each PM control device. The appropriate range of visible emissions defining proper functioning of the PM Control Device is no visible emissions.<sup>2</sup> **(R 336.1201(3), 40 CFR 64.6(c)(1)(i) and (ii))**
4. The permittee shall keep, in a satisfactory manner, all records necessary to show that the Campbell Complex fugitive dust plan required by SC III.1 is being implemented.<sup>2</sup> **(R 336.1372, R 336.2803, R 336.2804, Act 451, Section 324.5524)**
5. The permittee shall keep, in a satisfactory manner, all records necessary to show that the MAP required by SC III.2 is being implemented.<sup>2</sup> **(R 336.1910, R 336.1911)**
6. The permittee shall keep, in a satisfactory manner, visible emissions records for the times that the filter/separator associated with EUBOILER2 is routed to SVTT12-FSVE instead of the PJFF for EUBOILER1.<sup>2</sup> **(R 336.1205, R 336.1331, 40 CFR 52.21(c) and (d), R 336.1213(3))**
7. The permittee shall restore operation of the emission unit, control device, and associated pollutant capture system equipment to normal/compliant operation as quickly as possible in response to any noted exceedance or excursion. **(40 CFR 64.7(d))**
8. Upon detecting an excursion or exceedance, the owner or operator shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions or as specified by the MAP. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). **(40 CFR 64.7(d))**
9. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. **(40 CFR 64.6(c)(3), 40 CFR 64.7(c))**
10. The permittee shall properly maintain the monitoring system, including keeping necessary parts for routine repair of the monitoring equipment. **(40 CFR 64.7(b))**
11. The permittee shall maintain records of monitoring data, monitor performance data, corrective actions taken, any written quality improvement plan and any activities undertaken to implement a quality improvement plan, and

other information such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions. **(40 CFR 64.9(b)(1))**

**VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. Each semiannual report of monitoring and deviations shall include summary information on the number, duration and cause of excursions and/or exceedances and the corrective actions taken. If there were no excursions and/or exceedances in the reporting period, then this report shall include a statement that there were no excursions and/or exceedances. **(40 CFR 64.9(a)(2)(i))**
5. Each semiannual report shall include a Quality Improvement Plan (QIP) during the reporting period, if appropriate. If a QIP has been completed, the report shall include documentation that the QIP has been implemented, and a discussion pertaining to whether the QIP implementation has reduced the likelihood of excursions or exceedances. **(40 CFR 64.9(a)(2)(iii))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack and Vent ID	Maximum Exhaust Diameter/Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVTT12-BV1	9 <sup>2</sup>	32 <sup>2</sup>	R 336.2803 R 336.2804
2. SVTT12-BV2	9 <sup>2</sup>	32 <sup>2</sup>	R 336.2803 R 336.2804
3. SVTT12-FSVE	20 <sup>2</sup>	40 <sup>2</sup>	R 336.2803 R 336.2804
4. SVTT3-BV3A	14 <sup>2</sup>	70 <sup>2</sup>	R 336.2803 R 336.2804
5. SVTT3-BV3B	14 <sup>2</sup>	70 <sup>2</sup>	R 336.2803 R 336.2804
6. SVDCASS-BVA	24x60 <sup>2</sup>	141 <sup>2</sup>	R 336.2803 R 336.2804
7. SVDCASS-BVB	24x60 <sup>2</sup>	141 <sup>2</sup>	R 336.2803 R 336.2804
8. SVDCASS-BVC	24x60 <sup>2</sup>	136 <sup>2</sup>	R 336.2803 R 336.2804
9. SVBLR12	228 <sup>2</sup>	400 <sup>2</sup>	R 336.2803 R 336.2804
10. SVBLR3	327 <sup>2</sup>	642 <sup>2</sup>	R 336.2803 R 336.2804



**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with all applicable requirements of 40 CFR Part 64. **(40 CFR Part 64)**
2. If the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the AQD and if necessary, submit a proposed modification of the ROP and CAM Plan to address the necessary monitoring changes. Such a modification may include but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. **(40 CFR 64.7(e))**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUAUXBLR12  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

The common auxiliary boiler for Units 1 and 2 is an oil-fired fire-tube boiler rated at 17 MMBTU/hr. This boiler is a limited use boiler, which is defined in 40 CFR 63.7575 as any boiler that burns any amount of solid, liquid, or gaseous fuels and has a federally enforceable average annual capacity factor of no more than 10%. This unit is subject to the provisions of 40 CFR Part 63, Subpart DDDDD.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

NA

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Fuel Oil	0.5% sulfur by weight based on a higher heating value of 18,000 BTU/lb <sup>2</sup>	Applicable at all times	EUAUXBLR12	SC VI.1	<b>R 336.1401(1), Table 41</b>
2. #2 Fuel Oil (Note A)	10% annual capacity factor of oil (Note B) <sup>2</sup>	Calendar Year	EUAUXBLR12	SC VI.4	<b>40 CFR 63.7555(a)(3)</b>

*Note A:* This limit is to satisfy the Federally Enforceable capacity factor limit associated with the limited use definition under 40 CFR Part 63, Subpart DDDDD, 40 CFR 63.7575.

*Note B:* Annual capacity factor means the ratio between the actual heat input to a boiler from the fuels burned during a calendar year to the potential heat input to the boiler had it been operated for 8,760 hours during a year at the maximum steady state design heat input capacity. (40 CFR 63.7575)

3. The permittee shall only burn fuels as allowed in the Unit designed to burn gas under light liquid subcategory definition in 40 CFR 63.7575. **(40 CFR 63.7575, R336.1213(3))**

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. To demonstrate continuous compliance, the permittee shall conduct a tune-up of the boiler every 5 years (within 61 months) of the date of the last tune up. If the boiler is not operating on the required date for tune-up, the tune-up must be conducted within 30 calendar days of startup.<sup>2</sup> **(40 CFR 63.7500(a), 40 CFR 63.7515(d), 40 CFR 63.7540(12) and (13))**

2. The permittee shall conduct tune up of the boiler as specified in the following:<sup>2</sup> **(40 CFR 63.7540(a)(12))**

- a. As applicable, inspect the burner, and clean or replace any components of the burner as necessary (the permittee may delay the burner inspection until the next unit shutdown).
- b. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern.

- c. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next unit shutdown).
  - d. Optimize total emissions of CO.
  - e. Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made.
  - f. Maintain on-site and submit, if requested by the Administrator, a report containing the information below:
    - i. The concentrations of CO in the effluent stream in parts per million by volume, and oxygen content in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler or process heater.
    - ii. A description of any corrective actions taken as part of the tune-up.
3. At all times, the permittee must operate and maintain any affected source (as defined in 40 CFR 63.7490, stated in SC IX.1), including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. **(40 CFR 63.700(a)(3))**
4. Limited-use boilers and process heaters must complete a tune-up every 5 years as specified in 40 CFR 63.7540. They are not subject to the emission limits in Tables 1 and 2 or 11 through 13 to this subpart, the annual tune-up, or the energy assessment requirements in Table 3 to this subpart, or the operating limits in Table 4 to this subpart. **(40 CFR 63.7500(c))**
5. The permittee shall install a fuel meter.<sup>2</sup> **(R 336.1201(3))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall maintain sufficient records to demonstrate that the sulfur content for each shipment of fuel oil received is less than 0.5% by weight.<sup>2</sup> **(R 336.1201(3))**
2. The permittee shall conduct and maintain records of a daily (non-certified) visual observation for opacity in order to verify proper firing, whenever a boiler is in use for 24 consecutive hours or more. **(R 336.1213(3))**
3. The permittee shall keep a record of the following on a monthly basis:<sup>2</sup> **(R 336.1201(3))**
  - a. Total fuel usage
  - b. Sulfur content of fuel oil
  - c. Higher Heating Value of fuel oil
4. The permittee shall keep fuel use records for the days the boiler was operating.<sup>2</sup> **(40 CFR 63.7525(k))**
5. The permittee shall maintain a complete record of fuel oil specifications and/or fuel analysis for each delivery, or storage tank, of fuel oil used for the auxiliary boiler. These records may include purchase records for ASTM specification fuel oil, specifications or analyses provided by the vendor at the time of delivery, analytical results from laboratory testing, or any other records adequate to demonstrate compliance with the percent sulfur limit in fuel oil.<sup>2</sup> **(R 336.1201(3))**

6. The permittee shall keep records of compliance demonstrations.<sup>2</sup> **(R°336.1201(3))**
7. For each unit that meets the definition of limited-use boiler or process heater, the permittee must keep fuel use records for the days the boiler or process heater was operating. **(40 CFR 63.7525(k))**
8. The permittee must keep records according to paragraphs (a)(1) and (2) of 40 CFR 63.7555. **(40 CFR 63.7555(a))**
  - a. A copy of each notification and report that is submitted to comply with this subpart, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that permittee submitted, according to the requirements in 40 CFR Part 63.10(b)(2)(xiv). **(40 CFR 63.7555(a)(1))**
  - b. Records of performance tests, fuel analyses, or other compliance demonstrations and performance evaluations as required in 40 CFR Part 63.10(b)(2)(viii). **(40 CFR 63.7555(a)(2))**
9. For units in the limited use subcategory, the permittee must keep a copy of the federally enforceable permit that limits the annual capacity factor to less than or equal to 10 percent and fuel use records for the days the boiler or process heater was operating. **(40 CFR 63.7555(a)(3))**
10. Records must be in a form suitable and readily available for expeditious review, according to 40 CFR 63.10(b)(1). **(40 CFR 63.7560(a))**
11. As specified in 40 CFR 63.10(b)(1), the permittee must keep each record for 5 years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. **(40 CFR 63.7560(b))**
12. The permittee must keep each record on site, or they must be accessible from on-site (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record, according to 40 CFR 63.10(b)(1). The permittee can keep the records off site for the remaining 3 years. **(40 CFR 63.7560(c))**

**See Appendix 3-C (Fuel Oil Sulfur Monitoring)**

**VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee must meet the notification requirements in 40 CFR 63.7545 according to the schedule in 40 CFR 63.7545 and in Subpart A of 40 CFR Part 63. **(40 CFR 63.7495(d))**
5. The permittee must submit the Notification of Compliance Status containing the results of the initial compliance demonstration according to the requirements in 40 CFR 63.7545(e). **(40 CFR 63.7530(f))**
6. The permittee must submit to the Administrator all of the notifications in 40 CFR 63.7(b) and (c); 40 CFR 63.8(e), (f)(4) and (6); and 40 CFR 63.9(b) through (h) that apply by the dates specified. **(40 CFR 63.7545(a))**
7. Unless the USEPA Administrator has approved a different schedule for submission of reports under 40 CFR Part 63.10(a), the permittee must submit each report, according to paragraph (h) of 40 CFR 63.7550, by the date in Table 9 to this subpart and according to the requirements in paragraphs (b)(1) through (4) of 40 CFR 63.7550 as stated below. **(40 CFR 63.7550(b))**

- a. Each semi-annual compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31. Annual, biennial, and 5-year compliance reports must cover the applicable 1-, 2-, or 5-year periods from January 1 to December 31. **(40 CFR 63.7550(b)(3))**
  - b. Each semi-annual compliance report must be postmarked or submitted no later than September 15 or March 15, whichever date is the first date following the end of the semiannual reporting period. Annual, biennial, and 5-year compliance reports must be postmarked or submitted no later than March 15. **(40 CFR 63.7550(b)(4), 40 CFR 63.7550(b)(5))**
8. A compliance report must contain the information below depending on how the facility chooses to comply with the limits set in this rule. **(40 CFR 63.7550(c))**
- a. If the facility is subject to the requirements of a tune-up, permittee must submit a compliance report with the information in paragraphs (c)(5)(i) through (iii), (xiv) and (xvii) of 40 CFR 63.7550, and paragraph (c)(5)(iv) of 40 CFR 63.7550 for limited-use boiler or process heater. **(40 CFR 63.7550(c)(1))**
  - b. 40 CFR 63.7550(c)(5) is as follows:
    - i. Company and Facility name and address. **(40 CFR 63.7550(c)(5)(i))**
    - ii. Process unit information, emissions limitations, and operating parameter limitations. **(40 CFR 63.7550(c)(5)(ii))**
    - iii. Date of report and beginning and ending dates of the reporting period. **(40 CFR 63.7550(c)(5)(iii))**
    - iv. The total operating time during the reporting period. **(40 CFR 63.7550(c)(5)(iv))**
    - v. Include the date of the most recent tune-up for each unit subject to only the requirement to conduct a 5-year tune-up according to 40 CFR 63.7540(a)(12). Include the date of the most recent burner inspection if it was not done annually, biennially, or on a 5-year period and was delayed until the next scheduled or unscheduled unit shutdown. **(40 CFR 63.7550(c)(5)(xiv))**
    - vi. Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report. **(40 CFR 63.7550(c)(5)(xvii))**
9. The permittee must submit all reports required by Table 9 of 40 CFR Part 63, Subpart DDDDD electronically to the USEPA via the Compliance and Emissions Data Reporting Interface (CEDRI). (CEDRI can be accessed through the USEPA's CDX.) The permittee must use the appropriate electronic report in CEDRI for 40 CFR Part 63, Subpart DDDDD. Instead of using the electronic report in CEDRI for 40 CFR Part 63, Subpart DDDDD, the permittee may submit an alternate electronic file consistent with the XML schema listed on the CEDRI Web site (<http://www.epa.gov/ttn/chief/cedri/index.html>), once the XML schema is available. If the reporting form specific to 40 CFR Part 63, Subpart DDDDD is not available in CEDRI at the time that the report is due, the permittee must submit the report to the Administrator at the appropriate address listed in 40 CFR 63.13. The permittee must begin submitting reports via CEDRI no later than 90-days after the form becomes available in CEDRI. **(40 CFR 63.7550(h)(3))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVAUXBLR12	30 <sup>2</sup>	153 <sup>2</sup>	NA

**IX. OTHER REQUIREMENT(S)**

1. 40 CFR Part 63, Subpart DDDDD applies to new or reconstructed affected sources as described in paragraph (a)(2) of 40 CFR 63.7490, as listed below. **(40 CFR 63.7490(a))**
  - a. The affected source of 40 CFR Part 63, Subpart DDDDD is each new or reconstructed industrial, commercial, or institutional boiler or process heater, as defined in 40 CFR 63.7575, located at a major source. **(40 CFR 63.7490(a)(2))**
2. A boiler or process heater is:
  - a. New if the permittee commences construction of the boiler or process heater after June 4, 2010, and the permittee meets the applicability criteria at the time the permittee commences construction. **(40 CFR 63.7490(b))**
  - b. Reconstructed if the permittee meets the reconstruction criteria as defined in 40 CFR 63.2, the permittee commences reconstruction after June 4, 2010, and the permittee meets the applicability criteria at the time the permittee commence reconstruction. **(40 CFR 63.7490(c))**
3. For affected sources (as defined in 40 CFR 63.7490) that have not operated since the previous compliance demonstration and more than one year has passed since the previous compliance demonstration, you must complete the subsequent compliance demonstration no later than 180 days after the re-start of the affected source and according to the applicable provisions in 40 CFR 63.7(a)(2) as cited in Table 10 to 40 CFR Part 63, Subpart DDDDD. You must complete a subsequent tune-up by following the procedures described in 40 CFR 63.7540(a)(10)(i) through (vi) and within 30 calendar days of startup for units that are not operating at the time of their scheduled tune-up. **(40 CFR 63.7515(g))**
4. The permittee shall comply with the General Provisions in 40 CFR 63.1 through 63.15 that apply to this source as indicated in Table 10 of 40 CFR Part 63, Subpart DDDDD. **(40 CFR 63.7565, Table 10)**
5. The permittee shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD - National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters. **(40 CFR Part 63, Subpart DDDDD)**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUCAT3DIESEL  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

On-site, stationary, diesel-fired internal combustion engine, 9.4 MMBTU/hr heat input; emergency use only. This unit is subject to the provisions of 40 CFR Part 63, Subpart ZZZZ.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

NA

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Fuel Oil – sulfur content	1.0% by weight at 18,000 BTU/lb	Instantaneous; at all times	EUCAT3DIESEL	SC VI.6  (Use of No. 2 Fuel Oil, which by definition contains <0.5% Sulfur by weight; see <b>Appendix 3-C-1</b> )	<b>R 336.1401(1), Table 41</b>

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall:
  - a. Change oil and filter every 500 hours of operation or annually, whichever comes first, except as allowed in SC III.2;
  - b. Inspect the air filter every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and
  - c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

If the emergency engine is being operated during an emergency and it is not possible to shut down the engine to perform the work practice standards on the schedule required, the work practice standard can be delayed until the emergency is over. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State or local law has been abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law or which the risk was deemed unacceptable. **(40 CFR 63.6602, 40 CFR Part 63, Subpart ZZZZ, Table 2c, Item 1)**

2. The permittee may utilize an oil analysis program in order to extend the specified oil change requirement. The oil analysis must be performed at the same frequency as oil changes are required. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c of 40 CFR Part 63, Subpart ZZZZ. **(40 CFR 63.6625(i))**
3. The permittee shall install, maintain and operate EUCAT3DIESEL and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop your own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. **(40 CFR 63.6605, 40 CFR 63.6625(e))**
4. The permittee shall minimize the time spent at idle during startup and minimize the startup time EUCAT3DIESEL to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. **(40 CFR 63.6625(h))**
5. There is no time limit on the use of emergency stationary RICE in emergency situations. **(40 CFR 63.6640(f)(1))**
6. The permittee may operate EUCAT3DIESEL for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. **(40 CFR 63.6640(f)(2))**
7. EUCAT3DIESEL may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing as provided in 40 CFR 63.6640(f)(2). The 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for the permittee to supply non-emergency power as part of a financial arrangement with another entity. **(40 CFR 63.6640(f)(3))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall install a non-resettable hour meter on each engine in EUCAT3DIESEL. **(40 CFR 63.6625(f))**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. If using the oil analysis program, the permittee must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30% of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20% from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. **(40 CFR 63.6625(i))**

**See Appendix 3-C**



## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall keep in a satisfactory manner, records of the occurrence and duration of each malfunction of operation or the air pollution control monitoring equipment. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(a)(2), 40 CFR 63.6660)**
2. The permittee shall keep in a satisfactory manner, records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(a)(5), 40 CFR 63.6660)**
3. The permittee shall keep in a satisfactory manner, records to demonstrate continuous compliance with the operating limitations. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(d), 40 CFR 63.6660)**
4. The permittee shall keep in a satisfactory manner, records of the maintenance conducted to demonstrate that the engine and after-treatment control device (if any) were operated and maintained according to the developed maintenance plan. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(e), 40 CFR 63.6660)**
5. The permittee shall monitor and record the total hours of operation for EUCAT3DIESEL per calendar year, recorded through the non-resettable hours meter, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation; including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in 40 CFR 63.6640(f)(4)(ii), the permittee must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation. **(40 CFR 63.6655(f))**
6. The permittee shall maintain sufficient records to demonstrate that the sulfur content for each shipment of fuel oil received is less than 1.0% by weight. **(R 336.1213(3))**
7. The permittee shall conduct and maintain records of a daily (non-certified) visual observation for opacity in order to verify proper firing, whenever an engine is in use for 24 consecutive hours or more. **(R 336.1213(3))**
8. The permittee shall maintain a record of the applicability determination for each Reciprocating Internal Combustion Engine (RICE) relative to the requirements of 40 CFR Part 63, Subparts A and ZZZZ. **(40 CFR Part 63, Subpart A, Section 63.10(b)(3))**

**See Appendix 3-C (Fuel Oil Sulfur Monitoring)**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

4. The permittee shall submit to the AQD District Supervisor, a semiannual compliance report, as specified in 40 CFR 63.6650, which contains all deviations during the reporting period from any applicable emission limitation or operating limitation. If there are no deviations from any applicable emission limitations or operating limitations, the report shall contain a statement that there were no deviations during the reporting period. The first report shall cover the period beginning on the applicable compliance date specified in 40 CFR 63.6595 and ending on June 30 (postmarked or delivered by July 31) or December 31 (postmarked or delivered by January 31), whichever date is the first date following the end of the first calendar half after the applicable compliance date. Each subsequent report must cover the semiannual period from January 1 through June 30, or from July 1 through December 31. The subsequent reports must be postmarked or delivered by July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period, except as allowed in 40 CFR 63.6650(b)(5). The compliance report must also contain the following information, as specified in 40 CFR 63.6650(c) and (d):
  - a. Company name and address.
  - b. Certification of the report by a responsible official.
  - c. Date of report and beginning and ending dates of the reporting period.
  - d. The number of malfunctions, including a brief description of each event, that occurred during the reporting period and a demonstration that the Malfunction Plan was followed during such events.
  - e. The total operating time of the RICE at which the deviation occurred during the reporting period.
  - f. The number, duration, and cause of deviations and the corrective action taken.

A copy of the compliance report shall be kept on file for a period of at least five years (at least two years at the site) and made available to the Department upon request. **(40 CFR 63.6640(b), 40 CFR 63.6650(b),(c),(d), 40 CFR 63.6660)**

5. Each affected source that has obtained a Title V operating permit pursuant to 40 CFR Part 70 or 71 must report all deviations as defined in 40 CFR Part 63, Subpart ZZZZ in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of 40 CFR Part 63, Subpart ZZZZ along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in 40 CFR Part 63, Subpart ZZZZ, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority. **(40 CFR 63.6650(f))**
6. For any engine that is an emergency stationary engine with a site rating of more than 100 brake hp that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in 40 CFR 63.6640(f)(4)(ii), you must submit an annual report according to the requirements below and as specified in 40 CFR 63.6650(h): **(40 CFR 63.6650(h), 40 CFR 63.6660)**
  - a. The report must contain the following information:
    - i. Company name and address where the engine is located.
    - ii. Date of the report and beginning and ending dates of the reporting period.
    - iii. Engine site rating and model year.
    - iv. Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
    - v. Hours operated for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).
    - vi. Number of hours the engine is contractually obligated to be available for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).

- vii. Hours spent for operation for the purpose specified in 40 CFR 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
  - viii. If there were no deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.
  - ix. If there were deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.
- b. The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in 40 CFR 63.13.

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

NA

**IX. OTHER REQUIREMENT(S)**

- 1. The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ, as they apply to EUCAT3DIESEL. **(40 CFR Part 63, Subparts A and ZZZZ)**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUCATDIESEL12  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

A 2,000-kilowatt (kW) diesel-fueled emergency engine manufactured in 2007 or later. This unit is subject to the provisions of 40 CFR Part 60, Subpart IIII and 40 CFR Part 63, Subpart ZZZZ.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. NMHC + NOx	6.4 g/kW-hr <sup>2</sup>	Hourly	EUCATDIESEL12	SC V.1 SC VI.2	<b>40 CFR 60.4205(b)</b>
2. CO	3.5 g/kW-hr <sup>2</sup>	Hourly	EUCATDIESEL12	SC V.1 SC VI.2	<b>40 CFR 60.4205(b)</b>
3. PM	0.20 g/kW-hr <sup>2</sup>	Hourly	EUCATDIESEL12	SC V.1 SC VI.2	<b>40 CFR 60.4205(b)</b>

**II. MATERIAL LIMIT(S)**

1. The permittee shall burn only diesel fuel, in EUCATDIESEL12, with a sulfur content not to exceed 15 ppm (0.0015%) by weight.<sup>2</sup> **(R 336.1205(3), R 336.1402(1), 40 CFR 60.4207, 40 CFR 80.510(b))**

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall not operate EUCATDIESEL12 for more than 500 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 500 hours includes the 100 hours for the purpose of necessary maintenance checks and readiness testing as described in SC III.2.<sup>2</sup> **(R 336.1205(3), R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21(c) & (d))**
2. The permittee may operate EUCATDIESEL12 for no more than 100 hours per calendar year, as determined at the end of each calendar month, for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. EUCATDIESEL12 may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing. The 50 hours per calendar year for non-emergency situations may not be used for peak shaving or to generate income for a facility to supply non-emergency power as part of a financial arrangement with another entity.<sup>2</sup> **(40 CFR 60.4211(f), 40 CFR 63.6640(f))**

3. The permittee shall install, maintain, and operate EUCATDIESEL12 according to the manufacturer emissions-related written instructions, or procedures developed by the owner/operator and approved by the engine manufacturer, over the entire life of the engine.<sup>2</sup> **(R 336.1205(3), R 336.1225, R 336.1911, R 336.2803, R 336.2804, 40 CFR 52.21(c) & (d), 40 CFR 60.4206, 40 CFR 60.4211)**
4. There is no time limit on the use of emergency stationary RICE in emergency situations. **(40 CFR 60.4211(f)(1), 40 CFR 63.6640(f)(1))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall equip and maintain EUCATDIESEL12 with a non-resettable hours meter to track the operating hours.<sup>2</sup> **(R 336.1205(3), R 336.1225, 40 CFR 60.4209(a), 40 CFR 63.6625(f))**
2. The nameplate capacity of EUCATDIESEL12 shall not exceed 2,000 kW, as certified by the equipment manufacturer.<sup>2</sup> **(R 336.1205(3))**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall conduct an initial performance test for EUCATDIESEL12 within one year after startup of the engine to demonstrate compliance with the emission limits in 40 CFR 60.4205 unless the engine has been certified by the manufacturer and the permittee maintains the engine as required by 40 CFR Part 60, Subpart IIII. If a performance test is required, the performance tests shall be conducted at the owner's expense, in accordance with Department requirements and according to 40 CFR 60.4212. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> **(40 CFR 60.4211)**
2. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. **(R 336.1213(3))**

See Appendix 5

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the last day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition.<sup>2</sup> **(R 336.1205(3), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))**
2. The permittee shall keep, in a satisfactory manner, a record of testing required in SC V.1 or manufacturer certification documentation indicating that EUCATDIESEL12 meets the applicable emission limitations contained in the federal Standards of Performance for New Stationary Sources 40 CFR Part 60, Subpart IIII. The permittee shall keep all records on file and make them available to the Department upon request.<sup>2</sup> **(40 CFR 60.4211)**
3. The permittee shall monitor and record the total hours of operation and the hours of operation during non-emergencies for EUCATDIESEL12, on a monthly and 12-month rolling time period basis, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation of EUCATDIESEL12, including what classified the operation as emergency and how many hours are spent for maintenance or readiness testing and non-emergency operation.<sup>2</sup> **(R 336.1205(3), R 336.2803, R 336.2804, 40 CFR 60.4211(f), 40 CFR 60.4214(b))**

- The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in EUCATDIESEL12, demonstrating that the fuel sulfur content meets the requirement of 40 CFR 80.510(b). The certification or test data shall include the name of the oil supplier or laboratory, and the sulfur content of the fuel oil.<sup>2</sup> **(R 336.1205(3), R 336.1402(1), 40 CFR 80.510(b))**

See Appendix 3-C

**VII. REPORTING**

- The permittee shall submit all applicable notifications specified in 40 CFR 63.7(b) and (c), 40 CFR 63.8 (e), (f)(4), and (f)(6), and 40 CFR 63.9(b) through (e), (g), and (h) by the dates specified.<sup>2</sup> **(40 CFR 63.6645(a)(3) and (f))**
- Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
- Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
- Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
- The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter/ Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVCATDIESEL12	18 <sup>2*</sup>	47 <sup>2</sup>	R 336.1225 R 336.2803 R 336.2804 40 CFR 52.21 (c) & (d)

\* The maximum diameter applies to the exhaust stack itself and does not apply to any no-loss rain sleeve that may be in use.

**IX. OTHER REQUIREMENT(S)**

- The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subparts A and IIII, as they apply to EUCATDIESEL12.<sup>2</sup> **(40 CFR Part 60, Subparts A & IIII, )**
- The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ, as they apply to EUCATDIESEL12 upon startup.<sup>2</sup> **(40 CFR Part 63, Subparts A and ZZZZ, 40 CFR 63.6595)**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUGUARDSHK\_ENG  
 EMISSION UNIT CONDITIONS**

**DESCRIPTION**

A natural-gas, stationary internal combustion engine rated at 40 HP; Emergency Generator for the guard shack. This unit is subject to the provisions of 40 CFR Part 60, Subpart JJJJ and 40 CFR Part 63, Subpart ZZZZ.

**Flexible Group ID:** NA

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. NOx + Hc	10 g/kW-hr g/hp-hr	Hourly	EUGUARDSHK_ENG	SC VI.2	<b>40 CFR 60.6233(d)</b>
2. CO	387 g/hp-hr	Hourly	EUGUARDSHK_ENG	SC VI.2	<b>40 CFR 60.6233(d)</b>

**II. MATERIAL LIMIT(S)**

- The permittee shall burn only field or pipeline quality natural gas, in each engine in EUGUARDSHK\_ENG. **(40 CFR 60.4230, R 336.1213(3))**

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

- There is no time limit on the use of emergency stationary RICE in emergency situations. **(40 CFR 60.4243(d)(1))**
- The permittee may operate EUGUARDSHK\_ENG for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. **(40 CFR 60.4243(d)(2), 40 CFR 63.6640(f))**
- EUGUARDSHK\_ENG may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing as provided in 40 CFR 60.4243(d)(2). The 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for the permittee to supply non-emergency power as part of a financial arrangement with another entity. **(40 CFR 60.4243(d)(3), 40 CFR 63.6640(f))**
- The permittee shall operate and maintain EUGUARDSHK\_ENG such that it meets the emission limits in SC I.1, and I.2 over the entire life of the engine. **(40 CFR 60.4234, 40 CFR 60.4243(b))**
- If the permittee purchased a certified engine, according to procedures specified in 40 CFR Part 60, Subpart JJJJ, for the same model year, the permittee shall meet the following requirements for EUGUARDSHK\_ENG:
  - Operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions;

- b. Keep a maintenance plan and the permittee may only change those engine settings that are permitted by the manufacturer. If you do not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine will be considered a non-certified engine; and
- c. Meet the requirements as specified in 40 CFR Part 1068, Subparts A through D.

If the permittee does not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine will be considered a non-certified engine and be subject to SC III.5. **(40 CFR 60.4243(b)(1))**

- 6. If the permittee purchased a non-certified engine or a certified engine operating in a non-certified manner, the permittee shall keep a maintenance plan for EUGUARDSHK\_ENG and shall, to the extent practicable, maintain and operate each engine in a manner consistent with good air pollution control practice for minimizing emissions. **(40 CFR 60.4243(b)(2))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

- 1. EUGUARDSHK\_ENG shall be certified to meet the applicable emission standard of 40 CFR 60.4233. The permittee shall install and configure each engine according to the manufacturer's specifications. **(40 CFR 60.4243)**
- 2. The permittee shall equip and maintain EUGUARDSHK\_ENG with non-resettable hours meters to track the operating hours. **(40 CFR 60.4237, 40 CFR 63.6655(f))**
- 3. The nameplate capacity of EUGUARDSHK\_ENG shall not exceed 500 BHP, as certified by the equipment manufacturer. **(40 CFR 63.6590(c)(4))**

#### **V. TESTING/SAMPLING**

- 1. The permittee shall conduct an initial performance test for EUGUARDSHK\_ENG within one year after startup of the engine to demonstrate compliance with the emission limits in 40 CFR 60.4231 unless the engine has been certified by the manufacturer and the permittee maintains the engine as required by 40 CFR Part 60, Subpart JJJJ. If a performance test is required, the performance test shall be conducted at the owner's expense, in accordance with Department requirements and according to 40 CFR 60.4244. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> **(40 CFR 60.4244)**
- 2. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. **(R 336.1213(3))**

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

- 1. The permittee shall keep in a satisfactory manner, records of all maintenance conducted on EUGUARDSHK\_ENG. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 60.4245(a)(2))**
- 2. The permittee shall keep, in a satisfactory manner, a record of testing required in SC V.1 or manufacturer certification documentation indicating that EUGUARDSHK\_ENG meets the applicable emission limitations contained in the federal Standards of Performance for New Stationary Sources 40 CFR Part 60, Subpart JJJJ. The permittee shall keep all records on file and make them available to the Department upon request. **(40 CFR 60.4245)**



3. The permittee shall monitor and record the hours of operation of EUGUARDSHK\_ENG during emergencies and non-emergencies, on a calendar year basis, in a manner acceptable to the AQD District Supervisor. The permittee shall record the time of operation of EUGUARDSHK\_ENG and the reason it was in operation during that time. **(40 CFR 60.4243)**

See Appendix 4

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subparts A and JJJJ, as they apply to EUGUARDSHK\_ENG. **(40 CFR Part 60, Subparts A and JJJJ)**
2. The permittee shall comply with all applicable provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ, for Stationary Reciprocating Internal Combustion Engines by the initial compliance date. **(40 CFR 63.6595, 40 CFR Part 63, Subparts A and ZZZZ)**

### **Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## D. FLEXIBLE GROUP SPECIAL CONDITIONS

Part D outlines the terms and conditions that apply to more than one emission unit. The permittee is subject to the special conditions for each flexible group in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no special conditions that apply to more than one emission unit, this section will be left blank.

### FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGBOILER12	The common 40 CFR Part 64 (CAM) requirements for these emission units are in this flexible group.	EUBOILER1 EUBOILER2
FGMATS_U12	Common applicable Mercury and Air Toxics Standard requirements for EUBOILER1 and EUBOILER2.	EUBOILER1 EUBOILER2
FGMATS_U3	Mercury and Air Toxics Standard requirements for EUBOILER3.	EUBOILER3
FGEXISTINGRICE	Onsite, stationary diesel-fired internal combustion engines. Engines used as a source of emergency power or water supply that are subject to the RICE MACT.	EUCATFIREPUMP3 EUHPHSWP15001 EUHPHSWP15002 EUHPHSWP3000
FGAUXBLRS3	Distillate oil fired auxiliary boilers less than 10 MMBTU.	EUAUXBLR3B EUAUXBLR3C
FGNEWCIRICE	New stationary diesel-fired internal combustion, compression ignition engines. Engines used as a source of emergency power or water supply that are subject to the RICE MACT.	EUWPDIESEL EUTRNCNTRDIESEL
FGPARTSCLEANERS	Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278, 278a and Rule 281(2)(h) or Rule 285(2)(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.	EUPARTSCLEANERS

## FGBOILER12 FLEXIBLE GROUP CONDITIONS

### **DESCRIPTION**

The common 40 CFR Part 64 (CAM) requirements for these emission units are in this flexible group.

**Emission Units:** EUBOILER1, EUBOILER2

### **POLLUTION CONTROL EQUIPMENT**

Pollution control equipment is described for each unit in EUBOILER1 and EUBOILER2.

#### **I. EMISSION LIMIT(S)**

NA

#### **II. MATERIAL LIMIT(S)**

NA

#### **III. PROCESS/OPERATIONAL RESTRICTION(S)**

NA

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall assess opacity using USEPA Reference Method 9 - "Visual Determination of the Opacity of Emissions from Stationary Sources", upon the request of AQD.<sup>2</sup> **(R 336.1301)**

**See Appendices 3-A and 5**

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall utilize COMS-recorded opacity as an indicator of the emission unit's compliance with the particulate matter limit, except during periods of monitoring and system malfunction, system repairs or QA/QC activities. The appropriate range of opacity defining proper function of the PJFF is 0-20% opacity. An excursion is defined as any two (2) or more consecutive 1-hour block average opacity values greater than 15%. **(40 CFR 64.6(c)(1)(i) and (ii))**
2. The permittee shall continuously monitor and record any alarms and corrective actions taken. **(40 CFR 64.6(c)(1)(i) and (ii))**
3. The permittee shall properly maintain the COMS, including completing daily COMS zero and calibration tests; conduct necessary preventative maintenance; maintaining necessary parts for routine repairs of the monitoring equipment; and demonstrating adequate performance through an annual monitor audit. **(40 CFR 64.6(c)(1)(ii), 40 CFR 64.7(b))**

4. Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations or fulfilling a minimum data availability requirement, if applicable. The owner or operator shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions. The permittee shall operate the COMS during all required periods when the coal-fired boiler is operating. Data recorded during monitoring malfunctions, repair activities and QA/QC operations shall not be used for 40 CFR Part 64 compliance. **(40 CFR 64.6(c)(3), 40 CFR 64.7(c))**
5. The permittee shall conduct all required monitoring per the CAM Plan and otherwise satisfy the requirements specified in 40 CFR 64.7 through 40 CFR 64.9. **(40 CFR 64.6(c)(3), 40 CFR 64.7(a))**
6. The required COMS shall collect data for all required intervals when the emission unit is operating. **(40 CFR 64.7(c)(1)(iii))**
7. The permittee shall restore operation of the emission unit, control device, and associated pollutant capture system equipment to normal/compliant operation as quickly as possible, in accordance with good air pollution control practices for minimizing emissions in response to any noted exceedance or excursion. Excursions shall trigger an internal investigation, corrective action(s) per the MAP, and a CAM excursion summary reporting requirement. Necessary response shall include minimizing the period of any startup, shutdown or malfunction and taking necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of the excursion or exceedance (other than those caused by excused startup or shutdown conditions). **(40 CFR 64.7(d))**
8. If the permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the permittee shall promptly notify the AQD and if necessary, submit a proposed modification of the ROP and CAM Plan to address the necessary monitoring changes. Such a modification may include but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters. **(40 CFR 64.7(e))**

**See Appendices 3-A, 3-B and 3-D**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. Quarterly reporting of monthly excess sulfur dioxide emissions (including the nature and cause of the periods of excess emissions), and of the dates and times of the monitoring systems being inoperative. Each quarterly report is due within 30 days of the calendar quarter reporting period. **(R 336.2170)**

5. Quarterly reporting of excess opacity emissions (including the nature and cause of the periods of excess emissions), and of the dates and times of the monitoring systems being inoperative. Each quarterly report is due within 30 days of the calendar quarter reporting period. **(R 336.2170)**
6. Each semiannual report of monitoring deviations shall include summary information on the number, duration, and cause of exceedances/excursions in the reporting period; and the corrective actions taken in response. If there were no excursions and/or exceedances in the reporting period, then this report shall include a statement that there were no excursions and/or exceedances. **(40 CFR 64.9(a)(2)(i))**
7. Each semiannual report of monitoring deviations shall include summary information on monitor downtime in the reporting period. If there were no periods of monitor downtime in the reporting period, then this report shall include a statement that there were no periods of monitor downtime. **(40 CFR 64.9(a)(2)(ii))**
8. Each semiannual report of monitoring deviations shall include a description of the actions taken to implement a Quality Improvement Plan (QIP) during the reporting period, if appropriate. If a QIP has been completed, the report shall include documentation that the QIP has been implemented, and a discussion pertaining to whether the QIP implementation has reduced the likelihood of excursions or exceedances. **(40 CFR 64.9(a)(2)(iii))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

<b>Stack &amp; Vent ID</b>	<b>Maximum Exhaust Dimensions (inches)</b>	<b>Minimum Height Above Ground (feet)</b>	<b>Underlying Applicable Requirements</b>
1. SVBLR12	228 <sup>2</sup>	400 <sup>2</sup>	R 336.1225 R 336.2803 R 336.2804 <b>40 CFR 52.21(c) and (d)</b>

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with all applicable requirements of 40 CFR Part 64. **(40 CFR Part 64)**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).  
<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).  
<sup>3</sup>This condition is federally enforceable and was originally established in the consent decree settling, “U.S. V CONSUMERS ENERGY COMPANY, CIVIL ACTION 14-13580, E.D. MICH., 2014” and also pursuant to Act 451, Section 324.5503(b), and will remain in effect after termination of the consent decree.  
<sup>4</sup>Definitions specific to this condition may be found in Appendix 1-B: Definitions Applicable to Specified Permit Conditions.

**FGMATS\_U12**  
**FLEXIBLE GROUP CONDITIONS**

**DESCRIPTION**

40 CFR Part 63, Subpart UUUUU (Mercury and Air Toxics Standards or MATS) requirements for existing coal-fired electric utility steam generating unit(s) (EGU) rated more than 25 megawatts electric (MWe) that serve(s) a generator producing electricity for sale and designed to burn coal that is not low rank virgin coal (calorific value of  $\geq 8,300$  BTU/pound).

**Emission Units:** EUBOILER1 and EUBOILER2

**POLLUTION CONTROL EQUIPMENT**

EUBOILER1:

Low-NOx burners,  
 Sorbent injection (ACI) (activated carbon or other sorbent) for mercury control,  
 Dry sorbent injection (DSI) (hydrated lime or other sorbent) for acid gas control,  
 Pulse-jet fabric filter (PJFF) baghouse for PM control.

EUBOILER2:

Low-NOx burners,  
 Selective catalytic reduction (SCR),  
 Sorbent injection (ACI) (activated carbon or other sorbent) for mercury control,  
 Dry sorbent injection (DSI) (hydrated lime or other sorbent) for acid gas control,  
 Pulse-jet fabric filter (PJFF) baghouse for PM control.

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Filterable PM (per boiler)	0.030 lb/MMBTU*	Quarterly or Triennial Stack Test <sup>+</sup>	EUBOILER1 EUBOILER2	SC V.1	<b>40 CFR 63.9991</b> <b>40 CFR Part 63,</b> <b>Subpart UUUUU,</b> <b>Table 2.1.a</b>
2. Hydrogen chloride (HCl) (per boiler)	0.0020 lb/MMBTU*	Quarterly or Triennial Stack Test <sup>+</sup>	EUBOILER1 EUBOILER2	SC V.2	<b>40 CFR 63.9991</b> <b>40 CFR Part 63,</b> <b>Subpart UUUUU,</b> <b>Table 2.1.b</b>
3. Mercury (Hg) (per boiler)	1.2 lb/TBTU*	30-boiler operating day rolling arithmetic average updated at the end of each new boiler operating day	EUBOILER1 EUBOILER2	SC V.3 SC VI.3	<b>40 CFR 63.9991</b> <b>40 CFR Part 63,</b> <b>Subpart UUUUU,</b> <b>Table 2.1.c</b>

\* The emission limits apply at all times except during startup and shutdown.

+ If the unit(s) no longer meets the requirement for LEE status, the unit(s) will comply by stack testing quarterly until a continuous monitoring system has been installed, certified, and is operating.

4. If the permittee uses the provisions for low emitting EGU (LEE) status for any pollutant except Hg, performance test data must be collected showing average emissions less than 50% the of the applicable standard. **(40 CFR 63.10005(h)(1)(i))**

## **II. MATERIAL LIMIT(S)**

NA

## **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee shall conduct a tune-up of each emission unit of FGMATS\_U12 burner(s) and combustion controls, as applicable, at least every 36 calendar months, or each 48 calendar months if neural network combustion optimization software is employed, as specified in 40 CFR 63.10021(e). **(40 CFR 63.10000(e), 40 CFR 63.10006(i), 40 CFR 63.10021(e))**
2. For the startup of any emission unit of FGMATS\_U12 which will comply using paragraph (1) of the definition of "startup" in 40 CFR 63.10042, the permittee must use clean fuels as defined in 40 CFR 63.10042 for ignition. Once the emission unit(s) of FGMATS\_U12 convert(s) to firing coal, residual oil, or solid oil-derived fuel, the permittee must engage all the applicable control technologies except dry scrubber and SCR. The permittee must start the dry scrubber and SCR systems, if present, appropriately to comply with relevant standards applicable during normal operation. The permittee must comply with all applicable emission limits at all times except for periods that meet the applicable definitions of startup and shutdown in 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10042, 40 CFR Part 63, Subpart UUUUU, Table 3)**
3. During shutdown of any emission unit of FGMATS\_U12 while firing coal, residual oil, or solid oil-derived fuel, the permittee must vent emissions to the main stack(s) and operate all applicable control devices and continue to operate those control devices after the cessation of coal, residual oil, or solid oil-derived fuel being fed into the applicable emission unit(s) of FGMATS\_U12 and for as long as possible thereafter considering operational and safety concerns. In any case, the permittee must operate their controls when necessary to comply with other standards made applicable to the FGMATS\_U12 by a permit limit or a rule other than 40 CFR Part 63, Subpart UUUUU and that require operation of the control devices. If, in addition to the fuel used prior to initiation of shutdown, another fuel must be used to support the shutdown process, that additional fuel must be one or a combination of the clean fuels defined in 40 CFR 63.10042 and must be used to the maximum extent possible taking into account considerations such as not compromising boiler or control device integrity. **(40 CFR 63.10042, 40 CFR Part 63, Subpart UUUUU, Table 3)**
4. The emission limits and operating limits in 40 CFR Part 63, Subpart UUUUU apply at all times except during periods of startup and shutdown; however, the applicable work practice requirements, which are specified in items 3 and 4 of Table 3 of 40 CFR Part 63, Subpart UUUUU must be met during periods of startup or shutdown. **(40 CFR 63.10000(a), 40 CFR Part 63, Subpart UUUUU, Table 3, 40 CFR 63.10022(a)(4))**

## **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall operate and maintain all associated air pollution control equipment and monitoring equipment necessary for compliance with 40 CFR Part 63, Subpart UUUUU in a manner consistent with safety and good air pollution control practices for minimizing emissions. **(40 CFR 63.10000(b))**

## **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall verify the filterable PM emission rates from each emission unit by testing at owner's expense, in accordance with 40 CFR 63.10007 and Table 5 to 40 CFR Part 63, Subpart UUUUU. The permittee must complete the test once every calendar quarter and at least 45 days since the previous performance test if not a LEE for PM. The permittee may skip performance testing in those quarters during which less than 168 boiler operating hours occur, except that a performance test must be conducted at least once every calendar year. **(40 CFR 63.10006(f), 40 CFR 63.10007, 40 CFR 63.10021(d)(1) and (2), 40 CFR Part 63, Subpart UUUUU, Table 5)**

2. The permittee shall verify the HCl emission rates from each emission unit by testing at owner's expense, in accordance with 40 CFR 63.10007 and Table 5 to 40 CFR Part 63, Subpart UUUUU. The permittee must complete the test once every calendar quarter and at least 45 days since the previous performance test if not a LEE for HCl. The permittee may skip performance testing in those quarters during which less than 168 boiler operating hours occur, except that a performance test must be conducted at least once every calendar year. **(40 CFR 63.10006(f), 40 CFR 63.10007, 40 CFR 63.10021(d)(1) and (2), 40 CFR Part 63, Subpart UUUUU, Table 5)**
3. If the permittee uses the provisions for LEE status for any pollutant except for Hg, the permittee shall verify each LEE pollutant emission rate from the applicable emission unit(s) of FGMATS\_U12 by testing at owner's expense, in accordance with 40 CFR 63.10007 and Table 5 to 40 CFR Part 63, Subpart UUUUU. The permittee must complete the test once every 36 months and at least 1,050 days since the previous performance test to demonstrate continued LEE status. If a performance test deadline is missed due to the EGU being inoperative and 168 or more boiler operating hours occur in the next test period, an additional performance test shall be completed in the next test period, with at least 350 calendar days separating the performance tests conducted in the same 3-year period. **(40 CFR 63.10006(b), 40 CFR 63.10006(f), 40 CFR 63.10007, 40 CFR Part 63, Subpart UUUUU, Table 5)**
4. Unless an alternate schedule has been approved by the AQD, no less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing. The protocol shall describe the test method(s) and the maximum routine operating conditions, including targets for key operational parameters associated with air pollution control equipment to be monitored and recorded during testing, as applicable. **(40 CFR 63.7, 40 CFR 63.10007, 40 CFR 63.10030(a))**

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. During startup, as defined by paragraph (1) of the definition of "startup" in 40 CFR 63.10042, the permittee must operate all Continuous Monitoring Systems (CMS). Startup means either the first-ever firing of fuel in a boiler for the purpose of producing electricity, or the firing of fuel in a boiler after a shutdown event for any purpose. Startup ends when any of the steam from the boiler is used to generate electricity for sale over the grid or for any other purpose (including on site use). The permittee must comply with the applicable emission limits at all times except for startup and shutdown periods unless the permittee chooses to use just one set of sorbent traps to demonstrate compliance with the applicable Hg emission limit, then the permittee must comply with the applicable Hg emission limit at all times. The permittee must collect monitoring data during startup periods, as specified in 40 CFR 63.10020(a) and (b). The permittee must keep records during startup periods, as provided in 40 CFR 63.10032 and 40 CFR 63.10021(h). Any fraction of an hour in which startup occurs constitutes a full hour of startup. **(40 CFR Part 63, Subpart UUUUU, Table 3)**
2. The permittee must operate all CMS during shutdown. The permittee must also collect appropriate data, and the permittee must calculate the pollutant emission rate for each hour of shutdown for those pollutants for which a CMS is used. The permittee must collect monitoring data during shutdown periods, as specified in 40 CFR 63.10020(a). The permittee must keep records during shutdown periods, as provided in 40 CFR 63.10032 and 40 CFR 63.10021(h). Any fraction of an hour in which shutdown occurs constitutes a full hour of shutdown. **(40 CFR Part 63, Subpart UUUUU, Table 3)**
3. For any emission unit not relying on the LEE provisions for Hg, the permittee shall install, calibrate, maintain and operate a device to monitor and record the Hg concentration from each emission unit on a continuous basis. The permittee shall install and operate the Hg CEMS or sorbent trap monitoring system to meet the timelines, requirements and reporting detailed in Appendix A of 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10000(c)(1)(vi))**
4. If required to convert measured pollutant concentrations to the units of the applicable mass per heat input emission limit(s) or for routine operation of a sorbent trap monitoring system, the permittee shall install, calibrate, maintain and operate a device to monitor and record the oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) exhaust gas content, exhaust gas flow rate and/or moisture from each emission unit on a continuous basis. The monitor shall be operated in accordance with procedures outlined in 40 CFR Part 75, Appendices A and B. As an alternative



to moisture monitoring, the permittee may elect to use appropriate fuel-specific default moisture values from 40 CFR 75.11(b) for coal-fired units or a default moisture value for non-coal-fired units as established via petition to the Administrator under 40 CFR 75.66. **(40 CFR 63.10010(b)-(d), 40 CFR Part 63, Subpart UUUUU, Table 5)**

5. For any emission unit not relying on the LEE provisions for Hg, the permittee shall keep, in a satisfactory manner, hourly (if applicable) and 30-day rolling average Hg emission rate records for each emission unit **OR** (30-day (or 90-day if emission averaging (as applicable)) rolling weighted average Hg emission rate records for the combination of units participating in an averaging plan) excluding periods of startup and shutdown. **(40 CFR 63.10010, 40 CFR 63.10021, 40 CFR Part 63, Subpart UUUUU, Table 7)**
6. The permittee must operate the required monitoring system(s) and collect data at all required intervals at all times that the affected EGU is operating, except for periods of monitoring system malfunctions or out-of-control periods (see 40 CFR 63.8(c)(7) of 40 CFR Part 63, Subpart A), and required monitoring system quality assurance or quality control activities, including, as applicable, calibration checks and required zero and span adjustments. The permittee is required to affect monitoring system repairs in response to monitoring system malfunctions and to return the monitoring system to operation as expeditiously as practicable. **(40 CFR 63.10020(b))**
7. The permittee may not use data recorded during startup or shutdown in calculations used to report emissions, except as otherwise provided in 40 CFR 63.10000(c)(1)(vi)(B) and 40 CFR 63.10005(a)(2)(iii). In addition, data recorded during monitoring system malfunctions or monitoring system out-of-control periods, repairs associated with monitoring system malfunctions or monitoring system out-of-control periods or required monitoring system quality assurance or control activities may not be used in calculations used to report emissions or operating levels. The permittee must use all of the quality-assured data collected during all other periods in assessing the operation of the control device and associated control system. **(40 CFR 63.10020(c))**
8. Failure to collect required data is a deviation from the monitoring requirements except for periods of monitoring system malfunctions or monitoring system out-of-control periods, repairs associated with monitoring system malfunctions or monitoring system out-of-control periods and required monitoring system quality assurance or quality control activities including, as applicable, calibration checks and required zero and span adjustments. **(40 CFR 63.10020(d))**
9. If the permittee uses CEMS to measure SO<sub>2</sub>, PM, HCl, HF, or Hg emissions (or sorbent trap monitoring system), except as otherwise provided in 40 CFR 63.10020(c), the permittee must demonstrate continuous compliance by using all quality-assured hourly data recorded by the CEMS (or sorbent trap monitoring system) and other required monitoring systems to calculate the arithmetic average emissions rate in units of the standard on a continuous 30-boiler operating day (or, if alternate emissions averaging is used for Hg, a 90-boiler operating day) rolling average basis, updated at the end of each new boiler operating day. Use Equation 8 in 40 CFR 63.10021(b) to determine the 30- or 90-boiler operating day rolling average. **(40 CFR 63.10021(a) and (b))**
10. The permittee must keep the following records:
  - a. A copy of each notification and report that has been submitted to comply with 40 CFR Part 63, Subpart UUUUU, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that has been submitted, according to the requirements in 40 CFR 63.10(b)(2)(xiv). **(40 CFR 63.10032(a)(1))**
  - b. Records of performance stack tests, fuel analyses, or other compliance demonstrations and performance evaluations, as required in 40 CFR 63.10(b)(2)(viii). **(40 CFR 63.10032(a)(2))**
  - c. For each CEMS and CPMS, the permittee must keep the following records:
    - i. Records described in 40 CFR 63.10(b)(2)(vi) through (xi). **(40 CFR 63.10032(b)(1))**
    - ii. Previous (i.e., superseded) versions of the performance evaluation plan as required in 40 CFR 63.8(d)(3). **(40 CFR 63.10032(b)(2))**
    - iii. Request for alternatives to relative accuracy test for CEMS as required in 40 CFR 63.8(f)(6)(i). **(40 CFR 63.10032(b)(3))**
    - iv. The date and time that each deviation started and stopped and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period. **(40 CFR 63.10032(b)(4))**

- v. If the permittee continuously monitors Hg and/or HCl and/or HF emissions, the permittee must also keep the records required under Appendix A and/or Appendix B of 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10032(a))**
  - d. For each emission unit subject to an emission limit:
    - i. The permittee shall keep the monthly fuel use by each emission unit, including the type(s) of fuel and amount(s) used. **(40 CFR 63.10032(d)(1))**
    - ii. If the permittee combusts non-hazardous secondary materials that have been determined not to be solid waste pursuant to 40 CFR 241.3(b)(1), the permittee must keep a record which documents how the secondary material meets each of the legitimacy criteria. If the permittee combusts a fuel that has been processed from a discarded non-hazardous secondary material pursuant to 40 CFR 241.3(b)(2), the permittee must keep records as to how the operations that produced the fuel satisfies the definition of processing in 40 CFR 241.2. If the fuel received a non-waste determination pursuant to the petition process submitted under 40 CFR 241.3(c), the permittee must keep a record which documents how the fuel satisfies the requirements of the petition process. **(40 CFR 63.10032(d)(2))**
    - iii. For an emission unit that qualifies as a LEE under 40 CFR 63.10005(h), the permittee shall keep annual records that document that the emissions in the previous stack test(s) continue to qualify the unit for LEE status for an applicable pollutant, and document that there was no change in source operations including fuel composition and operation of air pollution control equipment that would cause emissions of the pollutant to increase within the past year. **(40 CFR 63.10032(d)(3))**
  - e. Regarding startup periods or shutdown periods:
    - i. If the permittee chooses to rely on paragraph (1) of the definition of “startup” in 40 CFR 63.10042 for the emission unit(s), the permittee shall keep records of the occurrence and duration of each startup or shutdown. **(40 CFR 63.10032(f)(1))**
    - ii. The type(s) and amount(s) of fuel used during each startup or shutdown. **(40 CFR 63.10032(i))**
  - f. The occurrence and duration of each malfunction of an operation (i.e., process equipment) or the air pollution control and monitoring equipment. **(40 CFR 63.10032(g))**
  - g. Actions taken during periods of malfunction to minimize emissions in accordance with 40 CFR 63.10000(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. **(40 CFR 63.10032(h))**
  - h. If the permittee elects to average emissions consistent with 40 CFR 63.10009, the permittee shall keep a copy of the emissions averaging implementation plan required in 40 CFR 63.10009(g), all calculations required under 40 CFR 63.10009, including daily records of heat input or steam generation, as applicable, and monitoring records consistent with 40 CFR 63.10022. **(40 CFR 63.10032(e))**
11. The permittee shall keep all records in a form suitable and readily available for expeditious review and for at least 5 years after the date of each occurrence, corrective action, report, or record. The records must be kept onsite for at least 2 years and may be kept offsite for the remaining 3 years. **(40 CFR 63.10(b)(1), 40 CFR 63.10033)**
12. The permittee shall maintain on site and submit, if requested by the Administrator, an annual report of periodic performance tune-ups containing the information required by 40 CFR 63.10021(e)(8). The reports shall be in a format acceptable to the Administrator. If requested by the AQD District Supervisor, the permittee shall also submit an annual report with the results of the performance tune-ups. **(40 CFR 63.10021(e)(8))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**

3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. Semiannual reporting of the information required in 40 CFR 63.10031(c)(1) through (9), (d), and (e) as applicable. The report shall be postmarked or received by the Administrator by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. The report shall include the following:
  - a. The information required by the Continuous Monitoring Summary Report located in 40 CFR 63.10(e)(3)(vi). **(40 CFR 63.10031(c)(1))**
  - b. The total fuel use by each affected source subject to an emission limit, for each calendar month within the semiannual reporting period, including, but not limited to, a description of the fuel, whether the fuel has received a non-waste determination by USEPA or the basis for concluding that the fuel is not a waste, and the total fuel usage amount with units of measure. **(40 CFR 63.10031(c)(2))**
  - c. Indicate whether any emission unit in FGMATS\_U12 burned new types of fuel during the reporting period. If new types of fuel were burned, include the date of the performance test where that fuel was in use. **(40 CFR 63.10031(c)(3))**
  - d. Include the date of the most recent tune-up for each emission unit. The date of the tune-up is the date the tune-up provisions specified in 40 CFR 63.10021(e)(6) and (7) were completed. **(40 CFR 63.10031(c)(4))**
  - e. Report emergency bypass information annually from units with LEE status. **(40 CFR 63.10031(c)(6))**
  - f. A summary of the results of the annual performance tests and documentation of any operating limits that were reestablished during the test, if applicable. If the permittee is conducting stack tests once every 3 years to maintain LEE status, consistent with 40 CFR 63.10006(b), the report shall include the date of each stack test conducted during the previous 3 years, a comparison of emission level the permittee achieved in each stack test conducted during the previous 3 years to the 50% emission limit threshold required in 40 CFR 63.10005(h)(1)(i), and a statement as to whether there have been any operational changes since the last stack test that could increase emissions. **(40 CFR 63.10031(c)(7))**
  - g. If there are no deviations from any emission limitation (emission limit and operating limit) that applies to FGMATS\_U12 and there are no deviations from the requirements for work practice standards in Table 3 to 40 CFR Part 63, Subpart UUUUU that apply to FGMATS\_U12, the report shall include a statement that there were no deviations from the emission limitations and work practice standards during the reporting period. If there were no periods during which the CMSs, including continuous emissions monitoring system, and operating parameter monitoring systems, were out-of-control as specified in 40 CFR 63.8(c)(7), a statement that there were no periods during which the CMSs were out-of-control during the reporting period. **(40 CFR Part 63, Subpart UUUUU, Table 8)**
  - h. If there is a deviation from any emission limitation (emission limit and operating limit) or work practice standard during the reporting period, the report must contain a brief description of the deviation, the duration of the deviation, the cause of the deviation, and the information in 40 CFR 63.10031(d). If there were periods during which the CMS's, including continuous emissions monitoring systems and continuous parameter monitoring systems, were out-of-control, as specified in 40 CFR 63.8(c)(7), the report must contain the information in 40 CFR 63.10031(e). **(40 CFR 63.10031(c)(1) through (9), (d), and (e), 40 CFR 63.10031(a), 40 CFR 63.10031(c)(9), 40 CFR Part 63, Subpart UUUUU, Table 8)**
  - i. If the affected source submits a compliance report pursuant to Table 8 in 40 CFR Part 63, Subpart UUUUU, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limit, operating limit, or work practice requirement in 40 CFR Part 63, Subpart UUUUU, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report required by SC VII.2. **(40 CFR 63.10031(e))**
5. The permittee must submit any of the following applicable notifications by the dates specified within the specific citation: 40 CFR 63.7(b) and (c) Notification of performance test and Quality assurance program; 40 CFR 63.8(e) Performance evaluation of continuous monitoring systems; 40 CFR 63.8(f)(4) Request to use alternative monitoring methods; 40 CFR 63.8(f)(6) Alternative to the relative accuracy test; 40 CFR 63.9(b) Initial

notifications; 40 CFR 63.9(c) Request for extension of compliance; 40 CFR 63.9(d) Notification that source is subject to special compliance requirements; 40 CFR 63.9(e) Notification of performance test, which shall be submitted at least 30 days before the performance test is scheduled to begin; 40 CFR 63.9(f) Notification of opacity and visible emission observations; 40 CFR 63.9(g) Additional notification requirements for sources with continuous monitoring systems; and 40 CFR 63.9(h) Notification of compliance status. **(40 CFR 63.10030(a))**

6. On or after July 1, 2020, within 60 days after the date of completing each performance test, the permittee must submit the performance test reports required by this subpart to USEPA's WebFIRE database by using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). Performance test data must be submitted in the file format generated through use of USEPA's Electronic Reporting Tool (ERT) (see <http://www.epa.gov/ttn/chief/ert/index.html>). Only data collected using those test methods on the ERT Web site are subject to this requirement for submitting reports electronically to WebFIRE. At the discretion of the AQD, the permittee must also submit these reports, one to the Technical Programs Unit Supervisor and one to the AQD District Supervisor, in a format approved by the AQD. **(40 CFR 63.10031(f))**
7. On or after July 1, 2020, within 60 days after the date of completing each CEMS (SO<sub>2</sub>, PM, HCl, HF, and Hg) performance evaluation test, as defined in 40 CFR 63.2, the permittee must submit the relative accuracy test audit (RATA) data (or, for PM CEMS, RCA and RRA data) required by this subpart to USEPA's WebFIRE database by using CEDRI that is accessed through USEPA's CDX ([www.epa.gov/cdx](http://www.epa.gov/cdx)). The RATA data shall be submitted in the file format generated through use of USEPA's Electronic Reporting Tool (ERT) (<http://www.epa.gov/ttn/chief/ert/index.html>). Only RATA data compounds listed on the ERT Web site are subject to this requirement. At the discretion of the AQD, the permittee must also submit these RATA reports to the AQD District Supervisor in a format approved by the AQD. Owners or operators shall submit calibration error testing, drift checks, and other information required in the performance evaluation as described in 40 CFR 63.2 and as required in this chapter. **(40 CFR 63.10031(f)(1))**
8. On or after July 1, 2020, for a PM CEMS, PM CPMS, or approved alternative monitoring using a HAP metals CEMS, within 60 days after the reporting periods ending on March 31, June 30, September 30, and December 31, the permittee must submit quarterly reports to USEPA's WebFIRE database by using the CEDRI that is accessed through USEPA's CDX ([www.epa.gov/cdx](http://www.epa.gov/cdx)). The permittee must use the appropriate electronic reporting form in CEDRI or provide an alternate electronic file consistent with USEPA's reporting form output format. For each reporting period, the quarterly reports must include all of the calculated 30-boiler operating day rolling average values derived from the CEMS and PM CPMS. **(40 CFR 63.10031(f)(2))**
9. Reports for a SO<sub>2</sub> CEMS, a Hg CEMS or sorbent trap monitoring system, a HCl or HF CEMS, and any supporting monitors for such systems (such as a diluent or moisture monitor) shall be submitted using the ECMPS Client Tool, as provided for in 40 CFR Part 63, Subpart UUUUU, Appendices A and B and 40 CFR 63.10021(f). **(40 CFR 63.10031(f)(3))**
10. On or after July 1, 2020, the permittee must submit all reports required by 40 CFR 63.10031 (c) and (d) electronically using CEDRI that is accessed through the USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). The permittee must use the appropriate electronic reporting form in CEDRI or provide an alternate electronic file consistent with USEPA's reporting form output format. If requested by the AQD, the permittee must also submit these reports to the AQD District Supervisor in a format approved by the AQD. **(40 CFR 63.10031(f)(4))**
11. Prior to July 1, 2020, all reports subject to electronic submittal in SC VII.6, VII.7, VII.8 and VII.10 shall be submitted to the USEPA at the frequency specified in those paragraphs in electronic portable document format (PDF) using the ECMPS Client Tool. Each PDF version of a submitted report must include sufficient information to assess compliance and to demonstrate that the testing was done properly. The data elements listed at 40 CFR 63.10031(f)(6)(i)-(xii) must be entered into the ECMPS Client Tool at the time of submission of each PDF file. **(40 CFR 63.10031(f)(6))**
12. If requested by the Administrator, the permittee must submit the monitoring plan (or relevant portion of the plan) at least 60 days before the initial performance evaluation of a particular CMS, except where the CMS has already

undergone a performance evaluation that meets the requirements of 40 CFR 63.10010 (e.g., if the CMS was previously certified under another program). **(40 CFR 63.10000(d)(3))**

See Appendix 8

## **VIII. STACK/VENT RESTRICTION(S)**

NA

## **IX. OTHER REQUIREMENT(S)**

1. For each emission unit or emissions averaging group complying with an emission limit as specified in Table 2 of 40 CFR Part 63, Subpart UUUUU, the permittee may request to switch from a mass per heat input to a mass per gross output limit (or vice versa).
  - a. The permittee may switch from a mass per heat input to a mass per gross output limit (or vice-versa), provided that:
    - i. The permittee submits a request that identifies for each emission unit or emissions averaging group involved in the proposed switch both the current and proposed emission limit. **(40 CFR 63.10030(e)(7)(iii)(A)(1))**
    - ii. The request arrives to the Administrator at least 30 calendar days prior to the date that the switch is proposed to occur. **(40 CFR 63.10030(e)(7)(iii)(A)(2))**
    - iii. The request demonstrates through performance stack test results completed within 30 days prior to the submission, compliance for each emission unit or emissions averaging group with both the mass per heat input and mass per gross output limits. **(40 CFR 63.10030(e)(7)(iii)(A)(3))**
    - iv. The permittee revises and submits all other applicable plans, e.g., monitoring and emissions averaging, with the request. **(40 CFR 63.10030(e)(7)(iii)(A)(4))**
    - v. The permittee maintains records of all information regarding the choice of emission limits. **(40 CFR 63.10030(e)(7)(iii)(A)(5))**
  - b. The permittee may begin to use the revised emission limits starting in the next reporting period, after receipt of written acknowledgement from the Administrator of the switch. **(40 CFR 63.10030(e)(7)(iii)(B))**
  - c. From the submission of the request until start of the next reporting period after receipt of written acknowledgement from the Administrator of the switch, the permittee shall demonstrate compliance with both the mass per heat input and mass per gross output emission limits for each pollutant for each emission unit or emissions averaging group. **(40 CFR 63.10030(e)(7)(iii)(C))**
2. If using a CMS to demonstrate continuous compliance with an emission limit or operating limit, the permittee must develop a site-specific monitoring plan and submit this site-specific monitoring plan, if requested, at least 60 days before the initial performance evaluation (where applicable) of the CMS. This requirement also applies to the permittee if the permittee petitions the Administrator for alternative monitoring parameters under 40 CFR 63.8(f). This requirement to develop and submit a site-specific monitoring plan does not apply to affected sources with existing monitoring plans that apply to CEMS and CPMS prepared under Appendix B of 40 CFR Part 60 or 40 CFR Part 75, and that meet the requirements of 40 CFR 63.10010. Using the process described in 40 CFR 63.8(f)(4), the permittee may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in this paragraph of this section and, if approved, include those in the site-specific monitoring plan. The monitoring plan must address the following provisions: **(40 CFR 63.10000(d), 40 CFR 63.10010)**
  - a. Installation of the CMS or sorbent trap monitoring system sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (e.g., on or downstream of the last control device). See 40 CFR 63.10010(a) for further details. For PM CPMS installations, follow the procedures in 40 CFR 63.10010(h).

- b. Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction systems.
  - c. Schedule for conducting initial and periodic performance evaluations.
  - d. Performance evaluation procedures and acceptance criteria (e.g., calibrations), including the quality control program in accordance with the general requirements of 40 CFR 63.8(d).
  - e. On-going operation and maintenance procedures, in accordance with the general requirements of 40 CFR 63.8(c)(1)(ii), (c)(3), and (c)(4)(ii).
  - f. Conditions that define a CMS that is out of control consistent with 40 CFR 63.8(c)(7)(i) and for responding to out of control periods consistent with 40 CFR 63.8(c)(7)(ii) and (c)(8).
  - g. On-going recordkeeping and reporting procedures, in accordance with the general requirements of 40 CFR 63.10(c), (e)(1), and (e)(2)(i), or as specifically required under 40 CFR Part 63, Subpart UUUUU.
  - h. Alternatively, the requirements are considered to be met for a particular CMS or sorbent trap monitoring system if:
    - i. The CMS or sorbent trap monitoring system is installed, certified, maintained, operated, and quality-assured either according to 40 CFR Part 75, or Appendix A or B of 40 CFR Part 63, Subpart UUUUU; and
    - ii. The recordkeeping and reporting requirements of 40 CFR Part 75, or Appendix A or B of 40 CFR Part 63, Subpart UUUUU, which pertain to the CMS, are met.
3. If the permittee chooses to reapply for LEE status, the permittee must demonstrate all performance tests and CEMS or sorbent trap monitoring system data over a consecutive 3-year period show compliance with the LEE criteria. **(40 CFR 63.10006(b)(2) and (h))**
  4. If any emission unit(s) cease(s) to operate in a manner that causes the unit(s) to meet the definition of an EGU subject to 40 CFR Part 63, Subpart UUUUU, the permittee must submit the notification in 40 CFR 63.10000(i)(2) no less than 30 days prior to when the EGU will cease complying with 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10000(i)(2), 40 CFR 63.10030(f))**
  5. The permittee shall comply with all provisions of the National Emission Standards for Hazardous Air Pollutants as specified in 40 CFR Part 63, Subparts A and UUUUU. **(40 CFR Part 63, Subparts A and UUUUU)**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**FGMATS\_U3  
 FLEXIBLE GROUP CONDITIONS**

**DESCRIPTION**

40 CFR Part 63, Subpart UUUUU (Mercury and Air Toxics Standards or MATS) requirements for existing coal-fired electric utility steam generating unit(s) (EGU) rated more than 25 megawatts electric (MWe) that serve(s) a generator producing electricity for sale and designed to burn coal that is not low rank virgin coal (calorific value of ≥ 8,300 BTU/pound).

**Emission Unit:** EUBOILER3

**POLLUTION CONTROL EQUIPMENT**

Low-NOx burners,  
 Selective catalytic reduction (SCR),  
 Sorbent injection (ACI) (activated carbon or other sorbent for mercury control),  
 Spray dry absorber (SDA) for acid gas control,  
 Pulse-jet fabric filter (PJFF) baghouse for PM control.

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Filterable PM	0.030 lb/MMBTU*	30-day boiler operating day rolling arithmetic average updated at the end of each new boiler operating day	EUBOILER3	SC VI.3 SC VI.7 SC VI.8	<b>40 CFR 63.9991 40 CFR Part 63, Subpart UUUUU, Table 2.1.a</b>
2. SO <sub>2</sub>	0.20 lb/MMBTU*	30-boiler operating day rolling arithmetic average updated at the end of each new boiler operating day	EUBOILER3	SC VI.2 SC VI.6 SC VI.7 SC VI.10 SC VI.14	<b>40 CFR 63.9991 40 CFR Part 63, Subpart UUUUU, Table 2.1.b</b>
3. Mercury (Hg)	1.2 lb/TBTU*	30-boiler operating day rolling arithmetic average updated at the end of each new boiler operating day	EUBOILER3	SC V.1 SC VI.4 SC VI.7 SC VI.9 SC VI.14	<b>40 CFR 63.9991 40 CFR Part 63, Subpart UUUUU, Table 2.1.c</b>

\* The emission limits apply at all times except during startup and shutdown

**II. MATERIAL LIMIT(S)**

NA

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

- 1. The permittee shall conduct a tune-up of each emission unit of FGMATS\_U3 burner(s) and combustion controls, as applicable, at least every 36 calendar months, or each 48 calendar months if neural network combustion

optimization software is employed, as specified in 40 CFR 63.10021(e). **(40 CFR 63.10000(e), 40 CFR 63.10006(i), 40 CFR 63.10021(e))**

2. For the startup of any emission unit of FGMATS\_U3 which will comply using paragraph (1) of the definition of “startup” in 40 CFR 63.10042, the permittee must use clean fuels as defined in 40 CFR 63.10042 for ignition. Once the emission unit(s) of FGMATS\_U3 convert(s) to firing coal, residual oil, or solid oil-derived fuel, the permittee must engage all the applicable control technologies except dry scrubber and SCR. The permittee must start the dry scrubber and SCR systems, if present, appropriately to comply with relevant standards applicable during normal operation. The permittee must comply with all applicable emission limits at all times except for periods that meet the applicable definitions of startup and shutdown in 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10042, 40 CFR Part 63, Subpart UUUUU, Table 3)**
3. During shutdown of any emission unit of FGMATS\_U3 while firing coal, residual oil, or solid oil-derived fuel, the permittee must vent emissions to the main stack(s) and operate all applicable control devices and continue to operate those control devices after the cessation of coal, residual oil, or solid oil-derived fuel being fed into the applicable emission unit(s) of FGMATS\_U3 and for as long as possible thereafter considering operational and safety concerns. In any case, the permittee must operate their controls when necessary to comply with other standards made applicable to the FGMATS\_U3 by a permit limit or a rule other than 40 CFR Part 63, Subpart UUUUU and that require operation of the control devices. If, in addition to the fuel used prior to initiation of shutdown, another fuel must be used to support the shutdown process, that additional fuel must be one or a combination of the clean fuels defined in 40 CFR 63.10042 and must be used to the maximum extent possible taking into account considerations such as not compromising boiler or control device integrity. **(40 CFR 63.10042, 40 CFR Part 63, Subpart UUUUU, Table 3)**
4. The emission limits and operating limits in 40 CFR Part 63, Subpart UUUUU apply at all times except during periods of startup and shutdown; however, the applicable work practice requirements, which are specified in items 3 and 4 of Table 3 of 40 CFR Part 63, Subpart UUUUU must be met during periods of startup or shutdown. **(40 CFR 63.10000(a), 40 CFR Part 63, Subpart UUUUU, Table 3)**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall operate and maintain all associated air pollution control equipment and monitoring equipment necessary for compliance with 40 CFR Part 63, Subpart UUUUU in a manner consistent with safety and good air pollution control practices for minimizing emissions. **(40 CFR 63.10000(b))**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

#### **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. During startup, as defined by paragraph (1) of the definition of “startup” in 40 CFR 63.10042, the permittee must operate all Continuous Monitoring Systems (CMS). Startup means either the first-ever firing of fuel in a boiler for the purpose of producing electricity, or the firing of fuel in a boiler after a shutdown event for any purpose. Startup ends when any of the steam from the boiler is used to generate electricity for sale over the grid or for any other purpose (including on site use). The permittee must comply with the applicable emission limits at all times except for startup and shutdown periods unless the permittee chooses to use just one set of sorbent traps to demonstrate compliance with the applicable Hg emission limit, then the permittee must comply with the applicable Hg emission limit at all times. The permittee must collect monitoring data during startup periods, as specified in 40 CFR 63.10020(a) and (b). The permittee must keep records during startup periods, as provided in 40 CFR 63.10032 and 40 CFR 63.10021(h). Any fraction of an hour in which startup occurs constitutes a full hour of startup. **(40 CFR Part 63, Subpart UUUUU, Table 3)**



2. The permittee must operate all CMS during shutdown. The permittee must also collect appropriate data, and the permittee must calculate the pollutant emission rate for each hour of shutdown for those pollutants for which a CMS is used. The permittee must collect monitoring data during shutdown periods, as specified in 40 CFR 63.10020(a). The permittee must keep records during shutdown periods, as provided in 40 CFR 63.10032 and 40 CFR 63.10021(h). Any fraction of an hour in which shutdown occurs constitutes a full hour of shutdown. **(40 CFR Part 63, Subpart UUUUU, Table 3)**
3. The permittee shall install, calibrate, maintain and operate a device to monitor and record the PM concentration of the exhaust gas from each emission unit on a continuous basis. The permittee shall install and operate the PM CEMS to meet the timelines, requirements and reporting detailed in Performance Specification 11 in 40 CFR Part 60, Appendix B and Procedure 2 in 40 CFR Part 60, Appendix F. **(40 CFR 63.10010(i), 40 CFR Part 63, Subpart UUUUU, Table 5)**
4. The permittee shall install, calibrate, maintain and operate a device to monitor and record the Hg concentration from each emission unit on a continuous basis. The permittee shall install and operate the Hg CEMS or sorbent trap monitoring system to meet the timelines, requirements and reporting detailed in Appendix A of 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10000(c)(1)(vi))**
5. The permittee shall install, maintain, and operate a device(s) to monitor and record the SO<sub>2</sub> concentration of the exhaust gas from each emission unit on a continuous basis. The permittee shall install and operate each CEMS to meet the timelines, requirements and reporting detailed in 40 CFR Part 75, Appendices A and B. **(40 CFR 63.10000(c)(1)(v))**
6. If required to convert measured pollutant concentrations to the units of the applicable mass per heat input emission limit(s) or for routine operation of a sorbent trap monitoring system, the permittee shall install, calibrate, maintain and operate a device to monitor and record the oxygen (O<sub>2</sub>) or carbon dioxide (CO<sub>2</sub>) exhaust gas content, exhaust gas flow rate and/or moisture from each emission unit on a continuous basis. The monitor shall be operated in accordance with procedures outlined in 40 CFR Part 75, Appendices A and B. As an alternative to moisture monitoring, the permittee may elect to use appropriate fuel-specific default moisture values from 40 CFR 75.11(b) for coal-fired units or a default moisture value for non-coal-fired units as established via petition to the Administrator under 40 CFR 75.66. **(40 CFR 63.10010(b)-(d), 40 CFR Part 63, Subpart UUUUU, Table 5)**
7. If the permittee elects to use a PM CEMS or participate in an averaging plan for PM, total non-Hg HAP metals, or individual metals, the permittee shall keep, in a satisfactory manner, hourly (if applicable) and 30-day rolling average PM, total non-Hg HAP metals, or individual metals (as applicable) emission rate records for each emission unit excluding periods of startup and shutdown. **(40 CFR 63.10010, 40 CFR 63.10021, 40 CFR Part 63, Subpart UUUUU, Table 7)**
8. For any emission unit not relying on the LEE provisions for Hg, the permittee shall keep, in a satisfactory manner, hourly (if applicable) and 30-day rolling average Hg emission rate records for each emission unit excluding periods of startup and shutdown. **(40 CFR 63.10010, 40 CFR 63.10021, 40 CFR Part 63, Subpart UUUUU, Table 7)**
9. The permittee shall keep, in a satisfactory manner, hourly and 30-day rolling average SO<sub>2</sub> emission rate records for each emission unit excluding periods of startup and shutdown. **(40 CFR 63.10010, 40 CFR 63.10021, 40 CFR Part 63, Subpart UUUUU, Table 7)**
10. The permittee must operate the required monitoring system(s) and collect data at all required intervals at all times that the affected EGU is operating, except for periods of monitoring system malfunctions or out-of-control periods (see 40 CFR 63.8(c)(7) of 40 CFR Part 63, Subpart A), and required monitoring system quality assurance or quality control activities, including, as applicable, calibration checks and required zero and span adjustments. The permittee is required to affect monitoring system repairs in response to monitoring system malfunctions and to return the monitoring system to operation as expeditiously as practicable. **(40 CFR 63.10020(b))**

11. The permittee may not use data recorded during startup or shutdown in calculations used to report emissions, except as otherwise provided in 40 CFR 63.10000(c)(1)(vi)(B) and 40 CFR 63.10005(a)(2)(iii). In addition, data recorded during monitoring system malfunctions or monitoring system out-of-control periods, repairs associated with monitoring system malfunctions or monitoring system out-of-control periods or required monitoring system quality assurance or control activities may not be used in calculations used to report emissions or operating levels. The permittee must use all of the quality-assured data collected during all other periods in assessing the operation of the control device and associated control system. **(40 CFR 63.10020(c))**
12. Failure to collect required data is a deviation from the monitoring requirements except for periods of monitoring system malfunctions or monitoring system out-of-control periods, repairs associated with monitoring system malfunctions or monitoring system out-of-control periods and required monitoring system quality assurance or quality control activities including, as applicable, calibration checks and required zero and span adjustments. **(40 CFR 63.10020(d))**
13. If the permittee uses CEMS to measure SO<sub>2</sub>, PM, HCl, HF, or Hg emissions (or sorbent trap monitoring system), except as otherwise provided in 40 CFR 63.10020(c), the permittee must demonstrate continuous compliance by using all quality-assured hourly data recorded by the CEMS (or sorbent trap monitoring system) and other required monitoring systems to calculate the arithmetic average emissions rate in units of the standard on a continuous 30-boiler operating day (or, if alternate emissions averaging is used for Hg, a 90-boiler operating day) rolling average basis, updated at the end of each new boiler operating day. Use Equation 8 in 40 CFR 63.10021(b) to determine the 30- or 90-boiler operating day rolling average. **(40 CFR 63.10021(a) and (b))**
14. The permittee must keep the following records:
  - a. A copy of each notification and report that has been submitted to comply with 40 CFR Part 63, Subpart UUUUU, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that has been submitted, according to the requirements in 40 CFR 63.10(b)(2)(xiv). **(40 CFR 63.10032(a)(1))**
  - b. Records of performance stack tests, fuel analyses, or other compliance demonstrations and performance evaluations, as required in 40 CFR 63.10(b)(2)(viii). **(40 CFR 63.10032(a)(2))**
  - c. For each CEMS and CPMS, the permittee must keep the following records:
    - i. Records described in 40 CFR 63.10(b)(2)(vi) through (xi). **(40 CFR 63.10032(b)(1))**
    - ii. Previous (i.e., superseded) versions of the performance evaluation plan as required in 40 CFR 63.8(d)(3). **(40 CFR 63.10032(b)(2))**
    - iii. Request for alternatives to relative accuracy test for CEMS as required in 40 CFR 63.8(f)(6)(i). **(40 CFR 63.10032(b)(3))**
    - iv. The date and time that each deviation started and stopped and whether the deviation occurred during a period of startup, shutdown, or malfunction or during another period. **(40 CFR 63.10032(b)(4))**
    - v. If the permittee continuously monitors Hg and/or HCl and/or HF emissions, the permittee must also keep the records required under Appendix A and/or Appendix B of 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10032(a))**
  - d. For each emission unit subject to an emission limit:
    - i. The permittee shall keep the monthly fuel use by each emission unit, including the type(s) of fuel and amount(s) used. **(40 CFR 63.10032(d)(1))**
    - ii. If the permittee combusts non-hazardous secondary materials that have been determined not to be solid waste pursuant to 40 CFR 241.3(b)(1), the permittee must keep a record which documents how the secondary material meets each of the legitimacy criteria. If the permittee combusts a fuel that has been processed from a discarded non-hazardous secondary material pursuant to 40 CFR 241.3(b)(2), the permittee must keep records as to how the operations that produced the fuel satisfies the definition of processing in 40 CFR 241.2. If the fuel received a non-waste determination pursuant to the petition process submitted under 40 CFR 241.3(c), the permittee must keep a record which documents how the fuel satisfies the requirements of the petition process. **(40 CFR 63.10032(d)(2))**

- e. Regarding startup periods or shutdown periods:
    - i. If the permittee chooses to rely on paragraph (1) of the definition of “startup” in 40 CFR 63.10042 for the emission unit(s), the permittee shall keep records of the occurrence and duration of each startup or shutdown. **(40 CFR 63.10032(f)(1))**
    - ii. The type(s) and amount(s) of fuel used during each startup or shutdown. **(40 CFR 63.10032(i))**
  - f. The occurrence and duration of each malfunction of an operation (i.e., process equipment) or the air pollution control and monitoring equipment. **(40 CFR 63.10032(g))**
  - g. Actions taken during periods of malfunction to minimize emissions in accordance with 40 CFR 63.10000(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. **(40 CFR 63.10032(h))**
15. The permittee shall keep all records in a form suitable and readily available for expeditious review and for at least 5 years after the date of each occurrence, corrective action, report, or record. The records must be kept onsite for at least 2 years and may be kept offsite for the remaining 3 years. **(40 CFR 63.10(b)(1), 40 CFR 63.10033)**
16. The permittee shall maintain on site and submit, if requested by the Administrator, an annual report of periodic performance tune-ups containing the information required by 40 CFR 63.10021(e)(8). The reports shall be in a format acceptable to the Administrator. If requested by the AQD District Supervisor, the permittee shall also submit an annual report with the results of the performance tune-ups. **(40 CFR 63.10021(e)(8))**

## **VII. REPORTING**

- 1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
- 2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
- 3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
- 4. Semiannual reporting of the information required in 40 CFR 63.10031(c)(1) through (9), (d), and (e) as applicable. The report shall be postmarked or received by the Administrator by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. The report shall include the following:
  - a. The information required by the Continuous Monitoring Summary Report located in 40 CFR 63.10(e)(3)(vi). **(40 CFR 63.10031(c)(1))**
  - b. The total fuel use by each affected source subject to an emission limit, for each calendar month within the semiannual reporting period, including, but not limited to, a description of the fuel, whether the fuel has received a non-waste determination by USEPA or the basis for concluding that the fuel is not a waste, and the total fuel usage amount with units of measure. **(40 CFR 63.10031(c)(2))**
  - c. Indicate whether any emission unit in FGMATS\_U3 burned new types of fuel during the reporting period. If new types of fuel were burned, include the date of the performance test where that fuel was in use. **(40 CFR 63.10031(c)(3))**
  - d. Include the date of the most recent tune-up for each emission unit. The date of the tune-up is the date the tune-up provisions specified in 40 CFR 63.10021(e)(6) and (7) were completed. **(40 CFR 63.10031(c)(4))**
  - e. If there are no deviations from any emission limitation (emission limit and operating limit) that applies to FGMATS\_U3 and there are no deviations from the requirements for work practice standards in Table 3 to 40 CFR Part 63, Subpart UUUUU that apply to FGMATS\_U3, the report shall include a statement that there were no deviations from the emission limitations and work practice standards during the reporting period. If there were no periods during which the CMSs, including continuous emissions monitoring system, and operating parameter monitoring systems, were out-of-control as specified in 40 CFR 63.8(c)(7), a statement

that there were no periods during which the CMSs were out-of-control during the reporting period. **(40 CFR Part 63, Subpart UUUUU, Table 8)**

- f. If there is a deviation from any emission limitation (emission limit and operating limit) or work practice standard during the reporting period, the report must contain a brief description of the deviation, the duration of the deviation, the cause of the deviation, and the information in 40 CFR 63.10031(d). If there were periods during which the CMS's, including continuous emissions monitoring systems and continuous parameter monitoring systems, were out-of-control, as specified in 40 CFR 63.8(c)(7), the report must contain the information in 40 CFR 63.10031(e). **(40 CFR 63.10031(c)(1) through (9), (d), and (e), 40 CFR 63.10031(a), 40 CFR 63.10031(c)(9), 40 CFR Part 63, Subpart UUUUU, Table 8)**
  - g. If the affected source submits a compliance report pursuant to Table 8 in 40 CFR Part 63, Subpart UUUUU, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the compliance report includes all required information concerning deviations from any emission limit, operating limit, or work practice requirement in 40 CFR Part 63, Subpart UUUUU, submission of the compliance report satisfies any obligation to report the same deviations in the semiannual monitoring report required by SC VII.2. **(40 CFR 63.10031(e))**
5. The permittee must submit any of the following applicable notifications by the dates specified within the specific citation: 40 CFR 63.7(b) and (c) Notification of performance test and Quality assurance program; 40 CFR 63.8(e) Performance evaluation of continuous monitoring systems; 40 CFR 63.8(f)(4) Request to use alternative monitoring methods; 40 CFR 63.8(f)(6) Alternative to the relative accuracy test; 40 CFR 63.9(b) Initial notifications; 40 CFR 63.9(c) Request for extension of compliance; 40 CFR 63.9(d) Notification that source is subject to special compliance requirements; 40 CFR 63.9(e) Notification of performance test, which shall be submitted at least 30 days before the performance test is scheduled to begin; 40 CFR 63.9(f) Notification of opacity and visible emission observations; 40 CFR 63.9(g) Additional notification requirements for sources with continuous monitoring systems; and 40 CFR 63.9(h) Notification of compliance status. **(40 CFR 63.10030(a))**
  6. On or after July 1, 2020, within 60 days after the date of completing each performance test, the permittee must submit the performance test reports required by this subpart to USEPA's WebFIRE database by using the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). Performance test data must be submitted in the file format generated through use of USEPA's Electronic Reporting Tool (ERT) (see <http://www.epa.gov/ttn/chief/ert/index.html>). Only data collected using those test methods on the ERT Web site are subject to this requirement for submitting reports electronically to WebFIRE. At the discretion of the AQD, the permittee must also submit these reports, one to the Technical Programs Unit Supervisor and one to the AQD District Supervisor, in a format approved by the AQD. **(40 CFR 63.10031(f))**
  7. On or after July 1, 2020, for a PM CEMS, PM CPMS, or approved alternative monitoring using a HAP metals CEMS, within 60 days after the reporting periods ending on March 31, June 30, September 30, and December 31, the permittee must submit quarterly reports to USEPA's WebFIRE database by using the CEDRI that is accessed through USEPA's CDX ([www.epa.gov/cdx](http://www.epa.gov/cdx)). The permittee must use the appropriate electronic reporting form in CEDRI or provide an alternate electronic file consistent with USEPA's reporting form output format. For each reporting period, the quarterly reports must include all of the calculated 30-boiler operating day rolling average values derived from the CEMS and PM CPMS. **(40 CFR 63.10031(f)(2))**
  8. Reports for a SO<sub>2</sub> CEMS, a Hg CEMS or sorbent trap monitoring system, a HCl or HF CEMS, and any supporting monitors for such systems (such as a diluent or moisture monitor) shall be submitted using the ECMPS Client Tool, as provided for in 40 CFR Part 63, Subpart UUUUU, Appendices A and B and 40 CFR 63.10021(f). **(40 CFR 63.10031(f)(3))**
  9. On or after July 1, 2020, the permittee must submit all reports required by 40 CFR 63.10031 (c) and (d) electronically using CEDRI that is accessed through the USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). The permittee must use the appropriate electronic reporting form in CEDRI or provide an alternate electronic file consistent with USEPA's reporting form output format. If requested by the AQD, the permittee must also submit these reports, to the AQD District Supervisor in a format approved by the AQD. **(40 CFR 63.10031(f)(4))**

10. Prior to July 1, 2020, all reports subject to electronic submittal in SC VII.6, VII.7, and VII.9 shall be submitted to the USEPA at the frequency specified in those paragraphs in electronic portable document format (PDF) using the ECMPS Client Tool. Each PDF version of a submitted report must include sufficient information to assess compliance and to demonstrate that the testing was done properly. The data elements listed at 40 CFR 63.10031(f)(6)(i)-(xii) must be entered into the ECMPS Client Tool at the time of submission of each PDF file. **(40 CFR 63.10031(f)(6))**
11. If requested by the Administrator, the permittee must submit the monitoring plan (or relevant portion of the plan) at least 60 days before the initial performance evaluation of a particular CMS, except where the CMS has already undergone a performance evaluation that meets the requirements of 40 CFR 63.10010 (e.g., if the CMS was previously certified under another program). **(40 CFR 63.10000(d)(3))**

### **VIII. STACK/VENT RESTRICTION(S)**

NA

### **IX. OTHER REQUIREMENT(S)**

1. For each emission unit or emissions averaging group complying with an emission limit as specified in Table 2 of 40 CFR Part 63, Subpart UUUUU, the permittee may request to switch from a mass per heat input to a mass per gross output limit (or vice versa).
  - a. The permittee may switch from a mass per heat input to a mass per gross output limit (or vice-versa), provided that:
    - i. The permittee submits a request that identifies for each emission unit or emissions averaging group involved in the proposed switch both the current and proposed emission limit. **(40 CFR 63.10030(e)(7)(iii)(A)(1))**
    - ii. The request arrives to the Administrator at least 30 calendar days prior to the date that the switch is proposed to occur. **(40 CFR 63.10030(e)(7)(iii)(A)(2))**
    - iii. The request demonstrates through performance stack test results completed within 30 days prior to the submission, compliance for each emission unit or emissions averaging group with both the mass per heat input and mass per gross output limits. **(40 CFR 63.10030(e)(7)(iii)(A)(3))**
    - iv. The permittee revises and submits all other applicable plans, e.g., monitoring and emissions averaging, with the request. **(40 CFR 63.10030(e)(7)(iii)(A)(4))**
    - v. The permittee maintains records of all information regarding the choice of emission limits. **(40 CFR 63.10030(e)(7)(iii)(A)(5))**
  - b. The permittee may begin to use the revised emission limits starting in the next reporting period, after receipt of written acknowledgement from the Administrator of the switch. **(40 CFR 63.10030(e)(7)(iii)(B))**
  - c. From the submission of the request until start of the next reporting period after receipt of written acknowledgement from the Administrator of the switch, the permittee shall demonstrate compliance with both the mass per heat input and mass per gross output emission limits for each pollutant for each emission unit or emissions averaging group. **(40 CFR 63.10030(e)(7)(iii)(C))**
2. If using a CMS to demonstrate continuous compliance with an emission limit or operating limit, the permittee must develop a site-specific monitoring plan and submit this site-specific monitoring plan, if requested, at least 60 days before the initial performance evaluation (where applicable) of the CMS. This requirement also applies to the permittee if the permittee petitions the Administrator for alternative monitoring parameters under 40 CFR 63.8(f). This requirement to develop and submit a site-specific monitoring plan does not apply to affected sources with existing monitoring plans that apply to CEMS and CPMS prepared under Appendix B of 40 CFR Part 60 or 40 CFR Part 75, and that meet the requirements of 40 CFR 63.10010. Using the process described in 40 CFR 63.8(f)(4), the permittee may request approval of monitoring system quality assurance and quality control procedures alternative to those specified in this paragraph of this section and, if approved, include those in the

site-specific monitoring plan. The monitoring plan must address the following provisions: **(40 CFR 63.10000(d), 40 CFR 63.10010)**

- a. Installation of the CMS or sorbent trap monitoring system sampling probe or other interface at a measurement location relative to each affected process unit such that the measurement is representative of control of the exhaust emissions (e.g., on or downstream of the last control device). See 40 CFR 63.10010(a) for further details. For PM CPMS installations, follow the procedures in 40 CFR 63.10010(h).
  - b. Performance and equipment specifications for the sample interface, the pollutant concentration or parametric signal analyzer, and the data collection and reduction systems.
  - c. Schedule for conducting initial and periodic performance evaluations.
  - d. Performance evaluation procedures and acceptance criteria (e.g., calibrations), including the quality control program in accordance with the general requirements of 40 CFR 63.8(d).
  - e. On-going operation and maintenance procedures, in accordance with the general requirements of 40 CFR 63.8(c)(1)(ii), (c)(3), and (c)(4)(ii).
  - f. Conditions that define a CMS that is out of control consistent with 40 CFR 63.8(c)(7)(i) and for responding to out of control periods consistent with 40 CFR 63.8(c)(7)(ii) and (c)(8).
  - g. On-going recordkeeping and reporting procedures, in accordance with the general requirements of 40 CFR 63.10(c), (e)(1), and (e)(2)(i), or as specifically required under 40 CFR Part 63, Subpart UUUUU.
  - h. Alternatively, the requirements are considered to be met for a particular CMS or sorbent trap monitoring system if:
    - i. The CMS or sorbent trap monitoring system is installed, certified, maintained, operated, and quality-assured either according to 40 CFR Part 75, or Appendix A or B of 40 CFR Part 63, Subpart UUUUU; and
    - ii. The recordkeeping and reporting requirements of 40 CFR Part 75, or Appendix A or B of 40 CFR Part 63, Subpart UUUUU, which pertain to the CMS, are met.
3. If any emission unit(s) cease(s) to operate in a manner that causes the unit(s) to meet the definition of an EGU subject to 40 CFR Part 63, Subpart UUUUU, the permittee must submit the notification in 40 CFR 63.10000(i)(2) no less than 30 days prior to when the EGU will cease complying with 40 CFR Part 63, Subpart UUUUU. **(40 CFR 63.10000(i)(2), 40 CFR 63.10030(f))**
4. The permittee shall comply with all provisions of the National Emission Standards for Hazardous Air Pollutants as specified in 40 CFR Part 63, Subparts A and UUUUU. **(40 CFR Part 63, Subparts A and UUUUU)**

**Footnotes:**

<sup>1</sup> This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup> This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**FGEXISTINGRICE  
 FLEXIBLE GROUP CONDITIONS**

**DESCRIPTION**

Existing Emergency Engines located at a Major Source < 500 HP, Commenced Construction or Reconstruction before June 12, 2006.

These four (4) existing stationary diesel-fired reciprocating compression ignition internal combustion engines are emergency generators subject to 40 CFR Part 63, Subpart ZZZZ (National Emission Standard for Hazardous Air Pollutants for Reciprocating Internal Combustion Engines (RICE)).

**Emission Units:** EUCATFIREPUMP3, EUHPHSWP15001, EUHPHSWP15002, EUHPHSWP3000.

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMITS**

NA

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Fuel Oil – sulfur content	1.0% by weight at 18,000 BTU/lb	Instantaneous; at all times	EUCATFIREPUMP3 EUHPHSWP15001 EUHPHSWP15002 EUHPHSWP3000	SC VI.5	R 336.1401(1), Table 41

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. Each engine in FGEXISTINGRICE shall be installed, maintained, and operated in a satisfactory manner. A list of recommended work practice standards as specified in 40 CFR 63.6602 and Table 2c, Item 1 or the permittee may petition the Administrator pursuant to the requirements of 40 CFR 63.6(g) for alternative work practices. The following are the recommended work practices specified in 40 CFR Part 63, Subpart ZZZZ, Table 2c:
  - a. Change oil and filter every 500 hours of operation or annually, whichever comes first, except as allowed in SC III.3.
  - b. Inspect the air cleaner every 1,000 hours of operation or annually, whichever comes first; and replace as necessary.
  - c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

If the emergency engine is being operated during an emergency and it is not possible to shut down the engine to perform the work practice standards on the schedule required the work practice standard can be delayed until the emergency is over. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State or local law has been abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law or which the risk was deemed unacceptable. **(40 CFR 63.6602, 40 CFR Part 63, Subpart ZZZZ, Table 2c, Item 6)**

2. The permittee may utilize an oil analysis program in order to extend the specified oil change requirement. The oil analysis must be performed at the same frequency as oil changes are required. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c of 40 CFR Part 63, Subpart ZZZZ. **(40 CFR 63.6625(i))**
3. The permittee shall maintain and operate each engine in FGEXISTINGRICE per the manufacturer's emission related written instructions or develop a maintenance plan which must provide for the maintenance and operation of the engine in a manner consistent with good air pollution control practices for minimizing emissions. **(40 CFR 63.6625(e), 40 CFR 63.6640(a), 40 CFR Part 63, Subpart ZZZZ, Table 6 Item 9)**
4. The permittee shall minimize the time spent at idle during startup and minimize the startup time of each engine in FGEXISTINGRICE to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. **(40 CFR 63.6625(h))**
5. There is no time limit on the use of emergency stationary RICE in emergency situations. **(40 CFR 63.6640(f)(1))**
6. The permittee may not operate each engine in FGEXISTINGRICE for more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. **(40 CFR 63.6640(f)(2))**
7. The permittee may operate each engine in FGEXISTINGRICE for up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing as provided in 40 CFR 63.6640 (f)(2). The 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income to supply non-emergency power as part of a financial arrangement with another entity, except as allowed in 40 CFR 63.6640(f)(4)(ii). **(40 CFR 63.6640(f)(4))**
8. If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the work practice requirements on the schedule required in Table 2c of this subpart, or if performing the work practice on the required schedule would otherwise pose an unacceptable risk under Federal, State, or local law, the work practice can be delayed until the emergency is over or the unacceptable risk under Federal, State, or local law has abated. The work practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State, or local law has abated. Sources must report any failure to perform the work practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. **(40 CFR Part 63, Table 2c, Footnote 1)**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall equip and maintain with a non-resettable hour meter to track the number of hours each engine operates. **(40 CFR 63.6625(f))**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. If using the oil analysis program in order to extend the specified oil change requirement in 40 CFR Part 63, Subpart ZZZZ, Table 2d, the permittee must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20% from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner



or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. **(40 CFR 63.6625(j))**

**See Appendix 5**

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. For each engine in FGEXISTINGRICE, the permittee shall keep in a satisfactory manner, records of the occurrence and duration of each malfunction of operation or the air pollution control monitoring equipment. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(a)(2), 40 CFR 63.6660)**
2. For each engine in FGEXISTINGRICE, the permittee shall keep in a satisfactory manner, records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(a)(5), 40 CFR 63.6660)**
3. For each engine in FGEXISTINGRICE, the permittee shall keep in a satisfactory manner, maintenance records to demonstrate compliance with SC III.1 and the written maintenance plan. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(d), 40 CFR 63.6655(e), 40 CFR 63.6660)**
4. The permittee shall monitor and record the total hours of operation for each engine in FGEXISTINGRICE per calendar year, recorded through the non-resettable hours meter, in a manner acceptable to the District Supervisor, Air Quality Division. The permittee shall document how many hours are spent for emergency operation; including what classified the operation as emergency and how many hours are spent for non-emergency operation. If the engine is used for the purposes specified in 40 CFR 63.6640(f)(4)(ii), the permittee must keep records of the notification of the emergency situation, and the date, start time, and end time of engine operation. **(40 CFR 63.6655(f))**
5. The permittee shall maintain sufficient records to demonstrate that the sulfur content for each shipment of fuel oil received is less than 1.0% by weight. **(R 336.1213(3))**
6. The permittee shall conduct and maintain records of a daily (non-certified) visual observation for opacity in order to verify proper firing, whenever an engine is in use for 24 consecutive hours or more. **(R 336.1213(3))**
7. The permittee shall maintain a record of the applicability determination for each engine in FGEXISTINGRICE relative to the requirements of 40 CFR Part 63, Subparts A and ZZZZ. **(40 CFR Part 63, Subpart A, Section 63.10(b)(3))**

**See Appendix 3-C**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**

3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit to the AQD District Supervisor, a semiannual compliance report, as specified in 40 CFR 63.6650, which contains all deviations during the reporting period from any applicable emission limitation or operating limitation. If there are no deviations from any applicable emission limitations or operating limitations, the report shall contain a statement that there were no deviations during the reporting period. The first report shall cover the period beginning on the applicable compliance date specified in 40 CFR 63.6595 and ending on June 30 (postmarked or delivered by July 31) or December 31 (postmarked or delivered by January 31), whichever date is the first date following the end of the first calendar half after the applicable compliance date. Each subsequent report must cover the semiannual period from January 1 through June 30, or from July 1 through December 31. The subsequent reports must be postmarked or delivered by July 31 or January 31, whichever date is the first date following the end of the semiannual reporting period, except as allowed in 40 CFR 63.6650(b)(5). The compliance report must also contain the following information, as specified in 40 CFR 63.6650(c) and (d):
  - a. Company name and address.
  - b. Certification of the report by a responsible official.
  - c. Date of report and beginning and ending dates of the reporting period.
  - d. The number of malfunctions, including a brief description of each event, that occurred during the reporting period and a demonstration that the Malfunction Plan was followed during such events.
  - e. The total operating time of the RICE at which the deviation occurred during the reporting period.
  - f. The number, duration, and cause of deviations and the corrective action taken.

A copy of the compliance report shall be kept on file for a period of at least five years (at least two years at the site) and made available to the Department upon request. **(40 CFR 63.6640(b), 40 CFR 63.6650(b),(c),(d), 40 CFR 63.6660)**

5. Each affected source that has obtained a Title V operating permit pursuant to 40 CFR Part 70 or 71 must report all deviations as defined in 40 CFR Part 63, Subpart ZZZZ in the semiannual monitoring report required by 40 CFR 70.6 (a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A). If an affected source submits a Compliance report pursuant to Table 7 of 40 CFR Part 63, Subpart ZZZZ along with, or as part of, the semiannual monitoring report required by 40 CFR 70.6(a)(3)(iii)(A) or 40 CFR 71.6(a)(3)(iii)(A), and the Compliance report includes all required information concerning deviations from any emission or operating limitation in 40 CFR Part 63, Subpart ZZZZ, submission of the Compliance report shall be deemed to satisfy any obligation to report the same deviations in the semiannual monitoring report. However, submission of a Compliance report shall not otherwise affect any obligation the affected source may have to report deviations from permit requirements to the permit authority. **(40 CFR 63.6650(f))**
  - c. For each engine in FGEXISTINGRICE that is an emergency stationary engine with a site rating of more than 100 brake hp that operates or is contractually obligated to be available for more than 15 hours per calendar year for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii) or that operates for the purpose specified in 40 CFR 63.6640(f)(4)(ii), you must submit an annual report according to the requirements below and as specified in 40 CFR 63.6650(h). **(40 CFR 63.6650(h), 40 CFR 63.6660)**
    - a. The report must contain the following information:
      - i. Company name and address where the engine is located.
      - ii. Date of the report and beginning and ending dates of the reporting period.
      - iii. Engine site rating and model year.
      - iv. Latitude and longitude of the engine in decimal degrees reported to the fifth decimal place.
      - v. Hours operated for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).
      - vi. Number of hours the engine is contractually obligated to be available for the purposes specified in 40 CFR 63.6640(f)(2)(ii) and (iii).

- vii. Hours spent for operation for the purpose specified in 40 CFR 63.6640(f)(4)(ii), including the date, start time, and end time for engine operation for the purposes specified in 40 CFR 63.6640(f)(4)(ii). The report must also identify the entity that dispatched the engine and the situation that necessitated the dispatch of the engine.
  - viii. If there were no deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), a statement that there were no deviations from the fuel requirements during the reporting period.
  - ix. If there were deviations from the fuel requirements in 40 CFR 63.6604 that apply to the engine (if any), information on the number, duration, and cause of deviations, and the corrective action taken.
- b. The permittee shall submit annual reports for each calendar year must be submitted no later than March 31 of the following calendar year.

The annual report must be submitted electronically using the subpart specific reporting form in the Compliance and Emissions Data Reporting Interface (CEDRI) that is accessed through USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). However, if the reporting form specific to this subpart is not available in CEDRI at the time that the report is due, the written report must be submitted to the Administrator at the appropriate address listed in 40 CFR 63.13.

**See Appendix 8**

#### **VIII. STACK/VENT RESTRICTION(S)**

NA

#### **IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with all applicable provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ, for Stationary Reciprocating Internal Combustion Engines by the initial compliance date of May 3, 2013. **(40 CFR 63.6595(a)(1), 40 CFR, Part 63, Subparts A and ZZZZ)**

#### **Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**FGNEWCIRICE  
 FLEXIBLE GROUP CONDITIONS**

**DESCRIPTION**

**EUWPDIESEL:** A Water Pump for EUSDA\_U3 emergency flush certified to NSPS IIII Tier 3 requirements. A diesel-powered, stationary internal combustion engine rated at 130 HP (97 kW).

**EUTRNCNTRDIESEL:** An emergency generator for the Training Center with diesel engine certified to NSPS IIII Tier 3 requirements. A diesel-powered, stationary internal combustion engine rated at 1,193 bHP.

These units are subject to the provisions of 40 CFR Part 60, Subpart IIII and 40 CFR Part 63, Subpart ZZZZ.

**Emission Units:** EUWPDIESEL, EUTRNCNTRDIESEL

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

Pollutant	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. NMHC + NOx	4.0 g/kW-hr <sup>2</sup>	Hourly	EUWPDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4205(b), 40 CFR 89.112(a) Table 1</b>
2. CO	5.0 g/kW-hr <sup>2</sup>	Hourly	EUWPDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4202(a)(2), 40 CFR 60.4205(b), 40 CFR 89.112(a) Table 1</b>
3. PM	0.30 g/kW-hr <sup>2</sup>	Hourly	EUWPDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4202(a)(2), 40 CFR 60.4205(b), 40 CFR 89.112(a) Table 1</b>
4. NMHC + NOx	6.4 g/kW-hr <sup>2</sup>	Hourly	EUTRNCNTRDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4205(c)</b>
5. CO	3.5 g/kW-hr <sup>2</sup>	Hourly	EUTRNCNTRDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4205(c)</b>
6. PM	0.20 g/kW-hr <sup>2</sup>	Hourly	EUTRNCNTRDIESEL	SC V.1 SC VI.2	<b>40 CFR 60.4205(c)</b>

**II. MATERIAL LIMIT(S)**

- The permittee shall burn only diesel fuel, in EUWPDIESEL and EUTRNCNTRDIESEL with the maximum sulfur content of 15 ppm (0.0015%) by weight and a minimum Cetane index of 40 or a maximum aromatic content of 35 volume percent.<sup>2</sup> **(R 336.1205(1)(a), R 336.1402(1), 40 CFR 60.4207(b), 40 CFR 80.510(b))**

See Appendix 3-C

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

- The permittee shall not operate EUWPDIESEL for more than 100 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 100 hours includes the hours for the purpose

of emergency operation, necessary maintenance checks and readiness testing as described in SC III.2.<sup>2</sup> **(R 336.1205(1)(a), R 336.1225, R 336.1702(a))**

2. The permittee may operate not either EUWPDIESEL or EUTRNCNTRDIESEL for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. EUWPDIESEL may operate up to 50 hours per calendar year in non-emergency situations, but those 50 hours are counted towards the 100 hours per calendar year provided for maintenance and testing.<sup>2</sup> **(40 CFR 60.4211(f))**
3. If EUWPDIESEL and/or EUTRNCNTRDIESEL is a certified engine, the permittee shall meet the following requirements:
  - a. Operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions;
  - b. Change only those emission-related settings that are permitted by the manufacturer; and
  - c. Meet the requirements as specified in 40 CFR 89, 94, and/or 1068, as they apply to each engine in FGNEWCIRICE.

If you do not operate and maintain the certified engine and control device according to the manufacturer's emission-related written instructions, the engine may be considered a non-certified engine.<sup>2</sup> **(40 CFR 60.4211(a))**

4. If EUWPDIESEL and/or EUTRNCNTRDIESEL is a non-certified engine or a certified engine operating in a non-certified manner, the permittee shall keep a maintenance plan and records of conducted maintenance for EUWPDIESEL and must, to the extent practicable, maintain and operate each engine in FGNEWCIRICE in a manner consistent with good air pollution control practice for minimizing emissions.<sup>2</sup> **(40 CFR 60.4211(g)(2))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The permittee shall equip and maintain EUWPDIESEL and EUTRNCNTRDIESEL with a non-resettable hours meter to track the operating hours.<sup>2</sup> **(R 336.1205(1)(a), R 336.1225, 40 CFR 60.4209)**
2. The nameplate capacity of EUWPDIESEL shall not exceed 130 hp, as certified by the equipment manufacturer.<sup>2</sup> **(R 336.1205(1)(a), R 336.1225, 40 CFR 60.4202, 40 CFR 89.112(a))**
3. The nameplate capacity of EUTRNCNTRDIESEL shall not exceed the capacity restrictions (560<kW<=2237) as certified by the equipment manufacturer. **(40 CFR 60.4202)**

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. Unless EUWPDIESEL and/or EUTRNCNTRDIESEL has been certified by the manufacturer as required by 40 CFR Part 60, Subpart IIII and the permittee maintains the engine as required by 40 CFR 60.4211, the permittee shall conduct an initial performance test to demonstrate compliance with the emission limits in SC I.1 – I.3 for each diesel engine, within one year after startup, or within 1 year after either diesel engine is no longer configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after the permittee changes emission-related settings in a way that is not permitted by the manufacturer, to demonstrate compliance with the emission limits in 40 CFR 60.4205(b). If a performance test is required, the performance test shall be conducted according to 40 CFR 60.4212. No less than 30 days prior to testing, a complete test plan shall be submitted to the AQD. The final plan must be approved by the AQD prior to testing. After conducting the initial performance test, the permittee shall conduct subsequent performance testing, for non-certified engines, every 8,760 hours or 3 years, whichever comes first. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. Verification of emission rates

includes the submittal of a complete report of the test results to the AQD within 60 days following the last date of the test.<sup>2</sup> **(R 336.2001, R 336.2003, R 336.2004, 40 CFR 60.4211(g)(2), 40 CFR 60.4212)**

2. Upon request of the AQD District Supervisor, the permittee shall verify NOx, CO, PM10, and PM2.5 emission rates from EUWPDIESEL or EUTRNCNTRDIESEL by testing at owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved USEPA Method listed in:

<b>Pollutant</b>	<b>Test Method Reference</b>
PM10/PM2.5	40 CFR Part 51, Appendix M
NOx	40 CFR Part 60, Appendix A
CO	40 CFR Part 60, Appendix A

An alternate method, or a modification to the approved USEPA Method, may be specified in an AQD-approved Test Protocol. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 7 days of the time and place before performance tests are conducted. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test.<sup>2</sup> **(R 336.1205, R 336.1225, R 336.2001, R 336.2003, R 336.2004)**

See Appendix 5

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30<sup>th</sup> day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition.<sup>2</sup> **(R 336.1205(1)(a))**
2. The permittee shall keep, in a satisfactory manner, records of testing required in SC V.1 or manufacturer certification documentation indicating that EUWPDIESEL and EUTRNCNTRDIESEL meets the applicable requirements contained in the federal Standards of Performance for New Stationary Sources 40 CFR Part 60, Subpart IIII. If EUWPDIESEL or EUTRNCNTRDIESEL becomes uncertified then the permittee must also keep records of a maintenance plan and maintenance activities. The permittee shall keep all records on file and make them available to the Department upon request.<sup>2</sup> **(40 CFR 60.4211(g)(2))**
3. The permittee shall monitor and record the total hours of operation and the hours of operation during non-emergencies for EUWPDIESEL and EUTRNCNTRDIESEL, on a monthly and 12-month rolling time period basis, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation of EUWPDIESEL and EUTRNCNTRDIESEL, including what classified the operation as emergency and how many hours are spent maintenance or readiness testing and for non-emergency operation.<sup>2</sup> **(R 336.1205(1)(a), 40 CFR 60.4211, 40 CFR 60.4214(b))**
4. The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in EUWPDIESEL and EUTRNCNTRDIESEL, demonstrating that the fuel meets the requirement of 40 CFR 80.510(b). The certification or test data shall include the name of the oil supplier or laboratory, the sulfur content, and cetane index or aromatic content of the fuel oil.<sup>2</sup> **(R 336.1205(1)(a), R 336.1402(1), 40 CFR 80.510(b))**

See Appendices 3, 4, and 7

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**

2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee shall submit any performance test reports to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8

**VIII. STACK/VENT RESTRICTION(S)**

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVWPDIESEL	14 <sup>2</sup>	16 <sup>2</sup>	<b>40 CFR 52.21(c) &amp; (d)</b>

**IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the provisions of the federal Standards of Performance for New Stationary Sources as specified in 40 CFR Part 60, Subparts A and IIII, as they apply to EUWPDIESEL and EUTRNCNTRDIESEL.<sup>2</sup> **(40 CFR Part 60, Subparts A & IIII, 40 CFR 63.6590)**
2. The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ, as they apply to EUWPDIESEL and EUTRNCNTRDIESEL.<sup>2</sup> **(40 CFR Part 63, Subparts A and ZZZZ, 40 CFR 63.6595)**

**Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).  
<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**FGAUXBLRS3**  
**FLEXIBLE GROUP CONDITIONS**

**DESCRIPTION**

Two (2) distillate oil fired boilers rated at 9.8 MMBTU heat input, providing heat to Plant 3. These units are subject to the provisions of 40 CFR Part 63, Subpart DDDDD.

**Emission Units:** EUAUXBLR3B, EUAUXBLR3C (Both are 9.8 MMBTU/hr, Diesel fuel)

**POLLUTION CONTROL EQUIPMENT**

NA

**I. EMISSION LIMIT(S)**

NA

**II. MATERIAL LIMIT(S)**

Material	Limit	Time Period/ Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. Fuel Oil – sulfur content	0.4% by weight at 18,000 BTU/lb	Instantaneous; at all times	EUAUXBLR3B EUAUXBLR3C	SC VI.1	<b>R 336.1282 (b)(ii)</b>

**III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. The permittee must meet the tune-up and energy assessment work practice standards for each applicable boiler or process heater at the source. **(40 CFR 63.7500(a)(1), 40 CFR Part 63, Subpart DDDDD, Table 3, Nos. 1-4)**
2. The permittee must operate and maintain affected sources in a manner consistent with safety and good air pollution control practices for minimizing emissions. Determination of whether such operation and maintenance procedures are being used will be based on information available to the AQD that may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source. **(40 CFR 63.7500(a)(3))**
3. The permittee may obtain approval from the USEPA Administrator to use an alternative to the tune-up and energy assessment work practice standards. **(40 CFR 63.7500(b))**
4. The permittee must conduct a biennial performance tune-up according to 40 CFR 63.7540(a)(11) as stated in SC III.5, respectively. Each biennial tune-up specified in 40 CFR 63.7540(a)(11) must be conducted no more than 25 months after the previous tune-up. **(40 CFR 63.7515(d))**
5. Boilers or process heaters with a heat input capacity of less than 10 million BTU per hour must conduct a biennial tune-up of the boiler or process heater. **(40 CFR 63.7540(a)(11), 40 CFR 63.7500(e))**
6. The permittee shall conduct the tune-up within 30 days of startup, if the unit is not operating on the required date for a tune-up. **(40 CFR 63.7540(a)(12))**
7. The permittee must demonstrate continuous compliance with the tune-up requirement by completing the following: **(40 CFR 63.7540(a)(10))**



- a. Inspect the burner, and clean or replace any components of the burner as necessary (the permittee may delay the burner inspection until the next scheduled unit shutdown). At units where entry into a piece of process equipment or into a storage vessel is required to complete the tune-up inspections, inspections are required only during planned entries into the storage vessel or process equipment. **(40 CFR 63.7540(a)(10)(i))**
- b. Inspect the flame pattern, as applicable, and adjust the burner as necessary to optimize the flame pattern. The adjustment should be consistent with the manufacturer's specifications, if available. **(40 CFR 63.7540(a)(10)(ii))**
- c. Inspect the system controlling the air-to-fuel ratio, as applicable, and ensure that it is correctly calibrated and functioning properly (the permittee may delay the inspection until the next scheduled unit shutdown). Units that produce electricity for sale may delay the inspection until the first outage, not to exceed 36 months from the previous inspection. **(40 CFR 63.7540(a)(10)(iii))**
- d. Optimize total emissions of CO. This optimization should be consistent with the manufacturer's specifications, if available, and with any NO<sub>x</sub> requirement to which the unit is subject. **(40 CFR 63.7540(a)(10)(iv))**
- e. Measure the concentrations in the effluent stream of CO in parts per million, by volume, and oxygen in volume percent, before and after the adjustments are made (measurements may be either on a dry or wet basis, as long as it is the same basis before and after the adjustments are made). Measurements may be taken using a portable CO analyzer. **(40 CFR 63.7540(a)(10)(v))**
- f. Maintain on-site and submit, if requested by the AQD, the most recent periodic report containing the information as listed below. **(40 CFR 63.7540(a)(10)(vi))**
  - i. The concentrations of CO in the effluent stream in parts per million by volume, and oxygen in volume percent, measured at high fire or typical operating load, before and after the tune-up of the boiler or process heater. **(40 CFR 63.7540(a)(10)(vi)(A))**
  - ii. A description of any corrective actions taken as a part of the tune-up. **(40 CFR 63.7540(a)(10)(vi)(B))**
  - iii. The type and amount of fuel used over the 12 months prior to the tune-up, but only if the unit was physically and legally capable of using more than one type of fuel during that period. Units sharing a fuel meter may estimate the fuel used by each unit. **(40 CFR 63.7540(a)(10)(vi)(C))**
8. The permittee must complete the Initial tune ups on all affected units except as provided in 40 CFR 63.7510(j) and 40 CFR 63.7540(a)(13). **(40 CFR 63.7510(e))**
9. For affected sources (as defined in 40 CFR 63.7490) that have not operated since the previous compliance demonstration and more than one year has passed since the previous compliance demonstration, the permittee must complete a subsequent tune-up within 30 days of startup by following the procedures described in SC III.7.a through SC III.7.f. **(40 CFR 63.7515(9))**

#### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

NA

#### **V. TESTING/SAMPLING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall maintain sufficient records to demonstrate that the sulfur content for each shipment of fuel oil received is less than 0.4% by weight. **(R 336.1213(3))**
2. The permittee must keep a copy of each notification and report submitted to comply with 40 CFR Part 63, Subpart DDDDD, including all documentation supporting any Initial Notification or Notification of Compliance Status or semiannual compliance report that the permittee submitted, according to the requirements in 40 CFR 63.10(b)(2)(xiv). **(40 CFR 63.7555(a)(1))**
3. The permittee must keep each record on site, or they must be accessible from on-site (for example, through a computer network), for at least 2 years after the date of each occurrence, measurement, maintenance, corrective action, report, or record. The permittee can keep the records off site for the remaining 3 years. **(40 CFR 63.7560(a), (b), and (c))**

**See Appendix 3-C (Fuel Oil Sulfur Monitoring)**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. The permittee must submit boiler tune-up compliance reports. Compliance reports must be postmarked or submitted by March 15 of the year following the tune-up and must cover the applicable 1, 2, or 5-year period starting from January 1 of the year following the previous tune-up to December 31 (of the latest tune-up year). Compliance reports must be submitted using the Compliance and Emissions Data Reporting Interface (CEDRI) which is accessed through the USEPA's Central Data Exchange (CDX) ([www.epa.gov/cdx](http://www.epa.gov/cdx)). If the reporting form is not available in CEDRI at the time the compliance report is due, a hardcopy of the compliance report shall be submitted to the state and USEPA Region 5. At the discretion of the Administrator, the permittee must submit these reports in the format specified by the Administrator. **(40 CFR 63.7550(b), 40 CFR 63.10(a)(5), 40 CFR 63.7550(h)(3))**
5. Unless the USEPA Administrator has approved a different schedule for submission of reports under 40 CFR 63.10(a), the permittee must submit each report, according to paragraph (h) of 40 CFR 63.7550, stated in SC VII.5, by the date in Table 9 of 40 CFR Part 63, Subpart DDDDD and according to the requirements in paragraphs (b)(1) through (4) of 40 CFR 63.7550, as listed below. For units that are subject only to a requirement to conduct a 5-year tune-up according to 40 CFR 63.7540(a)(12), stated in SC IX.5.b, and not subject to emission limits or operating limits, the permittee may submit only a 5-year compliance report, as specified in paragraphs (b)(1) through (4) of 40 CFR 63.7550, as listed below, instead of a semi-annual compliance report. **(40 CFR 63.7550(a) & (b))**
  - a. Each semi-annual compliance report must cover the semiannual reporting period from January 1 through June 30 or the semiannual reporting period from July 1 through December 31. 5-year compliance reports must cover the 5-year period from January 1 to December 31. **(40 CFR 63.7550(b)(3))**
  - b. Each semi-annual compliance report must be postmarked or submitted no later than September 15 or March 15, whichever date is the first date following the end of the semiannual reporting period. 5-year compliance reports must be postmarked or submitted no later than March 15. **(40 CFR 63.10(a)(5), 40 CFR 63.7550(b)(4), 40 CFR 63.7550(b)(5))**

6. The permittee must include the following information in the compliance report. **(40 CFR 63.7550(a) & (c))**
  - a. If the facility is subject to the requirements of a tune up the permittee must submit a compliance report with the information in paragraphs (c)(5)(i) through (iii), (xiv), and (xvii) of 40 CFR 63.7550. **(40 CFR 63.7550(c)(1))**
  - b. 40 CFR 63.7550(c)(5) is as follows:
    - i. Company and Facility name and address. **(40 CFR 63.7550(c)(5)(i))**
    - ii. Process unit information, emissions limitations, and operating parameter limitations. **(40 CFR 63.7550(c)(5)(ii))**
    - iii. Date of report and beginning and ending dates of the reporting period. **(40 CFR 63.7550(c)(5)(iii))**
    - iv. Include the date of the most recent tune-up for each unit subject to only the requirement to conduct a 5-year tune-up according to 40 CFR 63.7540(a)(12), stated in SC IX.5.b. Include the date of the most recent burner inspection if it was not done on a 5-year period and was delayed until the next scheduled or unscheduled unit shutdown. **(40 CFR 63.7550(c)(5)(xiv))**
    - v. Statement by a responsible official with that official's name, title, and signature, certifying the truth, accuracy, and completeness of the content of the report. **(40 CFR 63.7550(c)(5)(xvii))**
7. The permittee must submit the reports according to the procedures specified in paragraph (h)(3) of 40 CFR 63.7550, as listed below. **(40 CFR 63.7550(h))**
  - a. The permittee must submit all reports required by Table 9 of 40 CFR Part 63, Subpart DDDDD electronically to the USEPA via the Compliance and Emissions Data Reporting Interface (CEDRI). (CEDRI can be accessed through the USEPA's CDX.) The permittee must use the appropriate electronic report in CEDRI for 40 CFR Part 63, Subpart DDDDD. Instead of using the electronic report in CEDRI for 40 CFR Part 63, Subpart DDDDD, the permittee may submit an alternate electronic file consistent with the XML schema listed on the CEDRI Web site (<http://www.epa.gov/ttn/chief/cedri/index.html>), once the XML schema is available. If the reporting form specific to 40 CFR Part 63, Subpart DDDDD is not available in CEDRI at the time that the report is due, the permittee must submit the report to the Administrator at the appropriate address listed in 40 CFR 63.13. The permittee must begin submitting reports via CEDRI no later than 90 days after the form becomes available in CEDRI. **(40 CFR 63.7550(h)(3))**
8. The permittee must report each instance in which the permittee did not meet each applicable operating limit in Tables 3 and 4 to 40 CFR Part 63, Subpart DDDDD. These instances are deviations from the operating limits, respectively, in 40 CFR Part 63, Subpart DDDDD. These deviations must be reported according to the requirements in Section 63.7550. **(40 CFR 63.7540(b))**

See Appendix 8

### **VIII. STACK/VENT RESTRICTION(S)**

NA

### **IX. OTHER REQUIREMENT(S)**

1. The permittee shall comply with the applicable requirements of 40 CFR Part 63, Subpart DDDDD - National Emission Standards for Hazardous Air Pollutants for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters. **(40 CFR Part 63, Subparts A and DDDDD)**
2. The permittee must be in compliance with the work practice standards (tune ups, energy assessment) in 40 CFR Part 63, Subpart DDDDD. **(40 CFR 63.7505(a))**
3. The permittee shall comply with the General Provisions in 40 CFR 63.1 through 40 CFR 63.15 apply to this source as indicated in Table 10 of 40 CFR Part 63, Subpart DDDDD. **(40 CFR 63.7565, Table 10)**

#### **Footnotes:**

<sup>1</sup>This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

<sup>2</sup>This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

## **FGPARTSCLEANERS FLEXIBLE GROUP CONDITIONS**

### **DESCRIPTION**

Any cold cleaner that is grandfathered or exempt from Rule 201 pursuant to Rule 278, 278a and Rule 281(2)(h) or Rule 285(2)(r)(iv). Existing cold cleaners were placed into operation prior to July 1, 1979. New cold cleaners were placed into operation on or after July 1, 1979.

**Emission Unit:** EUPARTSCLEANERS

### **POLLUTION CONTROL EQUIPMENT**

NA

### **I. EMISSION LIMIT(S)**

NA

### **II. MATERIAL LIMIT(S)**

1. The permittee shall not use cleaning solvents containing more than five % by weight of the following halogenated compounds: methylene chloride, perchloroethylene, trichloroethylene, 1,1,1-trichloroethane, carbon tetrachloride, chloroform, or any combination thereof. **(R 336.1213(2))**

### **III. PROCESS/OPERATIONAL RESTRICTION(S)**

1. Cleaned parts shall be drained for no less than 15 seconds or until dripping ceases. **(R 336.1611(2)(b), R 336.1707(3)(b))**
2. The permittee shall perform routine maintenance on each cold cleaner as recommended by the manufacturer. **(R 336.1213(3))**

### **IV. DESIGN/EQUIPMENT PARAMETER(S)**

1. The cold cleaner must meet one of the following design requirements:
  - a. The air/vapor interface of the cold cleaner is no more than ten square feet. **(R 336.1281(2)(h))**
  - b. The cold cleaner is used for cleaning metal parts and the emissions are released to the general in-plant environment. **(R 336.1285((2)(r)(iv))**
2. The cold cleaner shall be equipped with a device for draining cleaned parts. **(R 336.1611(2)(b), R 336.1707(3)(b))**
3. All new and existing cold cleaners shall be equipped with a cover and the cover shall be closed whenever parts are not being handled in the cold cleaner. **(R 336.1611(2)(a), R 336.1707(3)(a))**
4. The cover of a new cold cleaner shall be mechanically assisted if the Reid vapor pressure of the solvent is more than 0.3 psia or if the solvent is agitated or heated. **(R 336.1707(3)(a))**
5. If the Reid vapor pressure of any solvent used in a new cold cleaner is greater than 0.6 psia; or, if any solvent used in a new cold cleaner is heated above 120 degrees Fahrenheit, then the cold cleaner must comply with at least one of the following provisions:

- a. The cold cleaner must be designed such that the ratio of the freeboard height to the width of the cleaner is equal to or greater than 0.7. **(R 336.1707(2)(a))**
- b. The solvent bath must be covered with water if the solvent is insoluble and has a specific gravity of more than 1.0. **(R 336.1707(2)(b))**
- c. The cold cleaner must be controlled by a carbon adsorption system, condensation system, or other method of equivalent control approved by the AQD. **(R 336.1707(2)(c))**

## **V. TESTING/SAMPLING**

NA

## **VI. MONITORING/RECORDKEEPING**

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. For each new cold cleaner in which the solvent is heated, the solvent temperature shall be monitored and recorded at least once each calendar week during routine operating conditions. **(R 336.1213(3))**
2. The permittee shall maintain the following information on file for each cold cleaner: **(R 336.1213(3))**
  - a. A serial number, model number, or other unique identifier for each cold cleaner.
  - b. The date the unit was installed, manufactured or that it commenced operation.
  - c. The air/vapor interface area for any unit claimed to be exempt under Rule 281(2)(h).
  - d. The applicable Rule 201 exemption.
  - e. The Reid vapor pressure of each solvent used.
  - f. If applicable, the option chosen to comply with Rule 707(2).
3. The permittee shall maintain written operating procedures for each cold cleaner. These written procedures shall be posted in an accessible, conspicuous location near each cold cleaner. **(R 336.1611(3), R 336.1707(4))**
4. As noted in Rule 611(2)(c) and Rule 707(3)(c), if applicable, an initial demonstration that the waste solvent is a safety hazard shall be made prior to storage in non-closed containers. If the waste solvent is a safety hazard and is stored in non-closed containers, verification that the waste solvent is disposed of so that not more than 20%, by weight, is allowed to evaporate into the atmosphere shall be made on a monthly basis. **(R 336.1213(3), R 336.1611(2)(c), R 336.1707(3)(c))**

## **VII. REPORTING**

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

**See Appendix 8**

**VIII. STACK/VENT RESTRICTION(S)**

NA

**IX. OTHER REQUIREMENT(S)**

NA

## **E. NON-APPLICABLE REQUIREMENTS**

At the time of the ROP issuance, the AQD has determined that no non-applicable requirements have been identified for incorporation into the permit shield provision set forth in the General Conditions in Part A pursuant to Rule 213(6)(a)(ii).

## APPENDICES

### Appendix 1-A. Acronyms and Abbreviations

Common Acronyms		Pollutant / Measurement Abbreviations	
AQD	Air Quality Division	acfm	Actual cubic feet per minute
BACT	Best Available Control Technology	BTU	British Thermal Unit
CAA	Clean Air Act	°C	Degrees Celsius
CAM	Compliance Assurance Monitoring	CO	Carbon Monoxide
CEM	Continuous Emission Monitoring	CO <sub>2</sub> e	Carbon Dioxide Equivalent
CEMS	Continuous Emission Monitoring System	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
Department/ department	Michigan Department of Environment, Great Lakes, and Energy	gr	Grains
EGLE	Michigan Department of Environment, Great Lakes, and Energy	HAP	Hazardous Air Pollutant
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallons of Applied Coating Solids	HP	Horsepower
GC	General Condition	H <sub>2</sub> S	Hydrogen Sulfide
GHGs	Greenhouse Gases	kW	Kilowatt
HVLP	High Volume Low Pressure*	lb	Pound
ID	Identification	m	Meter
IRSL	Initial Risk Screening Level	mg	Milligram
ITSL	Initial Threshold Screening Level	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	NMOC	Non-methane Organic Compounds
MAP	Malfunction Abatement Plan	NO <sub>x</sub>	Oxides of Nitrogen
MSDS	Material Safety Data Sheet	ng	Nanogram
NA	Not Applicable	PM	Particulate Matter
NAAQS	National Ambient Air Quality Standards	PM10	Particulate Matter equal to or less than 10 microns in diameter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	%	Percent
PTI	Permit to Install	psia	Pounds per square inch absolute
RACT	Reasonable Available Control Technology	psig	Pounds per square inch gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO <sub>2</sub>	Sulfur Dioxide
SNCR	Selective Non-Catalytic Reduction	TAC	Toxic Air Contaminant
SRN	State Registration Number	Temp	Temperature
TEQ	Toxicity Equivalence Quotient	THC	Total Hydrocarbons
USEPA/EPA	United States Environmental Protection Agency	tpy	Tons per year
VE	Visible Emissions	µg	Microgram
		µm	Micrometer or Micron
		VOC	Volatile Organic Compounds
		yr	Year

\*For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.



## Appendix 1-B. Definitions Related to the Consent Agreement.

The following definitions apply to permit conditions originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action No. 14-13580, E.D. Mich., 2014.” This Appendix is also federally enforceable pursuant to Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, Rule 201(1)(a), and Rule 214a, and will remain in effect after termination of the consent decree. **(Act 451, Section 324.5503(b))**

- For the purposes of the Consent Decree, every term expressly defined by this Appendix shall have the meaning given that term herein. Every other term used in the Consent Decree that is also a term used under the Act or in a federal regulation implementing the Act shall mean in the Consent Decree what such term means under the Act or those regulations. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 4)**
- A "30-Day Rolling Average Emission Rate" for a Unit shall be expressed in lb/MMBTU and calculated in accordance with the following procedure: first, sum the total pounds of NO<sub>x</sub> or SO<sub>2</sub> emitted from the Unit during the current Unit Operating Day and the previous 29 Unit Operating Days; second, sum the total heat input to the Unit in MMBTU during the current Unit Operating Day and the previous 29 Unit Operating Days; and third, divide the total number of pounds of NO<sub>x</sub> or SO<sub>2</sub> emitted during the 30 Unit Operating Days by the total heat input during the 30 Unit Operating Days. A new 30-Day Rolling Average Emission Rate shall be calculated for each new Unit Operating Day. Each 30-Day Rolling Average Emission Rate shall include all emissions that occur during all periods within any Unit Operating Day, including emissions from startup, shutdown, and malfunction. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 5)**
- A "90-Day Rolling Average Emission Rate" for a Unit shall be expressed in lb/MMBTU and calculated in accordance with the following procedure: first, sum the total pounds of NO<sub>x</sub> or SO<sub>2</sub> emitted from the Unit during the current Unit Operating Day and the previous 89 Unit Operating Days; second, sum the total heat input to the Unit in MMBTU during the current Unit Operating Day and the previous 89 Unit Operating Days; and third, divide the total number of pounds of NO<sub>x</sub> or SO<sub>2</sub> emitted during the 90 Unit Operating Days by the total heat input during the 90 Unit Operating Days. A new 90-Day Rolling Average Emission Rate shall be calculated for each new Unit Operating Day. Each 90-Day Rolling Average Emission Rate shall include all emissions that occur during all periods within any Unit Operating Day, including emissions from startup, shutdown, and malfunction. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 6)**
- A "365-Day Rolling Average Emission Rate" for a Unit shall be expressed in lb/MMBTU and calculated in accordance with the following procedure: first, sum the pounds of the pollutant in question emitted from the Unit during the most recent Unit Operating Day and the previous 364 Unit Operating Days; second, sum the total heat input to the Unit in MMBTU during the most recent Unit Operating Day and the previous 364 Unit Operating Days; and third, divide the total number of pounds of the pollutant emitted during the 365 Unit Operating Days by the total heat input during the 365 Unit Operating Days. A new 365-Day Rolling Average Emission Rate shall be calculated for each new Unit Operating Day. Each 365-Day Rolling Average Emission Rate shall include all emissions that occur during all periods of operation, including startup, shutdown, and malfunction. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 7)**
- "Baghouse" means a full stream (fabric filter or membrane) particulate emissions control device. Full stream is defined as capturing the entire stream of exhaust gas with no concurrent by-pass. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 8)**
- "Campbell" means Consumers' J.H. Campbell Generating Plant consisting of three electric utility steam-generating units designated as Unit 1 (260 MW), Unit 2 (360 MW), and Unit 3 (835 MW) and related equipment, located in West Olive, Ottawa County, Michigan. Campbell Unit 3 is co-owned by Consumers (approximately 93%) along with Wolverine Power Supply Cooperative and the Michigan Public Power Association. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 10)**
- "CEMS" or "Continuous Emission Monitoring System," means, for obligations involving the monitoring of NO<sub>x</sub> and SO<sub>2</sub> emissions under the Consent Decree, the devices defined in 40 CFR 72.2 and installed and

maintained as required by 40 CFR Part 75. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 12**)

- "Clean Air Act" or "CAA" or "Act" means the federal Clean Air Act, 42 U.S.C. §§ 7401-7671q, and its implementing regulations. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 13**)
- "Cobb" means, for purposes of the Consent Decree, Consumers' B.C. Cobb Generating Plant consisting of two electric utility steam-generating units designated as Unit 4 (160 MW) and Unit 5 (160 MW) and related equipment, located in Muskegon, Muskegon County, Michigan. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 14**)
- "Consent Decree" means Consent Decree (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014”**) and its Appendices. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 15**)
- "Consumers" means Consumers Energy Company. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 16**)
- "Consumers System" means the Campbell, Cobb, Karn, Weadock, and Whiting facilities as defined herein. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 17**)
- "Continuously Operate" or "Continuous Operation" means that when a pollution control technology or combustion control is required to be used at a Unit pursuant to the Consent Decree (including, but not limited to, SCR, FGD, DSI, ESP, Baghouse, or Low NOx Combustion System), it shall be operated at all times that the Unit it serves is in operation, except the SCRs on Campbell Units 2 and 3 need not be operated during scheduled maintenance on the applicable Unit's Urea Based Ammonia System and consistent with the technological limitations, manufacturers' specifications, good engineering and maintenance practices (including Campbell Unit 2 and Unit 3 scheduled Urea Based Ammonia System outages), and good air pollution control practices for minimizing emissions (as defined in 40 CFR 60.11(d)), as applicable, for such equipment and the Unit. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 18**)
- "Date of Entry" means the date the Consent Decree was signed by the United States District Court Judge (i.e. November 4, 2014). (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 19**)
- "Day" means calendar day unless otherwise specified in the Consent Decree. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 21**)
- "Dry Sorbent Injection" or "DSI" means a process in which a sorbent is pneumatically injected into the ducting downstream of where the coal is combusted and flue gas is produced, and upstream of the PM Control Device. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 22**)
- "Electrostatic Precipitator" or "ESP" means a device for removing particulate matter from combustion gases by imparting an electric charge to the particles and then attracting them to a metal plate or screen of opposite charge before the combustion gases are exhausted to the atmosphere. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 23**)
- "Emission Rate" for a given pollutant means the number of pounds of that pollutant emitted per million British Thermal Units of heat input (lb/MMBTU), calculated in accordance with each applicable 30, 90 or 365-Day Rolling Average Emission Rate definition. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 24**)
- "Flue Gas Desulfurization System" or "FGD" means a pollution control device that employs flue gas desulfurization technology, including an absorber or absorbers utilizing lime or limestone, or a sodium based material, for the reduction of SO<sub>2</sub> emissions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 27**)
- "Fossil Fuel" means any hydrocarbon fuel, including coal, petroleum coke, petroleum oil, or natural gas. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 29**)
- "Full Stream Operation" is defined as the design configuration of a control device such that it captures the

entire stream of exhaust gas with no concurrent by-pass. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 30**)

- "Karn," for purposes of the Consent Decree, means Consumers' D.E. Karn Generating Plant consisting of two electric utility steam-generating units designated as Unit 1 (255 MW) and Unit 2 (260 MW) and related equipment, located in Essexville, Bay County, Michigan. Karn does not include the oil-fired electricity generating units designated as Karn Units 3 and 4, also located in Essexville, Bay County, Michigan. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 34**)
- "Karn Units 3 and 4" means Consumers' oil-fired Units 3 and 4, in Essexville, Bay County, Michigan. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 35**)
- "KW" means Kilowatt or one thousand watts net. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 36**)
- "lb/MMBTU" means one pound per million British Thermal Units. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 37**)
- "Low NO<sub>x</sub> Combustion System" means burners and associated combustion air control equipment, including Over Fire Air if specified, which control mixing characteristics of Fossil Fuel and oxygen, thus restraining the formation of NO<sub>x</sub> during combustion of fuel in the boiler. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 38**)
- "Malfunction" means a failure to operate in a normal or usual manner by any air pollution control equipment, process equipment, or a process, which is sudden, infrequent, and not reasonably preventable. Failures that are caused in part by poor maintenance or careless operation are not malfunctions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 39**)
- "Michigan SIP" means the Michigan State Implementation Plan, and any amendments thereto, as approved by USEPA pursuant to Section 110 of the Act, 42 U.S.C. § 7410. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 40**)
- "MW" means a megawatt or one million watts net. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 41**)
- "NO<sub>x</sub>" means oxides of nitrogen, measured in accordance with the provisions of the Consent Decree. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 45**)
- "NO<sub>x</sub> Allowance" means an authorization to emit a specified amount of NO<sub>x</sub> that is allocated or issued under an emissions trading or marketable permit program of any kind established under the Clean Air Act or the Michigan SIP; provided, however, that with respect to any such program that first applies to emissions occurring after December 31, 2011, a "NO<sub>x</sub> Allowance" shall include an allowance created and allocated to a Consumers System Unit under such program only for control periods starting on or after November 4, 2018. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 46**)
- "Operating Day" means any calendar day on which a Unit fires Fossil Fuel. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 49**)
- "Over Fire Air" or "OFA" mean an in-furnace staged combustion control to reduce NO<sub>x</sub> emissions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 51**)
- "PM" means total filterable particulate matter, measured in accordance with the provisions of the Consent Decree. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 53**)
- "PM Continuous Emission Monitoring System" or "PM CEMS" means, for obligations involving the monitoring of PM emissions under the Consent Decree, the equipment that samples, analyzes, measures, and provides, by readings taken at frequent intervals, an electronic and/or paper record of PM emissions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 54**)
- "PM Control Device" means any device, including an ESP or Baghouse, which reduces emissions of PM. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 55**)
- "PM Emission Rate" means the number of pounds of PM emitted per million BTU of heat input (lb/MMBTU). (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 56**)

- "Selective Catalytic Reduction" or "SCR" means an air pollution control device for reducing NO<sub>x</sub> emissions in which ammonia ("NH<sub>3</sub>") is added to the flue gas and then passed through layers of a catalyst material. The ammonia and NO<sub>x</sub> in the flue gas stream react on the surface of the catalyst, forming nitrogen ("N<sub>2</sub>") and water vapor. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 61**)
- "SO<sub>2</sub>" means sulfur dioxide, measured in accordance with the provisions of the Consent Decree. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 62**)
- "SO<sub>2</sub> Allowance" means an authorization to emit a specified amount of SO<sub>2</sub> that is allocated or issued under an emissions trading or marketable permit program of any kind established under the Clean Air Act or the Michigan SIP; provided, however, that with respect to any such program that first applies to emissions occurring after December 31, 2011, an "SO<sub>2</sub> Allowance" shall include an allowance created and allocated to a Consumers System Unit under such program only for control periods starting on or after November 4, 2018. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 63**)
- "State" means the State of Michigan. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 64**)
- "State Implementation Plan" or "SIP" means regulations and other materials promulgated by a state for purposes of meeting the requirements of the Act that have been approved by USEPA pursuant to Section 110 of the Act, 42 U.S.C. § 7410. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 65**)
- "Surrender" or "Surrender of Allowances" means, for purposes of SO<sub>2</sub> or NO<sub>x</sub> allowances, permanently surrendering allowances from the accounts administered by USEPA and Michigan for all Units in the Consumers System, so that such allowances can never be used thereafter to meet any compliance requirements under the Act, a SIP, or the Consent Decree. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 66**)
- "System-Wide Annual NO<sub>x</sub> Tonnage Limitation" means the limitations, as specified in the Consent Decree, on the number of tons of NO<sub>x</sub> that may be emitted from Campbell, Cobb, Kam, Weadock, and Whiting, collectively, during the relevant calendar year (i.e., January 1 through December 31), and shall include all emissions of NO<sub>x</sub> during all periods of operations, including startup, shutdown, and malfunction. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 67**)
- "System-Wide Annual SO<sub>2</sub> Tonnage Limitation" means the limitations, as specified in the Consent Decree, on the number of tons of SO<sub>2</sub> that may be emitted from Campbell, Cobb, Kam, Weadock, and Whiting, collectively, during the relevant calendar year (i.e., January 1 through December 31), and shall include all emissions of SO<sub>2</sub> during all periods of operations, including startup, shutdown, and malfunction. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 68**)
- "Title V Permit" means the permit required of Consumers' major sources pursuant to Subchapter V of the Act, 42 U.S.C. §§ 7661-7661e. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 69**)
- "Unit" means collectively, the coal pulverizer, stationary equipment that feeds coal to the boiler, the boiler that produces steam for the steam turbine, the steam turbine, the generator, the equipment necessary to operate the generator, steam turbine, and boiler, and all ancillary equipment, including pollution control equipment and systems necessary for production of electricity. An electric steam generating station may comprise one or more Units. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 70**)
- "Urea Based Ammonia System" or "UBAS" means a type of ammonia feed system for SCRs where solid urea pellets are stored in a silo. Upon use, the solid urea is heated to liquid, thermally decomposed to ammonia, and injected into the SCR as the reagent for the NO<sub>x</sub> reduction reaction. (**"U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" paragraph 71**)
- "Weadock" means, for purposes of the Consent Decree, Consumers' J.C. Weadock Generating Plant consisting of two electric utility steam-generating Units designated as Unit 7 (155 MW) and Unit 8 (155 MW) and related equipment, located in Essexville, Bay County, Michigan. (**"U.S. v Consumers Energy**

**Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 72)**

- "Whiting" means, for purposes of the Consent Decree, Consumers' Whiting Generation Station consisting of three electric utility steam-generating Units designated as Unit 1 (102 MW), Unit 2 (102 MW), and Unit 3 (124 MW) and related equipment, located in Luna Pier, Monroe County, Michigan. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 73)**)

**Appendix 2. Schedule of Compliance**

The permittee certified in the ROP application that this stationary source is in compliance with all applicable requirements and the permittee shall continue to comply with all terms and conditions of this ROP. A Schedule of Compliance is not required. (**R 336.1213(4)(a), R 336.1119(a)(ii)**)

**Appendix 3. Monitoring Requirements**

**Appendix 3-A. Continuous Opacity Monitoring Systems**

(This section applies to each boiler.)

The Continuous Opacity Monitoring System (COMS) performance specifications defined in 40 CFR Part 60, Appendix B, are adopted.

Cycling time for opacity: complete a minimum of one cycle of sampling/analysis for each successive 10-second period and one cycle of data recording for each successive 6-minute period. (**R 336.2152**)

Zero and Drift: The COMS must be subject to the manufacturer's zero and span check at least once daily. (**R 336.2153**)

Location: The location of the COMS or the monitoring devices must be such that representative measurement of emissions or process parameters are obtained. (**R 336.2155**)

Alternative Systems: AQD may approve the use of an alternative monitoring system if one is available that meets COMS objectives and if, because of physical limitations or other reasons, COMS cannot be installed or give accurate measurements. (**R 336.2159**)

Monitoring and reporting requirements shall not apply during any period of monitoring system malfunction if it can be demonstrated to the satisfaction of AQD that: the cause of the malfunction could not have been avoided by any reasonable action and necessary repairs are being made as expeditiously as practicable. (**R 336.2190**)

**Appendix 3-B. Continuous Emissions Monitoring System (Title IV; Gas Flow, SO<sub>2</sub>, CO<sub>2</sub>, NO<sub>x</sub>)**

(This section applies to each boiler.)

The CEMS performance specifications defined in 40 CFR Part 75, Appendix B, are adopted.

Methods of measurement, frequency of measurement and recordkeeping methods for CEMS required under 40 CFR 75 are outlined in the most recent version of the Acid Rain Program - J. H. Campbell Plant Monitoring Plan, originally dated July 19, 1993.

Data Reporting: the AQD may approve alternative data reporting or reduction procedures if it can be demonstrated that such procedures are at least as accurate as the procedures identified in R 336.2175.

### **Appendix 3-C. Fuel Oil Sulfur Monitoring**

Maintain a complete record of fuel oil specifications and/or a fuel analysis for each delivery, or storage tank, of fuel oil. These records may include purchase records for ASTM specification fuel oil, specifications or analyses provided by the vendor at the time of delivery, analytical results from laboratory testing, or any other records adequate to demonstrate compliance with the percent sulfur limit in fuel oil.

### **Appendix 3-D. Continuous Emission Monitoring Systems (SO<sub>2</sub>/CO<sub>2</sub>)**

(This section applies to Units 1 and 2.)

The Continuous Emissions Monitoring Systems (CEMS) performance specifications defined in 40 CFR Part 75, Appendix B, are adopted. The Certified SO<sub>2</sub> and CO<sub>2</sub> monitors will be used to determine sulfur dioxide emissions. The data reduction procedures defined in R 336.2175 will be used to determine SO<sub>2</sub> lbs/MMBTU. On the last day of each calendar month, the CEMS data recording system will generate and record an “operating monthly average” as the average of the previous 31 operating days.

### **Appendix 3-E. PM CEMS**

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). This Appendix was originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. **(Act 451, Section 324.5503(b))**

- Consumers shall install, correlate, maintain, and operate a PM CEMS on Campbell Unit 3 as specified below. The PM CEMS shall comprise a continuous particle mass monitor measuring particulate matter concentration, directly or indirectly, on an hourly average basis and a diluent monitor used to convert the concentration to units expressed in lb/MMBTU. The PM CEMS installed must be appropriate for the anticipated stack conditions and capable of measuring PM concentrations on an hourly average basis. Consumers shall maintain, in an electronic database, the hourly average emission values of the PM CEMS in lb/MMBTU. Except for periods of monitor malfunction, maintenance, calibration, or repair, Consumers shall continuously operate the PM CEMS at all times when the Unit it serves is operating. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 159)**
- In developing both the plan for installation and correlation of the PM CEMS and the QA/QC protocol, Consumers shall use the criteria set forth in 40 CFR Part 60, Appendix B, Performance Specification 11, and Appendix F, Procedure 2. Following USEPA's approval of the plan described in Paragraph 160 of the Consent Decree and the QA/QC protocol described in Paragraph 161 of the Consent Decree, Consumers shall thereafter operate the PM CEMS in accordance with the approved plan and QA/QC protocol. Notwithstanding any other provision of the Consent Decree, exceedances of the PM Emission Rate that occur as a result of de-optimizing emission controls and/or spiking the exhaust gas with excess particulate required to achieve the high level PM test runs during the correlation testing shall not be a violation of the requirements of the Consent Decree (or credible evidence thereof); provided, however, that Consumers shall make best efforts to keep the high level PM test runs during such correlation testing below the applicable PM Emission Rate. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 162)**
- Consumers shall, correlate, maintain, and commence Continuous Operation of the PM CEMS approved by EGLE at Campbell Unit 3, conduct performance specification tests on the PM CEMS, and demonstrate compliance with the PM CEMS installation and correlation plans submitted to and approved by EGLE. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 163)**
- Except as approved pursuant to Paragraph 157 of the Consent Decree, stack testing shall be used to determine compliance with the PM Emission Rates established by the Consent Decree. Data from PM

CEMS shall be used, at a minimum, to provide information to operators on PM emissions rate trends on a continuous basis. (“**U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014**” paragraph 164)

- The data recorded by the PM CEMS shall be expressed in lb/MMBTU on a rolling average 3-hour basis to identify any PM emission rates in excess of the applicable PM Emission Rate and shall be available in electronic format. (**U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014**” paragraph 163)

### **Appendix 3-F. Optimization of Baghouses**

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). This Appendix was originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. (**Act 451, Section 324.5503(b)**)

Consumers shall:

- a) At a minimum, to the extent practicable: (i) operate each compartment of the Baghouse as designed for Full Stream Operation for each Unit, where applicable (regardless of whether those actions are needed to comply with opacity limits); (ii) maintain and replace bags on each Baghouse as needed to maximize collection efficiency, where applicable; and
- b) During the next planned Unit outage (or unplanned outage of sufficient length), optimize the PM controls on that Unit by inspecting for and repairing any failed Baghouse compartment.

The above requirements are found in “**U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014**” paragraph 141.

### **Appendix 4. Recordkeeping**

Specific recordkeeping requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

### **Appendix 5. Testing Procedures**

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). This Appendix was originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. (**Act 451, Section 324.5503(b)**)

Specific testing requirement plans, procedures and averaging times are detailed in the appropriate Requirement Tables. Moreover, the permittee shall use the following approved test plans, procedures and averaging times to measure the pollutant emissions for the applicable requirements referenced in Table EUBOILER3 (see below). Alternative test plans, procedures, or averaging must be approved by the AQD District Supervisor.

#### **Test Methods and Procedures for Boiler #3**

In conducting the performance test as required in 40 CFR 60.8, the owner or operator shall use the reference methods, procedures and test methods in 40 CFR Part 60, Appendix A or other methods and procedures specified in Section 60.46(d), except as provided in Section 60.8(b).

1. Particulate Matter: Method 17 at a facility without wet flue gas desulfurization system and Method 5B shall be used after flue gas desulfurization system. Method 5 and MATS method 5 shall also be used.
2. Opacity: Method 9.

3. SO<sub>2</sub>: Method 6C shall be in the same sample site selected for particulate sample. The emission rate correction factor, integrated sampling and analysis procedure of Method 3A shall be used to determine the O<sub>2</sub> or CO<sub>2</sub> concentration, and shall be taken simultaneously and in the same point as the SO<sub>2</sub> sample.
2. NO<sub>x</sub>: Method 7E shall be in the same sample site selected for particulate sample. The emission rate correction factor, integrated sampling and analysis procedure of Method 3A shall be used to determine the O<sub>2</sub> or CO<sub>2</sub> concentration, and shall be taken simultaneously and in the same point as the NO<sub>x</sub> sample.

### **PM Emissions Testing and Monitoring Requirements**

- Annually unless a Unit is Retired or Refueled to Natural Gas, Consumers shall conduct a stack test for PM pursuant to Paragraph 154 of the Consent Decree. The annual performance test requirement imposed on Consumers by this paragraph may be satisfied by stack tests conducted by Consumers as may be required by other conditions in its ROP for any year that such stack tests are required. Consumers may perform testing every other year, rather than every year, provided that two of the most recently completed test results from tests conducted in accordance with the methods and procedures specified above demonstrate that the PM emissions are equal to or less than 0.010 lb/MMBTU. Consumers shall perform testing every year, rather than every other year, beginning in the year immediately following any test result demonstrating that the PM emissions are greater than 0.010 lb/MMBTU.. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 153**)
- To determine compliance with the PM Emission Rate established in Subsections VI.B (Unit-Specific PM Requirements at Campbell Units 1 and 2), Consumers shall use the applicable reference methods and procedures (filterable portion only) specified in its ROP and the Michigan SIP for Campbell Units 1 and 2. Each test shall consist of three separate runs performed under representative operating conditions not including periods of startup, shutdown, or malfunction. The sampling time for each run associated with a Unit controlled by a Baghouse shall be at least 120 minutes and the volume of each run shall be at least 1.70 dry standard cubic meters (60 dry standard cubic feet). Consumers shall calculate the PM Emission Rate from the stack test results in accordance with 40 CFR 60.8(f). The results of each PM stack test shall be submitted to EGLE within 60 Days of completion of each test. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 154**)
- As an alternative to the PM testing required in this Appendix (PM Emissions Testing and Monitoring Requirements; beginning at paragraph 153) of the Consent Decree, following the installation and operation of PM CEMS as required by Appendix 3-E (PM CEMS), Consumers, at its sole discretion, may seek USEPA approval pursuant to Section XIII (Review and Approval of Submittals; beginning at paragraph 193) of the Consent Decree to forego stack testing and instead demonstrate continuous compliance with an applicable filterable PM Emission Rate by using the PM CEMS data on a 3-hour rolling average basis. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 157**)

*Note: JHC EUBOILER3 was approved by USEPA to use the PM CEMS alternative to testing per letter dated January 20, 2020 and mailed on February 3, 2020 this PM CEMS approval letter is available upon request.*

### **Appendix 6. Permits to Install**

The following table lists any PTIs issued or ROP revision applications received since the effective date of the previously issued ROP No. MI-ROP-B2835-2013. Those ROP revision applications that are being issued concurrently with this ROP renewal are identified by an asterisk (\*). Those revision applications not listed with an asterisk were processed prior to this renewal.

Source-Wide PTI No MI-PTI-B2835-2013 is being reissued as Source-Wide PTI No. MI-PTI-B2835-2020b.



Permit to Install Number	ROP Revision Application Number	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
142-12	201500412	PTI No. 141-12 incorporated EUCATDIESEL12.	EUCATDIESEL12
18-15	201500412	Incorporated USEPA Consent Decree conditions and to bridge the conditions with PTI No. 39-15. It also incorporated updates to control equipment that had been installed.	EUBYPRODUCT EUACIU123 EUDSI_U12 UESDA_U3
39-15	201500061	Incorporated Conditions of the USEPA Consent Decree that states: "The following must be included in the permit: a schedule for all unit-specific, plant-specific, and system-specific performance, operational, maintenance, and control technology requirements established by this Consent Decree including, but not limited to, any (a) 30-Day, 90-Day and 365-Day Rolling Average Emission Rates, (b) System-Wide Annual NOx and SO2 Tonnage Limitations, (c) the requirements pertaining to the Surrender of NOx and SO2 Allowances, (d) PM Emission Rate and annual stack test requirements, and (e) PM CEMS monitoring requirements."	EUBOILER1 EUBOILER2 EUBOILER3 Appendices 1, 3, 5, 7, and 10
18-15A	201800102*	Ash and byproduct handling system that transports ash and byproduct from the plant to the disposal silos. Unit 3 System: <ul style="list-style-type: none"> <li>• 2 Transfer tanks each with a built in filter separator</li> <li>• 5 Vacuum Exhausters – exhaust to the Unit 3 PJFF Inlet</li> </ul> Unit 1 and 2 System: <ul style="list-style-type: none"> <li>• 2 Transfer tanks each with a built in filter separator</li> <li>• 3 Vacuum Exhausters – normally discharge to the Unit 1 PJFF inlet except for times when the Unit 1 PJFF is unavailable</li> </ul> Common: <ul style="list-style-type: none"> <li>• 3 Disposal Silos (A, B &amp; C)</li> <li>• Truck loading</li> </ul>	EUBYPRODUCT

The following table lists the ROP amendments or modifications issued after the effective date of ROP No. MI-ROP-B2835-2020.

Permit to Install Number	ROP Revision Application Number - Issuance Date	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
50-20	202000099 / September 3, 2020	Incorporate PTI 50-20 into the ROP, which was to correct emission limits for the water pump EUWPDIESEL. The change was due to an incorrect emission limit cited from 40 CFR Part 60 Subpart IIII in the previous permit but the correct emission limit was	EUWPDIESEL EUTRNCNTRDIESEL FGNEWICIRICE

Permit to Install Number	ROP Revision Application Number - Issuance Date	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
		<p>used in the permit review. This correction was considered administrative and not subject to New Source Review during permitting.</p> <p>Additionally, the company identified two other errors in their ROP. The errors were related to the other engine in the flexible group, EUTRNCNTRDIESEL, which was not originally permitted through a PTI but was grouped with the fire pump engine EUWPDIESEL in the ROP. These errors were related to what federal subpart was/was not applicable to that engine. It appears that EUTRNCNTRDIESEL was accidentally included in FGNEWCIRICE Special Condition III. 1 at same time that EUTRNCNTRDIESEL was accidentally excluded from FGNEWCIRICE Special Condition III. 2. These emission units were corrected in FGNEWCIRICE. PTI 50-20 was not required to go through the public participation process.</p>	
39-15A	202100070 / July 1, 2021	<p>Incorporate PTI No. 39-15A into the ROP, which was for administrative updates to permitted conditions to reflect the termination of a Consent Decree between the USEPA and Consumers Energy. PTI No. 39-15A previously allowed Boiler #1 and #2 to have individual stacks or meet certain requirements if using a shared stack. The option and associated requirements for having a shared stack are also removed during this minor modification.</p> <p>It should be noted that PTI No. 39-15A had some errors that were corrected during this Modification. During the last ROP Renewal, the Company requested that the conditions common to boilers 1 and 2 housed in FGBOILER12 be separated and put into their respective boiler emission unit. This was done with the exception of all of the CAM requirements being kept in FGBOILERS12. Additionally, a separate FGMATSU12 table was created to house all of the common MATS requirements for the boilers. All requirements for EDTA and citrosolve have been removed as the units no longer burn any waste. The Conditions related to FGBOILER12 were accidentally added back into PTI No. 39-15A as well in</p>	<p>EUBOILER1,          EUBOILER2          EUBOILER3,          EUBYPRODUCT,          FGBOILER12          Appendices 1-B, 3, 5</p>

Permit to Install Number	ROP Revision Application Number - Issuance Date	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
		<p>the associated Emission Units, so the Conditions were duplicative. AQD removed the duplicative and obsolete Conditions that were present in PTI No. 39-15A during this minor modification.</p> <p>During the Company's review, the Company requested to clarify in Appendix 3-E. PM CEMS, PM specification tests will be sent in the future to EGLE. This change would also allow updates to the installation and correlation plans to be submitted to and approved by EGLE.</p>	

## Appendix 7. Emission Calculations

### Determination of Unit Specific NO<sub>x</sub> or SO<sub>2</sub> Mass Emissions for Those Units Where 40 CFR Part 75 NO<sub>x</sub> or SO<sub>2</sub> Mass Emissions Are Measured at a Common Stack

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). This Appendix was originally established in the consent decree settling, "U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014" and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. **(Act 451, Section 324.5503(b))**

For J.H. Campbell Units 1 and 2, NO<sub>x</sub> mass emission rates are monitored at the associated common stacks via the use of NO<sub>x</sub> concentration and flow CEMS. In addition, each of the preceding individual units are equipped with duct-level NO<sub>x</sub> and diluent (i.e., CO<sub>2</sub>) concentration CEMS to permit the determination of unit specific NO<sub>x</sub> lb/MMBTU emission rates. The following procedures shall be used to calculate unit level NO<sub>x</sub> mass emission rates for purposes of conducting rolling average NO<sub>x</sub> lb/MMBTU calculations. If Campbell Units EUBOILER1 and EUBOILER2 elect to install unit level SO<sub>2</sub> CEMS only in lieu of installing both unit level SO<sub>2</sub> CEMS and Flow CEMS, the same procedure shall be followed for calculating unit level SO<sub>2</sub> mass emissions except that the value of K in Paragraph c. shall equal 1.660 x 10<sup>-7</sup> (lb/scf)/ppm.

- a. From 40 CFR Part 75, Appendix F, equation F-15 (already calculated and reported under Part 75), common stack heat input shall be calculated as follows:

$$HI = Q_w \times \frac{1}{F_c} \times \frac{\%CO_{2w}}{100}$$

Where,

- HI* = Common stack hourly heat input rate during unit operation, MMBTU/hr  
*Q<sub>w</sub>* = Hourly average volumetric flow rate during unit operation, wet basis, scfh  
*F<sub>c</sub>* = Carbon-based F-factor, listed in 40 CFR 75, Appendix A, Section 3.3.5 for each fuel, scf/MMBTU  
 % CO<sub>2w</sub> = Hourly concentration of CO<sub>2</sub> during unit operation, percent CO<sub>2</sub>

- b. From 40 CFR Part 75, Appendix F, Equation F-21a (already calculated and reported under Part 75), individual unit heat input shall be calculated as follows:

$$HI_i = HI_{CS} \times \frac{T_{CS}}{t_i} \times \left[ \frac{MW_i \times t_i}{\sum_{i=1}^n MW_i \times t_i} \right]$$

Where,

- $HI_i$  = Heat input rate for a unit, MMBTU/hr  
 $HI_{CS}$  = Heat input rate at the common stack, MMBTU/hr  
 $MW_i$  = Gross electrical output, MWe  
 $t_c$  = Unit operating time, hour or fraction of an hour  
 $t_{CS}$  = Common stack or common pipe operating time, hour or fraction of an hour  
 $n$  = Total number of units using the common stack  
 $i$  = Designation of a particular unit

- c. From 40 CFR Part 75, Appendix F, Equation F-6 (already calculated and reported under Part 75), individual unit NO<sub>x</sub> lb/MMBTU emission rates shall be calculated as follows:

$$E = K \times C_h \times F_c \times \frac{100}{\%CO_2}$$

Where,

- $E$  = Pollutant emission rate during unit operation, lb/MMBTU  
 $K$  =  $1.194 \times 10^{-7}$  for NO<sub>x</sub> (lb/scj)/ppm  
 $C_h$  = Hourly average NO<sub>x</sub> concentration during unit operation, ppm  
 $F_c$  = Carbon-based F-factor, listed in 40 CFR 75, Appendix A, Section 3.3.5 for each fuel, scf/MMBTU  
 $\%CO_2$  = Hourly concentration of CO<sub>2</sub> during unit operation, percent CO<sub>2</sub>

- d. To calculate unit level NO<sub>x</sub> mass emissions in each operating hour (not calculated or reported under Part 75), the following calculation shall be performed:

$$E_{(NO_x)h} = E \times HI_i$$

Where,

- $E_{(NO_x)h}$  = NO<sub>x</sub> mass emission rate for hour "h", in lbs/hr  
 $E$  = Pollutant emission rate during unit operation, lb/MMBTU  
 $HI_i$  = Heat input rate for a unit, MMBTU/hr

$$M_{(NO_x)h} = E_{(NO_x)h} \times t_h$$

Where,

- $M_{(NO_x)h}$  = NO<sub>x</sub> mass emissions for hour "h", lbs  
 $E_{(NO_x)h}$  = NO<sub>x</sub> mass emission rate for hour "h", in lbs/hr  
 $t_h$  = Unit operating time for hour "h", in hours or fraction of an hour

- e. The preceding unit specific NO<sub>x</sub> mass emissions data shall then be used in accordance with Paragraphs 5, 6, and 7 of the CD (refer to Appendix 1-B) to calculate 30-day rolling, 90-day rolling and 365-day rolling NO<sub>x</sub> lb/MMBTU emission rates, respectively (as applicable).

## Appendix 8. Reporting

### A. Annual, Semiannual, and Deviation Certification Reporting

The permittee shall use the EGLE, AQD, Report Certification form (EQP 5736) and EGLE, AQD, Deviation Report form (EQP 5737) for the annual, semiannual and deviation certification reporting referenced in the Reporting Section of the Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Alternative formats must meet the provisions of Rule 213(4)(c) and Rule 213(3)(c)(i), respectively, and be approved by the AQD District Supervisor.

### B. Other Reporting

The permittee shall use the following approved formats and procedures for the reporting requirements referenced in. EUBOILER3, EUCOALHAND, FGMATS\_U12, and FGMATS\_U3. For other reporting requirements, specific reporting requirement formats and procedures are detailed in Part A or the appropriate Requirement Tables. Alternative formats must be approved by the AQD District Supervisor.

Standards of Performance for New Sources (NSPS) reporting requirements for EUBOILER3 and EUCOALHAND include, but are not necessarily limited to, the following:

#### Notification requirements per Section 60.7 of 40 CFR Part 60, Subpart A;

- 60.7(a)(1) Notification of the date of construction or reconstruction of an affected facility is commenced, postmarked no later than 30 days after such date.
- 60.7(a)(2) Notification of the date or anticipated date of the initial startup of an affected facility, postmarked not more than 60 nor less than 30 days prior to such date.
- 60.7(a)(3) Notification of the actual date of initial startup of an affected facility, postmarked within 15 days after such date.
- 60.7(a)(4) Notification of any physical or operational change to an existing facility which may increase the emission rate of any air pollutant to which a standard applies, unless that change is specifically exempted under an applicable subpart or in Section 60.14(e). This notice shall be postmarked 60 days (or as soon as practicable) before the change is commenced.

#### Notifications of reconstruction activities per Section 60.15 of 40 CFR, Part 60, Subpart A; and

- 60.15(d) If an owner or operator of an existing facility proposes to replace components and the fixed capital cost of the new components exceeds 50% of the fixed capital cost that would be required to construct a comparable entirely new facility, notification of the proposed replacements, postmarked 60 days (or as soon as practicable) before the construction of the replacements is commenced.

#### Reporting requirements per 40 CFR Part 60, Subpart D.

Excess emission (EE) reports and monitoring system performance (MSP) reports shall be submitted every quarter. All quarterly reports shall be postmarked by the 30th day following the end of each calendar quarter. Each EE and MSP report shall include the information required in Section 60.7(c). Periods of excess emission and monitoring system downtime that shall be reported are defined as followed:

1. Opacity: EE are defined as any 6-minute period during which the average opacity of emissions exceeds 20% opacity, except that one 6-minute average per hour of up to 27% need not be reported.
2. SO<sub>2</sub>: EE are defined as any 3-hour period during which the average emissions (arithmetic average of 3 contiguous one-hour periods) of SO<sub>2</sub> as measured by a CEMS exceeded the applicable standard under Section 60.43, per Section 60.45(g)(2).

3. NO<sub>x</sub>: EE are defined as any 3-hour period during which the average emissions (arithmetic average of 3 contiguous one-hour periods) of NO<sub>x</sub> as measured by a CEMS exceeded the applicable standard under Section 60.44, Section 60.45(g)(3).

**Appendix 9. Acid Rain Permit**

**PHASE II ACID RAIN PERMIT  
Permit No. MI-AR-1710-2020**

Permittee	Consumers Energy – J.H. Campbell Plant
Address	17000 Croswell, West Olive, MI
SRN	B2835
ORIS Code	1710
Issue Date	February 4, 2020
Effective	Issuance date of this facility’s Renewable Operating Permit at the facility in accordance with 40 CFR 72.73.
Expiration	This permit shall expire when the facility’s Renewable Operating Permit expires, in accordance with 40 CFR 72.73.
ROP No.	MI-ROP-B2835-2020

**The Acid Rain Permit Contents**

1. A statement of basis prepared by the Air Quality Division (AQD) containing:  
  
References to statutory and regulatory authorities, and with comments, notes, and justification that apply to the source in general;
2. Terms and conditions including:  
  
A table of sulfur dioxide allowances to be allocated during the term of the permit, if applicable, authorized by this permit during Phase II. Unless they are subject to Sections 405(g)(2) or (3) of the federal Clean Air Act, new units are not allocated allowances in 40 CFR Part 73 and must obtain allowances by other means (Section 403(e) of the federal Clean Air Act);  
  
Comments, notes and justifications regarding permit decisions and changes made to the permit application forms during the review process, and any additional requirements; and,  
  
Any applicable nitrogen oxides compliance plan. Unless they are coal fired utility units regulated pursuant to Sections 404, 405, or 409 of the federal Clean Air Act, new units are not subject to the acid rain nitrogen oxides requirements (40 CFR 76.1(a)).
3. The permit application that this source submitted, as corrected by the AQD. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

## **Statement of Basis**

### **Statutory and Regulatory Authorities.**

In accordance with the Natural Resources and Environmental Protection Act, 1994 PA 451 and Titles IV and V of the federal Clean Air Act, the Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division (AQD), issues this permit pursuant to the provisions of R 336.1210 to R 336.1218, and R 336.1299(d).

For further information contact:

Mr. Brian Carley  
Environmental Quality Specialist  
Michigan Department of Environment, Great Lakes, and Energy  
Air Quality Division, Jackson District Office  
State Office Building, 4<sup>th</sup> Floor  
301 East Louis B. Glick Highway  
Jackson, Michigan 49201-1556

Telephone: 517-416-4631  
Facsimile: 517-780-7855

**There are no comments, notes and/or justification that apply to the source in general for this section.**



**Terms and Conditions:**

**Phase II Sulfur Dioxide Allowance Allocation and Nitrogen Oxides Requirements for each affected unit.**

		2020	2021	2022	2023	2024
Unit 1	SO <sub>2</sub> allowances	8113	8113	8113	8113	8113
	NOx Emission Limits	<p>Pursuant to 40 CFR part 76, the State of Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division approves a NOx standard emissions limitation compliance plan for unit 1. The NOx compliance plan is effective beginning 2017. Under the NOx compliance plan, this unit's annual average NOx emissions rate for each year, determined in accordance with 40 CFR part 75, shall not exceed the applicable emission limitation, under 40 CFR 76.7(a)(2), of <b>0.45 lb/MMBTU</b> for Phase I tangentially fired boilers.</p> <p>In addition to the described NOx compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NOx compliance plan and requirements covering excess emissions.</p>				

		2020	2021	2022	2023	2024
Unit 2	SO <sub>2</sub> allowances	9702	9702	9702	9702	9702
	NOx Emission Limits	<p>Pursuant to 40 CFR part 76, the State of Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division approves a NOx standard emissions limitation compliance plan for unit 2. The NOx compliance plan is effective beginning 2017. Under the NOx compliance plan, this unit's annual average NOx emissions rate for each year, determined in accordance with 40 CFR part 75, shall not exceed the applicable emission limitation, under 40 CFR 76.7(a)(2), of <b>0.68 lb/MMBTU</b> for cell burner boilers.</p> <p>In addition to the described NOx compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NOx compliance plan and requirements covering excess emissions.</p>				

**Terms and Conditions (cont.):**

		2020	2021	2022	2023	2024
Unit 3	SO <sub>2</sub> allowances	27529	27529	27529	27529	27529
	NOx Emission Limits	<p>Pursuant to 40 CFR part 76, the State of Michigan Department of Environment, Great Lakes, and Energy, Air Quality Division approves a NOx standard emissions limitation compliance plan for unit 3. The NOx compliance plan is effective beginning 2017. Under the NOx compliance plan, this unit's annual average NOx emissions rate for each year, determined in accordance with 40 CFR part 75, shall not exceed the applicable emission limitation, under 40 CFR 76.7(a)(2), of <b>0.46 lb/MMBTU</b> for Phase II dry bottom wall-fired boilers.</p> <p>In addition to the described NOx compliance plan, this unit shall comply with all other applicable requirements of 40 CFR part 76, including the duty to reapply for a NOx compliance plan and requirements covering excess emissions.</p>				

**Comments, notes and justifications regarding permit decisions, and changes made to the permit application forms during the review process:**

**Permit Application:** (attached)

*Acid Rain Permit Application submitted February 27, 2018*  
*Acid Rain NOx Compliance Plan submitted July 5, 2017*



United States  
Environmental Protection Agency  
Acid Rain Program

OMB No. 2060-0258  
Approval expires 11/30/2018

## Acid Rain Permit Application

For more information, see instructions and 40 CFR 72.30 and 72.31.

This submission is:  new  revised  for ARP permit renewal

### STEP 1

Identify the facility name,  
State, and plant (ORIS) code.

<b>J.H. Campbell Plant</b> Facility (Source) Name	<b>MI</b> State	<b>1710</b> Plant Code
--	--------------------	---------------------------

### STEP 2

Enter the unit ID# for every  
affected unit at the affected  
source in column "a."

a	b
Unit ID#	Unit Will Hold Allowances in Accordance with 40 CFR 72.9(c)(1)
<b>Unit 1</b>	<b>Yes</b>
<b>Unit 2</b>	<b>Yes</b>
<b>Unit 3</b>	<b>Yes</b>
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes
	Yes

**J.H. Campbell Plant**  
Facility (Source) Name (from STEP 1)

**STEP 3**

**Read the standard requirements.**

**Permit Requirements**

- (1) The designated representative of each affected source and each affected unit at the source shall:
  - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
  - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
  - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
  - (ii) Have an Acid Rain Permit.

**Monitoring Requirements**

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

**Sulfur Dioxide Requirements**

- (1) The owners and operators of each source and each affected unit at the source shall:
  - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
  - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
  - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
  - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

**Nitrogen Oxides Requirements**

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

**J.H. Campbell Plant**  
Facility (Source) Name (from STEP 1)

**STEP 3, Cont'd.**

**Excess Emissions Requirements**

- (1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
  - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
  - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

**Recordkeeping and Reporting Requirements**

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
  - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
  - (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
  - (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and,
  - (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.
- (2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

**Liability**

- (1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.
- (2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.
- (3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.
- (4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.
- (5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.
- (6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit.
- (7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

**J.H. Campbell Plant**  
Facility (Source) Name (from STEP 1)

STEP 3, Cont'd.

**Effect on Other Authorities**


No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

- (1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;
- (2) Limiting the number of allowances a source can hold; *provided*, that the number of allowances held by the source shall not affect the source's obligation to comply with any other provisions of the Act;
- (3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;
- (4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,
- (5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4  
Read the  
certification  
statement, sign,  
and date.

**Certification**

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

<b>John P. Broschak, Designated Representative</b> Name	
Signature 	Date 1-24-18



United States  
 Environmental Protection Agency  
 Acid Rain Program

OMB No. 2060-0258  
 Approval expires 11/30/2018

## Acid Rain NO<sub>x</sub> Compliance Plan

For more information, see instructions and refer to 40 CFR 76.9

Page 1

This submission is:  New  Revised

Page 1 of 1

**STEP 1**

Indicate plant name, State, and Plant code from the current Certificate of Representation covering the facility.

Plant Name <b>J.H. Campbell</b>	State <b>MI</b>	Plant Code <b>1710</b>
---------------------------------	-----------------	------------------------

**STEP 2**

Identify each affected Group 1 and Group 2 boiler using the unit IDs from the current Certificate of Representation covering the facility. Also indicate the boiler type: "CB" for cell burner, "CY" for cyclone, "DBW" for dry bottom wall-fired, "T" for tangentially fired, "V" for vertically fired, and "WB" for wet bottom, and select the compliance option for each unit by making an 'X' in the appropriate row and column.

	ID# 1	ID# 2	ID# 3	ID#	ID#	ID#
	Type T	Type CB	Type DBW	Type	Type	Type
(a) Standard annual average emission limitation of 0.50 lb/mmBtu (for Phase I dry bottom wall-fired boilers)						
(b) Standard annual average emission limitation of 0.45 lb/mmBtu (for Phase I tangentially fired boilers)	X					
(c) Standard annual average emission limitation of 0.46 lb/mmBtu (for Phase II dry bottom wall-fired boilers)			X			
(d) Standard annual average emission limitation of 0.40 lb/mmBtu (for Phase II tangentially fired boilers)						
(e) Standard annual average emission limitation of 0.68 lb/mmBtu (for cell burner boilers)		X				
(f) Standard annual average emission limitation of 0.86 lb/mmBtu (for cyclone boilers)						
(g) Standard annual average emission limitation of 0.80 lb/mmBtu (for vertically fired boilers)						
(h) Standard annual average emission limitation of 0.84 lb/mmBtu (for wet bottom boilers)						
(i) NO <sub>x</sub> Averaging Plan (include NO <sub>x</sub> Averaging form)						
(j) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(A) (check the standard emission limitation box above for most stringent limitation applicable to any unit utilizing stack)						
(k) Common stack pursuant to 40 CFR 75.17(a)(2)(i)(B) with NO <sub>x</sub> Averaging (check the NO <sub>x</sub> Averaging Plan box and include NO <sub>x</sub> Averaging Form)						
(l) EPA-approved common stack apportionment method pursuant to 40 CFR 75.17(a)(2)(i)(C), (a)(2)(iii)(B), or (b)(2)						

J.H. Campbell Plant Name (from Step 1)
---

NO<sub>x</sub> Compliance - Page 2  
Page 1 of 1

**STEP 3**  
Identify the first calendar year in which this plan will apply.

January 1, <u>2017</u>
------------------------

**STEP 4**  
Read the special provisions and certification, enter the name of the designated representative, sign and date.

**Special Provisions**

General.

This source is subject to the standard requirements in 40 CFR 72.9. These requirements are listed in this source's Acid Rain Permit.

**Certification**

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <b>John P. Broschak</b>	
Signature <i>John P. Broschak</i>	Date <u>6/29/17</u>



**Appendix 10: Cross State Air Pollution Rule (CSAPR) Trading Program Title V Requirements**

**Description of CSAPR Monitoring Provisions**

The CSAPR subject units, and the unit-specific monitoring provisions, at this source are identified in the following tables. These units are subject to the requirements for the CSAPR NO<sub>x</sub> Annual Trading Program, CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, and CSAPR SO<sub>2</sub> Group 1 Trading Program, which are included below as Sections I, II, and III, respectively.

Each unit will use one of the following as the monitoring methodology for each parameter as provided below and shall comply with the general monitoring, recordkeeping, reporting and other requirements in conditions 1 through 5 below and in paragraph (b) of Sections I, II, and III:

- Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO<sub>2</sub> monitoring) or 40 CFR Part 75, Subpart H (for NO<sub>x</sub> monitoring)
- Excepted monitoring system requirements for gas- and oil-fired units pursuant to 40 CFR Part 75, Appendix D
- Excepted monitoring system requirements for gas- and oil-fired peaking units pursuant to 40 CFR Part 75, Appendix E
- Low Mass Emissions excepted monitoring (LME) requirements for gas- and oil-fired units pursuant to 40 CFR 75.19
- USEPA-approved alternative monitoring system requirements pursuant to 40 CFR Part 75, Subpart E

Unit ID: 1	
Parameter	Monitoring Methodology
SO <sub>2</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B
NO <sub>x</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H
Heat Input	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO <sub>2</sub> monitoring) or 40 CFR Part 75, Subpart H (for NO <sub>x</sub> monitoring)

Unit ID: 2	
Parameter	Monitoring Methodology
SO <sub>2</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B
NO <sub>x</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H
Heat Input	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO <sub>2</sub> monitoring) or 40 CFR Part 75, Subpart H (for NO <sub>x</sub> monitoring)

Unit ID: 3	
Parameter	Monitoring Methodology
SO <sub>2</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B
NO <sub>x</sub>	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart H
Heat Input	Continuous emission monitoring system or systems (CEMS) requirements pursuant to 40 CFR Part 75, Subpart B (for SO <sub>2</sub> monitoring) or 40 CFR Part 75, Subpart H (for NO <sub>x</sub> monitoring)

1. The above description of the monitoring used by a unit does not change, create an exemption from, or otherwise affect the monitoring, recordkeeping, and reporting requirements applicable to the unit under 40 CFR 97.430 through 97.435 (CSAPR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and 97.630 through 97.635 (CSAPR SO<sub>2</sub> Group 1 Trading Program). The monitoring, recordkeeping and reporting requirements applicable to each unit are included below in the standard conditions for the applicable CSAPR trading programs.

2. Owners and operators must submit to the Administrator a monitoring plan for each unit in accordance with 40 CFR 75.53, 75.62 and 75.73, as applicable. The monitoring plan for each unit is available at the USEPA's website at <https://www.epa.gov/airmarkets/clean-air-markets-monitoring-plans-part-75-sources>.
3. Owners and operators that want to use an alternative monitoring system must submit to the Administrator a petition requesting approval of the alternative monitoring system in accordance with 40 CFR Part 75, Subpart E and 40 CFR 75.66 and 97.435 (CSAPR NO<sub>x</sub> Annual Trading Program), 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and/or 97.635 (CSAPR SO<sub>2</sub> Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative monitoring system is available on the USEPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
4. Owners and operators that want to use an alternative to any monitoring, recordkeeping, or reporting requirement under 40 CFR 97.430 through 97.434 (CSAPR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and/or 97.630 through 97.634 (CSAPR SO<sub>2</sub> Group 1 Trading Program) must submit to the Administrator a petition requesting approval of the alternative in accordance with 40 CFR 75.66 and 97.435 (CSAPR NO<sub>x</sub> Annual Trading Program), 97.835 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and/or 97.635 (CSAPR SO<sub>2</sub> Group 1 Trading Program). The Administrator's response approving or disapproving any petition for an alternative to a monitoring, recordkeeping, or reporting requirement is available on the USEPA's website at <https://www.epa.gov/airmarkets/part-75-petition-responses>.
5. The descriptions of monitoring applicable to the unit included above meet the requirement of 40 CFR 97.430 through 97.434 (CSAPR NO<sub>x</sub> Annual Trading Program), 97.830 through 97.834 (CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program), and 97.630 through 97.634 (CSAPR SO<sub>2</sub> Group 1 Trading Program), and therefore minor permit modification procedures, in accordance with 40 CFR 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B), may be used to add or change this unit's monitoring system description.

#### **SECTION I: CSAPR NO<sub>x</sub> Annual Trading Program requirements (40 CFR 97.406)**

##### **(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.

##### **(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each CSAPR NO<sub>x</sub> Annual source and each CSAPR NO<sub>x</sub> Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of CSAPR NO<sub>x</sub> Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the CSAPR NO<sub>x</sub> Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

##### **(c) NO<sub>x</sub> emissions requirements.**

- (1) CSAPR NO<sub>x</sub> Annual emissions limitation.
  - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO<sub>x</sub> Annual source and each CSAPR NO<sub>x</sub> Annual unit at the source shall hold, in the source's compliance account, CSAPR NO<sub>x</sub> Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all CSAPR NO<sub>x</sub> Annual units at the source.

- (ii). If total NO<sub>x</sub> emissions during a control period in a given year from the CSAPR NO<sub>x</sub> Annual units at a CSAPR NO<sub>x</sub> Annual source are in excess of the CSAPR NO<sub>x</sub> Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
  - (A). The owners and operators of the source and each CSAPR NO<sub>x</sub> Annual unit at the source shall hold the CSAPR NO<sub>x</sub> Annual allowances required for deduction under 40 CFR 97.424(d); and
  - (B). The owners and operators of the source and each CSAPR NO<sub>x</sub> Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.
- (2) CSAPR NO<sub>x</sub> Annual assurance provisions.
  - (i). If total NO<sub>x</sub> emissions during a control period in a given year from all CSAPR NO<sub>x</sub> Annual units at CSAPR NO<sub>x</sub> Annual sources in the state and Indian country within the borders of such State exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO<sub>x</sub> Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Annual units at CSAPR NO<sub>x</sub> Annual sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
  - (ii). The owners and operators shall hold the CSAPR NO<sub>x</sub> Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
  - (iii). Total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Annual units at CSAPR NO<sub>x</sub> Annual sources in the State and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the state NO<sub>x</sub> Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).
  - (iv). It shall not be a violation of 40 CFR Part 97, Subpart AAAAA or of the Clean Air Act if total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Annual units at CSAPR NO<sub>x</sub> Annual sources in the State and Indian country within the borders of such State during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the CSAPR NO<sub>x</sub> Annual units at CSAPR NO<sub>x</sub> Annual sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
  - (v). To the extent the owners and operators fail to hold CSAPR NO<sub>x</sub> Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
    - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
    - (B). Each CSAPR NO<sub>x</sub> Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart AAAAA and the Clean Air Act.
- (3) Compliance periods.
  - (i). A CSAPR NO<sub>x</sub> Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.

- (ii). A CSAPR NO<sub>x</sub> Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
  - (i). A CSAPR NO<sub>x</sub> Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Annual allowance that was allocated for such control period or a control period in a prior year.
  - (ii). A CSAPR NO<sub>x</sub> Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO<sub>x</sub> Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart AAAAA.
- (6) Limited authorization. A CSAPR NO<sub>x</sub> Annual allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
  - (i). Such authorization shall only be used in accordance with the CSAPR NO<sub>x</sub> Annual Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR Part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO<sub>x</sub> Annual allowance does not constitute a property right.

**(d) Title V permit revision requirements.**

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO<sub>x</sub> Annual allowances in accordance with 40 CFR Part 97, Subpart AAAAA.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**(e) Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO<sub>x</sub> Annual source and each CSAPR NO<sub>x</sub> Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each CSAPR NO<sub>x</sub> Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart AAAAA.
  - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO<sub>x</sub> Annual Trading Program.
- (2) The designated representative of a CSAPR NO<sub>x</sub> Annual source and each CSAPR NO<sub>x</sub> Annual unit at the source shall make all submissions required under the CSAPR NO<sub>x</sub> Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

**(f) Liability.**

- (1) Any provision of the CSAPR NO<sub>x</sub> Annual Trading Program that applies to a CSAPR NO<sub>x</sub> Annual source or the designated representative of a CSAPR NO<sub>x</sub> Annual source shall also apply to the owners and operators of such source and of the CSAPR NO<sub>x</sub> Annual units at the source.
- (2) Any provision of the CSAPR NO<sub>x</sub> Annual Trading Program that applies to a CSAPR NO<sub>x</sub> Annual unit or the designated representative of a CSAPR NO<sub>x</sub> Annual unit shall also apply to the owners and operators of such unit.

**(g) Effect on other authorities.**

No provision of the CSAPR NO<sub>x</sub> Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO<sub>x</sub> Annual source or CSAPR NO<sub>x</sub> Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**(h) Effect on units in Indian country.**

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

**SECTION II: CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program Requirements (40 CFR 97.806)**

**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.813 through 97.818.

**(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.830 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.831 (initial monitoring system certification and recertification procedures), 97.832 (monitoring system out-of-control periods), 97.833 (notifications concerning monitoring), 97.834 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.835 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.830 through 97.835 shall be used to calculate allocations of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances under 40 CFR 97.811(a)(2) and (b) and 97.812 and to determine compliance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.830 through 97.835 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

**(c) NO<sub>x</sub> emissions requirements.**

- (1) CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation.
  - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold, in the source's compliance account, CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR 97.824(a) in an amount not less than the tons of total NO<sub>x</sub> emissions for such control period from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.
  - (ii). If total NO<sub>x</sub> emissions during a control period in a given year from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at a CSAPR NO<sub>x</sub> Ozone Season Group 2 source are in excess of the CSAPR NO<sub>x</sub> Ozone Season Group 2 emissions limitation set forth in paragraph (c)(1)(i) above, then:

- (A). The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required for deduction under 40 CFR 97.824(d); and
  - (B). The owners and operators of the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.
- (2) CSAPR NO<sub>x</sub> Ozone Season Group 2 assurance provisions.
- (i). If total NO<sub>x</sub> emissions during a control period in a given year from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO<sub>x</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances available for deduction for such control period under 40 CFR 97.825(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.825(b), of multiplying—
    - (A). The quotient of the amount by which the common designated representative's share of such NO<sub>x</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such NO<sub>x</sub> emissions exceeds the respective common designated representative's assurance level; and
    - (B). The amount by which total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
  - (ii). The owners and operators shall hold the CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
  - (iii). Total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total NO<sub>x</sub> emissions exceed the sum, for such control period, of the State NO<sub>x</sub> Ozone Season Group 2 trading budget under 40 CFR 97.810(a) and the state's variability limit under 40 CFR 97.810(b).
  - (iv). It shall not be a violation of 40 CFR Part 97, Subpart EEEEE or of the Clean Air Act if total NO<sub>x</sub> emissions from all CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if a common designated representative's share of total NO<sub>x</sub> emissions from the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at CSAPR NO<sub>x</sub> Ozone Season Group 2 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
  - (v). To the extent the owners and operators fail to hold CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
    - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
    - (B). Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart EEEEE and the Clean Air Act.
- (3) Compliance periods.
- (i). A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.

- (ii). A CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.830(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.
  - (i). A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for such control period or a control period in a prior year.
  - (ii). A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart EEEEE.
- (6) Limited authorization. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance is a limited authorization to emit one ton of NO<sub>x</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
  - (i). Such authorization shall only be used in accordance with the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart EEEEE, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR NO<sub>x</sub> Ozone Season Group 2 allowance does not constitute a property right.

**(d) Title V permit revision requirements.**

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR NO<sub>x</sub> Ozone Season Group 2 allowances in accordance with 40 CFR Part 97, Subpart EEEEE.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.830 through 97.835, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.806(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**(e) Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (i). The certificate of representation under 40 CFR 97.816 for the designated representative for the source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.816 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart EEEEE.
  - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program.
- (2) The designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source and each CSAPR NO<sub>x</sub> Ozone Season Group 2 unit at the source shall make all submissions required under the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program, except as provided in 40 CFR 97.818. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

**(f) Liability.**

- (1) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or the designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source shall also apply to the owners and operators of such source and of the CSAPR NO<sub>x</sub> Ozone Season Group 2 units at the source.
- (2) Any provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program that applies to a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit or the designated representative of a CSAPR NO<sub>x</sub> Ozone Season Group 2 unit shall also apply to the owners and operators of such unit.

**(g) Effect on other authorities.**

No provision of the CSAPR NO<sub>x</sub> Ozone Season Group 2 Trading Program or exemption under 40 CFR 97.805 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR NO<sub>x</sub> Ozone Season Group 2 source or CSAPR NO<sub>x</sub> Ozone Season Group 2 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**(h) Effect on units in Indian country.**

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

**SECTION III: CSAPR SO<sub>2</sub> Group 1 Trading Program requirements (40 CFR 97.606)**

**(a) Designated representative requirements.**

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.

**(b) Emissions monitoring, reporting, and recordkeeping requirements.**

- (1) The owners and operators, and the designated representative, of each CSAPR SO<sub>2</sub> Group 1 source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of CSAPR SO<sub>2</sub> Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the CSAPR SO<sub>2</sub> Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

**(c) SO<sub>2</sub> emissions requirements.**

- (1) CSAPR SO<sub>2</sub> Group 1 emissions limitation.
  - (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each CSAPR SO<sub>2</sub> Group 1 source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall hold, in the source's compliance account, CSAPR SO<sub>2</sub> Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO<sub>2</sub> emissions for such control period from all CSAPR SO<sub>2</sub> Group 1 units at the source.
  - (ii). If total SO<sub>2</sub> emissions during a control period in a given year from the CSAPR SO<sub>2</sub> Group 1 units at a CSAPR SO<sub>2</sub> Group 1 source are in excess of the CSAPR SO<sub>2</sub> Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:



- (A). The owners and operators of the source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall hold the CSAPR SO<sub>2</sub> Group 1 allowances required for deduction under 40 CFR 97.624(d); and
  - (B). The owners and operators of the source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.
- (2) CSAPR SO<sub>2</sub> Group 1 assurance provisions.
- (i). If total SO<sub>2</sub> emissions during a control period in a given year from all CSAPR SO<sub>2</sub> Group 1 units at CSAPR SO<sub>2</sub> Group 1 sources in the state and Indian country within the borders of such state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO<sub>2</sub> emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) CSAPR SO<sub>2</sub> Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—
    - (A). The quotient of the amount by which the common designated representative's share of such SO<sub>2</sub> emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state and Indian country within the borders of such state for such control period, by which each common designated representative's share of such SO<sub>2</sub> emissions exceeds the respective common designated representative's assurance level; and
    - (B). The amount by which total SO<sub>2</sub> emissions from all CSAPR SO<sub>2</sub> Group 1 units at CSAPR SO<sub>2</sub> Group 1 sources in the state and Indian country within the borders of such state for such control period exceed the state assurance level.
  - (ii). The owners and operators shall hold the CSAPR SO<sub>2</sub> Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.
  - (iii). Total SO<sub>2</sub> emissions from all CSAPR SO<sub>2</sub> Group 1 units at CSAPR SO<sub>2</sub> Group 1 sources in the state and Indian country within the borders of such state during a control period in a given year exceed the state assurance level if such total SO<sub>2</sub> emissions exceed the sum, for such control period, of the state SO<sub>2</sub> Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).
  - (iv). It shall not be a violation of 40 CFR Part 97, Subpart CCCCC or of the Clean Air Act if total SO<sub>2</sub> emissions from all CSAPR SO<sub>2</sub> Group 1 units at CSAPR SO<sub>2</sub> Group 1 sources in the state and Indian country within the borders of such state during a control period exceed the state assurance level or if a common designated representative's share of total SO<sub>2</sub> emissions from the CSAPR SO<sub>2</sub> Group 1 units at CSAPR SO<sub>2</sub> Group 1 sources in the state and Indian country within the borders of such state during a control period exceeds the common designated representative's assurance level.
  - (v). To the extent the owners and operators fail to hold CSAPR SO<sub>2</sub> Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,
    - (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and
    - (B). Each CSAPR SO<sub>2</sub> Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR Part 97, Subpart CCCCC and the Clean Air Act.
- (3) Compliance periods.
- (i). A CSAPR SO<sub>2</sub> Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
  - (ii). A CSAPR SO<sub>2</sub> Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.
- (4) Vintage of allowances held for compliance.

- (i). A CSAPR SO<sub>2</sub> Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a CSAPR SO<sub>2</sub> Group 1 allowance that was allocated for such control period or a control period in a prior year.
- (ii). A CSAPR SO<sub>2</sub> Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a CSAPR SO<sub>2</sub> Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.
- (5) Allowance Management System requirements. Each CSAPR SO<sub>2</sub> Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR Part 97, Subpart CCCCC.
- (6) Limited authorization. A CSAPR SO<sub>2</sub> Group 1 allowance is a limited authorization to emit one ton of SO<sub>2</sub> during the control period in one year. Such authorization is limited in its use and duration as follows:
  - (i). Such authorization shall only be used in accordance with the CSAPR SO<sub>2</sub> Group 1 Trading Program; and
  - (ii). Notwithstanding any other provision of 40 CFR Part 97, Subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.
- (7) Property right. A CSAPR SO<sub>2</sub> Group 1 allowance does not constitute a property right.

**(d) Title V permit revision requirements.**

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of CSAPR SO<sub>2</sub> Group 1 allowances in accordance with 40 CFR Part 97, Subpart CCCCC.
- (2) This permit incorporates the CSAPR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR Part 75, Subparts B and H), an excepted monitoring system (pursuant to 40 CFR Part 75, Appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR Part 75, Subpart E). Therefore, the Description of CSAPR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

**(e) Additional recordkeeping and reporting requirements.**

- (1) Unless otherwise provided, the owners and operators of each CSAPR SO<sub>2</sub> Group 1 source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
  - (i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each CSAPR SO<sub>2</sub> Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.
  - (ii). All emissions monitoring information, in accordance with 40 CFR Part 97, Subpart CCCCC.
  - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the CSAPR SO<sub>2</sub> Group 1 Trading Program.
- (2) The designated representative of a CSAPR SO<sub>2</sub> Group 1 source and each CSAPR SO<sub>2</sub> Group 1 unit at the source shall make all submissions required under the CSAPR SO<sub>2</sub> Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR Parts 70 and 71.

**(f) Liability.**

- (1) Any provision of the CSAPR SO<sub>2</sub> Group 1 Trading Program that applies to a CSAPR SO<sub>2</sub> Group 1 source or the designated representative of a CSAPR SO<sub>2</sub> Group 1 source shall also apply to the owners and operators of such source and of the CSAPR SO<sub>2</sub> Group 1 units at the source.

- (2) Any provision of the CSAPR SO<sub>2</sub> Group 1 Trading Program that applies to a CSAPR SO<sub>2</sub> Group 1 unit or the designated representative of a CSAPR SO<sub>2</sub> Group 1 unit shall also apply to the owners and operators of such unit.

**(g) Effect on other authorities.**

No provision of the CSAPR SO<sub>2</sub> Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a CSAPR SO<sub>2</sub> Group 1 source or CSAPR SO<sub>2</sub> Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**(h) Effect on units in Indian country.**

Notwithstanding the provisions of paragraphs (a) through (g) above, paragraphs (a) through (g) shall be deemed not to impose any requirements on any source or unit, or any owner, operator, or designated representative with regard to any source or unit, in Indian country within the borders of the state.

**Appendix 11-A. System Wide Tonnage Limitations**

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). Appendix 11-A and Appendix 11-B were originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. **(Act 451, Section 324.5503(b))**

**System-Wide Annual NO<sub>x</sub> Tonnage Limitations**

The Consumers System, collectively, shall operate so as not to exceed the following System-Wide Annual NO<sub>x</sub> Tonnage Limitations:

<b>For the Calendar Year Specified Below:</b>	<b>System-Wide Annual NO<sub>x</sub> Tonnage Limitation:</b>
2017 and continuing each calendar year thereafter	6,600

**(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 98)**

- For purposes of calculating the System-Wide Annual NO<sub>x</sub> Tonnage Limitations, Consumers shall use CEMS in accordance with the procedures specified in 40 CFR Part 75, which includes the requirements associated with the concepts of bias adjustments and missing data substitution. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 100)**

**System-Wide Annual SO<sub>2</sub> Tonnage Limitations**

The Consumers System, collectively, shall operate so as not to exceed the following System-Wide Annual SO<sub>2</sub> Tonnage Limitations:

<b>For the Calendar Year Specified Below:</b>	<b>System-Wide Annual SO<sub>2</sub> Tonnage Limitation:</b>
2017 and continuing each calendar year thereafter	10,900

**(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 129)**

- For purposes of calculating the System-Wide Annual SO<sub>2</sub> Tonnage Limitations, Consumers shall use CEMS in accordance with the procedures specified in 40 CFR Part 75, which includes the requirements associated with the concepts of bias adjustments and missing data substitution. **(“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 131)**

**Appendix 11-B. Allowance Provisions**

This Appendix is federally enforceable and was established pursuant to Rule 201(1)(a). This Appendix was originally established in the consent decree settling, “U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” and also pursuant Section 324.5503(b) of the Natural Resources and Environmental Protection Act, 1994 Act 451, as amended, and will remain in effect after termination of the consent decree. Definitions specific to this Appendix may be found in Appendix 1-B: Definitions. **(Act 451, Section 324.5503(b))**

### **Use and Surrender of NOx Allowances**

- Consumers shall not use NOx Allowances to comply with any requirement of the Consent Decree, as enumerated in this permit, including by claiming compliance with any emission limitation required by the Consent Decree, as provided in this permit, by using, tendering, or otherwise applying NOx Allowances to offset any excess emissions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 101**)
- Except as provided by Appendix 11-B: Allowance Provisions, Consumers shall not sell, bank, trade, or transfer any NOx Allowances allocated to the Consumers System Units. Nothing in the Consent Decree shall restrict Consumers’ ability to transfer NOx Allowances among its own facility or general accounts. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 102**)
- Beginning with the year 2014 compliance period, and continuing each year thereafter, Consumers shall Surrender all NOx Allowances allocated to the Consumers System for that year’s compliance period that Consumers does not need in order to meet its own federal and/or state CAA regulatory requirements for the Consumers System Units. However, NOx Allowances allocated to the Consumers System may be used by Consumers to meet its own federal and/or state CAA regulatory requirements for such Units. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 103**)
- Nothing in Appendix 11-B: Allowance Provisions, shall prevent Consumers from purchasing or otherwise obtaining NOx Allowances from another source for purposes of complying with federal and/or state CAA regulatory requirements to the extent otherwise allowed by law. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 104**)

### **Super-Compliant NOx Allowances**

- Beginning with the year 2014 and continuing in each calendar year thereafter, Consumers may sell, bank, use, trade, or transfer NOx Allowances made available in that year’s compliance period solely as a result of:
  - a. the installation and operation of any NOx pollution control that is not otherwise required by, or necessary to maintain compliance with, any provision of the Consent Decree as provided in this permit, and is not otherwise required by law;
  - b. the use of SCR prior to the date established by the Consent Decree; or
  - c. achievement and maintenance of an Emission Rate below a 365-Day Rolling Average Emission Rate for NO<sub>x</sub> at the following Units: (i) at Campbell Unit 1: 0.200 lb/MMBTU; (ii) at Campbell Unit 2: 0.070 lb/MMBTU; (iii) at Campbell Unit 3: 0.070 lb/MMBTU;provided that Consumers is also in compliance for that calendar year with all emission limitations for NO<sub>x</sub> set forth in the Consent Decree as provided in this permit. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 106**)

### **Method for Surrender of NOx Allowances**

- Consumers shall Surrender, or transfer to a non-profit third-party selected by Consumers for Surrender, all NOx Allowances required to be Surrendered pursuant to Appendix 11-B: Allowance Provisions by June 30 of the immediately following calendar year. Such Surrender need not include the specific NOx Allowances that were allocated to Consumers System Units, so long as Consumers Surrenders NO<sub>x</sub> Allowances that are from the same year or an earlier year and that are equal to the number required to be Surrendered under the Consent Decree as provided in this permit. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 107**)
- If any NOx Allowances required to be Surrendered under Appendix 11-B: Allowance Provisions are transferred directly to a non-profit third-party, Consumers shall include a description of such transfer in the next report submitted to USEPA pursuant to the Periodic Reporting provisions of the Consent Decree (beginning at paragraph 188 of the Consent Decree). Such report shall: (a) identify the non-profit third-party recipient(s) of the NOx Allowances and list the serial numbers of the transferred NOx Allowances; and (b) include a certification by the third-party recipient(s) stating that the recipient(s) will not sell, trade, or otherwise exchange any of the NOx Allowances and will not use any of the NOx Allowances to meet any obligation imposed by any environmental law. No later than the third periodic report due after the transfer of any NOx Allowances, Consumers shall include a statement that the third-party recipient(s) Surrendered the NOx Allowances for permanent Surrender to USEPA in accordance with the provisions of Appendix 11-B, “Method for Surrender of NOx Allowances,” within one year after Consumers transferred the NOx Allowances to them. Consumers shall not have complied with the NOx

Allowance Surrender requirements of Appendix 11-B, “Method for Surrender of NO<sub>x</sub> Allowances,” until all third-party recipient(s) have actually Surrendered the transferred NO<sub>x</sub> Allowances to USEPA. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 108**)

- For all NO<sub>x</sub> Allowances required to be Surrendered, Consumers or the third-party recipient(s) (as the case may be) shall first submit a NO<sub>x</sub> Allowance transfer request to USEPA’s Office of Air and Radiation’s Clean Air Markets Division directing the transfer of such NO<sub>x</sub> Allowances to the USEPA Enforcement Surrender Account or to any other USEPA account that USEPA may direct in writing. Such NO<sub>x</sub> Allowance transfer requests may be made in an electronic manner using USEPA’s Clean Air Markets Division Business System or similar system provided by USEPA. As part of submitting these transfer requests, Consumers or the third-party recipient(s) shall irrevocably authorize the transfer of these NO<sub>x</sub> Allowances and identify – by name of account and any applicable serial or other identification numbers or station names – the source and location of the NO<sub>x</sub> Allowances being Surrendered. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 109**)

### **Use and Surrender of SO<sub>2</sub> Allowances**

- Consumers shall not use SO<sub>2</sub> Allowances to comply with any requirement of the Consent Decree, as enumerated in this permit, including by claiming compliance with any emission limitation required by the Consent Decree, as enumerated in this permit, by using, tendering, or otherwise applying SO<sub>2</sub> Allowances to offset any excess emissions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 132**)
- Except as provided in Appendix 11-B: Allowance Provisions, Consumers shall not sell, bank, trade, or transfer any SO<sub>2</sub> Allowances allocated to the Consumers System Units. Nothing in Appendix 11-B: Allowance Provisions, shall restrict Consumers’ ability to transfer SO<sub>2</sub> Allowances among its own facility or general accounts. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 133**)
- Beginning with the year 2014 compliance period, and continuing each year thereafter, Consumers shall Surrender all SO<sub>2</sub> Allowances allocated to the Consumers System for that year’s compliance period that Consumers does not need in order to meet its own federal and/or state CAA regulatory requirements for the Consumers System Units. However, SO<sub>2</sub> Allowances allocated to the Consumers System Units may be used by Consumers to meet its own federal and/or state CAA regulatory requirements for such Units. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 134**)
- Nothing in Appendix 11-B: Allowance Provisions, shall prevent Consumers from purchasing or otherwise obtaining SO<sub>2</sub> Allowances from another source for purposes of complying with federal and/or state CAA regulatory requirements to the extent otherwise allowed by law. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 135**)

### **Super-Compliant SO<sub>2</sub> Allowances**

- Beginning with the year 2014 and continuing in each calendar year thereafter, Consumers may sell, bank, use, trade, or transfer SO<sub>2</sub> Allowances made available in that year’s compliance period solely as a result of:
  - a. the installation and operation of any SO<sub>2</sub> pollution control that is not otherwise required by, or necessary to maintain compliance with, any provision of the Consent Decree, and is not otherwise required by law;
  - b. the use of FGD or DSI prior to the date established by the Consent Decree; or
  - c. achievement and maintenance of an Emission Rate below a 365-Day Rolling Average Emission Rate for SO<sub>2</sub> at the following Units: (i) at Campbell Units 1 and 2: 0.260 lb/MMBTU; (ii) at Campbell Unit 3: 0.060 lb/MMBTUprovided that Consumers is also in compliance for that calendar year with all emission limitations for SO<sub>2</sub> set forth in the Consent Decree as provided in this permit. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 137**)

### **Method for Surrender of SO<sub>2</sub> Allowances**

- Consumers shall Surrender, or transfer to a non-profit third party selected by Consumers for Surrender, all SO<sub>2</sub> Allowances required to be Surrendered pursuant to Appendix 11-B: Allowance Provisions, by June 30 of the immediately following calendar year. Such Surrender need not include the specific SO<sub>2</sub> Allowances that were allocated to Consumers System Units, so long as Consumers Surrenders SO<sub>2</sub> Allowances that are from the same year or an earlier year and that are equal to the number required to be Surrendered under Appendix 11-B:

Allowance Provisions. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 138**)

- If any SO<sub>2</sub> Allowances required to be Surrendered under Appendix 11-B, “Use and Surrender of SO<sub>2</sub> Allowances,” are transferred directly to a non-profit third party, Consumers shall include a description of such transfer in the next report submitted to USEPA pursuant to the Periodic Reporting provisions of the Consent Decree (beginning at paragraph 188 of the Consent Decree). Such report shall: (a) identify the non-profit third-party recipient(s) of the SO<sub>2</sub> Allowances and list the serial numbers of the transferred SO<sub>2</sub> Allowances; and (b) include a certification by the non-profit third-party recipient(s) stating that the recipient(s) will not sell, trade, or otherwise exchange any of the allowances and will not use any of the SO<sub>2</sub> Allowances to meet any obligation imposed by any environmental law. No later than the third periodic report due after the transfer of any SO<sub>2</sub> Allowances, Consumers shall include a statement that the non-profit third-party recipient(s) Surrendered the SO<sub>2</sub> Allowances for permanent Surrender to USEPA in accordance with the provisions of the following Paragraph 140 Appendix 11-B, “Method for Surrender of SO<sub>2</sub> Allowances,” within one year after Consumers transferred the SO<sub>2</sub> Allowances to them. Consumers shall not have complied with the SO<sub>2</sub> Allowance Surrender requirements of this Appendix 11-B, “Method for Surrender of SO<sub>2</sub> Allowances,” until all third-party recipient(s) have actually Surrendered the transferred SO<sub>2</sub> Allowances to USEPA. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 139**)
- For all SO<sub>2</sub> Allowances required to be Surrendered, Consumers or the third-party recipient(s) (as the case may be) shall first submit an SO<sub>2</sub> Allowance transfer request to USEPA’s Office of Air and Radiation’s Clean Air Markets Division directing the transfer of such SO<sub>2</sub> Allowances to the USEPA Enforcement Surrender Account or to any other USEPA account that USEPA may direct in writing. Such SO<sub>2</sub> Allowance transfer requests may be made in an electronic manner using USEPA’s Clean Air Markets Division Business System or similar system provided by USEPA. As part of submitting these transfer requests, Consumers or the third-party recipient(s) shall irrevocably authorize the transfer of these SO<sub>2</sub> Allowances and identify – by name of account and any applicable serial or other identification numbers or station names – the source and location of the SO<sub>2</sub> Allowances being Surrendered. (**“U.S. v Consumers Energy Company, Civil Action 14-13580, E.D. Mich., 2014” paragraph 140**)