

**MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION**

EFFECTIVE DATE: July 6, 2021

ISSUED TO

Great Lakes Gas Transmission Limited Partnership

Great Lakes Gas Transmission - Crystal Falls Compressor Station No. 8

State Registration Number (SRN): N3760

LOCATED AT

151 Oss Road, Crystal Falls, Iron County, Michigan 49920

RENEWABLE OPERATING PERMIT

Permit Number: MI-ROP-N3760-2021

Expiration Date: July 6, 2026

Administratively Complete ROP Renewal Application Due Between
January 6, 2025 and January 6, 2026

This Renewable Operating Permit (ROP) is issued in accordance with and subject to Section 5506(3) of Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451). Pursuant to Rule 210(1) of the administrative rules promulgated under Act 451, this ROP constitutes the permittee's authority to operate the stationary source identified above in accordance with the general conditions, special conditions and attachments contained herein. Operation of the stationary source and all emission units listed in the permit are subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

SOURCE-WIDE PERMIT TO INSTALL

Permit Number: MI-PTI-N3760-2021

This Permit to Install (PTI) is issued in accordance with and subject to Section 5505(1) of Act 451. Pursuant to Rule 214a of the administrative rules promulgated under Act 451, the terms and conditions herein, identified by the underlying applicable requirement citation of Rule 201(1)(a), constitute a federally enforceable PTI. The PTI terms and conditions do not expire and remain in effect unless the criteria of Rule 201(6) are met. Operation of all emission units identified in the PTI is subject to all applicable future or amended rules and regulations pursuant to Act 451 and the federal Clean Air Act.

Michigan Department of Environment, Great Lakes, and Energy

Ed Lancaster, Marquette District Supervisor

TABLE OF CONTENTS

AUTHORITY AND ENFORCEABILITY	3
A. GENERAL CONDITIONS.....	4
Permit Enforceability	4
General Provisions.....	4
Equipment & Design	5
Emission Limits.....	5
Testing/Sampling	5
Monitoring/Recordkeeping	6
Certification & Reporting	6
Permit Shield	7
Revisions	8
Reopenings.....	8
Renewals.....	9
Stratospheric Ozone Protection	9
Risk Management Plan.....	9
Emission Trading	9
Permit to Install (PTI)	10
B. SOURCE-WIDE CONDITIONS	11
C. EMISSION UNIT SPECIAL CONDITIONS	12
EMISSION UNIT SUMMARY TABLE.....	12
EUUNIT801	13
EUUNIT802	15
EUUNIT803	18
D. FLEXIBLE GROUP SPECIAL CONDITIONS.....	20
FLEXIBLE GROUP SUMMARY TABLE.....	20
FGMACTZZZZ.....	21
FGRULE285(2)(mm).....	25
E. NON-APPLICABLE REQUIREMENTS	27
APPENDICES	28
Appendix 1. Acronyms and Abbreviations.....	28
Appendix 2. Schedule of Compliance.....	29
Appendix 3. Monitoring Requirements	29
Appendix 4. Recordkeeping	29
Appendix 5. Testing Procedures	29
Appendix 6. Permits to Install.....	29
Appendix 7. Emission Calculations	29
Appendix 8. Reporting	29

AUTHORITY AND ENFORCEABILITY

For the purpose of this permit, the **permittee** is defined as any person who owns or operates an emission unit at a stationary source for which this permit has been issued. The **department** is defined in Rule 104(d) as the Director of the Michigan Department of Environment, Great Lakes, and Energy (EGLE) or his or her designee.

The permittee shall comply with all specific details in the permit terms and conditions and the cited underlying applicable requirements. All terms and conditions in this ROP are both federally enforceable and state enforceable unless otherwise footnoted. Certain terms and conditions are applicable to most stationary sources for which an ROP has been issued. These general conditions are included in Part A of this ROP. Other terms and conditions may apply to a specific emission unit, several emission units which are represented as a flexible group, or the entire stationary source which is represented as a Source-Wide group. Special conditions are identified in Parts B, C, D and/or the appendices.

In accordance with Rule 213(2)(a), all underlying applicable requirements are identified for each ROP term or condition. All terms and conditions that are included in a PTI are streamlined, subsumed and/or is state-only enforceable will be noted as such.

In accordance with Section 5507 of Act 451, the permittee has included in the ROP application a compliance certification, a schedule of compliance, and a compliance plan. For applicable requirements with which the source is in compliance, the source will continue to comply with these requirements. For applicable requirements with which the source is not in compliance, the source will comply with the detailed schedule of compliance requirements that are incorporated as an appendix in this ROP. Furthermore, for any applicable requirements effective after the date of issuance of this ROP, the stationary source will meet the requirements on a timely basis, unless the underlying applicable requirement requires a more detailed schedule of compliance.

Issuance of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.

A. GENERAL CONDITIONS

Permit Enforceability

- All conditions in this permit are both federally enforceable and state enforceable unless otherwise noted. **(R 336.1213(5))**
- Those conditions that are hereby incorporated in a state-only enforceable Source-Wide PTI pursuant to Rule 201(2)(d) are designated by footnote one. **(R 336.1213(5)(a), R 336.1214a(5))**
- Those conditions that are hereby incorporated in a federally enforceable Source-Wide PTI pursuant to Rule 201(2)(c) are designated by footnote two. **(R 336.1213(5)(b), R 336.1214a(3))**

General Provisions

1. The permittee shall comply with all conditions of this ROP. Any ROP noncompliance constitutes a violation of Act 451, and is grounds for enforcement action, for ROP revocation or revision, or for denial of the renewal of the ROP. All terms and conditions of this ROP that are designated as federally enforceable are enforceable by the Administrator of the United States Environmental Protection Agency (USEPA) and by citizens under the provisions of the federal Clean Air Act (CAA). Any terms and conditions based on applicable requirements which are designated as "state-only" are not enforceable by the USEPA or citizens pursuant to the CAA. **(R 336.1213(1)(a))**
2. It shall not be a defense for the permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this ROP. **(R 336.1213(1)(b))**
3. This ROP may be modified, revised, or revoked for cause. The filing of a request by the permittee for a permit modification, revision, or termination, or a notification of planned changes or anticipated noncompliance does not stay any ROP term or condition. This does not supersede or affect the ability of the permittee to make changes, at the permittee's own risk, pursuant to Rule 215 and Rule 216. **(R 336.1213(1)(c))**
4. The permittee shall allow the department, or an authorized representative of the department, upon presentation of credentials and other documents as may be required by law and upon stating the authority for and purpose of the investigation, to perform any of the following activities: **(R 336.1213(1)(d))**
 - a. Enter, at reasonable times, a stationary source or other premises where emissions-related activity is conducted or where records must be kept under the conditions of the ROP.
 - b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of the ROP.
 - c. Inspect, at reasonable times, any of the following:
 - i. Any stationary source.
 - ii. Any emission unit.
 - iii. Any equipment, including monitoring and air pollution control equipment.
 - iv. Any work practices or operations regulated or required under the ROP.
 - d. As authorized by Section 5526 of Act 451, sample or monitor at reasonable times substances or parameters for the purpose of assuring compliance with the ROP or applicable requirements.
5. The permittee shall furnish to the department, within a reasonable time, any information the department may request, in writing, to determine whether cause exists for modifying, revising, or revoking the ROP or to determine compliance with this ROP. Upon request, the permittee shall also furnish to the department copies of any records that are required to be kept as a term or condition of this ROP. For information which is claimed by the permittee to be confidential, consistent with the requirements of the 1976 PA 442, MCL §15.231 et seq., and known as the Freedom of Information Act, the person may also be required to furnish the records directly to the USEPA together with a claim of confidentiality. **(R 336.1213(1)(e))**

6. A challenge by any person, the Administrator of the USEPA, or the department to a particular condition or a part of this ROP shall not set aside, delay, stay, or in any way affect the applicability or enforceability of any other condition or part of this ROP. **(R 336.1213(1)(f))**
7. The permittee shall pay fees consistent with the fee schedule and requirements pursuant to Section 5522 of Act 451. **(R 336.1213(1)(g))**
8. This ROP does not convey any property rights or any exclusive privilege. **(R 336.1213(1)(h))**

Equipment & Design

9. Any collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in Rule 370(2).² **(R 336.1370)**
10. Any air cleaning device shall be installed, maintained, and operated in a satisfactory manner and in accordance with the Michigan Air Pollution Control rules and existing law. **(R 336.1910)**

Emission Limits

11. Unless otherwise specified in this ROP, the permittee shall comply with Rule 301, which states, in part, "Except as provided in Subrules 2, 3, and 4 of this rule, a person shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of a density greater than the most stringent of the following:"² **(R 336.1301(1))**
 - a. A 6-minute average of 20% opacity, except for one 6-minute average per hour of not more than 27% opacity.
 - b. A limit specified by an applicable federal new source performance standard.

The grading of visible emissions shall be determined in accordance with Rule 303.

12. The permittee shall not cause or permit the emission of an air contaminant or water vapor in quantities that cause, alone or in reaction with other air contaminants, either of the following:
 - a. Injurious effects to human health or safety, animal life, plant life of significant economic value, or property.¹ **(R 336.1901(a))**
 - b. Unreasonable interference with the comfortable enjoyment of life and property.¹ **(R 336.1901(b))**

Testing/Sampling

13. The department may require the owner or operator of any source of an air contaminant to conduct acceptable performance tests, at the owner's or operator's expense, in accordance with Rule 1001 and Rule 1003, under any of the conditions listed in Rule 1001(1).² **(R 336.2001)**
14. Any required performance testing shall be conducted in accordance with Rule 1001(2), Rule 1001(3) and Rule 1003. **(R 336.2001(2), R 336.2001(3), R 336.2003(1))**
15. Any required test results shall be submitted to the Air Quality Division (AQD) in the format prescribed by the applicable reference test method within 60 days following the last date of the test. **(R 336.2001(5))**

Monitoring/Recordkeeping

16. Records of any periodic emission or parametric monitoring required in this ROP shall include the following information specified in Rule 213(3)(b)(i), where appropriate. **(R 336.1213(3)(b))**
 - a. The date, location, time, and method of sampling or measurements.
 - b. The dates the analyses of the samples were performed.
 - c. The company or entity that performed the analyses of the samples.
 - d. The analytical techniques or methods used.
 - e. The results of the analyses.
 - f. The related process operating conditions or parameters that existed at the time of sampling or measurement.
17. All required monitoring data, support information and all reports, including reports of all instances of deviation from permit requirements, shall be kept and furnished to the department upon request for a period of not less than 5 years from the date of the monitoring sample, measurement, report or application. Support information includes all calibration and maintenance records and all original strip-chart recordings, or other original data records, for continuous monitoring instrumentation and copies of all reports required by the ROP. **(R 336.1213(1)(e), R 336.1213(3)(b)(ii))**

Certification & Reporting

18. Except for the alternate certification schedule provided in Rule 213(3)(c)(iii)(B), any document required to be submitted to the department as a term or condition of this ROP shall contain an original certification by a Responsible Official which state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete. **(R 336.1213(3)(c))**
19. A Responsible Official shall certify to the appropriate AQD District Office and to the USEPA that the stationary source is and has been in compliance with all terms and conditions contained in the ROP except for deviations that have been or are being reported to the appropriate AQD District Office pursuant to Rule 213(3)(c). This certification shall include all the information specified in Rule 213(4)(c)(i) through (v) and shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the certification are true, accurate, and complete. The USEPA address is: USEPA, Air Compliance Data - Michigan, Air and Radiation Division, 77 West Jackson Boulevard, Chicago, Illinois 60604-3507. **(R 336.1213(4)(c))**
20. The certification of compliance shall be submitted annually for the term of this ROP as detailed in the special conditions, or more frequently if specified in an applicable requirement or in this ROP. **(R 336.1213(4)(c))**
21. The permittee shall promptly report any deviations from ROP requirements and certify the reports. The prompt reporting of deviations from ROP requirements is defined in Rule 213(3)(c)(ii) as follows, unless otherwise described in this ROP. **(R 336.1213(3)(c))**
 - a. For deviations that exceed the emissions allowed under the ROP, prompt reporting means reporting consistent with the requirements of Rule 912 as detailed in Condition 25. All reports submitted pursuant to this paragraph shall be promptly certified as specified in Rule 213(3)(c)(iii).
 - b. For deviations which exceed the emissions allowed under the ROP and which are not reported pursuant to Rule 912 due to the duration of the deviation, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe reasons for each deviation and the actions taken to minimize or correct each deviation.
 - c. For deviations that do not exceed the emissions allowed under the ROP, prompt reporting means the reporting of all deviations in the semiannual reports required by Rule 213(3)(c)(i). The report shall describe the reasons for each deviation and the actions taken to minimize or correct each deviation.

22. For reports required pursuant to Rule 213(3)(c)(ii), prompt certification of the reports is described in Rule 213(3)(c)(iii) as either of the following: **(R 336.1213(3)(c))**
 - a. Submitting a certification by a Responsible Official with each report which states that, based on information and belief formed after reasonable inquiry, the statements and information in the report are true, accurate, and complete.
 - b. Submitting, within 30 days following the end of a calendar month during which one or more prompt reports of deviations from the emissions allowed under the ROP were submitted to the department pursuant to Rule 213(3)(c)(ii), a certification by a Responsible Official which states that; “based on information and belief formed after reasonable inquiry, the statements and information contained in each of the reports submitted during the previous month were true, accurate, and complete.” The certification shall include a listing of the reports that are being certified. Any report submitted pursuant to Rule 213(3)(c)(ii) that will be certified on a monthly basis pursuant to this paragraph shall include a statement that certification of the report will be provided within 30 days following the end of the calendar month.
23. Semiannually for the term of the ROP as detailed in the special conditions, or more frequently if specified, the permittee shall submit certified reports of any required monitoring to the appropriate AQD District Office. All instances of deviations from ROP requirements during the reporting period shall be clearly identified in the reports. **(R 336.1213(3)(c)(i))**
24. On an annual basis, the permittee shall report the actual emissions, or the information necessary to determine the actual emissions, of each regulated air pollutant as defined in Rule 212(6) for each emission unit utilizing the emissions inventory forms provided by the department. **(R 336.1212(6))**
25. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the appropriate AQD District Office. The notice shall be provided not later than two business days after the start-up, shutdown, or discovery of the abnormal conditions or malfunction. Notice shall be by any reasonable means, including electronic, telephonic, or oral communication. Written reports, if required under Rule 912, must be submitted to the appropriate AQD District Supervisor within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal conditions or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5) and shall be certified by a Responsible Official in a manner consistent with the CAA.² **(R 336.1912)**

Permit Shield

26. Compliance with the conditions of the ROP shall be considered compliance with any applicable requirements as of the date of ROP issuance if either of the following provisions is satisfied. **(R 336.1213(6)(a)(i), R 336.1213(6)(a)(ii))**
 - a. The applicable requirements are included and are specifically identified in the ROP.
 - b. The permit includes a determination or concise summary of the determination by the department that other specifically identified requirements are not applicable to the stationary source.

Any requirements identified in Part E of this ROP have been identified as non-applicable to this ROP and are included in the permit shield.

27. Nothing in this ROP shall alter or affect any of the following:
 - a. The provisions of Section 303 of the CAA, emergency orders, including the authority of the USEPA under Section 303 of the CAA. **(R 336.1213(6)(b)(i))**
 - b. The liability of the owner or operator of this source for any violation of applicable requirements prior to or at the time of this ROP issuance. **(R 336.1213(6)(b)(ii))**
 - c. The applicable requirements of the acid rain program, consistent with Section 408(a) of the CAA. **(R 336.1213(6)(b)(iii))**

- d. The ability of the USEPA to obtain information from a source pursuant to Section 114 of the CAA. **(R 336.1213(6)(b)(iv))**
28. The permit shield shall not apply to provisions incorporated into this ROP through procedures for any of the following:
- a. Operational flexibility changes made pursuant to Rule 215. **(R 336.1215(5))**
 - b. Administrative Amendments made pursuant to Rule 216(1)(a)(i)-(iv). **(R 336.1216(1)(b)(iii))**
 - c. Administrative Amendments made pursuant to Rule 216(1)(a)(v) until the amendment has been approved by the department. **(R 336.1216(1)(c)(iii))**
 - d. Minor Permit Modifications made pursuant to Rule 216(2). **(R 336.1216(2)(f))**
 - e. State-Only Modifications made pursuant to Rule 216(4) until the changes have been approved by the department. **(R 336.1216(4)(e))**
29. Expiration of this ROP results in the loss of the permit shield. If a timely and administratively complete application for renewal is submitted not more than 18 months, but not less than 6 months, before the expiration date of the ROP, but the department fails to take final action before the end of the ROP term, the existing ROP does not expire until the renewal is issued or denied, and the permit shield shall extend beyond the original ROP term until the department takes final action. **(R 336.1217(1)(c), R 336.1217(1)(a))**

Revisions

30. For changes to any process or process equipment covered by this ROP that do not require a revision of the ROP pursuant to Rule 216, the permittee must comply with Rule 215. **(R 336.1215, R 336.1216)**
31. A change in ownership or operational control of a stationary source covered by this ROP shall be made pursuant to Rule 216(1). **(R 336.1219(2))**
32. For revisions to this ROP, an administratively complete application shall be considered timely if it is received by the department in accordance with the time frames specified in Rule 216. **(R 336.1210(10))**
33. Pursuant to Rule 216(1)(b)(iii), Rule 216(2)(d) and Rule 216(4)(d), after a change has been made, and until the department takes final action, the permittee shall comply with both the applicable requirements governing the change and the ROP terms and conditions proposed in the application for the modification. During this time period, the permittee may choose to not comply with the existing ROP terms and conditions that the application seeks to change. However, if the permittee fails to comply with the ROP terms and conditions proposed in the application during this time period, the terms and conditions in the ROP are enforceable. **(R 336.1216(1)(c)(iii), R 336.1216(2)(d), R 336.1216(4)(d))**

Reopenings

34. A ROP shall be reopened by the department prior to the expiration date and revised by the department under any of the following circumstances:
- a. If additional requirements become applicable to this stationary source with three or more years remaining in the term of the ROP, but not if the effective date of the new applicable requirement is later than the ROP expiration date. **(R 336.1217(2)(a)(i))**
 - b. If additional requirements pursuant to Title IV of the CAA become applicable to this stationary source. **(R 336.1217(2)(a)(ii))**
 - c. If the department determines that the ROP contains a material mistake, information required by any applicable requirement was omitted, or inaccurate statements were made in establishing emission limits or the terms or conditions of the ROP. **(R 336.1217(2)(a)(iii))**
 - d. If the department determines that the ROP must be revised to ensure compliance with the applicable requirements. **(R 336.1217(2)(a)(iv))**

Renewals

35. For renewal of this ROP, an administratively complete application shall be considered timely if it is received by the department not more than 18 months, but not less than 6 months, before the expiration date of the ROP. **(R 336.1210(9))**

Stratospheric Ozone Protection

36. If the permittee is subject to Title 40 of the Code of Federal Regulations (CFR), Part 82 and services, maintains, or repairs appliances except for motor vehicle air conditioners (MVAC), or disposes of appliances containing refrigerant, including MVAC and small appliances, or if the permittee is a refrigerant reclaimer, appliance owner or a manufacturer of appliances or recycling and recovery equipment, the permittee shall comply with all applicable standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.
37. If the permittee is subject to 40 CFR Part 82 and performs a service on motor (fleet) vehicles when this service involves refrigerant in the MVAC, the permittee is subject to all the applicable requirements as specified in 40 CFR Part 82, Subpart B, Servicing of Motor Vehicle Air Conditioners. The term "motor vehicle" as used in Subpart B does not include a vehicle in which final assembly of the vehicle has not been completed by the original equipment manufacturer. The term MVAC as used in Subpart B does not include the air-tight sealed refrigeration system used for refrigerated cargo or an air conditioning system on passenger buses using Hydrochlorofluorocarbon-22 refrigerant.

Risk Management Plan

38. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall register and submit to the USEPA the required data related to the risk management plan for reducing the probability of accidental releases of any regulated substances listed pursuant to Section 112(r)(3) of the CAA as amended in 40 CFR 68.130. The list of substances, threshold quantities, and accident prevention regulations promulgated under 40 CFR Part 68, do not limit in any way the general duty provisions under Section 112(r)(1).
39. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall comply with the requirements of 40 CFR Part 68, no later than the latest of the following dates as provided in 40 CFR 68.10(a):
- June 21, 1999,
 - Three years after the date on which a regulated substance is first listed under 40 CFR 68.130, or
 - The date on which a regulated substance is first present above a threshold quantity in a process.
40. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall submit any additional relevant information requested by any regulatory agency necessary to ensure compliance with the requirements of 40 CFR Part 68.
41. If subject to Section 112(r) of the CAA and 40 CFR Part 68, the permittee shall annually certify compliance with all applicable requirements of Section 112(r) as detailed in Rule 213(4)(c)). **(40 CFR Part 68)**

Emission Trading

42. Emission averaging and emission reduction credit trading are allowed pursuant to any applicable interstate or regional emission trading program that has been approved by the Administrator of the USEPA as a part of Michigan's State Implementation Plan. Such activities must comply with Rule 215 and Rule 216. **(R 336.1213(12))**

Permit to Install (PTI)

43. The process or process equipment included in this permit shall not be reconstructed, relocated, or modified unless a PTI authorizing such action is issued by the department, except to the extent such action is exempt from the PTI requirements by any applicable rule.² **(R 336.1201(1))**
44. The department may, after notice and opportunity for a hearing, revoke PTI terms or conditions if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of the PTI or is violating the department's rules or the CAA.² **(R 336.1201(8), Section 5510 of Act 451)**
45. The terms and conditions of a PTI shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by the PTI. If a new owner or operator submits a written request to the department pursuant to Rule 219 and the department approves the request, this PTI will be amended to reflect the change of ownership or operational control. The request must include all of the information required by Subrules (1)(a), (b) and (c) of Rule 219. The written request shall be sent to the appropriate AQD District Supervisor, EGLE.² **(R 336.1219)**
46. If the installation, reconstruction, relocation, or modification of the equipment for which PTI terms and conditions have been approved has not commenced within 18 months of the original PTI issuance date, or has been interrupted for 18 months, the applicable terms and conditions from that PTI, as incorporated into the ROP, shall become void unless otherwise authorized by the department. Furthermore, the person to whom that PTI was issued, or the designated authorized agent, shall notify the department via the Supervisor, Permit Section, EGLE, AQD, P. O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or modification of the equipment allowed by the terms and conditions from that PTI.² **(R 336.1201(4))**

Footnotes:

¹This condition is state-only enforceable and was established pursuant to Rule 201(1)(b).

²This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

B. SOURCE-WIDE CONDITIONS

Part B outlines the Source-Wide Terms and Conditions that apply to this stationary source. The permittee is subject to these special conditions for the stationary source in addition to the general conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply to this source, NA (not applicable) has been used in the table. If there are no Source-Wide Conditions, this section will be left blank.

C. EMISSION UNIT SPECIAL CONDITIONS

Part C outlines terms and conditions that are specific to individual emission units listed in the Emission Unit Summary Table. The permittee is subject to the special conditions for each emission unit in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no conditions specific to individual emission units, this section will be left blank.

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Including Process Equipment & Control Device(s))	Installation Date/ Modification Date	Flexible Group ID
EUUNIT801	Unit 801 - Rolls Royce Avon Model 101G stationary gas turbine installed in 1971. The peak load rating of EUUNIT801 is 18,000 HP at ISO conditions (59 degrees F at sea level).	01-01-1971	NA
EUUNIT802	Unit 802 - General Electric Model LM1600 stationary gas turbine installed in 1994 under Permit #286-93. The peak load rating of EUUNIT802 is 23,000 HP at ISO conditions (59 degrees F at sea level).	01-01-1994	NA
EUUNIT803	Unit 803 - General Electric Model MS3000 stationary gas turbine was installed in 1975. The peak load rating of EUUNIT803 is 14,600 HP at ISO conditions (59 degrees F at sea level).	01-01-1975	NA
EUAPU	Natural gas-fired 962 HP Caterpillar SP-4 emergency engine.	01-01-1996	FGMACTZZZZ
EUIPEMAINT	Routine and emergency venting of natural gas from transmission and distribution systems.	NA	FGRULE285(2)(mm)
EUFIELDMAINT	Routine and emergency venting of field gas from gathering lines.	NA	FGRULE285(2)(mm)

EUUNIT801
EMISSION UNIT CONDITIONS

DESCRIPTION

Unit 801 - Rolls Royce Avon Model 101G stationary gas turbine installed in 1971. The peak load rating of EU--UNIT801 is 18,000 HP at ISO conditions (59 degrees F at sea level).

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall only burn pipeline quality natural gas in EUUNIT801 as defined in 40 CFR 60.331(u). **(R 336.1213(2))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall monitor and record the following operating parameters on a daily basis for EUUNIT801: **(R 336.1213(3))**
 - a. Hours of operation
 - b. Fuel consumption

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

NA

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

**EUUNIT802
 EMISSION UNIT CONDITIONS**

DESCRIPTION

Unit 802 - General Electric Model LM1600 stationary gas turbine installed in 1994 under Permit #286-93. The peak load rating of EUUNIT802 is 23,000 HP at ISO conditions (59 degrees F at sea level).

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

Pollutant	Limit	Time Period/Operating Scenario	Equipment	Monitoring/ Testing Method	Underlying Applicable Requirements
1. CO	123.8 ppmv at 15% oxygen on a dry gas basis ²	Hourly at minimum load*	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)
2. CO	33.3 pph ²	Hourly at minimum load*	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)
3. CO	31.9 ppmv at 15% oxygen on a dry gas basis ²	Hourly at 100% load	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)
4. CO	14.8 pph ²	Hourly at 100% load	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)
5. NO _x	175.2 ppmv at 15% oxygen on a dry gas basis ^{2, a}	Hourly at 100% load	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)
6. NO _x	89 pph ²	Hourly at 100% load	EUUNIT802	SC V.1, SC VI.1	R 336.1201(3)

* Minimum load is defined as turbine operation at 10,990 shaft horsepower or less.

^a In accordance with Rule 213(2) and Rule 213(6), compliance with this streamlined nitrogen oxides emissions limit shall be considered compliance with the nitrogen oxides emissions limit established by **R 336.1201(3)**; and also compliance with the nitrogen oxides emissions limit in **40 CFR 60.332(a)(2)**, an additional applicable requirement that has been subsumed within this condition.

II. MATERIAL LIMIT(S)

1. The permittee shall not burn any fuel in EUUNIT802 which contains total sulfur in excess of 0.8 % by weight (8000 ppmw). **(40 CFR 60.333(b))**

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall only burn pipeline quality natural gas in EUUNIT802 as defined in 40 CFR 60.331(u). **(R 336.1213(2), 40 CFR 60.334(h))**
2. The permittee shall maintain and implement a parameter monitoring plan (PMP) acceptable to the AQD District Supervisor. The PMP shall identify, at a minimum, the range of fuel consumption rate established during the most recent performance test to assure compliance with the respective emission limits of EUUNIT802. **(R 336.1213(2)(a), R 336.1911(b))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall verify NOx and CO emission rates from EUUNIT802 by testing at owner's expense, in accordance with the Department requirements. Testing shall be performed using an approved EPA Method listed in:

Pollutant	Test Method Reference
NOx	40 CFR Part 60, Appendix A
CO	40 CFR Part 60, Appendix A

An alternate method, or a modification to the approved EPA Method, may be specified in an AQD-approved Test Protocol and must meet the requirements of the federal Clean Air Act, all applicable state and federal rules and regulations, and be within the authority of the AQD to make the change. No less than 30 days prior to testing, the permittee shall submit a complete test plan to the AQD Technical Programs Unit and District Office. The AQD must approve the final plan prior to testing, including any modifications to the method in the test protocol that are proposed after initial submittal. The permittee must submit a complete report of the test results to the AQD Technical Programs Unit and District Office within 60 days following the last date of the test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004, 40 CFR 60.335(a), 40 CFR 60.335(b)(1))**

2. The performance test required in SC V.1 must be performed within 5 % at 30, 50, 75, and 90-to-100 % of peak load or at four evenly-spaced load points in the normal operating range of EUUNIT802, including the minimum point in the operating range and 90-to-100 % of peak load, or at the highest achievable load point if 90-to-100 % of peak load cannot be physically achieved in practice. **(40 CFR 60.335(b)(2), R 336.1213(3))**
3. The permittee shall continuously monitor and record the fuel consumption rate in EUUNIT802 during each run of the performance test, to establish an acceptable operating range, for the purposes of the PMP. **(R 336.1213(3))**
4. The permittee shall verify the CO and NOx emission rates from EUUNIT802, at a minimum, every five years from the date of the last test. **(R 336.1213(3), R 336.2001, R 336.2003, R 336.2004)**
5. The permittee shall notify the AQD Technical Programs Unit Supervisor and the District Supervisor not less than 30 days before testing of the time and place before performance tests will be conducted. **(R 336.1213(3))**

See Appendix 5

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall monitor and record the fuel consumption rate on an hourly basis for EUUNIT802. **(R 336.1213(3))**
2. The permittee shall monitor and record the following operating parameters on a daily basis for EUUNIT802: **(R 336.1213(3))**
 - a. Hours of operation
 - b. Average shaft horsepower
3. The permittee shall use one of the following sources of information to demonstrate the gaseous fuel burned in EUUNIT802 is natural gas, as defined in 40 CFR 60.331(u): **(40 CFR 60.334(h)(3))**

- a. The gas quality characteristics in a current, valid purchase contract, tariff sheet or transportation contract for the gaseous fuel, specifying that the maximum total sulfur content of the fuel is 20.0 grains/100 scf or less:
or
- b. Representative fuel sampling data which show that the sulfur content of the gaseous fuel does not exceed 20 grains/100 scf. At a minimum, the amount of fuel sampling data specified in section 2.3.1.4 or 2.3.2.4 of Appendix D to 40 CFR Part 75 is required.

VII. REPORTING

- 1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
- 2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
- 3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
- 4. The permittee shall submit any performance test reports, including an updated PMP, to the AQD Technical Programs Unit and District Office, in a format approved by the AQD. **(R 336.1213(3)(c), R 336.2001(5))**

See Appendix 8

VIII. STACK/VENT RESTRICTION(S)

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed vertically upwards to the ambient air unless otherwise noted:

Stack & Vent ID	Maximum Exhaust Diameter / Dimensions (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVUNIT802	70 ²	40 ²	R 336.1201(3)

IX. OTHER REQUIREMENT(S)

- 1. The permittee shall comply with all applicable requirements of the New Source Performance Standards, as specified in 40 CFR Part 60, Subparts A and GG for Stationary Gas Turbines. **(40 CFR Part 60, Subparts A and GG)**

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).
² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

EUUNIT803 EMISSION UNIT CONDITIONS

DESCRIPTION

Unit 803 - General Electric Model MS3000 stationary gas turbine was installed in 1975. The peak load rating of EUUNIT803 is 14,600 HP at ISO conditions (59 degrees F at sea level).

Flexible Group ID: NA

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee shall only burn pipeline quality natural gas in EUUNIT803 as defined in 40 CFR 60.331(u). **(R 336.1213(2))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. The permittee shall monitor and record the following operating parameters on a daily basis for EUUNIT803: **(R 336.1213(3))**
 - a. Hours of operation
 - b. Fuel consumption

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

NA

Footnotes:

¹This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

²This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

D. FLEXIBLE GROUP SPECIAL CONDITIONS

Part D outlines the terms and conditions that apply to more than one emission unit. The permittee is subject to the special conditions for each flexible group in addition to the General Conditions in Part A and any other terms and conditions contained in this ROP.

The permittee shall comply with all specific details in the special conditions and the underlying applicable requirements cited. If a specific condition type does not apply, NA (not applicable) has been used in the table. If there are no special conditions that apply to more than one emission unit, this section will be left blank.

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FGMACTZZZZ	40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), located at an area source of HAP emissions, existing emergency, spark ignition (SI) RICE greater than 500 brake hp. A RICE is existing if the date of installation is before June 12, 2006.	EUAPU
FGRULE285(2)(mm)	Any emission unit that emits air contaminants and is exempt from the requirements of Rule 201 pursuant to Rule 278, Rule 278a and Rule 285(2)(mm).	EUPIPEMAINT EUFIELDMAINT

FGMACTZZZZ FLEXIBLE GROUP CONDITIONS

DESCRIPTION

40 CFR Part 63, Subpart ZZZZ - National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE), located at an area source of HAP emissions, existing emergency, spark ignition (SI) RICE greater than 500 brake hp. A RICE is existing if the date of installation is before June 12, 2006.

Emission Unit: EUAPU

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. The permittee must comply with the requirements in Item 5 of Table 2d of 40 CFR Part 63, Subpart ZZZZ which apply to each engine in FGMACTZZZZ as specified in the following:
 - a. Change oil and filter every 500 hours of operation or annually, whichever comes first, except as allowed in SC III.2;
 - b. Inspect spark plugs every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and
 - c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.

If the emergency engine is being operated during an emergency and it is not possible to shut down the engine to perform the management practice requirements on the schedule required, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice standard can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under Federal, State or local law has been abated. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. **(40 CFR 63.6603(a), 40 CFR Part 63, Subpart ZZZZ, Table 2d.5)**

2. The permittee may utilize an oil analysis program in order to extend the specified oil change requirement in SC III.1. The oil analysis must be performed at the same frequency specified for changing the oil in SC III.1. **(40 CFR 63.6625(j))**
3. The permittee shall operate and maintain each engine in FGMACTZZZZ and after-treatment control device (if any) according to the manufacturer's emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. **(40 CFR 63.6605, 40 CFR 63.6625(e), 40 CFR 63.6640(a), 40 CFR Part 63, Subpart ZZZZ, Table 6.9)**

4. For each engine in FGMACTZZZZ, the permittee shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. **(40 CFR 63.6625(h))**
5. The permittee may operate each engine in FGMACTZZZZ for no more than 100 hours per calendar year for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per calendar year. **(40 CFR 63.6640(f)(2))**
6. Each engine in FGMACTZZZZ may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing provided in SC III.5. The 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for the permittee to supply power to an electric grid or otherwise supply power as part of a financial arrangement with another entity. **(40 CFR 63.6640(f)(4))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

1. The permittee shall equip and maintain each engine in FGMACTZZZZ with non-resettable hours meters to track the operating hours. **(40 CFR 63.6625(f))**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. If using the oil analysis program, the permittee must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 % from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the permittee must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the permittee must change the oil within 2 business days or before commencing operation, whichever is later. The permittee must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. **(40 CFR 63.6625(j))**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

1. For each engine in FGMACTZZZZ, the permittee shall keep in a satisfactory manner the following:
 - a. A copy of each notification and report that was submitted to comply with 40 CFR Part 63, Subpart ZZZZ, including all documentation supporting any Initial Notification or Notification of Compliance Status that was submitted,
 - b. Records of the occurrence and duration of each malfunction of operation or the air pollution control and monitoring equipment,
 - c. Records of performance tests and performance evaluations,
 - d. Records of all required maintenance performed on the air pollution control and monitoring equipment,

- e. Records of actions taken during periods of malfunction to minimize emissions, including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation.

The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(a), 40 CFR 63.6660)**

2. For each engine in FGMACTZZZZ, the permittee shall keep in a satisfactory manner, records to demonstrate continuous compliance with the operation and maintenance of the engine according to the manufacturer's emission-related operation and maintenance instructions; or of a maintenance plan that provides to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(d), 40 CFR 63.6660, 40 CFR Part 63, Subpart ZZZZ, Table 6.9)**
3. For each engine in FGMACTZZZZ, the permittee shall keep in a satisfactory manner, records of the maintenance conducted to demonstrate that the engine and after-treatment control device (if any) were operated and maintained according to the developed maintenance plan. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(e), 40 CFR 63.6660)**
4. The permittee shall monitor and record, the total hours of operation for each engine in FGMACTZZZZ on a monthly basis, and the hours of operation during emergency and non-emergency service that are recorded through the non-resettable hour meter for each engine in FGMACTZZZZ on a calendar year basis, in a manner acceptable to the AQD District Supervisor. The permittee shall document how many hours are spent for emergency operation, including what classified the operation as emergency and how many hours are spent for emergency operation. The permittee shall keep all records on file and make them available to the department upon request. **(40 CFR 63.6655(f), 40 CFR 63.6660)**
5. The permittee's records must be in a form suitable and readily available for expeditious review according to 40 CFR 63.10(b)(1). **(40 CFR 63.6660(a))**
6. As specified in 40 CFR 63.10(b)(1), the permittee must keep each record for 5-years following the date of each occurrence, measurement, maintenance, corrective action, report, or record. **(40 CFR 63.6660(b))**

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**
3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**

See Appendix 8

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

1. The permittee shall comply with all applicable requirements of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR Part 63, Subparts A and ZZZZ for Stationary Reciprocating Internal Combustion Engines. **(40 CFR Part 63, Subparts A and ZZZZ)**

Footnotes:

¹ This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

² This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

FGRULE285(2)(mm)
FLEXIBLE GROUP CONDITIONS

DESCRIPTION

Any emission unit that emits air contaminants and is exempt from the requirements of Rule 201 pursuant to Rule 278, Rule 278a and Rule 285(2)(mm).

Emission Units: EUPIPEMAINT, EUFIELDMAINT

POLLUTION CONTROL EQUIPMENT

NA

I. EMISSION LIMIT(S)

NA

II. MATERIAL LIMIT(S)

NA

III. PROCESS/OPERATIONAL RESTRICTION(S)

1. For venting of natural gas for routine maintenance or relocation of transmission and distribution systems in amounts greater than 1,000,000 standard cubic feet, the permittee shall, at a minimum, implement measures to assure safety of employees and the public and minimize impacts to the environment. **(R 336.1285(2)(mm)(ii)(B))**
2. For venting of field gas for routine maintenance or relocation of gathering pipelines in amounts greater than 1,000,000 standard cubic feet, the permittee shall, at a minimum, implement measures to assure safety of employees and the public and minimize impacts to the environment. **(R 336.1285(2)(mm)(iii)(B))**

IV. DESIGN/EQUIPMENT PARAMETER(S)

NA

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1213(3)(b)(ii))**

NA

VII. REPORTING

1. Prompt reporting of deviations pursuant to General Conditions 21 and 22 of Part A. **(R 336.1213(3)(c)(ii))**
2. Semiannual reporting of monitoring and deviations pursuant to General Condition 23 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for reporting period July 1 to December 31 and September 15 for reporting period January 1 to June 30. **(R 336.1213(3)(c)(i))**

3. Annual certification of compliance pursuant to General Conditions 19 and 20 of Part A. The report shall be postmarked or received by the appropriate AQD District Office by March 15 for the previous calendar year. **(R 336.1213(4)(c))**
4. For venting of natural gas for routine maintenance or relocation of transmission and distribution systems in amounts greater than 1,000,000 standard cubic feet, the permittee shall notify the AQD District Supervisor prior to a scheduled pipeline venting. **(R 336.1285(2)(mm)(ii)(A))**
5. For venting of natural gas for routine maintenance or relocation of transmission and distribution systems in amounts greater than 1,000,000 standard cubic feet, the permittee shall provide necessary notification in accordance with the Michigan gas safety standards, the federal pipeline and hazardous materials safety administration standards, and the federal energy regulatory commission standards, as applicable. The permittee is not required to copy the AQD on the notifications. **(R 336.1285(2)(mm)(ii)(B))**
6. For venting of field gas for routine maintenance or relocation of gathering pipelines in amounts greater than 1,000,000 standard cubic feet, the permittee shall notify the AQD District Supervisor prior to a scheduled pipeline venting. **(R 336.1285(2)(mm)(iii)(A))**
7. For venting of field gas for routine maintenance or relocation of gathering pipelines in amounts greater than 1,000,000 standard cubic feet, the permittee shall provide necessary notification in accordance with the Michigan Department of Environment, Great Lakes and Energy, Office of Geological Survey, and the Michigan Public Service Commission Standards, as applicable. The permittee is not required to copy the AQD on the notifications. **(R 336.1285(2)(mm)(iii)(B))**
8. For emergency venting of natural gas or field gases in amounts greater than 1,000,000 standard cubic feet per event, the permittee shall notify the pollution emergency alert system (PEAS) within 24 hours of an emergency pipeline venting. For purposes of this requirement, an emergency is considered an unforeseen event that disrupts normal operating conditions and poses a threat to human life, health, property, or the environment if not controlled immediately. **(R 336.1285(2)(mm)(iv))**

See Appendix 8

VIII. STACK/VENT RESTRICTION(S)

NA

IX. OTHER REQUIREMENT(S)

NA

Footnotes:

¹This condition is state only enforceable and was established pursuant to Rule 201(1)(b).

²This condition is federally enforceable and was established pursuant to Rule 201(1)(a).

E. NON-APPLICABLE REQUIREMENTS

At the time of the ROP issuance, the AQD has determined that no non-applicable requirements have been identified for incorporation into the permit shield provision set forth in the General Conditions in Part A pursuant to Rule 213(6)(a)(ii).

APPENDICES

Appendix 1. Acronyms and Abbreviations

Common Acronyms		Pollutant / Measurement Abbreviations	
AQD	Air Quality Division	acfm	Actual cubic feet per minute
BACT	Best Available Control Technology	BTU	British Thermal Unit
CAA	Clean Air Act	°C	Degrees Celsius
CAM	Compliance Assurance Monitoring	CO	Carbon Monoxide
CEM	Continuous Emission Monitoring	CO ₂ e	Carbon Dioxide Equivalent
CEMS	Continuous Emission Monitoring System	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
Department/ department	Michigan Department of Environment, Great Lakes, and Energy	gr	Grains
EGLE	Michigan Department of Environment, Great Lakes, and Energy	HAP	Hazardous Air Pollutant
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallons of Applied Coating Solids	HP	Horsepower
GC	General Condition	H ₂ S	Hydrogen Sulfide
GHGs	Greenhouse Gases	kW	Kilowatt
HVLP	High Volume Low Pressure*	lb	Pound
ID	Identification	m	Meter
IRSL	Initial Risk Screening Level	mg	Milligram
ITSL	Initial Threshold Screening Level	mm	Millimeter
LAER	Lowest Achievable Emission Rate	MM	Million
MACT	Maximum Achievable Control Technology	MW	Megawatts
MAERS	Michigan Air Emissions Reporting System	NMOC	Non-methane Organic Compounds
MAP	Malfunction Abatement Plan	NO _x	Oxides of Nitrogen
MSDS	Material Safety Data Sheet	ng	Nanogram
NA	Not Applicable	PM	Particulate Matter
NAAQS	National Ambient Air Quality Standards	PM10	Particulate Matter equal to or less than 10 microns in diameter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM2.5	Particulate Matter equal to or less than 2.5 microns in diameter
NSPS	New Source Performance Standards	pph	Pounds per hour
NSR	New Source Review	ppm	Parts per million
PS	Performance Specification	ppmv	Parts per million by volume
PSD	Prevention of Significant Deterioration	ppmw	Parts per million by weight
PTE	Permanent Total Enclosure	%	Percent
PTI	Permit to Install	psia	Pounds per square inch absolute
RACT	Reasonable Available Control Technology	psig	Pounds per square inch gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO ₂	Sulfur Dioxide
SNCR	Selective Non-Catalytic Reduction	TAC	Toxic Air Contaminant
SRN	State Registration Number	Temp	Temperature
TEQ	Toxicity Equivalence Quotient	THC	Total Hydrocarbons
USEPA/EPA	United States Environmental Protection Agency	tpy	Tons per year
VE	Visible Emissions	µg	Microgram
		µm	Micrometer or Micron
		VOC	Volatile Organic Compounds
		yr	Year

*For HVLP applicators, the pressure measured at the gun air cap shall not exceed 10 psig.

Appendix 2. Schedule of Compliance

The permittee certified in the ROP application that this stationary source is in compliance with all applicable requirements and the permittee shall continue to comply with all terms and conditions of this ROP. A Schedule of Compliance is not required. (R 336.1213(4)(a), R 336.1119(a)(ii))

Appendix 3. Monitoring Requirements

Specific monitoring requirement procedures, methods or specifications are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 4. Recordkeeping

Specific recordkeeping requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 5. Testing Procedures

Specific testing requirement plans, procedures, and averaging times are detailed in the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 6. Permits to Install

The following table lists any PTIs issued or ROP revision applications received since the effective date of the previously issued ROP No. MI-ROP-N3760-2016. Those ROP revision applications that are being issued concurrently with this ROP renewal are identified by an asterisk (*). Those revision applications not listed with an asterisk were processed prior to this renewal.

Source-Wide PTI No MI-PTI-N3760-2016 is being reissued as Source-Wide PTI No. MI-PTI-N3760-2021.

Permit to Install Number	ROP Revision Application Number	Description of Equipment or Change	Corresponding Emission Unit(s) or Flexible Group(s)
NA	NA	NA	NA

Appendix 7. Emission Calculations

Specific emission calculations to be used with monitoring, testing or recordkeeping data are detailed in the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, this appendix is not applicable.

Appendix 8. Reporting

A. Annual, Semiannual, and Deviation Certification Reporting

The permittee shall use EGLE, AQD, Report Certification form (EQP 5736) and EGLE, AQD, Deviation Report form (EQP 5737) for the annual, semiannual and deviation certification reporting referenced in the Reporting Section of

ROP No: MI-ROP-N3760-2021

Expiration Date: July 6, 2026

PTI No: MI-PTI-N3760-2021

the Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Alternative formats must meet the provisions of Rule 213(4)(c) and Rule 213(3)(c)(i), respectively, and be approved by the AQD District Supervisor.

B. Other Reporting

Specific reporting requirement formats and procedures are detailed in Part A or the appropriate Source-Wide, Emission Unit and/or Flexible Group Special Conditions. Therefore, Part B of this appendix is not applicable.