

# Waste Management Renewable Energy

## Landfill Gas Treatment System Monitoring Data Sheet

### Engine Plants



Name: \_\_\_\_\_ Title: \_\_\_\_\_

	Date	Compressor/Blower Discharge Pressure (1-14 psi)	Within Spec (circle one)	Coalescing Filter Vessel Differential Pressure (0.0-4.0 psi / 2-100 In. WC)	Within Spec (circle one)	Gas Cooler Differential Temperature (> 10F)	Within Spec (circle one)	Corrective Action if out of Specification
January			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
February			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
March			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
April			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
May			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
June			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
July			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
August			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
September			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	

# Waste Management Renewable Energy

## Landfill Gas Treatment System Monitoring Data Sheet

### Engine Plants



Name: \_\_\_\_\_ Title: \_\_\_\_\_

	Date	Compressor/Blower Discharge Pressure (1-14 psi)	Within Spec (circle one)	Coalescing Filter Vessel Differential Pressure (0.0-4.0 psi / 2 - 100 In. WC)	Within Spec (circle one)	Gas Cooler Differential Temperature (> 10F)	Within Spec (circle one)	Corrective Action if out of Specification
October			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
November			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	
December			Yes / No		Yes / No		Yes / No	
			Yes / No		Yes / No		Yes / No	