

RECEIVED

JAN 21 2014

AIR QUALITY DIV.

Report


Emissions Test

Test Date: December 17th, 2013

Otsego Paper, Inc.
320 N. Farmer Street
Otsego, Michigan 49078

NTH Project No. 73-130607-01
January 20, 2014

NTH Consultants, Ltd.
608 S. Washington Avenue
Lansing, MI 48933



RECEIVED

JAN 21 2014



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

AIR QUALITY DIV.

**RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name Otsego Paper, Inc County Allegan

Source Address 320 North Farmer Street City Otsego

AQD Source ID (SRN) A0023 ROP No. MI-ROP-A0023-2013 ROP Section No. NA

Please check the appropriate box(es):

Annual Compliance Certification (Pursuant to Rule 213(4)(c))

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.

2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.

2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

Other Report Certification

Reporting period (provide inclusive dates): From _____ To _____

Additional monitoring reports or other applicable documents required by the ROP are attached as described:
Emissions test report for CO & VOC, conducted at EUTURBINE1 and EUDUCTBURNER1

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

| | | |
|--|----------------------|---------------------|
| <u>Henry Krell</u> | <u>Plant Manager</u> | <u>269-567-3554</u> |
| Name of Responsible Official (print or type) | Title | Phone Number |
| | | <u>1/17/14</u> |
| Signature of Responsible Official | | Date |

* Photocopy this form as needed.

Table of Contents



| | | |
|---------|-----------------------------------|-------------------------------------|
| 1.0 | INTRODUCTION | 1 |
| 1.1 | Purpose of Test | 1 |
| 1.2 | Test Date Requirement | 1 |
| 1.3 | Project Contact Information | 1 |
| 1.4 | Summary of Results | 2 |
| 2.0 | PROCESS DESCRIPTION | 2 |
| 3.0 | TEST REFERENCE METHODOLOGIES | 3 |
| 3.1 | Location of Traverse Points | 3 |
| 3.2 | Velocity and Temperature..... | 4 |
| 3.3 | Molecular Weight..... | 4 |
| 3.4 | Moisture | 4 |
| 3.5 | Carbon Monoxide..... | 4 |
| 3.6 | Total VOCs..... | 4 |
| 3.7 | Data Acquisition System | 5 |
| 4.0 | QUALITY ASSURANCE | 5 |
| 5.0 | DISCUSSION OF RESULTS | 6 |
| TABLES | | |
| | Table 1 | Summary of EUTURBINE1 Results |
| | Table 2 | Summary of EUDUCTBURNER1 Results |
| FIGURES | | |
| | Figure 1 | Method 10, and 25A Sample Schematic |
| | Figure 2 | Point Locations & Port Locations |



Table of Contents (continued)



APPENDICES

| | |
|------------------|--|
| Appendix A | Protocol and Approval letter |
| Appendix B..... | Results, Calculations and Equations |
| Appendix C | Process Data |
| Appendix D..... | Electronic Data |
| Appendix E..... | Handwritten Field Data |
| Appendix F..... | Quality Assurance/Quality Control Data |



NTH Consultants, Ltd.
608 S. Washington Avenue
Lansing, MI 48933
Phone: (517) 484-6900 • Fax: (517) 485-8323
www.nthconsultants.com



1.0 INTRODUCTION

NTH Consultants, Ltd. (NTH) has been retained by Otsego Paper, Inc. (Otsego Paper) to perform emissions testing on the turbine identified as EUTURBINE1 and turbine-duct burner identified as EUDUCTBURNER1 at the Otsego Paper facility in Otsego, Michigan. Testing was conducted for carbon monoxide (CO) and volatile organic compounds (VOCs) from the natural gas-fired combustion turbine (EUTURBINE1), with and without the associated heat recovery steam generators (HRSG) and natural gas-fired duct burner (EUDUCTBURNER1).

1.1 Purpose of Test

The purpose of the CO and VOC testing is to comply with specifications contained in Michigan Department of Environmental Quality (MDEQ) Renewable Operating Permit (ROP) MI-ROP-A0023-2013.

1.2 Test Date Requirement

Testing was completed December 17th, 2013.

1.3 Project Contact Information:

| Location | Address | Contact |
|-----------------------------|---|---|
| Test Facility | Otsego Paper, Inc. 320 North Farmer Street Otsego, Michigan 49078 | Mr. Gary Roys (269) 384-6345 groys@usg.com |
| Test Company Representative | NTH Consultants, Ltd. 1430 Monroe Avenue NW, Suite 180 Grand Rapids, Michigan 49505 | Ms. Lori Myott (517) 202-3295 lmyott@nthconsultants.com |
| State Representative | MDEQ 525 W. Allegan, Constitution Hall 3rd Floor Lansing, MI 48909 | Mr. Nathaniel Hude (517) 284-6779 huden@michigan.gov |



RECEIVED

JAN 21 2014

AIR QUALITY DIV.

1.4 Summary of Results

Table 1-1: Summary of EUTURBINE1 Only Test Results

| Run ¹ | CO | | VOC | |
|------------------|----------------|--------------|----------------|--------------|
| | Measured lb/hr | Permit lb/hr | Measured lb/hr | Permit lb/hr |
| Run 2 | 0.10 | | 0.0 | |
| Run 3 | 0.21 | | 0.0 | |
| Run 4 | 0.00 | | 0.0 | |
| Average | 0.10 | 17 | 0.0 | 0.3 |

¹Run 1 was voided due to an analyzer drift.

Table 1-2: Summary of EUTURBINE1 and EUDUCTBURNER1 Test Results

| Run | CO | | VOC | |
|---------|----------------|--------------|----------------|--------------|
| | Measured lb/hr | Permit lb/hr | Measured lb/hr | Permit lb/hr |
| Run 5 | 1.30 | | 0.04 | |
| Run 6 | 1.06 | | 0.00 | |
| Run 7 | 1.07 | | 0.00 | |
| Average | 1.14 | 8.5 | 0.01 | 2.2 |

2.0 PROCESS DESCRIPTION

The Otsego Paper facility produces electricity from a Mars T-15000 gas turbine, designated as EUTURBINE1, with a maximum heat input rate of 141.5 MMBtu/hr at low temperature operating conditions. Energy is generated at the combustion turbine by drawing in ambient air by means of burning fuel and expanding the hot combustion gases in the turbine. The hot exhaust gases are then directed to a multi-pressure ABCO heat recovery steam generator (HRSG) for steam production.



3.0 REFERENCE METHODOLOGIES

NTH performed the emissions testing using U.S. EPA approved test methods and procedures. Triplicate 60-minute test repetitions for CO and total VOC were conducted using the following U.S. EPA Reference Methods, in accordance with specifications stipulated in Appendix A to 40 CFR Part 60:

- **Method 1:** *Sample and Velocity Traverses for Stationary Sources* will be used to determine the locations of the sample/velocity traverse points and verify the absence of cyclonic flow.
- **Method 2:** *Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)* will be used to determine the exhaust gas velocity, volumetric flow rate, and stack temperature measurements (pitot tube equipped with a thermocouple).
- **Method 3A:** *Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)* will be used to determine the O₂ concentrations and calculate pollutant emission rates, as applicable.
- **Method 4:** *Determination of Moisture Content in Stack Gases* will be used in order to determine the moisture content.
- **Method 10:** *Determination of Carbon Monoxide Emissions from Stationary Sources* will be used to determine the CO concentrations.
- **Method 25A:** *Determination of Total Gaseous Organic Concentration using a Flame Ionization Analyzer* will be used to determine the VOC concentrations.

3.1 Location of Traverse Points

The number of traverse points was determined in accordance with U.S. EPA Reference Method 1. The cross-sectional inside diameter of the stack was measured, and based upon this value and the availability of access ports, traverse points were selected for measuring the exhaust gas velocity pressure, temperature and sampling. Schematics depicting traverse point locations and port locations are shown in Figure 2.



3.2 Velocity and Temperature

The exhaust gas velocities and temperatures were determined in accordance with U.S. EPA Reference Method 2. The exhaust gas velocity was measured using an S-Type pitot tube with an attached thermocouple probe. The Pitot tube was connected to an inclined water column manometer and checked for leaks at five inches of water. The exhaust gas temperature was measured using a calibrated K type thermocouple.

3.3 Molecular Weight

The exhaust gas composition was determined using U.S. EPA Reference Method 3A. The concentrations, taken and analyzed onsite, were used to determine exhaust gas composition and molecular weight.

3.4 Moisture

The exhaust gas moisture content was determined in accordance with U.S. EPA Reference Method 4. The sample was passed through a series of four impingers, with the first two containing deicing fluid (approved by DEQ), the third empty, and the fourth containing silica gel. The amount of water collected was measured gravimetrically to determine moisture content.

3.5 Carbon Monoxide

The CO concentrations were measured using a non-dispersive infrared analyzer (NDIR) following the guidelines of U.S. EPA Reference Method 10. The analyzer was calibrated at a minimum of three points: zero, mid-range (40-60 percent of span), and high range 90-100 percent of the span for the testing.

3.6 Total VOC

VOC concentrations were determined in accordance with U.S. EPA Method 25A. The FIA was used to measure and provide real-time analysis of total VOC. The analyzer was calibrated at three points: a zero gas (nitrogen), a low-range gas (25 to 35 percent of span), and a mid-range gas (45 to 55 percent of span), using propane gas standards. The analyzer was not calibrated at a high-range gas due to nearly negligible VOC concentrations.



3.7 Data Acquisition System

Information and data from each analog instrument signal output was collected with the STRATA® DAS. Calibration error, drift and bias corrections were calculated automatically. All gathered data was linked to spreadsheets that support dynamic data exchange (i.e. Microsoft Excel) for quick data reduction and report generation.

4.0 QUALITY ASSURANCE

Each promulgated U.S. EPA reference method described above is accompanied by a statement indicating that to obtain reliable results, persons using these methods should have a thorough knowledge of the techniques associated with each. To that end, NTH attempts to minimize any factors in the field that could increase error by implementing our quality assurance program into every testing activity segment.

The pitot tubes and thermocouples used to measure the exhaust gas during this test program were calibrated according to the procedures outlined in the *Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III, Stationary Source-Specific Methods, Method 2, Type S Pitot Tube Inspection, and Calibration Procedure 2E Temperature Sensor*.

U.S. EPA Protocol No. 1 gas standards were used to calibrate the analyzers during the test program. These gases are certified according to the *U.S. EPA Traceability Protocol for Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997*, and are certified to have a total relative uncertainty of ± 1 percent.

The DAS software in use during the testing was programmed to the specifications described in the applicable U.S. EPA Method in use during the test, and operated based on each pre-programmed analyzer span value. Calibration error, drift and bias corrections were calculated automatically. All gathered data was linked to spreadsheets that support dynamic data exchange for quick data reduction and report generation.



5.0 DISCUSSION OF RESULTS

Operations appeared normal throughout the testing event; however several minor issues occurred during the testing. The first run on EUTURBINE1 was voided due to an analyzer drift. The deionized water in the Method 4 impingers froze and was replaced with deicing fluid. Afterwards the moisture sample line began freezing, but was shortened to eliminate the issue. These issues were resolved and all tests were completed without further incident. Results indicate that the emissions are all under the limits. A complete summary of results can be found in Tables 1 and 2.

All calculations, results, and field and operational data are contained in Appendices B through E. Appendix F contains the QA/QC data.



TABLES



Table 1
Otsego Paper
EUTURBINE1 100% Load
Summary of CO and VOC Emissions
December 17, 2013

| Run No. | 2 | 3 | 4 | Average |
|--|-------------------|-------------------|-------------------|----------|
| Test Date | December 17, 2013 | December 17, 2013 | December 17, 2013 | |
| Moisture Run Time | 1216-1253 | 1348-1431 | 1640-1715 | |
| Analyzer Run Time | 1144-1244 | 1259-1359 | 1631-1731 | |
| Volumetric Flow Rates | | | | |
| Actual Cubic Feet per Minute: | 129,410 | 129,390 | 130,187 | 129,662 |
| Standard Cubic Feet per Minute: | 80,470 | 80,775 | 80,953 | 80,732 |
| Dry Standard Cubic Feet per Minute: | 75,082 | 75,367 | 76,505 | 75,651 |
| Fixed Gases | | | | |
| Oxygen, % by volume, dry: | 12.23 | 12.23 | 12.23 | 12.23 |
| Carbon dioxide, % by volume, dry: | 4.55 | 4.55 | 4.55 | 4.55 |
| Moisture, % by volume: | 6.70 | 6.70 | 5.49 | 6.29 |
| Run No. | 2 | 3 | 4 | Average |
| Concentration, (ppmvd): | | | | |
| Carbon Monoxide: | 0.30 | 0.63 | 0.00 | 0.31 |
| Volatile Organic Compounds (as propane): | 0.00 | 0.00 | 0.00 | 0.00 |
| Emission Rate, (lb/hr): | | | | |
| Carbon Monoxide: | 0.10 | 0.21 | 0.00 | 0.10 |
| Volatile Organic Compounds (as propane): | 0.00 | 0.00 | 0.00 | 0.00 |
| Emission Rate, (lb/MMBtu): | | | | |
| Carbon Monoxide: | 8.42E-04 | 1.77E-03 | 0.00E+00 | 8.69E-04 |
| Volatile Organic Compounds (as propane): | 0.00E+00 | 0.00E+00 | 0.00E+00 | 0.00E+00 |

ppmvd = parts per million by volume, dry

lb/hr = pounds per hour

lb/MMBtu = pounds per million British thermal units



RECEIVED

JAN 21 2014

AIR QUALITY DIV.

Table 2

Otsego Paper

EUTURBINE1 and EUDUCTBURNER1 100% Load

Summary of CO and VOC Emissions

December 17, 2013

| Run No. | 5 | 6 | 7 | Average |
|--|-------------------|-------------------|-------------------|----------|
| Test Date | December 17, 2013 | December 17, 2013 | December 17, 2013 | |
| Moisture Run Time | 1810-1847 | 1925-2000 | 2045-2119 | |
| Analyzer Run Time | 1802-1902 | 1917-2017 | 2031-2131 | |
| Volumetric Flow Rates | | | | |
| Actual Cubic Feet per Minute: | 131,185 | 129,229 | 132,085 | 130,833 |
| Standard Cubic Feet per Minute: | 85,054 | 83,759 | 85,610 | 84,808 |
| Dry Standard Cubic Feet per Minute: | 77,034 | 75,729 | 77,373 | 76,712 |
| Fixed Gases | | | | |
| Oxygen, % by volume, dry: | 12.23 | 12.23 | 12.23 | 12.23 |
| Carbon dioxide, % by volume, dry: | 4.55 | 4.55 | 4.55 | 4.55 |
| Moisture, % by volume: | 9.43 | 9.59 | 9.62 | 9.55 |
| Run No. | 5 | 6 | 7 | Average |
| Concentration, (ppmvd): | | | | |
| Carbon Monoxide: | 3.86 | 3.19 | 3.16 | 3.40 |
| Volatile Organic Compounds (as propane): | 0.08 | 0.00 | 0.00 | 0.03 |
| Emission Rate, (lb/hr): | | | | |
| Carbon Monoxide: | 1.30 | 1.06 | 1.07 | 1.14 |
| Volatile Organic Compounds (as propane): | 0.04 | 0.00 | 0.00 | 0.01 |
| Emission Rate, (lb/MMBtu): | | | | |
| Carbon Monoxide: | 5.55E-03 | 4.57E-03 | 4.50E-03 | 4.87E-03 |
| Volatile Organic Compounds (as propane): | 1.85E-04 | 0.00E+00 | 0.00E+00 | 6.18E-05 |

ppmvd = parts per million by volume, dry

lb/hr = pounds per hour

lb/MMBtu = pounds per million British thermal units



FIGURES

Figure 1. NTH CEMs/Reference Method Set Up

