



**CONTINUOUS EMISSIONS MONITORING SYSTEM
RELATIVE ACCURACY TEST AUDIT DETERMINATION**

Performed At
**USG-Otsego Paper, Inc.
USG-Otsego Facility
EUTURBINE1 (North – Unit 24)
EUTURBINE2 (South – Unit 25)
Otsego, Michigan**

Test Date
April 13, 2016

Report No.
TRC Environmental Corporation Report 250522A

Report Submittal Date
May 16, 2016

**TRC Environmental Corporation
7521 Brush Hill Road
Burr Ridge, Illinois 60527
USA**

**T (312) 533-2042
F (312) 533-2070**

RECEIVED

MAY 17 2016

AIR QUALITY DIV.

RECEIVED

MAY 17 2016



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

AIR QUALITY DIV.

**RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name USG-Otsego Paper, Inc. County Allegan

Source Address 320 N. Farmer Street City Otsego

AQD Source ID (SRN) A0023 ROP No. MI-ROP-A0023-2013 ROP Section No. 1

Please check the appropriate box(es):

Annual Compliance Certification (Pursuant to Rule 213(4)(c))

Reporting period (provide inclusive dates): From _____ To _____

- 1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.
- 2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))

Reporting period (provide inclusive dates): From _____ To _____

- 1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.
- 2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

Other Report Certification

Reporting period (provide inclusive dates): From _____ To _____
Additional monitoring reports or other applicable documents required by the ROP are attached as described:

Test Protocol for RATA to be conducted on EUTURBINE1, EUDUCTBURNER1,
EUTURBINE2 AND EUDUCTBURNER2

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

<u>Henry Krell</u>	<u>Plant Manager</u>	<u>269-692-6141</u>
Name of Responsible Official (print or type)	Title	Phone Number
		<u>5/13/16</u>
Signature of Responsible Official		Date

* Photocopy this form as needed.



RECEIVED

MAY 17 2016

AIR QUALITY DIV.

CONTINUOUS EMISSIONS MONITORING SYSTEM
RELATIVE ACCURACY TEST AUDIT DETERMINATION

1.0 INTRODUCTION

TRC Environmental Corporation (TRC) performed an oxides of nitrogen (NO_x) and oxygen (O₂) relative accuracy test audit (RATA) determination of the continuous emission monitoring system (CEMS) associated with the natural gas fired combustion turbines EUTURBINE1 (North-Unit 24) and EUTURBINE2 (South-Unit 25) on April 13, 2016 at the USG-Otsego Paper, Inc. facility located in Otsego, Michigan. The tests were authorized by and performed for USG-Otsego Paper, Inc.

This test program was performed to demonstrate compliance with Michigan Department of Environmental Quality (MDEQ) Renewable Operating Permit (ROP) No. MI-ROP-A0023-2013 and the CAIR Ozone Nitrogen Oxide Budget Permit No. MI-NOO-55799-2013 in Appendix 9 of the ROP. The test program was conducted according to the TRC Test Protocol 250522 dated February 2, 2016.

1.1 Project Contact Information

Participants		
Test Facility	USG-Otsego Paper, Inc. USG-Otsego Facility 320 N. Farmer Street Otsego, Michigan 49078	Franklin Knowles Environmental Compliance Supervisor 269-384-6351 (phone) fknowles@usg.com
Air Emissions Testing Body (AETB)	TRC Environmental Corporation 7521 Brush Hill Road Burr Ridge, Illinois 60527	Benigno Cacao Field Team Leader 312-533-2042 (phone) bcacao@trcsolutions.com
State Representative	MDEQ – Air Quality Division Constitution Hall 525 West Allegan Street Lansing, Michigan 48909	David Patterson Environmental Quality Analyst Technical Programs Unit 517-284-6782 (phone) pattersond2@michigan.gov

The tests were coordinated through Franklin Knowles, Environmental Compliance Supervisor, of Otsego Paper and conducted by Skylar Rothgeb and Benigno Cacao of TRC. David Patterson of Michigan Department of Environmental Quality (MDEQ) observed the testing. Documentation of the on-site ASTM D7036-04 Qualified Individual(s) (QI) can be found in the appendix to this report.



2.0 FACILITY DESCRIPTION

Otsego Paper, Inc is a subsidiary of the United States Gypsum Company. The facility manufactures gypsum paper.

The Otsego Paper facility produces electricity from two (2) Mars T-15000 gas turbines, designated as EUTURBINE1 and EUTURBINE2, with a maximum heat input rate of 141.5 million British thermal unit per hour (MMBtu/hr) at low temperature operating conditions as measured on a higher heating value (HHV) basis. Energy is generated at the combustion turbine by drawing in ambient air by means of burning fuel and expanding the hot combustion gases in the turbine. The hot exhaust gases of each turbine are directed to a multi-pressure ABCO heat recovery steam generator (HRSG). There are also natural gas-fired duct burners associated with each HRSG and coupled to a turbine, designated as EUDUCTBURNER1 and EUDUCTBURNER2, respectively.

The facility has one paper machine, No. 1 Paper Machine (EUPAPERMACHINE1), used to produce paper from 100 percent recycle stock and corrugated material. The paper machine has three fourdriniers and is capable of producing a triple ply sheet.

Plant capacity for base load operations is 11 megawatts (MW) for each turbine and 160,000 pounds per hour (lb/hr) of steam for each HRSG.

EUTURBINE1 and EUTURBINE2 each have a maximum heat input rate of 141.5 MMBtu/hr at low temperature operating conditions.



3.0 SUMMARY OF RESULTS

3.1 CEMS RATA Test Matrix

Parameter	Reference Methods (RM)	No. of Test Runs	Test Run Length (min)
NO _x	7E, 3A	10	21
O ₂	3A	10	21

3.2 CEMS RATA Results

EUTURBINE1 (Unit 24)						
Load (MW)	Parameter	Units	Performance Specifications (40CFR75)		CEMS Performance	
			Semi-Annual	Annual	Relative Accuracy	Bias Adjustment Factor
~10.0	NO _x	lb/MMBtu	7.5% < RA ≤ 10.0%	RA ≤ 7.5%	3.55 %	1.000
Load (MW)	Parameter	Units	Performance Specifications (40CFR60)		CEMS Performance	
			Specification No.	Acceptance Criteria	Relative Accuracy	
~10.0	NO _x	ppmvd @ 15% O ₂	2	RA ≤ 20%	3.46 %	
	O ₂	%	3	RA ≤ 1.0% difference for %O ₂	0.32 %	

EUTURBINE2 (Unit 25)						
Load (MW)	Parameter	Units	Performance Specifications (40CFR75)		CEMS Performance	
			Semi-Annual	Annual	Relative Accuracy	Bias Adjustment Factor
~10.0	NO _x	lb/MMBtu	7.5% < RA ≤ 10.0%	RA ≤ 7.5%	3.54 %	1.000
Load (MW)	Parameter	Units	Performance Specifications (40CFR60)		CEMS Performance	
			Specification No.	Acceptance Criteria	Relative Accuracy	
~10.0	NO _x	ppmvd @ 15% O ₂	2	RA ≤ 20%	3.74 %	
	O ₂	%	3	RA ≤ 1.0% difference for %O ₂	0.40 %	



Based on the above summary of results, the facility CEMS passed the RATA. The complete test results from this program are tabulated in Section 7.0

4.0 DISCUSSION OF RESULTS

The data acquisition and handling system (DAHS) computer printout for the same time periods as TRC's reference method (RM) testing was used to determine the relative accuracy (RA) of the CEMS. The watches of the test crew were synchronized with the facility's CEM system prior to the commencement of and during each test run. A total of ten (10) RATA runs, each 21-minutes in duration, were performed at each turbine unit location while operating within 90% of maximum load. The CEMS RATA data, comprised of twenty-one (21) minutes of data points for each test run, was provided to TRC by the facility.

No problems were encountered with the testing equipment during the course of the test program. Source operation appeared normal during the entire test program. Each turbine was operated near base load during the RATA.

Data collected from the O₂ and NO_x analyzers were averaged for each test run. A standard fuel factor of 8,710 dscf/MMBtu was used to calculate the NO_x emission rates on a pound per million Btu basis (lb/MMBtu) following the guidelines of USEPA Method 19.

5.0 TEST PROCEDURES

All testing, sampling, analytical, and calibration procedures used for this test program were performed in accordance with the methods presented in the following sections. Where applicable, the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, Stationary Source Specific Methods, USEPA 600/R-94/038c, September 1994 was used to supplement procedures.

5.1 Determination of the Concentration of Gaseous Pollutants Using a Multi-Pollutant Sampling System

Concentrations of the pollutants in the following sub-sections were determined using one sampling system. The number of points at which sample was collected was determined in accordance with 40CFR75 Appendix A, Section 6.5.6. Sampling was performed at three points (16.7%, 50%, and 83.3%) across one diameter of each turbine exhaust stack.

A straight-extractive sampling system was used. A data logger continuously recorded pollutant concentrations and generated one-minute averages of those concentrations. All calibrations and system checks were conducted using USEPA Protocol gases. Three-



point linearity checks were performed prior to sampling, and in the event of a failing system bias or drift test (and subsequent corrective action). System bias and drift checks were performed using the low-level gas and either the mid- or high-level gas prior to and following each test run.

The Low Concentration Analyzers (those that routinely operate with a calibration span of less than 20 ppm) used by TRC are ambient-level analyzers. Per Section 3.12 of Method 7E, a Manufacturer's Stability Test is not required for ambient-level analyzers. Analyzer interference tests were conducted in accordance with the regulations in effect at the time that TRC placed an analyzer model in service.

5.1.1 O₂ Determination by USEPA Method 3A

This method is applicable for the determination of O₂ concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The O₂ analyzer was equipped with a paramagnetic-based detector.

5.1.2 NO_x Determination by USEPA Method 7E

This method is applicable for the determination of NO_x concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The NO_x analyzer used a photomultiplier tube to measure the light emitted from the chemiluminescent decomposition of NO₂. A NO_x converter efficiency test was performed on site. The results show the NO_x analyzer passed. Results are appended.

5.1.3 Determination of F-Factors by USEPA Method 19

This method is applicable for the determination of the pollutant emission rate using oxygen (O₂) concentrations and the appropriate F factor (the ratio of combustion gas volumes to heat inputs) and the pollutant concentration. The appropriate F-Factor was selected from Table 19-2 of Method 19.



6.0 QUALITY ASSURANCE PROCEDURES

TRC integrates our Quality Management System (QMS) into every aspect of our testing service. We follow the procedures specified in current published versions of the test Method(s) referenced in this report. Any modifications or deviations are specifically identified in the body of the report. We routinely participate in independent, third party audits of our activities, and maintain:

- Louisiana Environmental Lab Accreditation Program (LELAP) accreditation;
- Accreditation from the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA) that our operations conform with the requirements of ASTM D 7036 as an Air Emission Testing Body (AETB).

These accreditations demonstrate that our systems for training, equipment maintenance and calibration, document control and project management will fully ensure that project objectives are achieved in a timely and efficient manner with a strict commitment to quality.

All calibrations are performed in accordance with the test Method(s) identified in this report. If a Method allows for more than one calibration approach, or if approved alternatives are available, the calibration documentation in the appendices specifies which approach was used. All measurement devices are calibrated or verified at set intervals against standards traceable to the National Institute of Standards and Technology (NIST). NIST traceability information is available upon request.

ASTM D7036-04 specifies that: *"AETBs shall have and shall apply procedures for estimating the uncertainty of measurement. Conformance with this section may be demonstrated by the use of approved test protocols for all tests. When such protocols are used, reference shall be made to published literature, when available, where estimates of uncertainty for test methods may be found."* TRC conforms with this section by using approved test protocols for all tests.



7.0 TEST RESULTS SUMMARIES



RATA Type: Nitrogen Oxides (NO_x), lb/MMBtu
Regulation: 40CFR75
RM Used: 3A, 7E

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE1 (North)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240071	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO _x lb/MMBtu	CEM NO _x lb/MMBtu	(RM-CEM) Difference (di)	
1	1	4/13/16	6:49	7:09	0.063	0.065	-0.002	
1	2	4/13/16	7:31	7:51	0.066	0.068	-0.002	
1	3	4/13/16	8:14	8:34	0.068	0.070	-0.002	
0	4	4/13/16	8:52	9:12	0.070	0.073	-0.003	
1	5	4/13/16	9:31	9:51	0.072	0.074	-0.002	
1	6	4/13/16	10:25	10:45	0.074	0.075	-0.001	
1	7	4/13/16	11:03	11:23	0.076	0.077	-0.001	
1	8	4/13/16	11:44	12:04	0.075	0.078	-0.003	
1	9	4/13/16	12:24	12:44	0.075	0.077	-0.002	
1	10	4/13/16	13:04	13:24	0.075	0.078	-0.003	

n	9	
t(0.025)	2.306	
Mean RM Value	0.072	RM avg
Mean CEM Value	0.074	CEM avg
Mean Difference	-0.0020	d avg
Standard Deviation	0.001	sd
Confidence Coefficient	0.001	CC
RA based on RM	3.55	%
Bias Adjustment Factor	1.000	BAF



RATA Type: Nitrogen Oxides (NO_x), ppmvd at 15% Oxygen
Regulation: 40CFR60
RM Used: 7E

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE1 (North)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240071	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO _x ppmvd at 15% Oxygen	CEM NO _x ppmvd at 15% Oxygen	(RM-CEM) Difference (di)	
1	1	4/13/16	6:49	7:09	17.1	17.7	-0.600	
1	2	4/13/16	7:31	7:51	18.0	18.4	-0.400	
1	3	4/13/16	8:14	8:34	18.4	19.0	-0.600	
1	4	4/13/16	8:52	9:12	19.0	19.7	-0.700	
1	5	4/13/16	9:31	9:51	19.4	20.0	-0.600	
1	6	4/13/16	10:25	10:45	20.1	20.3	-0.200	
1	7	4/13/16	11:03	11:23	20.5	21.0	-0.500	
1	8	4/13/16	11:44	12:04	20.4	21.1	-0.700	
1	9	4/13/16	12:24	12:44	20.4	21.0	-0.600	
0	10	4/13/16	13:04	13:24	20.3	21.1	-0.800	

n	9	
t(0.975)	2.306	
Mean RM Value	19.256	RM avg
Mean CEM Value	19.800	CEM avg
Mean Difference	-0.544	d avg
Sum of Differences ²	2.870	di ²
Standard Deviation	0.159	sd
Confidence Coefficient	0.122	CC
RA based on RM	3.46	%



RATA Type: Oxygen (O₂), % by volume
Regulation: 40CFR60
RM Used: 3A

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE1 (North)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240071	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM O ₂ % v/v dry	CEM O ₂ % v/v dry	(RM-CEM) Difference (di)	
0	1	4/13/16	6:49	7:09	15.5	15.9	-0.400	
1	2	4/13/16	7:31	7:51	15.6	15.9	-0.300	
1	3	4/13/16	8:14	8:34	15.6	15.9	-0.300	
1	4	4/13/16	8:52	9:12	15.6	15.9	-0.300	
1	5	4/13/16	9:31	9:51	15.6	15.9	-0.300	
1	6	4/13/16	10:25	10:45	15.6	15.9	-0.300	
1	7	4/13/16	11:03	11:23	15.5	15.9	-0.400	
1	8	4/13/16	11:44	12:04	15.5	15.9	-0.400	
1	9	4/13/16	12:24	12:44	15.6	15.9	-0.300	
1	10	4/13/16	13:04	13:24	15.6	15.9	-0.300	

n	9	
t(0.975)	2.306	
Mean RM Value	15.578	RM avg
Mean CEM Value	15.900	CEM avg
Mean Difference	-0.322	d avg
Standard Deviation	0.044	sd
Confidence Coefficient	0.034	CC
RA (Absolute Mean Difference)	0.32	%vol diff.



RATA Type: Nitrogen Oxides (NO_x), lb/MMBtu
Regulation: 40CFR75
RM Used: 3A, 7E

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE 2 (South)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240073	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO _x lb/MMBtu	CEM NO _x lb/MMBtu	(RM-CEM) Difference (di)	
1	1	4/13/16	13:58	14:18	0.090	0.093	-0.003	
1	2	4/13/16	14:36	14:56	0.089	0.093	-0.004	
1	3	4/13/16	15:14	15:34	0.109	0.113	-0.004	
1	4	4/13/16	15:54	16:14	0.110	0.114	-0.004	
1	5	4/13/16	16:35	16:55	0.110	0.113	-0.003	
1	6	4/13/16	17:14	17:34	0.110	0.113	-0.003	
1	7	4/13/16	17:51	18:11	0.110	0.113	-0.003	
0	8	4/13/16	18:29	18:49	0.110	0.114	-0.004	
1	9	4/13/16	19:14	19:34	0.109	0.112	-0.003	
1	10	4/13/16	19:52	20:12	0.109	0.112	-0.003	

n	9	
t(0.025)	2.306	
Mean RM Value	0.105	RM avg
Mean CEM Value	0.108	CEM avg
Mean Difference	-0.0033	d avg
Standard Deviation	0.000	sd
Confidence Coefficient	0.000	CC
RA based on RM	3.54	%
Bias Adjustment Factor	1.000	BAF



RATA Type: Nitrogen Oxides (NO_x), ppmvd at 15% Oxygen
Regulation: 40CFR60
RM Used: 7E

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE 2 (South)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240073	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM NO _x ppmvd at 15% Oxygen	CEM NO _x ppmvd at 15% Oxygen	(RM-CEM) Difference (di)	
1	1	4/13/16	13:58	14:18	24.5	25.2	-0.700	
1	2	4/13/16	14:36	14:56	24.2	25.2	-1.000	
1	3	4/13/16	15:14	15:34	29.5	30.7	-1.200	
0	4	4/13/16	15:54	16:14	29.8	31.0	-1.200	
1	5	4/13/16	16:35	16:55	29.8	30.8	-1.000	
1	6	4/13/16	17:14	17:34	29.8	30.7	-0.900	
1	7	4/13/16	17:51	18:11	29.8	30.8	-1.000	
1	8	4/13/16	18:29	18:49	29.8	30.8	-1.000	
1	9	4/13/16	19:14	19:34	29.5	30.5	-1.000	
1	10	4/13/16	19:52	20:12	29.7	30.4	-0.700	

n	9	
t(0.975)	2.306	
Mean RM Value	28.511	RM avg
Mean CEM Value	29.456	CEM avg
Mean Difference	-0.944	d avg
Sum of Differences ²	8.230	di ²
Standard Deviation	0.159	sd
Confidence Coefficient	0.122	CC
RA based on RM	3.74	%



RATA Type: Oxygen (O₂), % by volume
Regulation: 40CFR60
RM Used: 3A

Customer:		Otsego Paper, Inc.			Project #:		250522	
Unit ID:		EUTURBINE 2 (South)			CEM Model:		Horiba/CMA-EC622	
Sample Loc:		Stack			CEM Serial #:		41678240073	
Use? 1 = Y 0 = N	Test Run	Date	Start Time	End Time	RM O ₂ % v/v dry	CEM O ₂ % v/v dry	(RM-CEM) Difference (di)	
1	1	4/13/16	13:58	14:18	15.5	15.9	-0.400	
1	2	4/13/16	14:36	14:56	15.5	15.9	-0.400	
1	3	4/13/16	15:14	15:34	15.5	15.9	-0.400	
1	4	4/13/16	15:54	16:14	15.5	15.9	-0.400	
1	5	4/13/16	16:35	16:55	15.5	15.9	-0.400	
1	6	4/13/16	17:14	17:34	15.5	15.9	-0.400	
1	7	4/13/16	17:51	18:11	15.5	15.9	-0.400	
1	8	4/13/16	18:29	18:49	15.5	15.9	-0.400	
0	9	4/13/16	19:14	19:34	15.5	15.9	-0.400	
1	10	4/13/16	19:52	20:12	15.5	15.9	-0.400	

n	9	
t(0.975)	2.306	
Mean RM Value	15.500	RM avg
Mean CEM Value	15.900	CEM avg
Mean Difference	-0.400	d avg
Standard Deviation	0.000	sd
Confidence Coefficient	0.000	CC
RA (Absolute Mean Difference)	0.40	%vol diff.