



ADVANCED INDUSTRIAL RESOURCES

RECEIVED

OCT 31 2016

AIR QUALITY DIV.

PERMIT (ROP) COMPLIANCE TEST REPORT
No. 11 BOILER
AT
ESCANABA PAPER COMPANY
ESCANABA, MICHIGAN
PROJECT ID: KR- 9563

PREPARED FOR:



VERSO

Escanaba Paper Company

7100 COUNTY ROAD 426

ESCANABA, MICHIGAN 49829

PREPARED BY:

ADVANCED INDUSTRIAL RESOURCES, INC.

3407 NOVIS POINTE

ACWORTH, GEORGIA 30101

Test Date:

AUGUST 30-31, 2016



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

RECEIVED

OCT 31 2016

RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION

AIR QUALITY DIV.

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name Verso Corporaion - Escanaba Paper Company County Delta

Source Address 7100 County Rd 426, PO Box 757 City Escanaba

AQD Source ID (SRN) A0884 ROP No. MI-ROP-A0884-2016 ROP Section No. 1

Please check the appropriate box(es):

Annual Compliance Certification (Pursuant to Rule 213(4)(c))

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.

2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))

Reporting period (provide inclusive dates): From _____ To _____

1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.

2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

Other Report Certification

Reporting period (provide inclusive dates): From 2/26/16 To 2/26/21

Additional monitoring reports or other applicable documents required by the ROP are attached as described:
No. 11 and No. 9 Boilers ROP Compliance Test Reports, August - September 2016

- Testing was conducted in accordance with the approved test plans and sources were operating under maximum routine operating conditions.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

<u>Matt Archambeau</u>	<u>Mill Manager</u>	<u>906-233-1660</u>
Name of Responsible Official (print or type)	Title	Phone Number
		<u>10/26/16</u>
Signature of Responsible Official		Date

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

The Verso Corporation operates The Escanaba Paper Company (EPC) pulp and paper mill in Escanaba, Michigan. Processes at the facility include the No. 11 Boiler. The facility is operated under the Michigan Department of Environmental Quality (MDEQ) issued Renewable Operating Permit (ROP) Number MI-ROP-A0884-2016.

Testing was conducted on the No. 11 Boiler exhaust duct and stack to quantify the emissions of particulate matter (total filterable) and carbon monoxide.

The field sampling portion of the test program was conducted on August 30-31, 2016, in accordance with the site-specific Test Plan submitted to the MDEQ. All test methods and procedures were performed by Advanced Industrial Resources, Inc. (AIR) in accordance with approved USEPA Methods (i.e., 40 CFR 60 Appendix A Methods 1, 2, 3a, 4, 5, 10 and 19).

1.2 KEY PERSONNEL

The key personnel who coordinated the test program and their telephone numbers are:

Paula LaFleur, Escanaba Paper Company	906-233-2603
Derek Stephens, <i>QSTI I-IV</i> , Advanced Industrial Resources	404-843-2100
Scott Wilson, Advanced Industrial Resources	800-224-5007

RECEIVED

OCT 31 2016

AIR QUALITY DIV.

2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS

2.1 PROCESS & CONTROL EQUIPMENT DESCRIPTION

Escanaba Paper Company operates a pulp and paper mill in Escanaba, Michigan. Processes at the facility include the No. 11 Boiler.

The No. 11 Boiler (EU11B68), installed 1981, modified 1986, is an ABB Combustion Engineering combination fuel boiler rated for 750,000 pounds of steam per hour (approximately 1040 million BTU per hour heat input) that provides steam for mill processes and steam turbine-generators for producing electricity. The No. 11 Boiler burns natural gas and solid fuels, which include pulverized coal, wood residue, wastewater treatment plant residuals, Tire-Derived Fuel (TDF), and non-hazardous secondary material (NHSM) engineered fuel pellets. Emissions from the No. 11 Boiler are controlled by an over-fired air system (OAF), multi-clone, and electrostatic precipitator. Opacity is monitored by a COMS which meets the design, installation, performance and certification requirements of Performance Specification 1 under Appendix B of 40 CFR 60 and the quality assurance requirements of Procedure 2 under Appendix F to 40 CFR 60. The COMS also meets the requirements of 63.7525. The boiler utilizes an oxygen trim system to maintain optimum air to fuel ratios.

2.2 SAMPLING LOCATION

The sampling location for PM emissions testing on the No. 11 Boiler exhaust is located at greater than 8.0 equivalent diameters downstream from the nearest upstream flow disturbance and at least 2.0 equivalent diameters upstream from the stack exhaust. The exhaust stack has a circular cross-section with an internal diameter of 168.0 inches. The stack has four sampling ports oriented on a 90 degree horizontal plane perpendicular to the exhaust flow direction. A schematic diagram of the sampling location is presented in Appendix D. Twelve (12) sampling points (three points per port) were used for USEPA Methods 2, 3A, 4 and 5 sampling, in accordance with USEPA Method 1 requirements.

The sampling location for CO emissions testing on the No. 11 Boiler exhaust is located within the duct prior to the breach of the No. 11 Boiler stack which is within the vicinity

of the facility's CEMS probes and is where annual RATA certification tests are conducted. This sample location is rectangular and is equipped with a single sample port. Previous testing and certification of the facility's CEMS has indicated an absence of stratification at this sample location. Therefore, sampling was conducted within the centroidal region of the duct for Methods 3A and 10.

3.0 SUMMARY AND DISCUSSION OF TEST RESULTS

3.1 OBJECTIVES

The purpose of the testing was to establish compliance with the applicable emissions limits set-forth in the facility's ROP. Because this testing was conducted simultaneously and in conjunction with Boiler MACT performance testing (for PM, Hg, HCl and CO), testing was conducted under two (2) separate operating conditions - while firing coal, bark, and gas (Condition #1) and firing only coal and bark (Condition #2). Although included in this report for completeness, **Condition #1 was not intended to demonstrate compliance with ROP CO limit, but instead to establish Boiler MACT operational parameters of maximum steam flow and minimum O₂ (see section 3.2 items of note for additional explanation).**

3.2 FIELD TEST CHANGES, PROBLEMS, OR ITEMS OF NOTE

The testing was conducted in accordance with the Site-Specific Test Protocol submitted to the MDEQ. No problems were encountered during testing that required deviation from the planned test protocol.

Items of note include the following:

- 1) As noted in the Objective section above and shown in Table 3-1, the ROP CO emission limit of 0.50 lb/mmBTU was not achieved under the Condition #1 operational scenario used for Boiler MACT performance testing. CO emissions were well within the Boiler MACT emission limit (3500 ppm @ 3% O₂) during this test, but not the more stringent ROP emission limit. Because the goal of the Condition #1 test was to establish the Boiler MACT operating parameters of maximum boiler loading and minimum O₂ and to demonstrate compliance with the Boiler MACT CO emission limit, boiler operating conditions were not appropriate for the determination of ROP CO compliance under normal operating conditions. CO emissions during the Condition #1 test were abnormally high due to the low O₂ levels and high operating load required to establish the Boiler MACT operating parameters. During Condition #2, the boiler operated under a

more typical load and O₂ level. Condition #2 CO emissions were well below the ROP emission limit.

- 2) As indicated in the Test Plan, oxygen and carbon dioxide emission concentrations utilized to quantify the molecular weight of the exhaust stack gases as well as to determine the heat input (MMBtu/hr) using F-factor methodology were collected in integrated bag samples at the stack in the same location as the PM emission tests. Additionally, oxygen concentrations were also collected at the 'breach' location where the CO emission concentrations were quantified

3.3 PRESENTATION OF TEST RESULTS

Emission rates and concentrations are summarized and compared to ROP limits in Table 3-1. Complete emissions data are presented in Appendix A and Reduced and tabulated data from the field-testing is included in Appendix B. The calculations and nomenclature used to reduce the data are presented in Appendix C. Actual raw field data sheets are presented in Appendix D. Laboratory reports and custody records are presented in Appendix E.

TABLE 3-1: Results Summary - Facility Permit (ROP) Emission Standards

Source	Operating Condition	Pollutant	Average Measured	Allowable	Units	% of Allowable
No. 11 Power Boiler	Condition 1 (Gas, Bark, & Coal)	PM	0.002	0.06*	lb / MMBtu	3%
		CO	0.97	0.50*	lb / MMBtu	194%**
	Condition 2 (Bark & Coal only)	PM	0.003	0.06*	lb / MMBtu	5%
		CO	0.03	0.50*	lb / MMBtu	5%

*limit when firing solid fuels

**Condition 1 was designed for Boiler MACT performance testing purposes, not ROP compliance. See section 3.0 discussion.

3.4 PROCESS OPERATION DATA

All essential process and control device monitoring equipment was operating and data was being recorded throughout the test periods. Data collected is presented in Appendix

G and includes heat input rates per fuel type, applicable CEMS and COMS data, control device operating parameters and steam production rates.

RECEIVED

OCT 31 2016

AIR QUALITY DIV.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

Emission rate testing was performed on the No. 11 Power Boiler exhaust in accordance with 40 *CFR* 60 Appendix A. Specifically:

- EPA Method 1 was used for the qualification of the location of sampling ports and for the determination of the number and positions of stack traverse points, as applicable to sample traverses for Method 2.
- EPA Method 2 was employed for the determination of the stack gas velocity and volumetric flow rate during stack sampling using the Type "S" Pitot tube.
- EPA Method 3A was used for the calculation of the density and dry molecular weight of the effluent stack gas as well as to determine the oxygen and carbon dioxide concentrations using a calibrated instrumental analyzer.
- EPA Method 4 was used for the determination of moisture content.
- EPA Method 5 was used for the determination of total filterable particulate matter.
- EPA Method 10 was used for the determination of carbon monoxide emission concentrations.
- EPA Method 19 was to determine the heat input of the boiler and was used to report the applicable emissions in the units of lbs/MMBtu.

All samples were stored upright in a closed sample box until final laboratory analysis. In order to limit the chain of custody, only essential *AIR* personnel are permitted access to these samples.

5.0 QUALITY ASSURANCE ACTIVITIES

The quality assurance/quality control (QA/QC) measures associated with the sampling and analysis procedures given in the noted EPA reference methodologies, in Subparts A of 40 *CFR* 60 and 40 *CFR* 63, and in the *EPA QA/QC Handbook*, Volume III (EPA 600/R-94/038c) were employed, as applicable. Such measures included, but were not limited to, the procedures detailed below.

5.1 PROBE NOZZLE DIAMETER CHECKS

Probe nozzles were calibrated before field testing by measuring the internal diameter of the nozzle entrance orifice along three different diameters. Each diameter was measured to the nearest 0.001 inch, and all measurements were averaged. The diameters were within the limit of acceptable variation of 0.004”.

5.2 PITOT TUBE FACE PLANE ALIGNMENT CHECK

Before field testing, each Type S Pitot tube was examined in order to verify that the face planes of the tube were properly aligned, per Method 2 of 40 *CFR* 60, Appendix A. The external tubing diameter and base-to-face plane distances were measured in order to verify the use of 0.84 as the baseline (isolated) Pitot coefficient. At that time the entire probe assembly (i.e., the sampling probe, nozzle, thermocouple, and Pitot tube) was inspected in order to verify that its components met the interference-free alignment specifications given in EPA Method 2. Because the specifications were met, then the baseline Pitot coefficient was used for the entire probe assembly.

After field testing, the face plane alignment of each Pitot tube was checked. No damage to the tube orifices was noted.

5.3 METERING SYSTEM CALIBRATION

Every three months each dry gas meter (DGM) console is calibrated at five orifice settings according to Method 5 of 40 *CFR* 60, Appendix A. From the calibration data, calculations of the values of Y_m and $\Delta H_{@}$ are made, and an average of each set of values

is obtained. The limit of total variation of Y_m values is ± 0.02 , and the limit for $\Delta H_{@}$ values is ± 0.20 .

After field testing, the calibration of the DGM console was checked by performing three calibration runs at a single intermediate orifice setting that is representative of the range used during field-testing. Each DGM was within the limit of acceptable relative variation from Y_m of 5.0%.

5.4 TEMPERATURE GAUGE CALIBRATION

After field testing, the temperature measuring instruments on each sampling train was calibrated against standardized mercury-in-glass reference thermometers. Each indicated temperature was within the limit of acceptable variation between the absolute reference temperature and the absolute indicated temperature of 1.5%.

5.5 GAS ANALYZER CALIBRATION

5.5.1 CALIBRATION GAS CONCENTRATION VERIFICATION

AIR obtained a certificate from the gas manufacturer and confirmed that the documentation included all information required by the Environmental Protection Agency Traceability Protocol No. 1. AIR confirmed that the manufacturer certification was complete and current and that calibration gases certifications had not expired. This documentation was available on-site for inspection during testing and is presented in Appendix E.

5.5.2 MEASUREMENT SYSTEM PREPARATION

AIR assembled, prepared, and preconditioned each measurement system by following the manufacturer's written instructions for preparing and preconditioning each gas analyzer and, as applicable, the other system components. AIR made all necessary adjustments to calibrate the analyzers and the data recorders and to achieve the correct sampling rate.

5.5.3 ANALYZER CALIBRATION ERROR

After sampling system and analyzer assembly, preparation and calibration, AIR conducted a 3-point analyzer calibration error test before the first run. AIR introduced the low-, mid-, and high-level calibration gases sequentially in direct calibration mode. During the test, AIR made no adjustments to the system except to maintain the correct flow rate. AIR recorded the analyzer's response to each calibration gas and calculated the system calibration error. At each calibration gas level (low, mid, and high) the calibration error was within ± 2.0 percent or 0.5 ppm of the calibration span.

5.5.4 INITIAL SYSTEM BIAS AND CALIBRATION ERROR CHECKS

Before sampling began, AIR determined that the high-level calibration gas best approximated the emissions and used it as the upscale gas. AIR introduced the upscale gas at the probe upstream of all sample conditioning components in system calibration mode. The time it took for the measured concentration to increase to a value that is within 95 percent of the certified gas concentration was recorded. AIR continued to observe the gas concentration reading until it reached a final, stable value and recorded the value.

Next, AIR introduced the low-level gas in system calibration mode and recorded the time required for the concentration response to decrease to a value that was within 5.0 percent of the certified low-range gas concentration.

AIR continued to observe the low-level gas reading until it reached a final, stable value and recorded the result. AIR operated the measurement system at the normal sampling rate during all system bias checks and made only the adjustments necessary to achieve proper calibration gas flow rates at the analyzer. From this data, AIR determined the initial system bias was less than 5% of the calibration span for the low- and high- level gases.

5.5.5 MEASUREMENT SYSTEM RESPONSE TIME

AIR calculated the measurement system response time from the data collected during the Initial System Bias Check.

5.6 INSTRUMENT INTERFERENCE RESPONSE

AIR obtained instrument vendor data that demonstrates the interference performance specification is not exceeded as defined in EPA Method 7E Section 13.4. Documentation is provided in Appendix D.

5.7 DATA REDUCTION CHECKS

AIR ran an independent check (using a validated computer program) of the calculations with predetermined data before the field test, and the *AIR* Team Leader conducted spot checks on-site to assure that data was being recorded accurately. After the test, *AIR* checked the data input to assure that the raw data had been transferred to the computer accurately.

5.8 EXTERNAL QUALITY ASSURANCE

5.8.1 TEST PROTOCOL EVALUATION

A Site-Specific Test Protocol (SSTP) was submitted to MDEQ in advance of testing, which provided regulatory personnel the opportunity to review and comment upon the test and quality assurance procedures used in conducting this testing.

5.8.2 ON-SITE TEST EVALUATION

A test schedule was submitted with the Site-Specific Test Protocol and MDEQ personnel were notified of all changes in the schedule. No tests were performed earlier than stated in the original schedule. Therefore, regulatory personnel were afforded the opportunity for on-site evaluation of all test procedures.

6.0 DATA QUALITY OBJECTIVES

The data quality objectives (DQOs) process is generally a seven-step iterative planning approach to ensure development of sampling designs for data collection activities that support decision making. The seven steps are as follows: (1) defining the problem; (2) stating decisions and alternative actions; (3) identifying inputs into the decision; (4) defining the study boundaries; (5) defining statistical parameters, specifying action levels, and developing action logic; (6) specifying acceptable error limits; and (7) selecting resource-effective sampling and analysis plan to meet the performance criteria. The first five steps are primarily focused on identifying qualitative criteria such as the type of data needed and defining how the data will be used. The sixth step defines quantitative criteria and the seventh step is used to develop a data collection design. In regards to emissions sampling, these steps have already been identified for typical monitoring parameters.

Monitoring methods presented in 40 *CFR* 60 Appendix A indicate the following regarding DQOs: Adherence to the requirements of this method will enhance the quality of the data obtained from air pollutant sampling methods. At a minimum, each method provides the following types of information: summary of method; equipment and supplies; reagents and standards; sample collection, preservation, storage, and transportation; quality control; calibration and standardization; analytical procedures, data analysis and calculations; and alternative procedures. These test methods have been designed and tested according to DQOs for emissions testing and analysis. These test methods have been specified and were followed in accordance with the Site-Specific Test Protocol submitted to MDNRE to ensure that DQOs were met for this project.