

1.0 EXECUTIVE SUMMARY

MOSTARDI PLATT conducted a Hydrogen Chloride (HCl) compliance emissions test program for the Verso Corporation at the Escanaba Mill on the No. 11 Power Boiler in Escanaba, Michigan on September 29, 2020. This report summarizes the results of the test program and test methods used.

The test location, test date, test parameter, and test methods are summarized below.

| TEST INFORMATION | | | |
|-------------------------|--------------------|-------------------------|---------------------------|
| Test Location | Test Date | Test Parameter | Test Methods |
| No. 11 Power Boiler | September 29, 2020 | Hydrogen Chloride (HCl) | USEPA Methods 26A and 320 |

The purpose of this test program was to determine hydrogen chloride (HCl) compliance in accordance with the Michigan Department of Environment, Great Lakes and Energy (EGLE) issued Renewable Operating Permit (ROP) Number MI-ROP-A0884-2016 and the emission limits established under 40 CFR 63 Subpart DDDDD – NESHAP for Major Sources: Industrial, Commercial, and Institutional Boilers and Process Heaters listed below:

| TEST RESULTS | | | | |
|----------------------|-----------------------|------------------------|--------------------|----------------------|
| Test Location | Test Parameter | Emission Limits | Methodology | Emission Rate |
| No. 11 Power Boiler | HCl | 2.2E-02 lb/MMBtu | M26A | 7.03E-03 lb/mmBtu |
| | | | M320 | 8.07E-03 lb/mmBtu |

Method 320 analysis was also completed at the No. 11 Power Boiler in order to utilize Method 301 and validate M320 as an alternative test method. The Method 301 Summary can be found in Section 3.0 of the report.

Emissions on lb/mmBtu basis were determined using calculated F_d -Factors of 9,682, 9,689, and 9,665 dscf/mmBtu. Plant operating data as provided by Verso Corporation is included in Appendix A.

The Stationary Source Audit Sample Program audit sample was obtained by Mostardi Platt from ERA and analyzed by Mostardi Platt. The results of the audit sample were compared to the assigned value by ERA and found to be acceptable. The audit sample result and evaluation are appended to this report.

The identifications of the individuals associated with the test program are summarized below.

| TEST PERSONNEL INFORMATION | | |
|--------------------------------|---|---|
| Location | Address | Contact |
| Test Facility | Verso Corporation Escanaba Mill 1097 N 950 W Escanaba, Michigan 47665-9747 | Mr. Adam Becker Environmental Engineer (906) 233-2929 (phone) Adam.Becker@versoco.com |
| Testing Company Representative | Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126 | Mr. Richard J. Sollars II Senior Project Manager (630) 993-2100 (phone) rsollars@mp-mail.com |

The test crew consisted of Messrs. N. Colangelo, R. Simon, J. Kukla, W. Petrovich, M. Sather, M. Friduss and R. Sollars of Mostardi Platt.

Ms. Lindsey Wells and Ms. Sydney Bruestle of EGLE were on site to observe testing.

2.0 TEST METHODOLOGY

Emissions testing was conducted following the methods specified in 40CFR60, Appendix A. A schematic of the test section diagram is found in Appendix B and schematics of the sampling trains used are included in Appendix C. Calculation nomenclature and sample calculations are included in Appendix D. Laboratory analysis data are found in Appendix E. Copies of analyzer print-outs for each test run are included in Appendix F and field data sheets are found in Appendix G.

The following methodologies were used during the test program:

Method 1 Traverse Point Determination

Test measurement points were selected in accordance with Method 1. The characteristics of the measurement locations are summarized below.

| TEST POINT INFORMATION | | | | |
|------------------------|--------------------|----------------------|----------------|---------------------------|
| Location | Upstream Diameters | Downstream Diameters | Test Parameter | Number of Sampling Points |
| No. 11 Power Boiler | >2.0 | >8.0 | HCl | 12 (26A) /1 (320) |

Method 2 Volumetric Flowrate Determination

Gas velocity was measured following Method 2, for purposes of calculating stack gas volumetric flow rate and HCl emission rates. An S-type pitot tube, differential pressure gauge, thermocouple and temperature readout were used to determine gas velocity at each sample point. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.

Method 3A Carbon Dioxide (CO₂) and Oxygen (O₂) Determination

An ECOM analyzer was used to determine O₂ and CO₂ concentrations in the stack gas. Samples were taken from the exhaust of the dry gas meter of the USEPA Method 26A sample train. Linearity calibrations were performed prior to sampling, and mid-range and zero calibration checks were performed after each test run. Final O₂ and CO₂ concentrations were corrected for calibration error of the instrument. The instrument has a nondispersive infrared-based detector and operates in a range of 0-21% for O₂ and 0-20% for CO₂. Calibration data is presented in the Appendix H and copies of the gas cylinder certifications are found in Appendix I.

Method 26A Hydrogen Chloride (HCl) Determination

Stack gas HCl concentrations and emission rates were determined in accordance with Method 26A, 40CFR60, Appendix A. An Environmental Supply Company, Inc. sampling train was used to sample stack gas at an isokinetic rate. Five impingers were utilized. The first two impingers each contained 100 mL of 0.1N sulfuric acid (H₂SO₄), the following two impingers each contained 100 mL of sodium hydroxide (NaOH), and the final impinger contained approximately 200 grams of silica gel. The impingers were weighed prior to and after each test run in order to determine moisture content of the stack gas. The total sample time for each run was 60 minutes, with twelve sample points being utilized (3 points per port, 4 total ports).

After gravimetric weighing of the impinger train, samples were recovered by transferring the dilute H₂SO₄ and NaOH solutions into separate sample containers and performing deionized water washes on the impingers. Samples were analyzed by Mostardi Platt on-site, along with an audit sample. Sample analysis data are found in Appendix E. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.

Method 301 Field Validation of Pollutant Measurement Methods from Various Waste Media

Method 301 includes minimum procedures to determine and document systematic error (bias) and random error (precision) of measured concentrations from exhaust gases, wastewater, sludge, and other media. It contains procedures for ensuring sample stability if such procedures are not included in the test method. This method also includes optional procedures for ruggedness and detection limits. The method is used to validate an alternative test method to meet requirements under 40CFR63. The Method 301 summary table can be found in Section 3.0 of this document.

Method 320 Fourier Transform Infrared (FTIR) Detector Multi-Gas Determination

FTIR data was collected using an MKS MultiGas 2030 FTIR spectrometer.

The FTIR was equipped with a temperature-controlled, 5.11 meter multi-pass gas cell maintained at 191°C. Gas flows and sampling system pressures were monitored using a rotameter and pressure transducer. All data was collected at 0.5 cm⁻¹ resolution. Each spectrum was derived from the coaddition of 64 scans, with a new data point generated approximately every one minute. Analyzer data for each run is present in Appendix F.

| SAMPLING SYSTEM PARAMETERS | | | | |
|----------------------------|-------------------------------|-------------------------|--|------------------------|
| MKS Serial # | Sampling Line | Probe Assembly | Particulate Filter Media | Operating Temperatures |
| 019088195 | 100' 3/8" dia., heated Teflon | Heated 6', 3/8" dia. SS | 0.01 μ heated borosilicate glass fiber | 191°C |

QA/QC procedures followed US EPA Method 320. See below for QA/QC procedure details and list of calibration gas standards. All calibration gases were introduced to the analyzer and the sampling system using an instrument grade stainless steel rotameter. All QA/QC procedures were within the acceptance criteria allowance of the applicable EPA methodology. See Appendix H for FTIR QA/QC Data.

| FTIR QA/QC Procedures | | | | | | |
|--|---|-------------------------|--|----------------------------|------------------------------|--------|
| QA/QC Specification | Purpose | Calibration Gas Analyte | Delivery | Frequency | Acceptance Criteria | Result |
| M320: Zero | Verify that the FTIR is free of contaminants & zero the FTIR | Nitrogen (zero) | Direct to FTIR | pre/post test | < MDL or Noise | Pass |
| M320: Calibration Transfer Standard (CTS) Direct | Verify FTIR stability, confirm optical path length | Ethylene | Direct to FTIR | pretest | +/- 5% cert. value | Pass |
| M320: Analyte Direct | Verify FTIR calibration | HCl | Direct to FTIR | pretest | +/- 5% cert. value | Pass |
| M320: CTS Response | Verify system stability, recovery, response time | Ethylene | Sampling System | Daily, pre/post test | +/- 5% of Direct Measurement | Pass |
| M320: Zero Response | Verify system is free of contaminants, system bias | Nitrogen (zero) | Sampling System | pretest | Bias correct data | Pass |
| M320: Analyte Spike | Verify system ability to deliver and quantify analyte of interest in the presence of other effluent gases | HCl | Dynamic Addition to Sampling System, 1:10 effluent | Throughout testing – daily | +/- 30% theoretical recovery | Pass |

Note: The determined concentrations from direct analyses were used in all system/spike recovery calculations.

| CALIBRATION GAS STANDARDS | | | | |
|---------------------------|---------------------|--------|------------|--------------------------------|
| Components | Concentration (ppm) | Vendor | Cylinder # | Standard Type |
| Ethylene | 100.0 | Airgas | CC240155 | Primary +/- 1% |
| HCl/SF6 | 99.76/5.169 | Airgas | CC513810 | Certified Standard-Spec +/- 5% |
| Nitrogen | zero gas | Airgas | N/A | UHP Grade |

Analyte Spiking

HCl spiking was performed prior to testing to verify the ability of the sampling system to quantitatively deliver a sample containing HCl from the base of the probe to the FTIR. Analyte spiking assures the ability of the FTIR sampling system to recover acid gases in the presence of effluent gas.

As part of the spiking procedure, samples were measured to determine native HCl concentrations to be used in the spike recovery calculations. The analyte spiking gases contained a low concentration of sulfur hexafluoride (SF₆). The determined SF₆ concentration in the spiked sample was used to calculate the dilution factor of the spike and thus used to calculate the concentration of the spiked HCl. The spike target dilution ratio was 1:10 or less.

The following equation illustrates the percent recovery calculation.

$$DF = \frac{SF6(spik)}{SF6(direct)} \quad (\text{Sec. 9.2.3 (3) USEPA Method 320})$$

$$CS = DF * Spike(dir) + Unspike(1 - DF) \quad (\text{Sec. 9.2.3 (4) USEPA Method 320})$$

DF = Dilution factor of the spike gas

SF_{6(dir)} = SF₆ concentration measured directly in undiluted spike gas

SF_{6(spik)} = Diluted SF₆ concentration measured in a spiked sample

Spike_{dir} = Concentration of the analyte in the spike standard measure by the FTIR directly

CS = Expected concentration of the spiked samples

Unspike = Native concentration of analytes in unspiked samples

Post Collection Data Validation

As part of the data validation procedure, reference spectra are manually fit to that of the sample spectra and a concentration is determined. The reference spectra are scaled to match the peak amplitude of the sample, thus providing a scale factor. The scale factor multiplied by the reference spectra concentration is used to determine the concentration value for the sample spectra. Sample pressure and temperature corrections are then applied to compute the final sample concentration. The manually calculated results are then compared with the software-generated results. The data is then validated if the two concentrations are within ± 20% agreement. If there is a difference greater than ± 20% the spectra are reviewed for possible spectra interferences or any other possible causes leading to incorrectly quantified data.

Detection Limit

The detection limit of each analyte was calculated following Annex A2 of ASTM D6348-12 procedure using spectra that contained similar amounts of moisture.

| FTIR DETECTION LIMITS | | | |
|------------------------------|-----------------------------------|-----------------------------|---------------------------------|
| Analyte | Detection Limit (ppmv wet) | Detection Limit (%v) | Detection Limit (%v wet) |
| Hydrogen Chloride | 0.2 | — | — |
| Water | — | 0.1 | N/A |
| Carbon Dioxide | — | N/A | 0.1 |

QA/QC data are found in Appendix H. Copies of gas cylinder certifications are found in Appendix I. All concentration data were recorded on a wet, volume basis. The FTIR measured carbon dioxide concentration to calculate HCl on a lb/mmBtu basis. HCl spiking was performed prior to testing to confirm the measurement system's ability to deliver and quantify HCl. The sample and data collection followed the procedures outlined in Method 320.

3.0 TEST RESULT SUMMARY

Client: Verso Corporation
Facility: Escanaba Mill
Test Location: No. 11 Power Boiler Stack
Test Method: 26A

| Source Condition | Normal | Normal | Normal | |
|---|----------|----------|----------|----------|
| Date | 9/29/20 | 9/29/20 | 9/29/20 | |
| Start Time | 9:40 | 12:20 | 14:00 | |
| End Time | 11:01 | 13:36 | 15:50 | |
| | Run 1 | Run 2 | Run 3 | Average |
| Stack Conditions | | | | |
| Average Gas Temperature, °F | 385.8 | 379.9 | 390.3 | 385.3 |
| Flue Gas Moisture, percent by volume | 14.5% | 13.0% | 15.9% | 14.5% |
| Average Flue Pressure, in. Hg | 28.83 | 28.83 | 28.83 | 28.83 |
| Gas Sample Volume, dscf | 51.996 | 54.515 | 61.343 | 55.951 |
| Average Gas Velocity, ft/sec | 26.934 | 27.895 | 31.759 | 28.863 |
| Gas Volumetric Flow Rate, acfm | 248,771 | 257,643 | 293,335 | 266,583 |
| Gas Volumetric Flow Rate, dscfm | 127,935 | 135,772 | 147,648 | 137,118 |
| Gas Volumetric Flow Rate, scfm | 149,641 | 156,054 | 175,514 | 160,403 |
| Average %CO ₂ by volume, dry basis | 11.5 | 9.5 | 12.1 | 11.0 |
| Average %O ₂ by volume, dry basis | 8.4 | 10.5 | 8.1 | 9.0 |
| Isokinetic Variance | 103.0 | 101.7 | 105.3 | 103.3 |
| Calculated Fuel Factor Fd, dscf/mmBtu | 9,682.0 | 9,689.0 | 9,665.0 | 9,678.7 |
| Hydrogen Chloride (HCl) Emissions | | | | |
| ug of sample collected | 7383.34 | 11737.55 | 12048.98 | 10389.96 |
| ppm | 3.31 | 5.01 | 4.57 | 4.30 |
| mg/dscm | 5.01 | 7.60 | 6.94 | 6.52 |
| lb/hr | 2.4030 | 3.8668 | 3.8361 | 3.3686 |
| lb/mmBtu (Calculated Fd Factor) | 5.10E-03 | 9.20E-03 | 6.80E-03 | 7.03E-03 |

Client: Verson Corporation
Facility: Escanaba Mill
Test Location: No. 11 Power Boiler Stack
Test Methods: 3A, 320

| Source Condition | Normal | Normal | Normal | |
|---|----------|----------|----------|----------|
| Date | 9/29/20 | 9/29/20 | 9/29/20 | |
| Start Time | 9:40 | 12:20 | 14:00 | |
| End Time | 10:39 | 13:19 | 14:59 | |
| | Run 1 | Run 2 | Run 3 | Average |
| Stack Conditions | | | | |
| Average Gas Temperature, °F | 385.8 | 379.9 | 390.3 | 385.3 |
| Flue Gas Moisture, percent by volume | 13.8 | 13.3 | 16.1 | 14.4 |
| Average Flue Pressure, in. Hg | 28.83 | 28.83 | 28.83 | 28.83 |
| Average Gas Velocity, ft/sec | 26.934 | 27.895 | 31.759 | 28.863 |
| Gas Volumetric Flow Rate, acfm | 248,771 | 257,643 | 293,335 | 266,583 |
| Gas Volumetric Flow Rate, dscfm | 127,935 | 135,772 | 147,648 | 137,118 |
| Gas Volumetric Flow Rate, scfm | 149,641 | 156,054 | 175,514 | 160,403 |
| Average %CO ₂ by volume, wet basis | 11.5 | 9.5 | 12.1 | 11.0 |
| Average %O ₂ by volume, dry basis | 8.4 | 10.5 | 8.1 | 9.0 |
| Calculated Fuel Factor Fd, dscf/mmBtu | 9,682.0 | 9,689.0 | 9,665.0 | 9,678.7 |
| Hydrogen Chloride (HCl) Emissions | | | | |
| ppmv | 3.9 | 4.5 | 4.3 | 4.2 |
| ppmvd | 4.6 | 5.2 | 5.1 | 5.0 |
| lb/hr | 3.35 | 4.00 | 4.27 | 3.87 |
| lb/mmBtu (Calculated Fd Factor) | 7.01E-03 | 9.59E-03 | 7.62E-03 | 8.07E-03 |

| | |
|----------------------------------|--------------------------------------|
| Client: Verso Corporation | Location: No. 11 Power Boiler |
| Facility: Escanaba Mill | Date: 9/29/20 |
| Project #: M204004 | Test Method: 26A, 320 |
| Fuel Type: Coal/Bark | |

HCl lb/mmbtu Method 301 comparison

| 1=accept 0=reject | Test Run | Test Date | Start Time | End Time | M26A HCl lb/MMBtu | M320 HCl lb/MMBtu | (M26A-M320) Difference (di) | (M26A-M320) Difference ² (di ²) |
|-----------------------------------|----------|-----------|------------|----------|----------------------|----------------------|-----------------------------------|--|
| 1 | 1 | 09/29/20 | 09:40 | 11:01 | 0.0051 | 0.0070 | -0.0019 | 0.00000361 |
| 1 | 2 | 09/29/20 | 12:20 | 13:36 | 0.0092 | 0.0096 | -0.0004 | 0.00000016 |
| 1 | 3 | 09/29/20 | 14:00 | 15:50 | 0.0068 | 0.0076 | -0.0008 | 0.00000064 |
| n | | | | | 3 | | | |
| t critical | | | | | 3.182 | | | |
| t calculated | | | | | 2.245 | | | |
| Mean Method 26A Value | | | | | 0.0070 | | | |
| Mean Method 320 Value | | | | | 0.0081 | | | |
| Sum of Differences | | | | | -0.0031 | | di | |
| Mean Difference | | | | | -0.0010 | | d | |
| Sum of Differences Squared | | | | | 0.000004 | | di² | |
| Standard Deviation | | | | | 0.000777 | | sd | |
| Relative Bias | | | | | 14.8927 | | B_R | |


4.0 CERTIFICATION

MOSTARDI PLATT is pleased to have been of service to Verso Corporation. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

CERTIFICATION


As project manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results, and the test program was performed in accordance with the methods specified in this test report.

MOSTARDI PLATT



Richard J. Sollars II

Project Supervisor



Jeffrey M. Crivlare

Quality Assurance