

# FINAL REPORT



## UNITED STATES STEEL CORPORATION

ECORSE, MICHIGAN

### COMPLIANCE TESTING REPORT: CGL ANNEALING FURNACE - NOX AND AMMONIA

RWDI #2302716

May 6, 2023

#### SUBMITTED TO

**Nathan Ganhs**  
Coordinating Manager-Environmental  
Naganhs@uss.com

**United States Steel Corporation**  
1 Quality Drive  
Ecorse, Michigan 48229

**Dr. April Wendling**  
**EGLE, Air Quality Division**  
Cadillac Place  
3058 West Grand Boulevard  
Suite 2-300  
Detroit, Michigan 48202-6058

**TPU Supervisor**  
**EGLE, Air Quality Division**  
Constitution Hall, 2<sup>nd</sup> Floor South  
525 West Allegan Street  
Lansing, MI 48933

#### SUBMITTED BY

**Steve Smith, QSTI**  
Project Manager  
Steve.Smith@rwdi.com | ext. 3706

**Mason Sakshaug, QSTI**  
Technical Supervisor | Associate  
Mason.Sakshaug@rwdi.com | ext. 3703

**RWDI USA LLC**  
**Consulting Engineers & Scientists**  
2239 Star Court  
Rochester Hills, Michigan 48309

T: 248.841.8442  
F: 519.823.1316

RECEIVED

MAY 23 2023



[rwdi.com](http://rwdi.com)

©2022 RWDI USA LLC ("RWDI") ALL RIGHTS RESERVED.

This document is intended for the sole use of the party to whom it is addressed and may contain information that is privileged and/or confidential. If you have received this in error, please notify us immediately. Accessible document formats provided upon request.

© RWDI name and logo are registered trademarks in Canada and the United States of America.

AIR QUALITY DIVISION



## EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) has been retained by United States Steel Corporation (US Steel) to complete the emission sampling program at the Great Lakes Works facility located at 1 Quality Drive, Ecorse, Michigan 48229. US Steel operates a steel manufacturing facility that produces steel coils and flat rolled sheet steel. The operation includes the Continuous Galvanizing Line (CGL) annealing furnace (SV CONGALVGNCE) under Emission Unit EUCON-GALV-LINE-51. Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>) and ammonia (NH<sub>3</sub>). The testing was required Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit to Install MI-PTI-219-06B and 98-15.

Compliance testing was completed for the Annealing Furnace was completed on March 23, 2023.

**Executive Table i:** Results Summary – Annealing Furnace

Source	Analyte	Units	Average	Limit
Annealing Furnace	NO <sub>x</sub>	ppmv <sub>d</sub>	1.23	-
		lb/hr	0.24	6.6
	NH <sub>3</sub>	ppmv <sub>d</sub>	9.96	-
		lb/hr	0.71	1.44



# TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION</b> .....	<b>1</b>
1.1	Location and Date of Testing .....	1
1.2	Purpose of the Testing .....	1
1.3	Description of the Source .....	1
1.4	Personnel Involved in Testing .....	2
<b>2</b>	<b>SUMMARY OF RESULTS</b> .....	<b>2</b>
2.1	Operating Data .....	2
2.2	Applicable Permit Number .....	2
<b>3</b>	<b>SOURCE DESCRIPTION</b> .....	<b>3</b>
3.1	Description of Process and Emission Control Equipment .....	3
3.2	Process Flow Sheet or Diagram .....	3
3.3	Type and Quantity of Raw and Finished Materials .....	3
3.4	Normal Rated Capacity of Process .....	3
3.5	Process Instrumentation Monitored During the Testing .....	3
<b>4</b>	<b>POLLUTANTS TO BE MEASURED</b> .....	<b>3</b>
<b>5</b>	<b>SAMPLING AND ANALYSIS PROCEDURES</b> .....	<b>3</b>
5.1	Stack Velocity, Temperature, and Volumetric Flow Rate Determination .....	4
5.2	NO <sub>x</sub> and NH <sub>3</sub> by USEPA Method 320 .....	4
<b>6</b>	<b>NUMBER AND LENGTH OF SAMPLING RUNS</b> .....	<b>6</b>
<b>7</b>	<b>STACK INFORMATION</b> .....	<b>6</b>
<b>8</b>	<b>FLUE GAS CONDITIONS</b> .....	<b>7</b>
<b>9</b>	<b>TEST RESULTS AND DISCUSSION</b> .....	<b>7</b>
9.1	Detailed Results .....	7



9.2 Discussion of Results..... 7

9.3 Variations in Testing Procedures..... 7

9.4 Process Upset Conditions During Testing..... 7

9.5 Maintenance Performed in Last Three Months ..... 8

9.6 Re-Test..... 8

9.7 Audit Samples..... 8

9.8 Process Data..... 8

9.9 Calibration Data..... 8

9.10 Example Calculations..... 8

9.11 Laboratory Data ..... 8

9.12 Source Testing Plan and EGLE Correspondence..... 8

## LIST OF TABLES

(Found Within the Report Text)

**Table 1.4.1:** List of Testing Personnel.....2

**Table 7.1:** Summary of the Stack Characteristics.....6

**Table 8.1:** Flue Gas Conditions.....7

**Table 9.1.1:** Results Summary – Annealing Furnace.....Executive Summary Table i & 7



## LIST OF TABLES

(Found After the Report Text)

**Table 1:** Summary of Emissions – Annealing Furnace

**Table 2:** Annealing Furnace Flow Measurements

## LIST OF FIGURES

**Figure 1:** Annealing Furnace Exhaust Stack Diagram

**Figure 2:** USEPA Method 2 Diagram

**Figure 3:** USEPA Method 320/3A Diagram

## LIST OF APPENDICES

**Appendix A:** Process Data

**Appendix B:** FTIR Results

**Appendix C:** Flowrate Data

**Appendix D:** Field Notes

**Appendix E:** Calibration Data

**Appendix F:** Example Calculation

**Appendix G:** Test Plan and EGLE Correspondence

RECEIVED

MAY 23 2023

AIR QUALITY DIVISION



# 1 INTRODUCTION

RWDI USA LLC (RWDI) has been retained by United States Steel Corporation (US Steel) to complete the emission sampling program at the Great Lakes Works facility located at 1 Quality Drive, Ecorse, Michigan 48229. US Steel operates a steel manufacturing facility that produces steel coils and flat rolled sheet steel. The operation includes the Continuous Galvanizing Line (CGL) annealing furnace (SV CONGALVGNCE) under Emission Unit EUCON-GALV-LINE-51. Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>) and ammonia (NH<sub>3</sub>). The testing was required Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit to Install MI-PTI-219-06B and 98-15.

## 1.1 Location and Date of Testing

The testing program was completed on March 23, 2023, at the US Steel Great Lakes Works facility located at 1 Quality Drive, Ecorse, Michigan.

## 1.2 Purpose of the Testing

The testing was required Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit to Install MI-PTI-219-06B and 98-15.

## 1.3 Description of the Source

US Steel Great Lakes Works is a steel manufacturing facility producing steel coils and flat rolled sheet steel. The Continuous Galvanizing Line is where steel coils are galvanized. The coils of steel are loaded into the entry end of the process and are uncoiled and straightened. Each leading edge of the next coil is welded to the preceding coil to allow the process to run continuously while production is occurring. In the Pre-Cleaner section of the CGL process, the straightened coils are cleaned within caustic solution tanks, which are heated by a hot water and heat exchanger system. Emissions of dilute caustic generated in the cleaning process tanks are controlled by a mist eliminator and a scrubber before being exhausted to the outer atmosphere through the Pre-Cleaner stack.

After cleaning and rinsing, the coil is dried with hot air. After drying, the coil enters the Annealing Furnace. The coil is heated according to required specifications within the Annealing Furnace and then proceeds to the zinc pot where the steel is given a zinc coating (i.e. galvanized). Excess zinc is removed immediately upon exit of the molten zinc pot, and the zinc-coated steel strip is allowed to dry as it travels in a vertical direction. After air cooling, the strip is quenched in water, dried, inspected, and packaged for customer delivery.



## 1.4 Personnel Involved in Testing

**Table 1.4.1:** List of Testing Personnel

<p><b>Nathan Ganhs</b> Coordinating Manager - Environmental NAGanhs@uss.com</p>	<p><b>US Steel Corporation</b> 1 Quality Drive Ecorse, MI 48229</p>	<p>(313) 749-3857</p>
<p><b>Andrew Riley</b> Air Quality Division RileyA8@michigan.gov</p>	<p><b>State of Michigan</b> EGLE Air Quality</p>	<p>(586) 565-7379</p>
<p><b>Mason Sakshaug</b> Technical Supervisor Mason.Sakshaug@rwdi.com</p>	<p><b>RWDI USA LLC</b> 2239 Star Court Rochester Hills, MI 48309</p>	<p>(989) 323-0355</p>
<p><b>Ben Durham</b> Senior Field Technician Ben.Durham@rwdi.com</p>		<p>(734) 474-1731</p>

## 2 SUMMARY OF RESULTS

### 2.1 Operating Data

Operational data collected during the testing included the following (found in **Appendix A**):

- NO<sub>x</sub> ppm
- O<sub>2</sub> %
- Natural gas usage in the annealing furnace
- Natural gas usage by the edge burners
- Amount of urea injected
- Gas inlet temperature to the SCR; and
- Amount of galvanized steel produced.

### 2.2 Applicable Permit Number

The testing was required Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit to Install MI-PTI-219-06B and 98-15.



## 3 SOURCE DESCRIPTION

### 3.1 Description of Process and Emission Control Equipment

Refer to Section 1.3 for a description of the process. Emissions are controlled by a single selective catalytic reduction (SCR) system with a duct burner servicing the annealing furnace.

### 3.2 Process Flow Sheet or Diagram

A process schematic can be provided upon request.

### 3.3 Type and Quantity of Raw and Finished Materials

Cold rolled steel is uncoiled, welded together, and cleaned prior to entering the annealing furnace.

### 3.4 Normal Rated Capacity of Process

The maximum rated capacity of the line is 850,000 tons per year and 838.6 million cubic feet per year of natural gas from the edge burners and annealing furnace. Tons of steel and natural gas usage is based on a 12-month rolling average.

### 3.5 Process Instrumentation Monitored During the Testing

Annealing Furnace parameters included the following:

- NO<sub>x</sub> ppm
- O<sub>2</sub> %
- Natural gas usage in the annealing furnace
- Natural gas usage by the edge burners
- Amount of urea injected
- Gas inlet temperature to the SCR; and
- Amount of galvanized steel produced.

## 4 POLLUTANTS TO BE MEASURED

Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>) and ammonia (NH<sub>3</sub>).

## 5 SAMPLING AND ANALYSIS PROCEDURES

The following section provides brief descriptions of the proposed sampling methods and discusses any proposed modifications to the reference test methods.





## 5.1 Stack Velocity, Temperature, and Volumetric Flow Rate Determination

The exhaust velocities and flow rates were determined following the USEPA Method 2, "Determination of Stack Gas Velocity and Flow Rate (Type S Pitot Tube)" from the outlet only. Velocity measurements were taken with a pre-calibrated S-Type pitot tube and incline manometer. Volumetric flow rates were determined following the equal area method as outlined in US EPA Method 2. Temperature measurements were made simultaneously with the velocity measurements and were conducted using a chromel-alumel type "k" thermocouple in conjunction with a digital temperature indicator.

The dry molecular weight of the stack gas was determined following calculations outlined in US EPA Method 3A "Determination of Molecular Weight of Dry Stack Gas" for O<sub>2</sub>. USEPA Method 320 was used for CO<sub>2</sub> content.

Stack moisture content was determined in accordance with USEPA Method 320.

## 5.2 NO<sub>x</sub> and NH<sub>3</sub> by USEPA Method 320

Emissions testing was performed at the outlet of the annealing furnace. Pollutant concentrations was determined utilizing RWDI's continuous emissions monitoring system (CEM) which consists of the FTIR and oxygen analyzer (measuring on wet basis).


Stack gas concentrations for NO<sub>x</sub>, NH<sub>3</sub>, and O<sub>2</sub> were measured using EPA Reference Methods 320 and 3A.

Oxygen measurements were taken continuously following USEPA Method 3A on the outlet (using a wet oxygen analyzer or equivalent). Stratification checks using O<sub>2</sub> as the surrogate for all pollutants, was completed on the exhaust of the annealing furnace at three points (16.7%, 50% and 83.3% of inner diameter) on a line passing through the centroidal area, as per the alternative approach in EPA Method 7E Section 8.1.2.

Regular performance checks on the CEMS were carried out by zero and span calibration checks on the oxygen analyzer and necessary QA procedures on the FTIR using USEPA Protocol calibration gases. These checks will verify the ongoing precision of the FTIR with time by introducing pollutant-free (zero) air followed by known calibration gas (span) into the FTIR. The response of the monitor to pollutant-free air and the corresponding sensitivity to the span gases was reviewed frequently as an ongoing indication of analyzer performance.

Monitoring was conducted by drawing a sample stream of flue gases through a stainless-steel probe attached to a heated filter and a heated sample line that is attached to the MAX Analytical ASC-10ST sampling console. Lengths of unheated sample line was kept to a minimum and insulated. The ASC-10ST sampling console delivers a continuous sample to the MKS MultiGas 2030 FTIR and oxygen analyzer for analysis. The heated filter and line were maintained at approximately 191°C (375°F) and the MKS MultiGas 2030 FTIR and ASC-10ST gas components were kept at 191°C (375°F). The end of the probe was connected to a heated Teflon sample line, which will deliver the sample gases from the stack to the FTIR system. The heated sample line was designed to maintain the gas temperature at approximately 375°F to prevent condensation of stack gas moisture within the line and condition air to the same temperature as the FTIR. A schematic of the sampling system setup is depicted in **Figure 5.2a**.

Figure 5.2a: MKS 2030 Multigas FTIR/ASC-10ST/Model 4710 Oxygen Analyzer Sampling System Schematic



The ASC-10ST was used to deliver calibration gases (Calibration Transfer Standard (CTS), QA Spike and Nitrogen) to the FTIR in direct (to analyzer) and system (to probe) modes.

A laptop computer was utilized for operating the MKS MultiGas 2030 FTIR and MAX Analytical ASC-10ST sampling console and logging the multi-gas FTIR data. Data was logged as one-minute averages for the actual test period (FTIR PRN files and Spectra). All concentration data was determined using the MKS 2030 MultiGas FTIR software. A typical MKS 2030 FTIR and ASC-10 ST configuration is depicted in **Figure 5.2b**

For oxygen measurement only, prior to testing, a 3-point analyzer calibration error check was conducted using USEPA protocol gases. The calibration error check was performed by introducing zero, mid and high-level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response is within  $\pm 2\%$  of the certified calibration gas introduced. Prior to each test run, a system-bias test was performed where known concentrations of calibration gases were introduced at the probe tip to measure if the analyzers response was within  $\pm 5\%$  of the introduced calibration gas concentrations. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre and post-test system bias checks. The system bias checks were used to confirm that the analyzer did not drift greater than  $\pm 3\%$  throughout a test run. The analyzer will measure the respective gas concentrations on a wet volumetric basis which was converted to a dry volumetric number.

The probe tip was equipped with a heated filter for particulate removal. The end of the probe was connected to a heated Teflon sample line, which will deliver the sample gases from the stack to the FTIR/4710 Oxygen analyzer system. The heated sample line was designed to maintain the gas temperature at approximately 375°F to prevent condensation of stack gas moisture within the line.

Figure 5.2b: Typical MKS 2030 Multigas FTIR and ASC-10ST Configuration



## 6 NUMBER AND LENGTH OF SAMPLING RUNS

Testing consisted of triplicate 1-hour tests.

## 7 STACK INFORMATION

Table 7.1: Summary of the Stack Characteristics

Source	Diameter	Approximate Duct Diameters from Flow Disturbance	Number of Ports	Points per Traverse	Total Points per Test
Annealing Furnace	58.5	2.05 downstream 4.10 upstream	2	8	16 Flow



## 8 FLUE GAS CONDITIONS

**Table 8.1:** Flue Gas Conditions

Parameter	Flue Gas Conditions		
	Stack Temperature	Flow Rate	Percent Moisture
Annealing Furnace	608	27,005 dscfm	12%

## 9 TEST RESULTS AND DISCUSSION

### 9.1 Detailed Results

Detailed results for all analytes are provided in **Appendix B**.

**Table 9.1.1:** Results Summary – Annealing Furnace

Source	Analyte	Units	Average	Limit
Annealing Furnace	NO <sub>x</sub>	ppmv <sub>d</sub>	1.23	-
		lb/hr	0.24	6.6
	NH <sub>3</sub>	ppmv <sub>d</sub>	9.96	-
		lb/hr	0.71	1.44

### 9.2 Discussion of Results

The detailed results of individual tests can be found in **Appendix B** and detailed flow data can be found in **Appendix C**. All field sheets can be found in **Appendix D**.

### 9.3 Variations in Testing Procedures

Due to the port projecting into the stack, the flow point closest to the port could not be used so an alternative point between point 2 and the port was used for the final point.

### 9.4 Process Upset Conditions During Testing

There were no upsets in the process during testing.



## 9.5 Maintenance Performed in Last Three Months

All maintenance in the last three months has been routine.

## 9.6 Re-Test

This was not a retest.

## 9.7 Audit Samples

This test did not require any audit samples.

## 9.8 Process Data

Process data can be found in **Appendix A**.

## 9.9 Calibration Data

Calibration can be found in **Appendix E**.

## 9.10 Example Calculations

Example calculations can be found in **Appendix F**.

## 9.11 Laboratory Data

There was no laboratory data affiliated with this testing.

## 9.12 Source Testing Plan and EGLE Correspondence

Copy of the correspondence received from the Source Testing Plan from EGLE and the Source Testing Plan submitted can be found in **Appendix G**.

# TABLES



**Table 1: Summary of Emissions - Annealing Furnace**

US Steel

**Facility:** Great Lakes Works

**City:** Ecorse, MI

**Source:** Annealing Furnace

**Date:** 3/23/2023

	Symbol	Units	Test 1	Test 2	Test 3	Average	Limits
Nitrogen Oxides Concentration	NO <sub>x</sub>	ppmvd	1.13	1.57	1.01	1.23	-
Ammonia Concentration	NH <sub>3</sub>	ppmvd	11.12	11.00	7.77	9.96	-
Oxygen Concentration	O <sub>2</sub>	% <sub>wet</sub>	8.29	8.59	9.28	8.72	-
Oxygen Concentration	O <sub>2</sub>	% <sub>dry</sub>	9.48	9.78	10.48	9.92	-
Nitrogen Oxides Emission Rate	NO <sub>x</sub>	pph	0.22	0.30	0.19	0.24	6.6
Ammonia Emission Rate	NH <sub>3</sub>	pph	0.82	0.78	0.54	0.71	1.44

## Table 2: Annealing Furnace Flow Measurements

US Steel

Facility: Great Lakes Works

City: Ecorse, MI


Source: Annealing Furnace

Date: 3/23/23

Parameter	Units	Test 1	Test 2	Test 3	Average
Stack Gas Temperature	°F	607	605	612	608.1
Stack Gas Moisture	%	12.61%	12.21%	11.44%	12.09%
Velocity	ft/sec	58.9	56.3	55.7	57.0
Actual Flowrate	acfm	65,958	63,000	62,420	63,793
Dry Reference Flowrate	dscfm	27,753	26,690	26,504	26,982
Dry Reference Flowrate	m <sup>3</sup> /s	13.10	12.60	12.51	12.74



FIGURES




RECEIVED

MAY 23 2023

AIR QUALITY DIVISION



Figure No. 1: Annealing Furnace Exhaust Stack Diagram




Source  
US Steel  
Great Lakes Works  
Ecorse, Michigan

Date:  
23-Mar-23

RWDI USA LLC  
2239 Star Court  
Rochester Hills, MI 48309



Figure No. 2: USEPA Method 2



**USEPA Method 2**

US Steel  
Great Lakes Works  
Annealing Furnace  
Ecorse, Michigan

Project #2302716


Figure No. 2

Date: March 23, 2023





Figure No. 3: USEPA Method 320/3A



**USEPA Method 320**

US Steel  
Great Lakes Works  
Annealing Furnace  
Ecorse, Michigan

Project# 2302716

Date: March 23, 2023

