CleanAir Engineering 500 W. Wood Street Palatine, IL 60067-4975 www.cleanair.com



Marathon Petroleum Company 1300 South Fort Street Detroit, MI 48217

RECEIVED
FEB 0 3 2014
AIR QUALITY DIV.

#### **REPORT ON RATA TESTING**

Performed for:
MARATHON PETROLEUM COMPANY
DETROIT REFINERY

**DHT NEW HEATER STACK (SV77-H1)** 

Client Reference No: CN00081321 CleanAir Project No: 12384-1 Revision 0: January 3, 2014

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,

Andy Øbuchowski Project Manager

abuchowski@cleanair.com (800) 627-0033 ext. 4537

Reviewed by,

Scott Brown

Senior Project Manager sbrown@cleanair.com (800) 627-0033 ext. 4544

Client Reference No: CN00081321 CleanAir Project No: 12384-1

# **REVISION HISTORY**

İi

### **REPORT ON RATA TESTING**

### DRAFT REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
D0a	12/23/13	All	Draft version of original document.

#### FINAL REPORT REVISION HISTORY

Date	Pages	Comments
01/03/14	All	Final version of original document.

CONTENTS

# MARATHON PETROLEUM COMPANY DETROIT REFINERY

Client Reference No: CN00081321 CleanAir Project No: 12384-1

·	E	

1	PROJECT OVERVIEW1-1
	INTRODUCTION1-1
	Key Project Participants1-1
	Test Program Parameters1-1
	TEST PROGRAM SYNOPSIS1-2
	Test Schedule1-2
	Table 1-1: Schedule of Activities1-2
	Results Summary1-3
	Table 1-2: Summary of RATA Results1-3
	Table 1-3; Summary of Emission Compliance Test Results1-3
	Discussion of Test Program1-4
2	RESULTS2-1
	Table 2-1: DHT New Heater Stack – O₂ Relative Accuracy (USEPA M-3A / PS3)2-1
	Table 2-2: DHT New Heater Stack - NO <sub>X</sub> Relative Accuracy (USEPA M-7E / PS2)2-2
	Table 2-3: DHT New Heater Stack – NO <sub>X</sub> Emissions (USEPA M-7E)2-3
3	DESCRIPTION OF INSTALLATION3-1
	PROCESS DESCRIPTION3-1
	DESCRIPTION OF SAMPLING LOCATIONS3-1
	Table 3-1: Sampling Points3-1
	Figure 3-1: USEPA Method 3A/7E Sampling Points – RATA and Emissions Testing3-2
4	METHODOLOGY4-1
	Table 4-1: Summary of Sampling Procedures4-1
5	APPENDIX5-1
	TEST METHOD SPECIFICATIONSA
	SAMPLE CALCULATIONSB
	PARAMETERSC
	QA/QC DATAD
	REFERENCE METHOD CEMS DATAE FACILITY CEMS AND OPERATING DATAF
	FUEL ANALYSIS
	FUEL ANAL FOID

Client Reference No: CN00081321 CleanAir Project No: 12384-1

### **PROJECT OVERVIEW**

### INTRODUCTION

Marathon Petroleum Company (MPC) contracted Clean Air Engineering (CleanAir) to perform a relative accuracy test audit (RATA) on a continuous emissions monitoring system (CEMS) installed at the Detroit Refinery and to demonstrate compliance with permit limits.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (USEPA) and the Michigan Department of Environmental Quality (DEQ). The permit limits are referenced in Michigan Department of Environmental Quality, Air Quality Division Permit to Install No. 63-08C, issued January 11, 2012.

### Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

Crystal Davis – MPC Joe Reidy – MPC Thomas Gasloli – DEQ John Rooney– CleanAir

### **Test Program Parameters**

The testing was performed at the DHT New Heater Stack (Emission Unit ID No. EG77-DHTHTR; Stack ID No. SV77-H1) on November 5, 2013 and included the following emissions measurements:

- nitrogen oxides (NO<sub>X</sub>)
- oxygen (O<sub>2</sub>)

Client Reference No: CN00081321 CleanAir Project No: 12384-1

## **PROJECT OVERVIEW**

### **TEST PROGRAM SYNOPSIS**

### **Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

Table 1-1: Schedule of Activities

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	DHT New Heater Stack	USEPA Method 3A/7E	O <sub>2</sub> /CO <sub>2</sub> /NO <sub>X</sub>	11/05/13	12:06	12:27
2	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	12:35	12:56
3	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	13:02	13:23
4	DHT New Heater Stack	USEPA Method 3A/7E	O <sub>2</sub> /CO <sub>2</sub> /NO <sub>X</sub>	11/05/13	13:30	13:51
5	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	13:57	14:18
6	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	14:28	14:49
7	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	14:58	15:19
8	DHT New Heater Stack	USEPA Method 3A/7E	O <sub>2</sub> /CO <sub>2</sub> /NO <sub>X</sub>	11/05/13	15:28	15:49
9	DHT New Heater Stack	USEPA Method 3A/7E	O2/CO2/NOX	11/05/13	15:55	16:16
10	DHT New Heater Stack	USEPA Method 3A/7E	O <sub>2</sub> /CO <sub>2</sub> /NO <sub>X</sub>	11/05/13	16:22	16:43

121613 162728

Client Reference No: CN00081321 CleanAir Project No: 12384-1

### **PROJECT OVERVIEW**

1-3

### Results Summary

Table 1-2 and Table 1-3 summarize the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown on pages 2-1 through 2-3.

Table 1-2: Summary of RATA Results

Source Constituent (Units)	Reference Method (USEPA)	Applicable Specification	Relative Accuracy (%)	Specification Limit <sup>1</sup>
DHT New Heater Stack				
O <sub>2</sub> (% dv)	M-3A	PS3	0.13	±1.0% dv
NOx (ppmdv)	M-7E	PS2	4.3%	20% of RM or

<sup>&</sup>lt;sup>1</sup> Specification limits obtained from 40 CFR 60, Appendix B, Performance Specifications.

121613 162728

Table 1-3: Summary of Emission Compliance Test Results

Source Constituent	(Units)	Sampling Method	Average Emission	Permit Limit <sup>1</sup>
DHT New Heater NO <sub>X</sub>	<u>Stack</u> (lb/MMBtu)	USEPA M-7E	0.03	0.05

<sup>&</sup>lt;sup>1</sup> Permit limits obtained from MDEQ Permit To Install No. 63-08C.

121613 162728

Client Reference No: CN00081321 CleanAir Project No: 12384-1

### **PROJECT OVERVIEW**

1-4

### Discussion of Test Program

O<sub>2</sub> and NO<sub>X</sub> Emissions / RATA Testing - USEPA Methods 3A and 7E; Performance Specifications 2 and 3

Minute-average data points for O<sub>2</sub>, CO<sub>2</sub>, and NO<sub>X</sub> (dry basis) were collected over a period of 21 minutes for each RATA Reference Method (RM) run. The average result for each RM run was calculated and compared to the average result from the facility CEMs over an identical time interval in order to calculate relative accuracy (RA).

- For  $O_2$ , RA is expressed as the average absolute difference between the RM and facility CEMs runs. The final result was below the limit of  $\pm 1.0\%$ dv set by PS3.
- For NO<sub>X</sub>, RA is expressed as the percent difference between RM and facility CEMs runs. The final result was below the limit of 20% of the RM set by PS2.
- CO<sub>2</sub> data was collected only as supplemental information.

 $NO_X$  results from the RATA were converted from units of dry volume-based concentration (ppmdv) to mass-based emission rate units (lb/MMBtu) to demonstrate compliance with permit limits. The final result was expressed as the average of all ten (10) RATA runs. The final result was below the permit limit.

#### Calculation of Final Results

Emission results in units of dry volume-based concentration (lb/dscf, ppmdv) were converted to units of pounds per million Btu (lb/MMBtu) by calculating an oxygen-based fuel factor ( $F_d$ ) for refinery gas per USEPA Method 19 specifications. The heat content and  $F_d$  factor were calculated from percent volume composition analytical data provided by MPC and tabulated heating values for the measured constituent.

End of Section 1 - Project Overview

RECEIVED

FEB 0 3 2014

AIR QUALITY DIV.

Client Reference No: CN00081321 CleanAir Project No: 12384-1

# **RESULTS**

Table 2-1:
DHT New Heater Stack – O<sub>2</sub> Relative Accuracy (USEPA M-3A / PS3)

Run No.	Start Time	Date (2013)	RM Data (%dv) C	EMS Data (%dv)	Difference (%dv)
1	12:06	Nov 5	5.03	5.15	-0.12
2	12:35	Nov 5	4.55	4.69	-0.14
3	13:02	Nov 5	4.98	5.13	-0.15
4	13:30	Nov 5	3.85	3.91	-0.06
5	13:57	Nov 5	7.21	7.33	-0.12
6	14:28	Nov 5	8.58	8.70	-0.13
7	14:58	Nov 5	7.98	8.13	-0.15
8	15:28	Nov 5	7.80	7.96	-0.16
9 *	15:55	Nov 5	7.54	7.76	-0.22
10	16:22	Nov 5	5.95	6.08	-0.12
	Average		6.21	6.34	-0.13


#### **Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.027	
Confidence Coefficient (CC)	0.021	
t-Value for 9 Data Sets	2.306	
		Limit
Avg. Abs. Diff. (%dv)	0.13	1.0

RM = Reference Method (CleanAir Data)

121613 162728

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)



Client Reference No: CN00081321 CleanAir Project No: 12384-1

**RESULTS** 

2-2

Table 2-2: DHT New Heater Stack – NO<sub>X</sub> Relative Accuracy (USEPA M-7E / PS2)

				= :	•	
Run No.	Start Time	Date (2013)	RM Data (ppmdv)	CEMS Data (ppmdv)	Difference (ppmdv)	Difference Percent
1	12:06	Nov 5	19.40	18.71	0.69	3.5%
2	12:35	Nov 5	19.06	18.36	0.70	3.7%
3	13:02	Nov 5	19.37	18.60	0.77	4.0%
4	13:30	Nov 5	17.31	16.72	0.59	3.4%
5	13:57	Nov 5	22.75	21.89	0.86	3.8%
6	14:28	Nov 5	24.03	23.14	0.89	3.7%
7	14:58	Nov 5	24.38	23.45	0.93	3.8%
8	15:28	Nov 5	24.48	23.50	0.98	4.0%
9	15:55	Nov 5	24.69	23.64	1.04	4.2%
10 *	16:22	Nov 5	23.44	22.43	1.01	4.3%
	Average		21.72	20.89	0.83	3.8%


#### **Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.150	
Confidence Coefficient (CC)	0.116	
t-Value for 9 Data Sets	2.306	
		Limit
Relative Accuracy (as % of RM)	4.3%	20.0%

RM = Reference Method (CleanAir Data)

121613 162728

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)



Client Reference No: CN00081321 CleanAir Project No: 12384-1

#### **RESULTS Table 2-3:** DHT New Heater Stack - NO<sub>x</sub> Emissions (USEPA M-7E) 2 Run No. 1 6 5 Nov 5 Nov 5 Date (2013) Nov 5 Nov 5 Nov 5 Nov 5 14:28 13:02 Start Time (approx.) 12:06 12:35 13:30 13:57 12:27 12:56 13:23 13:51 14:18 14:49 Stop Time (approx.) **Process Conditions** Fuel gas flow rate (Mscf/day) 900 889 846 1,126 1,364 1,390 Fd Oxygen-based F-factor (dscf/MMBtu) 7,666 7,666 7,666 7,666 7,666 7,666 H. Actual heat input (MMBtu/hr) 26 26 24 40 32 Сар 8,760 Capacity factor (hours/year) 8,760 8,760 8,760 8,760 8,760 **Gas Conditions** $O_2$ Oxygen (dry volume %) 5.0 4.5 5.0 3.8 7.2 8.6 CO2 Carbon dioxide (dry volume %) 7.1 7.6 7.6 8.1 6.3 5.2 Nitrogen Oxides Results $C_{sd}$ Concentration (ppmdv) 19.4 19.1 19.4 17.3 22.7 24.0 $C_{sd}$ Concentration (lb/dscf) 2.32E-06 2.28E-06 2.31E-06 2.07E-06 2.72E-06 2.87E-06 Emission Rate - F<sub>d</sub>-based (lb/MMBtu) 0.0373 0.0234 0.0233 0.0318 $E_{Fd}$ 0.0223 0.0194

080410 154528

#### Table 2-3 (Continued): DHT New Heater Stack – NO<sub>X</sub> Emissions (USEPA M-7E)

Average	10	9	8	7		Run No.
	Nov 5	Nov 5	Nov 5	Nov 5	(3)	Date (201
	16:22	15:55	15:28	14:58	e (approx.)	Start Tim
	16:43	16:16	15:49	15:19	e (approx.)	Stop Time
					Conditions	Process
1,269	1,512	1,571	1,581	1,516	Fuel gas flow rate (Mscf/day)	P <sub>1</sub>
7,666	7,666	7,666	7,666	7,666	Oxygen-based F-factor (dscf/MMBtu)	$F_d$
36	43	45	45	44	Actual heat input (MMBtu/hr)	$H_i$
8,760	8,760	8,760	8,760	8,760	Capacity factor (hours/year)	Cap
					ditions	Gas Con
6.3	6.0	7.5	7.8	8.0	Oxygen (dry volume %)	$O_2$
6.4	6.2	5.4	5.1	5.3	Carbon dioxide (dry volume %)	$CO_2$
					Oxides Results	Nitrogen
21.9	23.4	24.7	24.5	24.4	Concentration (ppmdv)	$C_{sd}$
2.61E-06	2.80E-06	2.95E-06	2.92E-06	2.91E-06	Concentration (lb/dscf)	$C_{sd}$
0.0295	0.0300	0.0353	0.0358	0.0361	Emission Rate - F <sub>d</sub> -based (lb/MMBtu)	$E_{Fd}$
	6.2 23.4 2.80E-06	5.4 24.7 2.95E-06	5.1 24.5 2.92E-06	5.3 24.4 2.91E-06	Carbon dioxide (dry volume %) Oxides Results Concentration (ppmdv) Concentration (lb/dscf)	CO <sub>2</sub> Nitrogen C <sub>sd</sub> C <sub>sd</sub>

Average includes 10 runs.

080410 154528

End of Section 2 - Results

Client Reference No: CN00081321 CleanAir Project No: 12384-1

### **DESCRIPTION OF INSTALLATION**

#### PROCESS DESCRIPTION

MPC's facility in Detroit, Michigan, produces refined petroleum products from crude oil. As part of the Detroit Heavy Oil Upgrade Project (DHOUP), new equipment is being installed to process heavy crude oil from Canada. As a condition of proceeding with the DHOUP, MPC must demonstrate that select process units are in compliance with permitted emission limits.

The Distillate Hydrotreater Unit (EG77-DHTHYTREAT) reacts sour distillate (and occasionally gas oil) streams with hydrogen over a catalyst bed to removed sulfur. The DHT unit consists of process vessels (reactors, distillation tower absorbing towers, stripper tower), heater (EG77-DHTHTR), cooling tower, compressors, pumps, piping, drains, and various components (pumps and compressor seals, process valves, pressure relief valves, flanges, connectors, etc.).

The DHT New Heater is fired by refinery fuel gas. Emissions are vented to the atmosphere via the DHT New Heater Stack (SV77-H1).

The testing reported in this document was performed at the DHT New Heater Stack.

### **DESCRIPTION OF SAMPLING LOCATIONS**

Sampling point locations were determined according to Performance Specification 2.

Table 3-1 outlines the sampling point configurations. The figure shown on the following page illustrates the sampling points and orientation of sampling ports.

Table 3-1: Sampling Points

Source Constituent	Method (USEPA)	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
DHT New Heater Stack O <sub>2</sub> /NO <sub>X</sub> (RATAs)	M-3A+PS3 / 7E+PS2	1-10	1	3	7	21	3-1

121613 162728

RECEIVED
FEB 0 3 2014
AIR QUALITY DIV.

Client Reference No: CN00081321 CleanAir Project No: 12384-1

3-2




Figure 3-1: USEPA Method 3A/7E Sampling Points – RATA and Emissions Testing

End of Section 3 - Description of Installation

Client Reference No: CN00081321 CleanAir Project No: 12384-1

### **METHODOLOGY**

4-1

Clean Air Engineering followed procedures as detailed in USEPA Methods 3A, 7E, 19, and Performance Specifications 2 and 3. The following table summarizes the methods and their respective sources.

# Table 4-1: Summary of Sampling Procedures

Title 40 CFR Pa	rt 60 Appendix A
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from
	Stationary Sources (instrumental Analyzer Procedure)"
Method 7E	"Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental
	Analyzer Procedure)"
Method 19	"Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur
motiloa 30	Dioxide, and Nitrogen Oxide Emission Rates"
	bloxide, and Millogen Oxide Emission Rates
Title 40 CER Pa	rt 60 Appendix B (Performance Specifications (PS))
PS2	
P32	"Specifications and Test Procedures for SO <sub>2</sub> and NO <sub>x</sub> Continuous Emission Monitoring
	Systems in Stationary Sources"
PS3	"Specifications and Test Procedures for O <sub>2</sub> and CO <sub>2</sub> Continuous Emission Monitoring
	Systems in Stationary Sources"

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at http://ecfr.gpoaccess.gov.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in CleanAir's internal Quality Manual. Results of all QA/QC activities performed by CleanAir are summarized in Appendix D.

Client Reference No: CN00081321 CleanAir Project No: 12384-1

#### **METHODOLOGY**

4-2

O<sub>2</sub>, CO<sub>2</sub>, and NO<sub>X</sub>, Emissions / RATA Testing - USEPA Methods 3A and 7E; Performance Specifications 2 and 3

Reference method O<sub>2</sub> and CO<sub>2</sub> emissions were determined using a paramagnetic/NDIR CEMs analyzer per EPA Method 3A and Performance Specification 3. Reference method NO<sub>X</sub> emissions were determined using a chemiluminescent CEMs analyzer per EPA Method 7E and Performance Specification 2.

The sampling system consisted of a heated probe, heated filter, and heated sample line. Flue gas was extracted at a constant rate at the points specified performance specification and delivered at 250°F to a gas conditioner which removed moisture. The flue gas was then delivered via a flow panel to an analyzer bank. Each analyzer measured concentration on a dry basis (units of %dv or ppmdv).

Calibration error checks were performed by introducing zero nitrogen (N<sub>2</sub>), high-range and mid-range calibration gases to the inlet of each analyzer during calibration error checks. Bias checks were performed before and after each sampling run by introducing calibration gas to the inlet of the sampling system's heated filter. Per M-3A and 7E, the average results for each run were drift-corrected. Documentation of interference checks and NO<sub>2</sub> converter efficiency checks are included in Appendix D.

End of Section 4 – Methodology