



REPORT ON COMPLIANCE TESTING

Detroit Refinery
Crude/Vacuum Heater Stack


Marathon Petroleum Company
1300 South Fort Street
Detroit, MI 48217
Client Reference No. 4101815470

CleanAir Project No. 13996
A2LA ISO 17025 Certificate No. 4342.01
A2LA / STAC Certificate No. 4342.02
Revision 0, Final Report
December 5, 2019

COMMITMENT TO QUALITY

To the best of our knowledge, the data presented in this report are accurate, complete, error free and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Report Writer:



December 5, 2019

Chad Eilering
Field Test Leader
ceilering@cleanair.com
(800) 627-0033

Date

I hereby certify that the information contained within the final test report has been reviewed and, to the best of my ability, verified as accurate.

Independent Report and Appendix Reviewer:



December 5, 2019

Andy Obuchowski
Midwest Engineering Group Leader
aobuchowski@cleanair.com
(800) 627-0033 ext. 4537

Date

REPORT REVISION HISTORY

Version	Revision	Date	Pages	Comments
Draft	D0a	12/03/19	All	Draft version of original document.
Final	0	12/05/19	All	Final version of original document.

PROJECT PERSONNEL

Name	Affiliation	Project Responsibility
Cody Spoon	Marathon Petroleum Company LP	Client / Site Contact
Ken Sullivan	CleanAir	Project Manager / Report Coordinator
Chad Eilering	CleanAir	Report Writer
Andy Obuchowski	CleanAir	Independent Reviewer of Report
Justin Giel	CleanAir	Project Field Leader
Josh Myers	CleanAir	Field Engineer
Jonathan Kolling	CleanAir	Field Engineer
Michael Kavulic	CleanAir	Field Engineer

TABLE OF CONTENTS

1. Project Overview	1
Test Program Summary	1
Test Program Details	1
Parameters	1
Schedule	2
Discussion	2
2. Results	4
3. Description of Installation	8
Process Description	8
Test Location	8
4. Methodology	10
Procedures and Regulations.....	10
Title 40 CFR Part 60, Appendix A	10
CTM-013 (Mod.) Controlled Condensation Method (CCM)	10
Methodology Discussion	10
FPM – USEPA Method 5	10
H ₂ SO ₄ – CTM-013 (Modified).....	11
NSFPM – USEPA Method 5B.....	11
5. Appendix.....	12
Appendix A: Test Method Specifications.....	A
Appendix B: Sample Calculations	B
Appendix C: Parameters	C
Appendix D: QA/QC Data	D
Appendix E: Field Data.....	E
Appendix F: Field Data Printouts.....	F
Appendix G: Laboratory Data	G
Appendix H: Facility Operating Data	H
Appendix I: DEQ Letter	I
Appendix J: CleanAir Resumes and Certifications	J

LIST OF TABLES

Table 1-1: Summary of Compliance Results	1
Table 1-2: Test Schedule.....	2
Table 2-1: Crude/Vacuum Heater Stack – FPM Emissions	4
Table 2-2: Crude/Vacuum Heater Stack – H ₂ SO ₄ Emissions	5
Table 2-3: Crude/Vacuum Heater Stack – PM Emissions	6
Table 2-4: Crude/Vacuum Heater – NSFPM Emissions	7
Table 3-1: Sampling Information	8

LIST OF FIGURES

Figure 3-1: FPM and NSFPM Sample Point Layout.....	9
--	---

ACRONYMS & ABBREVIATIONS

AAS (atomic absorption spectrometry)	ft ³ (cubic feet)	MW (megawatt(s))
acfm (actual cubic feet per minute)	ft/sec (feet per second)	NCASI (National Council for Air and Stream Improvement)
ACI (activated carbon injection)	FTIR (Fourier Transform Infrared Spectroscopy)	ND (non-detect)
ADL (above detection limit)	FTRB (field train reagent blank)	NDIR (non-dispersive infrared)
AIG (ammonia injection grid)	g (gram(s))	NDO (natural draft opening)
APC (air pollution control)	GC (gas chromatography)	NESHAP (National Emission Standards for Hazardous Air Pollutants)
AQCS (air quality control system(s))	GFAAS (graphite furnace atomic absorption spectroscopy)	ng (nanogram(s))
ASME (American Society of Mechanical Engineers)	GFC (gas filter correlation)	Nm ³ (Normal cubic meter)
ASTM (American Society for Testing and Materials)	gr/dscf (grains per dry standard cubic feet)	% (percent)
BDL (below detection limit)	> (greater than)/ ≥ (greater than or equal to)	PEMS (predictive emissions monitoring systems)
Btu (British thermal units)	g/s (grams per second)	PFGC (pneumatic focusing gas chromatography)
CAM (compliance assurance monitoring)	H ₂ O (water)	pg (picogram(s))
CARB (California Air Resources Board)	HAP(s) (hazardous air pollutant(s))	PJFF (pulse jet fabric filter)
CCM (Controlled Condensation Method)	HI (heat input)	ppb (parts per billion)
CE (capture efficiency)	hr (hour(s))	PPE (personal protective equipment)
°C (degrees Celsius)	HR GC/MS (high-resolution gas chromatography and mass spectrometry)	ppm (parts per million)
CEMS (continuous emissions monitoring system(s))	HRVOC (highly reactive volatile organic compounds)	ppmdv (parts per million, dry volume)
CFB (circulating fluidized bed)	HSRG(s) (heat recovery steam generator(s))	ppmwv (parts per million, wet volume)
CFR (Code of Federal Regulations)	HVT (high velocity thermocouple)	PSD (particle size distribution)
cm (centimeter(s))	IC (ion chromatography)	psi (pound(s) per square inch)
COMS (continuous opacity monitoring system(s))	IC/PCR (ion chromatography with post column reactor)	PTE (permanent total enclosure)
CT (combustion turbine)	ICP/MS (inductively coupled argon plasma mass spectroscopy)	PTFE (polytetrafluoroethylene)
CTI (Cooling Technology Institute)	ID (induced draft)	QA/QC (quality assurance/quality control)
CTM (Conditional Test Method)	in. (inch(es))	QI (qualified individual)
CVAAS (cold vapor atomic absorption spectroscopy)	in. H ₂ O (inches water)	QSTI (qualified source testing individual)
CVAFS (cold vapor atomic fluorescence spectrometry)	in. Hg (inches mercury)	QSTO (qualified source testing observer)
DI H ₂ O (de-ionized water)	IPA (isopropyl alcohol)	RA (relative accuracy)
%dv (percent, dry volume)	ISE (ion-specific electrode)	RATA (relative accuracy test audit)
DLL (detection level limited)	kg (kilogram(s))	RB (reagent blank)
DE (destruction efficiency)	kg/hr (kilogram(s) per hour)	RE (removal or reduction efficiency)
DCI (dry carbon injection)	< (less than)/ ≤ (less than or equal to)	RM (reference method)
DGM (dry gas meter)	L (liter(s))	scf (standard cubic feet)
dscf (dry standard cubic feet)	lb (pound(s))	scfm (standard cubic feet per minute)
dscfm (dry standard cubic feet per minute)	lb/hr (pound per hour)	SCR (selective catalytic reduction)
dscm (dry standard cubic meter)	lb/MMBtu (pound per million British thermal units)	SDA (spray dryer absorber)
ESP (electrostatic precipitator)	lb/TBtu (pound per trillion British thermal units)	SNCR (selective non-catalytic reduction)
FAMS (flue gas adsorbent mercury speciation)	lb/lb-mole (pound per pound mole)	STD (standard)
*F (degrees Fahrenheit)	LR GC/MS (low-resolution gas chromatography and mass spectrometry)	STMS (sorbent trap monitoring system)
FB (field blank)	m (meter)	TBtu (trillion British thermal units)
FCC (fluidized catalytic cracking)	m ³ (cubic meter)	TEOM (Tapered Element Oscillating Microbalance)
FCCU (fluidized catalytic cracking unit)	MACT (maximum achievable control technology)	TEQ (toxic equivalency quotient)
FEGT (furnace exit gas temperatures)	MASS® (Multi-Point Automated Sampling System)	ton/hr (ton per hour)
FF (fabric filter)	MATS (Mercury and Air Toxics Standards)	ton/yr (ton per year)
FGD (flue gas desulfurization)	MDL (method detection limit)	TSS (third stage separator)
FIA (flame ionization analyzer)	µg (microgram(s))	USEPA or EPA (United States Environmental Protection Agency)
FID (flame ionization detector)	min. (minute(s))	UVA (ultraviolet absorption)
FPD (flame photometric detection)	mg (milligram(s))	WFGD (wet flue gas desulfurization)
FRB (field reagent blank)	ml (milliliter(s))	%wv (percent, wet volume)
FSTM (flue gas sorbent total mercury)	MMBtu (million British thermal units)	
ft (feet or foot)		
ft ² (square feet)		

1. PROJECT OVERVIEW

TEST PROGRAM SUMMARY

Marathon Petroleum Company LP (MPC) contracted CleanAir Engineering (CleanAir) to complete testing on the Crude/Vacuum Heater (EU05-CRUDEHTR-S1 & EU04-VACHTR-S-1) at the Detroit Refinery. The test program included the following objective:

- Perform particulate matter (PM) and sulfuric acid mist (H₂SO₄) testing to demonstrate quarterly compliance with the Michigan Department of Environmental Quality (DEQ) Permit No. MI-ROP-A9831-2012c.

A summary of the test program results is presented below. Section 2 Results provides a more detailed account of the test conditions and data analysis.

**Table 1-1:
 Summary of Compliance Results**

<u>Source</u> Constituent	<u>Sampling</u> Method	<u>Average</u> Emission	<u>Permit Limit</u> ¹
<u>Crude/Vacuum Heater Stack</u>			
FPM (lb/MMBtu)	USEPA 5	0.0008	N/A
H ₂ SO ₄ (lb/MMBtu)	CTM-013 (Mod)	0.0006	N/A
PM (lb/MMBtu) ²	USEPA 5 / CTM-013 (Mod)	0.0003	0.0019
NSFPM (lb/MMBtu)	USEPA 5B	0.0009	N/A

¹ Permit limits obtained from MDEQ Renewable Operating Permit No. MI-ROP-A9831-2012c.

² PM assumed equivalent to FPM less H₂SO₄. The letter from MDEQ referenced in the appendix further outlines the correction of PM emission for H₂SO₄ bias.

TEST PROGRAM DETAILS

PARAMETERS

The test program included the following measurements:

- filterable particulate matter (FPM)
- nonsulfuric acid filterable particulate matter (NSFPM)
- sulfuric acid mist (H₂SO₄) conducted concurrently with FPM measurements
- PM assumed equivalent to FPM minus H₂SO₄
- flue gas composition (e.g., O₂, CO₂, H₂O)
- flue gas temperature
- flue gas flow rate

SCHEDULE

Testing was performed on October 31 and November 1, 2019. The on-site schedule followed during the test program is outlined in Table 1-2.

**Table 1-2:
Test Schedule**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Crude/Vac Stack	USEPA Method 5	FPM	10/31/19	11:35	13:15
2	Crude/Vac Stack	USEPA Method 5	FPM	11/01/19	10:45	12:03
3	Crude/Vac Stack	USEPA Method 5	FPM	11/01/19	13:30	14:45
4	Crude/Vac Stack	USEPA Method 5	FPM	11/01/19	16:12	17:27
1	Crude/Vac Stack	USEPA Method 5B	NSFPM	10/31/19	11:35	13:15
2	Crude/Vac Stack	USEPA Method 5B	NSFPM	11/01/19	10:45	12:03
3	Crude/Vac Stack	USEPA Method 5B	NSFPM	11/01/19	13:30	14:45
4	Crude/Vac Stack	USEPA Method 5B	NSFPM	11/01/19	16:12	17:27
1	Crude/Vac Stack	CTM-013 (mod)	H ₂ SO ₄	10/31/19	11:35	13:15
2	Crude/Vac Stack	CTM-013 (mod)	H ₂ SO ₄	11/01/19	10:45	12:03
3	Crude/Vac Stack	CTM-013 (mod)	H ₂ SO ₄	11/01/19	13:30	14:45
4	Crude/Vac Stack	CTM-013 (mod)	H ₂ SO ₄	11/01/19	16:12	17:27

DISCUSSION

Project Synopsis

FPM Testing

A total of four (4) 60-minute EPA Method 5 test runs were performed. FPM emission results were calculated in units of pounds per million Btu (lb/MMBtu). The final results were expressed as the average of the four (4) valid runs.

H₂SO₄ Testing

H₂SO₄ emissions were determined referencing Conditional Test Method 013 (CTM-013). Four (4) 60-minute CTM-013 test runs were performed concurrently with all Method 5 runs. H₂SO₄ emission results were calculated in units of lb/MMBtu. The H₂SO₄ final results were expressed as the average of four (4) valid runs.

PM Results

PM is assumed equivalent to the difference of FPM and H₂SO₄ emissions. This is recommended in a letter from the DEQ, dated December 18, 2017; "Marathon Petroleum, Crude/Vacuum Heater Stack, Request to Substitute Method 5B for Method 5, Permit: MI-ROP-A9831-2012c, SRN: A9831."

H₂SO₄ emissions were determined concurrently with FPM emissions, converted to units of lb/MMBtu and subtracted from total FPM emissions from each respective run. The PM final results were expressed as the average of the three (3) highest runs.

NSFPM Testing

A total of four (4) 60-minute EPA Method 5B test runs were performed. NSFPM emission results were calculated in units of lb/MMBtu. The final results were expressed as the average of the four (4) valid runs. Method 5B testing was conducted for supplemental purposes only. It should be noted that the average result for NSFPM was greater than the average result for FPM. This is due to the result for Method 5B Run 1 being uncharacteristically elevated comparatively to subsequent runs. There is no overt explanation for this occurrence. The result from Run 1 should be considered with caution.

Fuel Factor

Emission results in units of dry volume-based concentration (lb/dscf, ppm_{dv}) were converted into units of lb/MMBtu by applying an oxygen-based fuel factor (F_d) provided by MPC for each test run.

Test Conditions

The unit was operated at the maximum normal operating capacity during each of the emissions compliance test runs. MPC was responsible for logging any relevant process-related data and providing it to CleanAir for inclusion in the test report.

End of Section

2. RESULTS

This section summarizes the test program results. Additional results are available in the report appendices.

**Table 2-1:
Crude/Vacuum Heater Stack – FPM Emissions**

Run No.	1	2	3	4	Average
Date (2019)	Oct 31	Nov 1	Nov 1	Nov 1	
Start Time (approx.)	11:35	10:45	13:30	16:12	
Stop Time (approx.)	13:15	12:03	14:45	17:27	
Process Conditions					
P ₁ Production rate (BPD)	145,100	144,300	145,900	144,700	145,000
F _d Oxygen-based F-factor (dscf/MMBtu)	8,433	8,499	8,499	8,499	
H _i Actual heat input (MMBtu/hr)	297	291	288	298	294
Gas Conditions					
O ₂ Oxygen (dry volume %)	8.4	8.6	8.0	7.8	8.2
CO ₂ Carbon dioxide (dry volume %)	6.9	7.1	7.4	7.4	7.2
T _s Sample temperature (°F)	299	297	295	298	297
B _w Actual water vapor in gas (% by volume)	14.6	14.1	13.3	14.2	14.0
Gas Flow Rate					
Q _a Volumetric flow rate, actual (acfm)	118,000	111,000	117,000	118,000	116,000
Q _s Volumetric flow rate, standard (scfm)	79,700	76,400	80,900	80,600	79,400
Q _{std} Volumetric flow rate, dry standard (dscfm)	68,100	65,700	70,100	69,200	68,300
Sampling Data					
V _{mstd} Volume metered, standard (dscf)	34.04	32.45	34.60	33.18	33.57
%I Isokinetic sampling (%)	104.3	103.1	103.0	100.0	102.6
Laboratory Data					
m _{filter} Matter collected on filter(s) (g)	0.00029	0.00035	0.00053	0.00029	
m _s Matter collected in solvent rinse(s) (g)	0.00079	0.00032	0.00050	0.00058	
m _n Total FPM (g)	0.00108	0.00067	0.00103	0.00087	
FPM Results					
C _{sd} Particulate Concentration (lb/dscf)	7.00E-08	4.55E-08	6.56E-08	5.78E-08	5.97E-08
E _{lb/hr} Particulate Rate (lb/hr)	0.286	0.179	0.276	0.240	0.245
E _{Fd} Particulate Rate - F _d -based (lb/MMBtu)	0.000986	0.000658	0.000904	0.000784	0.000833

**Table 2-2:
 Crude/Vacuum Heater Stack – H₂SO₄ Emissions**

Run No.		1	2	3	4	Average
Date (2019)		Oct 31	Nov 1	Nov 1	Nov 1	
Start Time (approx.)		11:35	10:45	13:30	16:12	
Stop Time (approx.)		13:15	12:03	14:45	17:27	
Process Conditions						
P ₁	Charge rate (BPD)	145,100	144,300	145,900	144,700	145,000
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,433	8,499	8,499	8,499	
H _i	Actual heat input (MMBtu/hr)	297	291	288	298	295
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.4	8.1	8.0	9.3	7.2
CO ₂	Carbon dioxide (dry volume %)	6.9	6.9	7.3	6.4	7.8
T _s	Sample temperature (°F)	299	299	298	299	302
B _w	Actual water vapor in gas (% by volume)	14.6	10.2	12.9	13.7	14.1
Sampling Data						
V _{mstd}	Volume metered, standard (dscf)	26.81	27.70	28.74	27.55	26.32
Laboratory Data (Ion Chromatography)						
m _n	Total H ₂ SO ₄ collected (mg)	0.4890	0.3063	0.7878	0.4053	
Sulfuric Acid Vapor (H₂SO₄) Results						
C _{sd}	H ₂ SO ₄ Concentration (lb/dscf)	4.02E-08	2.44E-08	6.04E-08	3.24E-08	4.57E-08
C _{sd}	H ₂ SO ₄ Concentration (ppm dv)	0.158	0.096	0.238	0.127	0.180
E _{Fd}	H ₂ SO ₄ Rate - Fd-based (lb/MMBtu)	0.000567	0.000338	0.000832	0.000497	0.000597

**Table 2-3:
 Crude/Vacuum Heater Stack – PM Emissions**

Run No.		1	2	3	4	Average
Date (2019)		Oct 31	Nov 1	Nov 1	Nov 1	
Start Time (approx.)		11:35	10:45	13:30	16:12	
Stop Time (approx.)		13:15	12:03	14:45	17:27	
Process Conditions						
P ₁	Production rate (BPD)	145,100	144,300	145,900	144,700	145,000
F _d	Oxygen-based F-factor (ds cf/MMBtu)	8,433	8,499	8,499	8,499	8,482
H _i	Actual heat input (MMBtu/hr)	297	291	288	298	294
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.4	8.6	8.0	7.8	8.2
CO ₂	Carbon dioxide (dry volume %)	6.9	7.1	7.4	7.4	7.2
T _s	Sample temperature (°F)	299	297	295	298	297
B _w	Actual water vapor in gas (% by volume)	14.6	14.1	13.3	14.2	14.0
FPM Results						
E _{Fd}	Particulate Rate - F _d -based (lb/MMBtu)	0.000986	0.000658	0.000904	0.000784	0.000833
Sulfuric Acid Vapor (H₂SO₄) Results						
E _{Fd}	H ₂ SO ₄ Rate - F _d -based (lb/MMBtu)	0.000567	0.000338	0.000832	0.000497	0.000597
Particulate Matter (as PM₁₀) Results¹						
E _{Fd}	Particulate Rate - F _d -based (lb/MMBtu)	0.000419	0.000319	0.000072	0.000287	0.000342

¹ Final PM result is the average of three (3) highest valid runs (Runs 1, 2, & 4).

**Table 2-4:
Crude/Vacuum Heater – NSFPM Emissions**

Run No.		1	2	3	4	Average
Date (2019)		Oct 31	Nov 1	Nov 1	Nov 1	
Start Time (approx.)		11:35	10:45	13:30	16:12	
Stop Time (approx.)		13:15	12:03	14:45	17:26	
Process Conditions						
P ₁	Production rate (BPD)	145,100	144,300	145,900	144,700	145,000
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,433	8,499	8,499	8,499	8,482
H _i	Actual heat input (MMBtu/hr)	297	291	288	298	294
Gas Conditions						
O ₂	Oxygen (dry volume %)	8.4	8.7	8.1	8.6	8.5
CO ₂	Carbon dioxide (dry volume %)	6.8	6.9	7.3	6.8	7.0
T _s	Sample temperature (°F)	301	300	299	300	300
B _w	Actual water vapor in gas (% by volume)	16.2	12.9	13.0	13.4	13.9
Gas Flow Rate						
Q _a	Volumetric flow rate, actual (acfm)	110,000	117,000	116,000	117,000	115,000
Q _s	Volumetric flow rate, standard (scfm)	73,800	80,300	79,600	79,700	78,400
Q _{std}	Volumetric flow rate, dry standard (dscfm)	61,800	70,000	69,300	69,100	67,500
Sampling Data						
V _{mstd}	Volume metered, standard (dscf)	31.75	35.14	34.91	35.13	34.23
%I	Isokinetic sampling (%)	107.1	104.8	105.1	106.1	105.8
Laboratory Data						
m _{filter}	Matter collected on filter(s) (g)	0.00067	0.00029	0.00029	0.00031	
m _s	Matter collected in solvent rinse(s) (g)	0.00108	0.00032	0.00051	0.00038	
m _n	Total NSFPM (g)	0.00175	0.00061	0.00080	0.00069	
NSFPM Results						
C _{sd}	Particulate Concentration (lb/dscf)	1.22E-07	3.83E-08	5.05E-08	4.33E-08	6.34E-08
E _{lb/hr}	Particulate Rate (lb/hr)	0.451	0.161	0.210	0.179	0.250
E _{Fd}	Particulate Rate - F _d -based (lb/MMBtu)	0.00171	0.000557	0.000701	0.000625	0.000899

End of Section

3. DESCRIPTION OF INSTALLATION

PROCESS DESCRIPTION

MPC's facility in Detroit, Michigan produces refined petroleum products from crude oil. MPC must continue to demonstrate that select process units are in compliance with permitted emission limits.

The Crude Unit (EU05-CRUDE) separates crude oil into various fractions through the use of distillation processes. These fractions are sent to other units in the refinery for further processing. The Crude Unit consists of process vessels (including heat exchangers and fractionation columns), the Alcorn heater (EU05-CRUDEHTR-S1), tanks, containers, compressors, pumps, piping, drains, and various components (pump and compressor seals, process valves, pressure relief valves, flanges, connectors, etc.).

The Vacuum Unit (EU04-VACUUM) separates the reduced crude from the Crude Unit through the use of a vacuum column. The reduced crude is separated into light vacuum gas oil, medium vacuum gas oil, heavy vacuum gas oil and a bottoms product called flux. The various fractions are sent to other units in the refinery for further processing. The Vacuum Unit consists of process vessels (including heat exchangers and vacuum column), two process heaters, tanks, containers, two cooling towers, flare, compressors, pumps, piping, drains, and various components (pumps and compressor seals, process valves, pressure relief valves, flanges, connectors, etc.).

The Vacuum Heater (EU04-VACHTR-S1) and Crude Heater (EU05-CRUDEHTR-S1) are fired by refinery fuel gas. Emissions are vented to the atmosphere via a common stack known as the Crude/Vacuum Heater Stack (SV04-H1-05-H1). Additional emissions are vented to the atmosphere via the Vacuum 2 Heater Stack (SV04-H2). The testing reported in this document was performed at the Crude/Vacuum Heater Stack (SV04-H1-05-H1).

TEST LOCATION


The sample point locations were determined by EPA Method 1. Table 3-1 presents the sampling information for the test location described in this report. The figure shown on page 9 represents the layout of the test location.

**Table 3-1:
Sampling Information**

Source Constituent	Method (USEPA)	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Crude/Vacuum Heater Stack</u>							
FPM	5	1-4	4	6	2.5	60	3-1
NSFPM	5B	1-4	4	6	2.5	60	3-1
H ₂ SO ₄	CTM-013 (mod.)	1-4	1	1	60	60	N/A ¹

¹CTM-013 (mod) sampling occurred at a single point near the center of the duct.

**Figure 3-1:
 FPM and NSFPM Sample Point Layout**



Sampling Point	% of Stack Diameter	Port to Point Distance (inches)	Point + Port (14") Distance (inches)
1	35.6	39.2	53.2
2	25.0	27.5	41.5
3	17.7	19.5	33.5
4	11.8	13.0	27.0
5	6.7	7.4	21.4
6	2.1	2.3	16.3

Duct diameters upstream from flow disturbance (A): 5.3 Limit: 0.5
 Duct diameters downstream from flow disturbance (B): 2.4 Limit: 2.0

4. METHODOLOGY

PROCEDURES AND REGULATIONS

The test program sampling measurements followed procedures and regulations outlined by the United States Environmental Protection Agency (USEPA) and the Michigan Department of Environment, Great Lakes and Energy (EGLE). These methods appear in detail in Title 40 of the CFR and at <https://www.epa.gov/emc>.

Appendix A includes diagrams of the sampling apparatus, as well as specifications for sampling, recovery, and analytical procedures. Any modifications to standard test methods are explicitly indicated in this appendix. In accordance with ASTM D7036 requirements, CleanAir included a description of any such modifications along with the full context of the objectives and requirements of the test program in the test protocol submitted prior to the measurement portion of this project. Modifications to standard methods are not covered by the ISO 17025 and TNI portions of CleanAir's A2LA accreditation.

CleanAir follows specific QA/QC procedures outlined in the individual methods and in USEPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods," EPA/600/R-94/038C. Appendix D contains additional QA/QC measures, as outlined in CleanAir's internal Quality Manual.

TITLE 40 CFR PART 60, APPENDIX A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 5	"Determination of Particulate Matter Emissions from Stationary Sources"
Method 5B	"Determination of Nonsulfuric Acid Particulate Matter Emissions from Stationary Sources"

CTM-013 (MOD.) CONTROLLED CONDENSATION METHOD (CCM)

"Determination of Sulfur Oxides Including Sulfur Dioxide, Sulfur Trioxide and Sulfuric Acid Vapor and Mist from Stationary Sources Using a Controlled Condensation Sampling Apparatus"

METHODOLOGY DISCUSSION

FPM – USEPA METHOD 5

FPM emissions were determined using EPA Method 5. The front-half of the sampling train consisted of a glass nozzle, glass liner, and filter holder heated to 248°F ± 25°F and a quartz fiber filter. Flue gas samples were extracted isokinetically per Method 5 requirements.

After exiting the front-half filter, the flue gas passed through a series of knock-out jars. Condensate in the knock-out jars were collected to determine the flue gas moisture and thoroughly dry the gas. The sample gas then flowed into a calibrated dry gas meter where the collected sample gas volume was determined.

The front-half portion of the sample train (nozzle, probe, and heated filter) was recovered per Method 5 requirements, using acetone as the recovery solvent.

All samples and blanks were returned to CleanAir Analytical Services in Palatine, Illinois, for gravimetric analysis. Upon receipt, the filters desiccated for 24 hours at ambient temperature. The front-half rinses were evaporated at ambient temperature and pressure. The masses from each fraction were then summed for a total FPM mass.

H₂SO₄ – CTM-013 (MODIFIED)

H₂SO₄ emissions were determined referencing modified CTM-013. A gas sample was extracted from the source at a constant flow rate using a quartz-lined probe maintained at a temperature of 650°F ± 25°F and a quartz fiber filter (to remove PM) maintained at the same temperature as the probe.

The sample then passed through a glass coil condenser for collection of sulfuric acid vapor and/or mist. A glass frit/filter was located at the condenser outlet for the collection of residual sulfuric acid mist (SAM) not collected by the condenser. The condenser temperature is regulated by a water jacket and the SAM filter is regulated by a closed oven. Both the water jacket and SAM filter oven were maintained at 140°F ± 9°F plus 2°F for each 1% moisture above 16% flue gas moisture (above the water dew point which eliminates the possibility of oxidation of dissolved SO₂ into the H₂SO₄-collecting fraction of the sample train).

After exiting the SAM filter, the sample gas then continued through a series of four (4) glass knock-out jars: two (2) containing water, one (1) empty and one (1) containing silica gel for residual moisture removal. The exit temperature from the knock-out jar set is maintained below 68°F. The sample gas then flowed into a dry gas meter where the collected sample gas volume is determined by means of a calibrated, dry gas meter.

The H₂SO₄-collecting portion of the sample train (condenser and SAM filter) was recovered into a single fraction using DI H₂O as the recovery/extraction solvent; any H₂SO₄ disassociates into sulfate ion (SO₄²⁻) and was stabilized in the H₂O matrix until analysis. Following the initial sample recovery, a second DI H₂O rinse was completed.

Samples, back-up rinses, and blanks were returned to CleanAir Analytical Services in Palatine, Illinois, for ion chromatography analysis.

NSFPM – USEPA METHOD 5B

NSFPM emissions were determined using EPA Method 5B. The front-half of the sampling train consisted of a glass nozzle, glass liner, and filter holder heated to 320°F ± 25°F and a quartz fiber filter. Flue gas samples were extracted isokinetically per Method 5B requirements.

After exiting the front-half filter, the flue gas passed through a series of knock-out jars. Condensate in the knock-out jars were collected to determine the flue gas moisture and thoroughly dry the gas. The sample gas then flowed into a calibrated dry gas meter where the collected sample gas volume was determined.

The front-half portion of the sample train (nozzle, probe, and heated filter) was recovered per Method 5B requirements, using acetone as the recovery solvent.

All samples and blanks were returned to CleanAir Analytical Services in Palatine, Illinois, for gravimetric analysis. Upon receipt, the filters desiccated for 24 hours at ambient temperature. The front-half rinses were evaporated at ambient temperature and pressure. The masses from each fraction were then summed for a total FPM mass.