



AIR EMISSIONS TESTING FOR INDUSTRY

*Relative Accuracy Test Audit
and Performance Testing*

for

Marathon Petroleum Company LP

at the

Marathon Detroit Refinery in Detroit, MI

on the

CCR Interheater (CCRPLINTHTR)

Unit: EU14-CCRPLINTHTR-S1

Permit No. MI-ROP-A9831-2012c

Prepared for:



**Marathon
Petroleum Company LP**

Test Date: June 7, 2022
Erthwrks Project No. 9049.1.B4



Endorsement Page

This report was developed in accordance with the requirements designated in the applicable regulatory permit(s) and or regulatory rules. To the best of my knowledge the techniques, instrumentation, and calculations presented in this report will serve to accurately and efficiently detail the results of the test campaign requirements.

Erthwrks, Inc.

Name: Jason Dunn

Title: QC Specialist

Signature: 

This report has been reviewed for accuracy and completeness. The actions presented in this report are, to the best of my knowledge, an accurate representation of the results and findings of the test campaign. Erthwrks, Inc. operates in conformance with the requirements on ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies and is accredited as such by the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA).

Erthwrks, Inc.

Name: Trey Chapman

Title: CEO


Signature: 

Table of Contents

1.0	INTRODUCTION	4
1.1	Identification, location and dates of tests	4
1.2	Purpose of Testing.....	4
1.3	Description of Source.....	4
1.4	Contact Information	5
2.0	SUMMARY OF RESULTS	6
3.0	SOURCE DESCRIPTION.....	6
3.1	Description of the process	6
3.2	Applicable permit and source designation	7
3.3	Type and quantity of materials processed during tests	7
4.0	SAMPLING AND ANALYTICAL PROCEDURES.....	7
4.1	Gaseous Emissions – NO _x , CO, O ₂ , and CO ₂	7
4.2	Filterable Particulate Matter Sampling – EPA Method 5	8
4.3	Condensable Particulate Matter Sampling – EPA Method 202.....	9
4.4	EPA Method CTM-013 (ALT-133 Analysis) H ₂ SO ₄ Determination	10
4.5	RATA Procedures	11
4.6	Discussion of sampling procedure or operational variances.....	12

ATTACHMENTS

- A. Detailed Results of Emissions Test
- B. Quality Control Documentation
- C. Sampling Datasheets
- D. Example Calculations
- E. Raw Datalog Records
- F. Calibrations and Certifications
- G. CEMS Logs and Operational Data
- H. Laboratory Analysis

1.0 INTRODUCTION

1.1 Identification, location and dates of tests

Erthwrks, Inc. was contracted to conduct emission testing on the CCR Interheater (CCRPLINTHTR) in operation at the Marathon Detroit Refinery, located in Detroit Michigan. The testing program was conducted on June 7, 2022.

1.2 Purpose of Testing

The exhaust from the CCR Interheater was sampled and analyzed to determine the relative accuracy of the associated carbon monoxide (CO), oxides of nitrogen (NO_x), and oxygen (O₂) continuous emissions monitoring system (CEMS) in accordance with the requirements in the Marathon Permit No. MI-ROP-A9831-2012c and the Title 40 CFR Part 60, Appendix F. In addition, compliance testing was conducted to determine the compliance status of the units' emission for sulfuric acid (H₂SO₄), and particulate matter (PM). The carbon dioxide (CO₂) concentration was also measured in order to determine stack gas molecular weight.

1.3 Description of Source

Marathon Petroleum Company LP operates the CCR Interheater designated as EU14-CCRPLINTHTR-S1 in the refinery. This report addresses the RATA for the CEMS associated with the unit as well as the required compliance test for H₂SO₄ and PM. Table 1.1 below details the CEMS analyzer information.

Table 1.1—Marathon CCR Interheater Stack CEMS Details

Crude/Vac Heater Stack CEMS	Manufacturer	Model No.	S/N	Install Date
NO _x	ABB	Limas 11	3.342969.1	2012
CO	ABB	Uras 26	3.342967.1	2012
O ₂	ABB	Magnos 206	3.342970.1	2012

1.4 Contact Information

Marathon Petroleum Company LP

Addie Koerner
Michigan Refining Division
330-479-5662 office
419-306-5162 cell
akoerner@marathonpetroleum.com

Erthwrks, Inc.

John Wood
Technical Director
P.O. Box 150549
Austin, TX 78745
512-585-1685 office
888-573-9994 fax
jwood@erthwrks.com

Erthwrks, Inc.

Jarrold Hoskinson
Senior Project Manager
P.O. Box 150549
Austin, TX 78745
512-994-7487 office
888-573-9994 fax
jhoskinson@erthwrks.com

Erthwrks, Inc.

Jason Dunn
QC Specialist
P.O. Box 150549
Austin, TX 78745
614-565-9177 office
888-573-9994 fax
jdunn@erthwrks.com

Facility Location:

Marathon Petroleum Company LP
Detroit Refinery
1300 South Fort Street
Detroit, MI 48217



2.0 SUMMARY OF RESULTS

Table 2.1—Marathon Crude/Vac Heater Stack (SV04-H1-05-H1) CEMS RATA Results

Pollutant Measured	Performance Specification	Relative Accuracy	Applicable Limit	Pass/Fail
NO _x	Performance Spec. 2	3.9% RA_{RM}	20%	Pass
CO	Performance Spec. 4A	0.3 ppm RA_{AA}	<5 ppm	Pass
O ₂	Performance Spec. 3	0.2% MD	1%	Pass

Table 2.2—Marathon Crude/Vac Heater Stack (SV04-H1-05-H1) Compliance Test Results

Pollutant Measured	Methodology	Measured Results	Applicable Limit	Pass/Fail
PM	EPA Method 5	0.0008 lb/MMBtu	0.0019 lb/MMBtu	Pass
PM/PM ₁₀	EPA Method 5/202	0.0027 lb/MMBtu	0.0076 lb/MMBtu	Pass
H ₂ SO ₄	EPA Method CTM-013	0.06 ppm	n/a	n/a

3.0 SOURCE DESCRIPTION

3.1 Description of the process

Marathon Petroleum Company LP produces refined petroleum products from crude oil and is required to demonstrate that select process emission sources are operating in compliance with permitted emissions limits.

The Continuous Catalytic Regeneration Platformer Unit (EG14-CCRPLATFORMER) is a catalytic reformer that rearranges the structure of low octane naphtha feed into higher octane reformates. Hydrogen is produced as a product of the reaction and is used in other refinery processes. The CCR Charge Heater (EG14-CCRPLCHARHTR) is the stack for Heater 14H8 and Heater 14H9. The CCR Interheater (EU14-CCRPLINTHTR) is the stack for Heater 14H1-4. Both units are fired by refinery fuel gas. Emissions are vented to the atmosphere via the CCR Charge Heater (SV14-H6) and CCR Interheater Stack (SV14-H4A).

3.2 Applicable permit and source designation

Marathon Petroleum Company LP operates the CCR Interheater (CCRPLINTHTR) (EU14-CCRPLINTHTR-S1) under EGLE Renewable Operating Permit No. MI-ROP-A9831-2012c.

3.3 Type and quantity of materials processed during tests

During the emission testing on June 7, 2022, at the Marathon Petroleum Company LP Refinery, the CCR Interheater (CCRPLINTHTR) was tested while operating at the maximum achievable load condition. This operational data was provided by MPC and is located in Attachment G of this report.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

4.1 Gaseous Emissions – NO_x, CO, O₂, and CO₂

For the gaseous sampling, Erthwrks utilized a stainless-steel probe, of sufficient length to reach all sampling points, inserted into a sampling port that is located on the stack in accordance with EPA Method 1. The sample is extracted through the probe, a heated Teflon sampling line, to a heating filter. The sample then enters a minimum contact sample conditioner that cools and removes moisture from the gas matrix prior to entering the Erthwrks sampling manifold.

Erthwrks followed all quality assurance and quality control procedures as defined in US EPA 40 CFR 60 Appendix A. The Calibration Error (CE) Test was conducted as specified in EPA Method 7E §8.2.3. In accordance with this requirement, a three-point analyzer calibration error test was conducted prior to sampling. The CE test was conducted by introducing the low, mid, and high-level calibration gasses (as defined in EPA Method 7E §3.3.1-3) sequentially and the response was recorded. The results of the CE test are acceptable if the calculated calibration error is within $\pm 2.0\%$ of calibration span (or ≤ 0.5 ppmv).

The Initial System Bias and System Calibration Error Check was conducted in accordance with EPA Method 7E §8.2.5. The upscale calibration gas was introduced at the probe upstream of all sample system components and the response recorded. The procedure will be repeated with the low-level gas and the response recorded. During this activity, the sample system response time will also be recorded. This specification is acceptable if the calculated values of the system calibration error check are within $\pm 5.0\%$ of the calibration span value (or ≤ 0.5 ppmv).

After each test run, the sample system bias check is conducted to validate the run data. The low-level and upscale drift are calculated using Equation 7E-4. The run data is valid if the calculated drift is within $\pm 3.0\%$ of the calibration span value (or ≤ 0.5 ppmv).

After each test run, the corrected effluent gas concentration was calculated as specified in EPA Method 7E §12.6. The arithmetic average of all valid concentration values are adjusted for bias using equation 7E-5B.




Figure 1: Example Erthwrks Gaseous Sampling System Diagram

4.2 Filterable Particulate Matter Sampling – EPA Method 5

EPA Test Method 1 will be used for the selection of sampling points. Stack dimensions, number of sample ports and sample port locations were confirmed prior to testing to determine the appropriate number of traverse points for the test.

EPA Test Method 5 was used to determine filterable particulate matter emission rates. Method 5 is the method at which particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter and on the lining of the isokinetic probe maintained at a temperature of $120 \pm 14^{\circ}\text{C}$. Upon completion of each test run, the nozzle and probe liner were rinsed and brushed with acetone. The acetone rinse catch will be collected and combined with the filter holder rinse and labeled as “front half rinse”. The total PM mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically. Filterable PM will be calculated by combining the net gravimetric gain of the filter and the net gravimetric gain of the evaporated front half rinse. Figure 2 below shows the Method 5 sampling system components.




Figure 2: Example Erthwrks PM System Diagram

4.3 Condensible Particulate Matter Sampling – EPA Method 202

For the determination of PM/PM₁₀, condensable particulate matter (CPM) was measured via EPA Method 202. The Method 202 components begin at the back half of the Method 5 filter housing. The filterable particulate matter is removed in these “front half” components. The condensable particulate matter is then collected by drawing the filtered gas through a water jacketed, spiral condenser maintained at 65° – 85° F. The cooled effluent gas is then passed through two empty impingers and finally through a hexane extracted Teflon filter. Upon completion of each test run, the moisture collected in this portion of the sampling train is purged with ultra-high purity (UHP) nitrogen gas for one hour to remove any dissolved sulfur dioxide. The moisture is collected in a container and combined with the deionized water used to rinse all Method 202 sampling glassware two times.

The glassware is next rinsed with hexane and acetone. These rinses are collected and combined in an additional container. The Teflon filter is removed from the filter housing, labeled, and collected. Gravimetric analysis is then conducted on the extracted, evaporated samples for each run.

4.4 EPA Method CTM-013 (ALT-133 Analysis) H₂SO₄ Determination

The H₂SO₄ emissions were determined utilizing the conditional test method 13 (CTM-013). The sample was extracted at a constant rate through a quartz lined heated probe (>350 °F), A heated quartz filter holder and filter (>500 °F), and through a Modified Graham condenser (H₂SO₄ Condenser) with Type C glass frit and 200 cm of 5-mmID glass tubing condenser coil. The H₂SO₄ condenser is maintained between 167 to 185 °F. Because SO₂ was not to be determined via this method, the sample was then passed through four impingers with the specifications delineated in EPA Method 4.

The sampling was conducted at a single point at a constant rate of about 10 L/min and the DGM readings and all temperatures were recorded every five minutes. After the completion of the test run, the samples were recovered in accordance with the test method and the samples were sent to Enthalpy Analytical for analysis via Ion Chromatography (ALT-133). See the figure below that details the CTM-013 Sampling Train.




Figure 3: Example Erthwrks H₂SO₄ System Diagram

4.5 RATA Procedures

The RATA testing was conducted following the sampling and measurement procedures found in the EPA Part 60, Appendix B, Performance Specifications which requires that EPA Reference Methods, from EPA Part 60, Appendix A, be utilized to conduct independent stack emissions measurements for comparison with installed CEMS readings. The following performance specifications will be used during this testing program.

- EPA Performance Specification 2 for NO_x relative accuracy
- EPA Performance Specification 3 for O₂ relative accuracy
- EPA Performance Specification 4A for CO relative accuracy

As required by these methods, the use EPA Protocol 1 gases are mandatory and were used for this portion of the project.

A minimum of nine (9) RATA test runs were conducted at each exhaust stack for a minimum duration of twenty-one (21) minutes for each run. A 3-point traverse located at 16.7%, 50.0%, and 83.3% of the way across the stack (or 0.4, 1.2, and 2.0 meters from the stack wall) was conducted during each RATA test run (7 minutes per point). A maximum of twelve (12) RATA test runs will be conducted and up to three test runs may be discarded and not used to determine relative accuracy. The results of the reference method tests were compared to CEMS measurement data from the same time periods to determine the relative accuracy of the CEMS.

For NO_x, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 20.0% as calculated by Equation 2-6 in Performance Specification 2. Alternatively, for affected units where the average of the reference method measurements is less than 50 percent of the emission standard (emission limit), the relative accuracy must not exceed 10% when the applicable emission standard is used in the denominator of Eq. 2-6.

For O₂, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 20.0% as calculated by Equation 3.1 in Performance Specification 3. The results are also acceptable if the result of Equation 3-2 is less than or equal to 1.0 percent.

For CO, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 10.0% as calculated by Equation 2-6 in Performance Specification 2. Alternatively, for affected units where the average of the reference method measurements is less than 50 percent of the emission standard (emission limit), the relative accuracy must not exceed 5% when the applicable emission standard is used in the denominator of Eq. 2-6. Performance Specification 4A criteria may be used to determine relative accuracy for CEMS with low emission standards (less than 200 ppmv). In these cases, the results of the RATA test are considered acceptable if the absolute average difference between the RM and CEMS is within 5 ppmv.

4.6 Discussion of sampling procedure or operational variances

Erthwrks, Inc. conducted the emissions testing with no sampling or procedural variances.

Attachment A
Detailed Results of Emission Test

**Erthwrks Relative Accuracy Test Audit--NOx RATA
Performance Specification 2**

CCR InterHtr								NO _x CEMS RATA - lb/MMBtu				
Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Fuel F-Factor	8595.3	scf/MMBtu	Run 9	Run 10	Run 11
Date	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022
Start Time	10:27	10:57	11:27	12:03	12:59	13:29	13:59	14:30	15:02	15:32	16:04	
End Time	10:48	11:18	11:48	12:24	13:20	13:50	14:20	14:51	15:23	15:53	16:25	
RM NO _x (ppmvd)	21.80	22.08	21.74	21.89	21.37	21.64	21.82	22.11	22.64	22.99	22.97	
RM O ₂ Results (%vd)	6.21	6.26	6.21	6.32	6.23	6.31	6.25	6.17	6.20	6.32	6.29	
RM NO _x (lb/MMBtu)	0.0318	0.0323	0.0317	0.0322	0.0312	0.0318	0.0319	0.0322	0.0330	0.0338	0.0337	
CEMS NO _x (lb/MMBtu)	0.0329	0.0331	0.0329	0.0330	0.0325	0.0333	0.0336	0.0333	0.0342	0.0348	0.0349	
Difference	-0.0011	-0.0008	-0.0012	-0.0008	-0.0013	-0.0015	-0.0017	-0.0011	-0.0012	-0.0010	-0.0012	
Accept or Reject	Accept	Accept	Accept	Accept	Reject	Accept	Reject	Accept	Accept	Accept	Accept	

Applicable Standard (lb/MMBtu)

0.05

Mean of the Difference (d_{avg})

-0.0011

Standard Deviation (S_d)

0.0002

Confidence Coefficient (CC)

0.0002

Relative Accuracy via RM, RA_{RM}*

3.88%

← Pass

*RA_{RM} (Reference Method) must be less than 20%



Erthwrks Relative Accuracy Test Audit--O₂ RATA Performance Specification 3

CCR InterHtr O₂ CEMS RATA

Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Run 8	Run 9	Run 10	Run 11
Date	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022
Start Time	10:27	10:57	11:27	12:03	12:59	13:29	13:59	14:30	15:02	15:32	16:04
End Time	10:48	11:18	11:48	12:24	13:20	13:50	14:20	14:51	15:23	15:53	16:25
RM O ₂ Result (%vd)	6.21	6.26	6.21	6.32	6.23	6.31	6.25	6.17	6.20	6.32	6.29
CEMS O ₂ Data (%vd)	6.37	6.47	6.41	6.51	6.43	6.52	6.49	6.40	6.42	6.53	6.50
Difference	-0.16	-0.21	-0.20	-0.19	-0.20	-0.21	-0.24	-0.23	-0.22	-0.21	-0.21
Accept or Reject	Accept	Accept	Accept	Accept	Accept	Accept	Reject	Reject	Accept	Accept	Accept

Relative Accuracy via RM, $RA_{RM-CEMS}^*$ 0.20% ← Pass

* $RA_{RM-CEMS}$ (Reference Method - CEMS) Absolute difference must be less than 1.0%

RECEIVED
 AUG 08 2022
 AIR QUALITY DIVISION



**Erthwrks Relative Accuracy Test Audit--CO RATA
Performance Specification 4**

CCR InterHtr CO CEMS RATA at Stack Conditions

Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Run 8	Run 9	Run 10	Run 11
Date	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022	6/7/2022
Start Time	10:27	10:57	11:27	12:03	12:59	13:29	13:59	14:30	15:02	15:32	16:04
End Time	10:48	11:18	11:48	12:24	13:20	13:50	14:20	14:51	15:23	15:53	16:25
RM CO Result (ppmvd)	0.34	-0.01	0.09	-0.10	-0.02	0.09	0.22	0.11	0.02	-0.09	-0.06
CEMS CO Data (ppmvd)	-0.17	-0.20	-0.18	-0.20	-0.17	-0.19	-0.20	-0.22	-0.22	-0.22	-0.23
Difference	0.51	0.19	0.27	0.10	0.15	0.28	0.42	0.33	0.24	0.13	0.17
Accept or Reject	Reject	Accept	Accept	Accept	Accept	Accept	Reject	Accept	Accept	Accept	Accept

Mean of the Difference (d_{avg})	0.21	
Standard Deviation (S_d)	0.08	
Confidence Coefficient (CC)	0.06	
Relative Accuracy via M.4A, RA_{4A} †	0.27	← Pass

† RA_{4A} must be less than 5 ppmv



Erthwrks Particulate Matter Summary of Results

Project: Marathon Petroleum Company
Facility: Detroit Refinery
Location: Detroit, MI
Unit ID: CRR Inter Heater

Run Designation						
Run Number		1	2	3	Average	
Date		6/7/2022	6/7/2022	6/7/2022		mm:dd:yyyy
Run Start Time		10:28	13:00	15:02		hh:mm
Run End Time		12:09	14:35	16:36		hh:mm
Operating Conditions						
Firing Rate (MMBtu/hr)		94.55	95.59	94.29	94.81	MMBtu/hr
Stack Gas Composition						
Oxygen Concentration	(%O ₂)	6.23	6.26	6.27	6.25	%
Carbon Dioxide Concentration	(%CO ₂)	8.82	8.75	8.79	8.79	%
Stack Moisture Content	(B _{ws})	11.01	9.92	14.29	11.74	%
Stack Dry Molecular Weight	(M _d)	29.66	29.65	29.66	29.66	lb/lb-mole
Stack Wet Molecular Weight	(M _s)	28.38	28.49	27.99	28.29	lb/lb-mole
Stack Gas Volumetric Flow Calculations						
Absolute Stack Pressure	(P _s)	29.04	29.04	29.04	29.04	in Hg
Average Stack Temperature	(t _s) _{avg}	1100.4	1104.3	1098.6	1101.1	°R
Average Square Root of ΔP's	(Δp ^{1/2}) _{avg}	0.4944	0.5021	0.5031	0.4999	%
Average Stack Gas Velocity	(v _s)	2461.57	2498.96	2519.89	2493.47	ft/min
Average Stack Gas Flow	(Q _{aw})	5.85E+04	5.94E+04	5.99E+04	5.92E+04	acfm
Wet Standard Stack Flow Rate	(Q _{sw})	1.63E+06	1.65E+06	1.68E+06	1.65E+06	wscfh
Dry Standard Stack Flow Rate	(Q _{sd})	1.45E+06	1.49E+06	1.44E+06	1.46E+06	dscfh
Particulate Matter Emission Rate Calculations						
Mass of Filterable PM (M.5)	mg	1.83	1.99	1.2	1.67	mg
Mass of Condensable PM (M.202)	mg	4.27	3.94	4.58	4.26	mg
Total Mass of Particulates	mg	6.10	5.93	5.78	5.94	mg
Filterable PM Mass Concentration	lb/dscf	5.49E-08	5.78E-08	3.47E-08	4.91E-08	lb/dscf
Total PM Mass Concentration	lb/dscf	1.83E-07	1.72E-07	1.67E-07	1.74E-07	lb/dscf
Filterable PM Mass Emission Rate	lb/hr	0.08	0.09	0.05	0.07	lb/hr
Total PM Mass Emission Rate	lb/hr	0.27	0.26	0.24	0.25	lb/hr
Filterable PM Mass Emission Rate	lb/day	1.92	2.06	1.20	1.73	lb/day
Total PM Mass Emission Rate	lb/day	6.38	6.15	5.77	6.10	lb/day
Filterable PM Mass Emission Rate	lb/MMBtu	0.0008	0.0009	0.0005	0.0008	lb/MMBtu
Total PM Mass Emission Rate	lb/MMBtu	0.0028	0.0027	0.0025	0.0027	lb/MMBtu

Detailed Summary of Results

Client: Marathon Petroleum
Facility: Detroit
Unit ID: CCR Inter Heater
Erthwrks Tech: MK, JW

Run Information				
Run Number	Run 1	Run 2	Run 3	
Date	6/7/2022	6/7/2022	6/7/2022	
Run Start Time	16:53	17:44	18:36	
Run End Time	17:23	18:14	19:06	
Unit Fuel Flow Data				Averages
Fuel F Factor (F _d) (scf/MMBtu)	8595.3	8595.3	8595.3	8595.3
Emission Concentrations				
H ₂ SO ₄ (ug)	82.9	93.2	33.3	69.80
Train volume (scf)	10.26	10.05	10.20	10.17
Emission Rates				
H ₂ SO ₄ (lb/scf)	1.78E-08	2.04E-08	7.20E-09	1.51E-08
H ₂ SO ₄ (ppm)	0.07	0.08	0.03	0.06

Attachment B
Quality Control Documentation

Erthwrks Method 1 Traverse Point Location Worksheet

Client: MPC Detroit
 Project #: 9049.1.B4
 Facility: Detroit Refinery
 Unit ID: CCR Interheater
 Technician: jmw

Stack ID Measurements

Stack ID + Port (inches):	73.5
Port Extension (inches):	7.5
Stack Diameter (inches):	66



Port Location Measurements

Distance Upstream (A) (inches):	865
Distance Downstream (B) (inches):	240
Stack Diameters Upstream (A):	13.1
Stack Diameters Downstream (B):	3.6

Total Traverse Points to be used:	3
Traverse Points per Diameter:	3

Traverse Point Locations ⁽¹⁾⁽²⁾	
Point 1:	11.02"
Point 2:	33.00"
Point 3:	54.98"

Stack Cross Section View



⁽¹⁾For stack diameter >4.0" and <2.4 meters, stratification is measured at 16.7%, 50.0%, and 83.3" of stack diameter (M7E, §8.1.2).

⁽²⁾For stack diameter >2.4 meters, stratification is measured at 0.4, 1.2, and 2.0 meters from stack wall (M7E, §8.1.2).

Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Date: 6/7/2022
 Client: MPC
 Facility: Detroit
 Project No: 9049.1.B4
 Unit ID: CCR InterHtr
 Erthwrks Tech: John Wood

Calibration Gas Verification

Pollutant	Low-Level Gas Conc. (C _L)	Cylinder Serial #	Mid-Level Gas Conc. (C _M)	Cylinder Serial #	High-Level Gas Conc. (C _H /CS)	Cylinder Serial #	Dilutor Root Gas
NO _x	n/a	n/a	24.77	CC446268	53.76	CC339873	NA
CO	n/a	n/a	25.43	CC446268	50.83	CC339873	NA
O ₂	n/a	n/a	10.13	CC287657	19.92	ALM038955	NA
CO ₂	n/a	n/a	10.00	CC287657	19.69	ALM038955	NA

Reference Method Analyzer Info

Make	Model	Serial No.
Teledyne	T200H	802
Teledyne	T300M	734
Teledyne	T200H	802
Teledyne	T300M	734

Direct Calibration Error Test

Pollutant	Zero Gas Response (C _{Dir})	Calibration Error (ACE) [*]	Low-Level Response (C _{Dir})	Calibration Error (ACE) [*]	Mid-Level Response (C _{Dir})	Calibration Error (ACE) [*]	High-Level Response (C _{Dir})	Calibration Error (ACE) [*]
NO _x	0.03	0.05%	n/a	n/a	24.78	0.02%	53.43	-0.62%
CO	-0.09	-0.18%	n/a	n/a	25.33	-0.19%	50.98	0.30%
O ₂	0.01	0.06%	n/a	n/a	10.00	-0.65%	19.86	-0.29%
CO ₂	0.00	0.01%	n/a	n/a	10.10	0.49%	19.77	0.41%

*Unless otherwise noted in protocol or report, THC's calibration error test is conducted using the entire sample system and must be less than 5% of applicable calibration gas

*ACE must either be within ± 2.0% or ≤ 0.5 ppmv absolute difference

NO ₂ to NO Conversion Efficiency Test	
NO ₂ Cal Gas Cyl. Number	CC502181
NO ₂ Cal Gas Concentration	60.52
NO _x Analyzer Response	57.68
NO ₂ -NO Conv. Efficiency (Eff _{NO2}) ⁽¹⁾	95.3%

⁽¹⁾ Eff_{NO2} must be ≥ 90%

Method 7E Traverse Point Determination			
Stack ID (inches)		Trav. Location	Inside ID + Port
66	Point 1	11.02	18.52
	Point 2	33.00	40.50
7.5	Point 3	54.98	62.48

Initial Sample System Bias and Response Time

Pollutant	Upscale Gas Cert. Conc. (C _{SA})	Upscale Gas Direct (C _{Dir})	Upscale Response (C _U)	Sample System Bias (SB) [*]	Response Time (sec)	Downscale Response (C _D)	Sample System Bias (SB) [*]	Response Time (sec)
NO _x	24.77	24.78	24.74	-0.07%	60	0.11	0.15%	60
CO	25.43	25.33	25.42	0.17%	60	-0.10	-0.01%	60
O ₂	10.13	10.00	9.97	-0.16%	60	0.10	0.45%	60
CO ₂	10.00	10.10	9.96	-0.68%	60	0.00	0.01%	60

*SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference



Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 1**
 Start Time: 10:27
 End Time: 10:48

Pollutant	Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
NO _x	-0.06	24.76	21.79	-0.05	24.76
CO	-1.00	25.40	-0.28	-0.27	25.40
O ₂	0.04	9.97	6.13	0.04	9.97
CO ₂	0.00	10.11	8.95	0.00	10.11

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 3**
 Start Time: 11:27
 End Time: 11:48

Pollutant	Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
NO _x	0.02	24.85	21.92	0.01	25.11
CO	-0.34	25.04	-0.28	-0.40	25.13
O ₂	0.06	10.00	6.15	0.05	9.99
CO ₂	0.02	10.15	8.93	0.01	10.12

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 5**
 Start Time: 12:59
 End Time: 13:20

Pollutant	Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
NO _x	0.01	24.77	21.28	0.04	24.56
CO	-0.12	25.25	-0.31	-0.46	24.99
O ₂	0.04	9.98	6.16	0.05	9.99
CO ₂	0.01	10.12	8.89	0.02	10.13

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 7**
 Start Time: 13:59
 End Time: 14:20

Pollutant	Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
NO _x	-0.03	24.73	21.81	-0.02	24.78
CO	-0.61	24.92	-0.32	-0.48	24.96
O ₂	0.05	9.98	6.18	0.05	9.99
CO ₂	0.01	10.15	8.88	0.00	10.13

Run #: **Run 2**
 Start Time: 10:57
 End Time: 11:18

Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
-0.05	24.76	22.11	0.02	24.85
-0.27	25.40	-0.32	-0.34	25.04
0.04	9.97	6.19	0.06	10.00
0.00	10.11	8.91	0.02	10.15

Run #: **Run 4**
 Start Time: 12:03
 End Time: 12:24

Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
0.01	25.11	22.04	0.01	24.77
-0.40	25.13	-0.36	-0.12	25.25
0.05	9.99	6.24	0.04	9.98
0.01	10.12	8.84	0.01	10.12

Run #: **Run 6**
 Start Time: 13:29
 End Time: 13:50

Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
0.04	24.56	21.54	-0.03	24.73
-0.46	24.99	-0.45	-0.61	24.92
0.05	9.99	6.24	0.05	9.98
0.02	10.13	8.84	0.01	10.15

Run #: **Run 8**
 Start Time: 14:30
 End Time: 14:51

Initial Zero SSC (C _{S1})	Initial Upscale SSC (C _{S2})	Raw Results (C _{Ave})	Final Zero SSC (C _{S7})	Final Upscale SSC (C _{S7})
-0.02	24.78	22.38	-0.07	25.36
-0.48	24.96	-0.43	-0.61	24.86
0.05	9.99	6.10	0.04	9.99
0.00	10.13	8.94	0.00	10.12



Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 9**
Start Time: 15:02
End Time: 15:23

Pollutant	Initial Zero SSC (C _z)	Initial Upscale SSC (C _u)	Raw Results (C _{rr})	Final Zero SSC (C _z)	Final Upscale SSC (C _u)
NO _x	-0.07	25.36	22.82	0.04	24.56
CO	-0.61	24.86	-0.52	-0.46	24.99
O ₂	0.04	9.99	6.13	0.05	9.99
CO ₂	0.00	10.12	8.94	0.02	10.13

Run #: **Run 10**
Start Time: 15:32
End Time: 15:53

Initial Zero SSC (C _z)	Initial Upscale SSC (C _u)	Raw Results (C _{rr})	Final Zero SSC (C _z)	Final Upscale SSC (C _u)
0.04	24.56	23.12	-0.05	25.26
-0.46	24.99	-0.72	-0.78	24.83
0.05	9.99	6.24	0.04	9.95
0.02	10.13	8.87	0.02	10.10

Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: **Run 11**
Start Time: 16:04
End Time: 16:25

Pollutant	Initial Zero SSC (C _z)	Initial Upscale SSC (C _u)	Raw Results (C _{rr})	Final Zero SSC (C _z)	Final Upscale SSC (C _u)
NO _x	-0.05	25.26	23.17	-0.05	24.73
CO	-0.78	24.83	-0.73	-0.55	25.62
O ₂	0.04	9.95	6.19	0.05	9.95
CO ₂	0.02	10.10	8.88	0.02	10.12

Run 1 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C _z)	Avg. Upscale Sys. Bias (C _u)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{rr})
NO _x	-0.17%	-0.03%	-0.14%	-0.03%	-0.05	24.76	0.03%	0.00%	21.80
CO	-1.79%	0.13%	-0.34%	0.13%	-0.63	25.40	1.45%	0.00%	0.34
O ₂	0.16%	-0.13%	0.16%	-0.13%	0.04	9.97	0.00%	0.00%	6.21
CO ₂	0.01%	0.06%	0.01%	0.06%	0.00	10.11	0.00%	0.00%	8.85

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 2 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C _z)	Avg. Upscale Sys. Bias (C _u)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{rr})
NO _x	-0.14%	-0.03%	-0.02%	0.14%	-0.01	24.81	0.12%	0.17%	22.08
CO	-0.34%	0.13%	-0.50%	-0.58%	-0.30	25.22	0.16%	0.71%	-0.01
O ₂	0.16%	-0.13%	0.22%	-0.01%	0.05	9.99	0.07%	0.13%	6.26
CO ₂	0.01%	0.06%	0.09%	0.25%	0.01	10.13	0.08%	0.19%	8.80

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference



Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Run 3 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)	Upscale Drift Assessment (D)	Corrected Results (C _{corr})
NO _x	-0.02%	0.14%	-0.03%	0.62%	0.02	24.98	0.01%	0.49%	21.74
CO	-0.50%	-0.58%	-0.61%	-0.41%	-0.37	25.08	0.12%	0.17%	0.09
O ₂	0.22%	-0.01%	0.22%	-0.08%	0.05	9.99	0.01%	0.07%	6.21
CO ₂	0.09%	0.25%	0.05%	0.10%	0.01	10.13	0.04%	0.15%	8.81

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 4 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)	Upscale Drift Assessment (D)	Corrected Results (C _{corr})
NO _x	-0.03%	0.62%	-0.04%	-0.01%	0.01	24.94	0.01%	0.63%	21.89
CO	-0.61%	-0.41%	-0.06%	-0.17%	-0.26	25.19	0.56%	0.24%	-0.10
O ₂	0.22%	-0.08%	0.15%	-0.12%	0.05	9.98	0.07%	0.04%	6.32
CO ₂	0.05%	0.10%	0.05%	0.10%	0.01	10.12	0.00%	0.00%	8.74

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 5 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)	Upscale Drift Assessment (D)	Corrected Results (C _{corr})
NO _x	-0.04%	-0.01%	0.02%	-0.40%	0.02	24.67	0.06%	0.39%	21.37
CO	-0.06%	-0.17%	-0.73%	-0.68%	-0.29	25.12	0.68%	0.51%	-0.02
O ₂	0.15%	-0.12%	0.22%	-0.07%	0.05	9.98	0.07%	0.05%	6.23
CO ₂	0.05%	0.10%	0.11%	0.17%	0.02	10.12	0.06%	0.08%	8.78

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 6 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)	Upscale Drift Assessment (D)	Corrected Results (C _{corr})
NO _x	0.02%	-0.40%	-0.10%	-0.09%	0.01	24.65	0.12%	0.31%	21.64
CO	-0.73%	-0.68%	-1.02%	-0.81%	-0.54	24.96	0.29%	0.13%	0.09
O ₂	0.22%	-0.07%	0.18%	-0.10%	0.05	9.98	0.04%	0.03%	6.31
CO ₂	0.11%	0.17%	0.02%	0.26%	0.01	10.14	0.09%	0.09%	8.72

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 7 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)	Upscale Drift Assessment (D)	Corrected Results (C _{corr})
NO _x	-0.10%	-0.09%	-0.09%	0.00%	-0.02	24.76	0.01%	0.09%	21.82
CO	-1.02%	-0.81%	-0.76%	-0.74%	-0.54	24.94	0.27%	0.07%	0.22
O ₂	0.18%	-0.10%	0.19%	-0.04%	0.05	9.99	0.01%	0.06%	6.25
CO ₂	0.02%	0.26%	0.02%	0.15%	0.00	10.14	0.01%	0.11%	8.76

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference



Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Run 8 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{corr})
NO _x	-0.09%	0.00%	-0.18%	1.08%	-0.04	25.07	0.09%	1.08%	22.11
CO	-0.76%	-0.74%	-1.02%	-0.93%	-0.54	24.91	0.27%	0.19%	0.11
O ₂	0.19%	-0.04%	0.14%	-0.08%	0.04	9.99	0.05%	0.04%	6.17
CO ₂	0.02%	0.15%	0.01%	0.11%	0.00	10.12	0.01%	0.05%	8.84

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 9 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{corr})
NO _x	-0.18%	1.08%	0.02%	-0.40%	-0.01	24.96	0.20%	1.48%	22.64
CO	-1.02%	-0.93%	-0.73%	-0.68%	-0.54	24.92	0.29%	0.25%	0.02
O ₂	0.14%	-0.08%	0.22%	-0.07%	0.05	9.99	0.08%	0.01%	6.20
CO ₂	0.01%	0.11%	0.11%	0.17%	0.01	10.12	0.10%	0.07%	8.83

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 10 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{corr})
NO _x	0.02%	-0.40%	-0.15%	0.89%	-0.01	24.91	0.16%	1.29%	22.99
CO	-0.73%	-0.68%	-1.36%	-1.00%	-0.62	24.91	0.63%	0.31%	-0.09
O ₂	0.22%	-0.07%	0.14%	-0.23%	0.05	9.97	0.08%	0.17%	6.32
CO ₂	0.11%	0.17%	0.08%	0.03%	0.02	10.12	0.03%	0.15%	8.76

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference

Run 11 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C ₀)	Avg. Upscale Sys. Bias (C ₁)	Zero Drift Assessment (D)†	Upscale Drift Assessment (D)†	Corrected Results (C _{corr})
NO _x	-0.15%	0.89%	-0.14%	-0.09%	-0.05	24.99	0.01%	0.97%	22.97
CO	-1.36%	-1.00%	-0.90%	0.57%	-0.67	25.22	0.45%	1.56%	-0.06
O ₂	0.14%	-0.23%	0.19%	-0.26%	0.04	9.95	0.05%	0.03%	6.29
CO ₂	0.08%	0.03%	0.10%	0.14%	0.02	10.11	0.03%	0.11%	8.77

* SB must either be within ± 5.0% or ≤ 0.5 ppmv absolute difference

† D must either be within ± 3.0% or the pre- and post-run bias responses are ≤ 0.5 ppmv absolute difference



Attachment C
Sampling Datasheets

Erthwiks Method 2 Traverse Point Location Worksheet

Client: Marathon Petroleum Company
 Project #: 9049.1.B4
 Facility: Detroit Refinery
 Unit ID: CRR Inter Heater
 Technician: jmw, jh, mk, jt


Stack ID Measurements

Stack ID + Port (inches):	73.5
Port Extension (inches):	7.5
Stack Diameter (inches):	66


Port Location Measurements

Distance Upstream (A) (inches):	865
Distance Downstream (B) (inches):	240
Stack Diameters Upstream (A):	13.1
Stack Diameters Downstream (B):	3.6

Total Traverse Points to be used: 24
Traverse Points per Diameter: 12



Stack Cross Section View



Traverse Point Location Table From EPA Method 1, Table 1-2

Traverse Point Number per Diameter	Total Number of Traverse Points to be Used (from EPA M.1 Table 1-2)					
	4	8	12	16	20	24
1	14.60	6.70	4.40	3.20	2.60	2.10
2	85.40	25.00	14.60	10.50	8.20	6.70
3		75.00	29.60	19.40	14.60	11.80
4		93.30	70.40	32.30	22.60	17.70
5			85.40	67.70	34.20	25.00
6			95.60	80.60	65.80	35.60
7				89.50	77.40	64.40
8				96.80	85.40	75.00
9					91.80	82.30
10					97.40	88.20
11						93.30
12						97.90

Calculated Traverse Point Locations per Diameter

Traverse Point Number per Diameter	Total Number of Traverse Points Used					
	4	8	12	16	20	24
1	17.14	11.92	10.40	9.61	9.22	8.89
2	63.86	24.00	17.14	14.43	12.91	11.92
3		57.00	27.04	20.30	17.14	15.29
4		69.08	53.96	28.82	22.42	19.18
5			63.86	52.18	30.07	24.00
6			70.60	60.70	50.93	31.00
7				66.57	58.58	50.00
8				71.39	63.86	57.00
9					68.09	61.82
10					71.78	65.71
11						69.08
12						72.11

Measurements in bold will be the traverse points used for the emission test

Erthwrks Isokenetic Sampling Field Data and Calculation Worksheet

Client: Marathon Petroleum Company	Run ID: 1	Meterbox ID: M5-2
Facility: Detroit Refinery	Date: 6/7/22	DGM Y Factor: 0.989
Location: Detroit, MI	Amb Temp: 67	DGM ΔH @: 1.816
Unit ID: CRR Inter Heater	Baro. Press: 29.11	

Pre and Post DGM Leak Checks			
Pre	0.000	ft3/min @ 14	inHg
Post	0.002	ft3/min @ 10	inHg
Pitot Not Damaged & Leak Checks Good?			
Pre	Yes	Post	Yes

Isokinetic Sampling Data				Post Sample Moisture Determination			Post Sampling Moisture and MW Determination						
Meter K Factor	(NA)	9.34	unitless	Impinger Weights (g)			O ₂ Concentration	(%O ₂)	6.23	%			
Pitot Tube Factor	(C _{pt})	0.84	unitless	Impinger ID	contents	Pre Run	CO ₂ Concentration	(%CO ₂)	8.82	%			
Stack Static Pressure	(P _{static})	-0.90	in H ₂ O	Impinger 1	Empty	525.2	Sample Volume Metered	(V _m)	77.21	dcf			
Dry Gas Fraction	(NA)	0.860	unitless	Impinger 2	Empty	613.4	Standard Volume at STP	(V _{std})	73.53	dscf			
Stack Gas Wet MW	(M _s)	27.95	lb/lb-mole	Impinger 3	DI H ₂ O	739.6	Moisture Content	(B _{wet})	11.013	%			
Actual Nozzle Area	(NA)	8.73E-04	ft ²	Impinger 4	Silica Gel	914.3	Final Dry Gas Fraction	(B _{dry})	0.890	unitless			
Total Sample Time	(NA)	90	min	Total Weights		2625.6	2818.6	Stack Gas Wet MW	(M _s)	28.38	lb/lb-mole		
Number of Traverse Points	(NA)	24	points	Filter ID:		51329		Stack Gas Velocity	(V _s)	41.03	ft/sec		
Time per Traverse Point	(NA)	0:03:45	time	Stack Gas Vol. Flow Rate							(Q _d)	1.45E+06	dscfh
								Final Isokinetic Calc.	(%iso)	91.8	%		
								Post -Test Meter Cal (M.5 §16.3)	(Y _{gas})	0.994			

	Start Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM	Obs. DGM	% ISO	% ISO
											Reading	Reading	Point	Total
Port 1 Start →	10:28:00	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(inHg)	in H ₂ O	in H ₂ O	ft ³	869.666	unitless	unitless
Point 1	10:31:45	630	250	239	70	64	73	4	0.16	1.51	872.428	872.250	93.6	93.6
Point 2	10:35:30	637	248	249	66	63	74	4	0.22	2.08	875.480	875.350	96.0	94.8
Point 3	10:39:15	644	250	236	68	63	74	5	0.19	1.79	878.344	878.200	95.2	95.0
Point 4	10:43:00	645	247	264	66	60	75	5	0.21	1.99	881.351	881.150	93.6	94.6
Point 5	10:46:45	647	245	261	67	59	75	6	0.30	2.84	884.904	885.030	103.3	96.6
Point 6	10:50:30	648	246	231	68	64	76	6	0.35	3.32	889.086	888.750	91.7	95.6
Point 7	10:54:15	649	248	233	68	65	76	7	0.38	3.60	892.971	892.650	92.4	95.0
Point 8	10:58:00	646	248	234	67	66	76	8	0.33	3.13	896.594	896.510	97.9	95.4
Point 9	11:01:45	645	247	236	66	62	76	8	0.27	2.56	900.084	899.840	93.2	95.2
Point 10	11:05:30	641	244	234	70	57	76	6	0.28	2.65	903.485	903.350	96.3	95.3
Point 11	11:09:15	636	244	234	70	55	77	6	0.25	2.37	906.811	906.650	95.3	95.3
Point 12	11:13:00	633	245	234	70	53	78	5	0.22	2.09	909.910	909.771	95.7	95.3
Port 2 Start →	11:24:00													
Point 13	11:27:45	624	247	233	67	53	76	5	0.27	2.56	913.380	913.080	91.7	95.0
Point 14	11:31:30	638	245	247	67	47	77	4	0.18	1.71	916.019	915.750	90.8	94.8
Point 15	11:35:15	643	244	247	67	49	77	4	0.20	1.90	918.840	918.660	94.2	94.7
Point 16	11:39:00	647	245	249	66	51	77	5	0.24	2.28	922.035	921.720	90.7	94.5
Point 17	11:42:45	647	246	248	65	51	77	6	0.27	2.56	925.298	925.050	93.1	94.4
Point 18	11:46:30	651	249	251	65	53	78	8	0.33	3.14	929.000	928.700	92.4	94.3
Point 19	11:50:15	649	248	256	68	55	78	8	0.33	3.14	932.653	932.440	94.6	94.3
Point 20	11:54:00	646	246	254	69	56	78	7	0.29	2.76	936.154	935.940	94.2	94.3
Point 21	11:57:45	644	246	255	69	57	78	5	0.21	2.00	939.110	938.970	95.6	94.3
Point 22	12:01:30	639	245	256	69	58	79	5	0.20	1.91	942.077	941.860	93.0	94.3
Point 23	12:05:15	614	246	253	68	58	79	4	0.15	1.43	944.585	944.435	94.5	94.3
Point 24	12:09:00	626	243	252	68	57	79	4	0.14	1.33	947.054	946.872	93.1	94.2
Average Values		640.4	246.3	245.3	67.7	57.3	76.6	5.6	0.25	2.36		77.206		94.2

Erthwrks Isokenetic Sampling Field Data and Calculation Worksheet

Client: Marathon Petroleum Company Run ID: **2**
 Facility: Detroit Refinery Date: **6/7/22**
 Location: Detroit, MI Amb Temp: **75**
 Unit ID: CRR Inter Heater Baro. Press: **29.11**

Meterbox ID: **M5-2**
 DGM Y Factor: **0.989**
 DGM ΔH @: **1.816**

Pre and Post DGM Leak Checks				
Pre	0.002	ft3/min @	15	inHg
Post	0.001	ft3/min @	19	inHg
Pitot Not Damaged & Leak Checks Good?				
Pre	Yes	Post	Yes	

Isokinetic Sampling Data				Post Sample Moisture Determination				Post Sampling Moisture and MW Determination						
Meter K Factor	(NA)	9.34	unitless	Impinger Weights (g)				O ₂ Concentration	(%O ₂)	6.26	%			
Pitot Tube Factor	(C _{pt})	0.84	unitless	Impinger ID	contents	Pre Run	Post Run	CO ₂ Concentration	(%CO ₂)	8.75	%			
Stack Static Pressure	(P _{static})	-0.90	in H ₂ O	Impinger 1	Empty	365.4	589.6	Sample Volume Metered	(V _m)	79.68	dcf			
Dry Gas Fraction	(NA)	0.860	unitless	Impinger 2	Empty	713.2	613.8	Standard Volume at STP	(V _{std})	75.96	dscf			
Stack Gas Wet MW	(Ms)	27.95	lb/lb-mole	Impinger 3	DI H ₂ O	729.0	755.5	Moisture Content	(B _{wc})	9.924	%			
Actual Nozzle Area	(NA)	8.73E-04	ft ²	Impinger 4	Silica Gel	833.5	859.7	Final Dry Gas Fraction	(B _{wc})	0.901	unitless			
Total Sample Time	(NA)	90	min	Total Weights				2641.1	2818.6	Stack Gas Wet MW	(Ms)	28.49	lb/lb-mole	
Number of Traverse Points	(NA)	24	points	Filter ID:				51324	Stack Gas Velocity	(v _s)	41.65	ft/sec		
Time per Traverse Point	(NA)	0:03:45	time	Stack Gas Vol. Flow Rate				(Qd)	1.49E+06	dscfh	Final Isokinetic Calc.	(%iso)	92.6	%
								Post-Test Meter Cal (M.5 §16.3)		(Y _{ca})	0.976			

	Start Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM Reading	Obs. DGM Reading	% ISO Point	% ISO Total
Port 1 Start →	13:00:00	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(inHg)	in H ₂ O	in H ₂ O	ft ³	947.442	unitless	unitless
Point 1	13:03:45	633	252	247	75	55	73	5	0.15	1.41	950.113	950.050	97.6	97.6
Point 2	13:07:30	639	247	259	71	52	73	5	0.18	1.70	952.966	952.760	92.9	95.2
Point 3	13:11:15	642	246	262	70	52	74	6	0.19	1.79	955.757	955.460	90.1	93.4
Point 4	13:15:00	649	244	273	71	55	75	7	0.23	2.18	958.750	958.540	93.6	93.4
Point 5	13:18:45	649	240	270	70	55	75	7	0.24	2.27	961.900	961.750	95.5	93.9
Point 6	13:22:30	649	250	267	70	58	75	10	0.31	2.93	965.562	965.330	93.9	93.9
Point 7	13:26:15	653	249	258	71	58	76	10	0.33	3.13	969.262	969.070	95.1	94.1
Point 8	13:30:00	646	247	250	72	60	76	9	0.27	2.56	972.643	972.540	97.1	94.5
Point 9	13:33:45	642	246	248	71	60	76	9	0.24	2.28	975.917	975.940	100.7	95.2
Point 10	13:37:30	647	246	247	73	60	76	7	0.23	2.18	979.239	979.080	95.2	95.2
Point 11	13:41:15	639	247	255	73	60	76	7	0.17	1.61	981.931	981.820	96.1	95.2
Point 12	13:45:00	634	245	255	74	59	76	6	0.16	1.52	984.592	984.460	95.2	95.2
Port 2 Start →	13:50:00													
Point 13	13:53:45	631	248	255	72	61	75	6	0.19	1.80	987.478	987.370	96.4	95.3
Point 14	13:57:30	642	245	255	71	61	76	7	0.22	2.09	990.605	990.430	94.6	95.3
Point 15	14:01:15	644	245	251	71	61	76	9	0.26	2.46	993.940	993.800	96.0	95.3
Point 16	14:05:00	646	247	257	71	64	76	9	0.28	2.65	997.437	997.240	94.6	95.3
Point 17	14:08:45	647	247	257	70	63	77	9	0.28	2.66	1000.882	1000.730	95.8	95.3
Point 18	14:12:30	651	248	252	72	60	77	10	0.31	2.94	1004.553	1004.470	97.8	95.5
Point 19	14:16:15	651	246	249	72	60	78	10	0.35	3.33	1008.536	1008.350	95.4	95.4
Point 20	14:20:00	652	242	247	73	61	78	11	0.36	3.43	1012.470	1012.400	98.3	95.6
Point 21	14:23:45	648	243	244	74	62	78	11	0.34	3.23	1016.413	1016.300	97.2	95.7
Point 22	14:27:30	646	246	241	73	63	78	10	0.31	2.95	1020.139	1020.020	96.9	95.8
Point 23	14:31:15	643	247	240	73	63	79	9	0.28	2.67	1023.682	1023.570	96.9	95.8
Point 24	14:35:00	640	248	234	72	63	79	9	0.26	2.48	1027.106	1027.121	100.4	96.0
Average Values		644.3	246.3	253.0	71.9	59.4	76.2	8.3	0.26	2.43		79.679		96.0

Erthwrks Isokenetic Sampling Field Data and Calculation Worksheet

Client: Marathon Petroleum Company
 Facility: Detroit Refinery
 Location: Detroit, MI
 Unit ID: CRR Inter Heater

Run ID: 3
 Date: 6/7/22
 Amb Temp: 75
 Baro. Press: 29.11

Meterbox ID: M5-2
 DGM Y Factor: 0.989
 DGM ΔH @: 1.816

Pre and Post DGM Leak Checks			
Pre	0.00	ft3/min @	17 inHg
Post	0.05	ft3/min @	12 inHg
Pitot Not Damaged & Leak Checks Good?			
Pre	Yes	Post	Yes

Isokinetic Sampling Data				Post Sample Moisture Determination				Post Sampling Moisture and MW Determination					
Meter K Factor	(NA)	9.34	unitless	Impinger Weights (g)				O ₂ Concentration	(%O ₂)	6.27	%		
Pitot Tube Factor	(C _{pt})	0.84	unitless	Impinger ID	contents	Pre Run	Post Run	CO ₂ Concentration	(%CO ₂)	8.79	%		
Stack Static Pressure	(P _{static})	-0.90	in H ₂ O	Impinger 1	Empty	358.8	583.5	Sample Volume Metered	(V _m)	80.26	dcf		
Dry Gas Fraction	(NA)	0.860	unitless	Impinger 2	Empty	614.5	614.1	Standard Volume at STP	(V _{std})	76.15	dscf		
Stack Gas Wet MW	(M _s)	27.95	lb/lb-mole	Impinger 3	Dl H ₂ O	743.1	761.6	Moisture Content	(B _{wet})	14.286	%		
Actual Nozzle Area	(NA)	8.73E-04	ft ²	Impinger 4	Silica Gel	933.6	960	Final Dry Gas Fraction	(B _{dry})	0.857	unitless		
Total Sample Time	(NA)	90	min	Total Weights				2650.0	2919.2	Stack Gas Wet MW	(M _s)	27.99	lb/lb-mole
Number of Traverse Points	(NA)	24	points	Filter ID:				51330	Stack Gas Velocity	(V _s)	42.00	ft/sec	
Time per Traverse Point	(NA)	0:03:45	time	Stack Gas Vol. Flow Rate				(Q _d)	1.44E+06	dscfh			
								Final Isokinetic Calc.	(%iso)	96.2	%		
								Post-Test Meter Cal (M.5 §16.3)	(Y _{gas})	0.977			

	Clock Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM Reading	Obs. DGM Reading	% ISO Point	% ISO Total
Port 1 Start →	15:02:00	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(inHg)	in H ₂ O	in H ₂ O	ft ³	27.527	unitless	unitless
Point 1	15:05:45	634	245	227	71	59	74	4	0.17	1.61	30.373	30.170	92.9	92.9
Point 2	15:09:30	638	251	233	69	53	75	5	0.22	2.08	33.404	33.190	93.4	93.1
Point 3	15:13:15	644	249	236	68	51	75	5	0.18	1.70	36.110	36.020	96.9	94.4
Point 4	15:17:00	645	246	255	68	53	75	6	0.28	2.65	39.652	39.400	93.1	94.0
Point 5	15:20:45	646	243	263	69	54	75	6	0.31	2.93	43.217	43.140	98.0	94.9
Point 6	15:24:30	648	248	257	69	55	76	8	0.32	3.03	47.021	46.960	98.4	95.5
Point 7	15:28:15	648	248	255	70	57	76	9	0.37	3.51	51.128	50.910	94.8	95.4
Point 8	15:32:00	648	241	251	73	59	76	8	0.34	3.22	54.909	54.750	96.0	95.5
Point 9	15:35:45	642	248	249	72	60	77	7	0.29	2.75	58.464	58.380	97.7	95.7
Point 10	15:39:30	633	246	246	71	60	78	7	0.27	2.57	61.987	62.020	100.9	96.3
Point 11	15:43:15	622	246	241	70	60	79	5	0.17	1.62	64.909	64.770	95.2	96.1
Point 12	15:47:00	613	245	239	70	58	79	5	0.17	1.62	67.671	67.705	101.2	96.5
Port 2 Start →	15:51:00													
Point 13	15:54:45	629	245	228	73	59	78	5	0.15	1.43	70.406	70.250	94.2	96.3
Point 14	15:58:30	641	243	245	72	56	79	6	0.21	2.00	73.430	73.240	94.0	96.2
Point 15	16:02:15	643	247	253	72	57	80	6	0.24	2.29	76.640	76.440	94.1	96.0
Point 16	16:06:00	646	249	261	72	58	80	7	0.30	2.86	80.231	80.000	93.9	95.9
Point 17	16:09:45	647	243	261	73	60	80	9	0.35	3.34	84.088	83.750	91.7	95.6
Point 18	16:13:30	648	245	260	72	61	82	9	0.35	3.35	87.851	87.550	92.7	95.4
Point 19	16:17:15	645	248	261	73	62	82	9	0.33	3.16	91.540	91.430	97.3	95.5
Point 20	16:21:00	642	247	265	72	63	82	8	0.31	2.97	95.304	95.150	96.0	95.5
Point 21	16:24:45	644	247	264	72	63	83	7	0.27	2.59	98.772	98.650	96.6	95.6
Point 22	16:28:30	635	246	269	73	64	83	6	0.24	2.30	102.081	101.950	96.2	95.6
Point 23	16:32:15	629	246	270	74	65	83	5	0.19	1.82	105.015	104.880	95.6	95.6
Point 24	16:36:00	617	243	261	75	66	83	5	0.16	1.54	107.711	107.784	102.6	95.8
Average Values		638.6	246.0	252.1	71.4	58.9	78.8	6.5	0.26	2.46		80.257		95.8

Erthwrks Method 8A (CTM-013) Sampling Worksheet

Date: 6/7/2022
Client: Marathon Petroleum
Facility: Detroit
Unit ID: CCR Inter Heater
Erthwrks Tech: MK, JW
Run No: 1

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H ₂ O)	cubic feet	Time (s)	Vac ("H ₂ O)	cubic feet	Time (s)
14	0.00	60	12	0.000	60

Start Time:	16:53
Meter Box ID:	M5-2
DGM y-fact:	0.9890
Atm Press ("Hg)	29.227

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft ³)	ΔV_m (ft ³)	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H ₂ SO ₄ Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 16:53	16:53		112.670	<--- Starting Reading		(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)	
1	16:58:00	0.42	114.481	1.811	74	360	515	182	64	2
2	17:03:00	0.42	116.281	1.800	75	361	516	183	65	2
3	17:08:00	0.42	118.071	1.790	75	362	516	175	62	2
4	17:13:00	0.42	119.925	1.854	75	366	518	175	62	2
5	17:18:00	0.42	121.658	1.733	76	366	516	176	63	2
6	17:23:00	0.42	123.450	1.792	78	365	518	176	63	2
Totals		0.4	10.780		75.5	363.3	516.5	177.8	63.2	2.0

Sample Gas Volume, $V_{m(std)}$

$V_{m(std)} =$ 10.26

Erthwrks Method 8A (CTM-013) Sampling Worksheet

Date: 6/7/2022
Client: Marathon Petroleum
Facility: Detroit
Unit ID: CCR Inter Heater
Erthwrks Tech: MK, JW
Run No: 2

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H ₂ O)	cubic feet	Time (s)	Vac ("H ₂ O)	cubic feet	Time (s)
8	0.00	60	9	0.000	60

Start Time: 17:44
 Meter Box ID: M5-2
 DGM y-fact: 0.9890
 Atm Press ("Hg) 29.227

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft ³)	ΔV_m (ft ³)	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H ₂ SO ₄ Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 17:44	17:44		125.400	<--- Starting Reading		(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)	
1	17:49:00	0.42	127.140	1.740	78	357	511	168	63	2
2	17:54:00	0.42	128.937	1.797	78	363	519	175	58	2
3	17:59:00	0.42	130.691	1.754	79	366	520	175	58	2
4	18:04:00	0.42	132.469	1.778	78	366	519	175	57	2
5	18:09:00	0.43	134.221	1.752	78	367	520	175	58	2
6	18:14:00	0.43	136.007	1.786	78	366	524	178	60	2
Totals		0.4	10.607		78.2	364.2	518.8	174.3	59.0	2.0

Sample Gas Volume, $V_{m(std)}$

$V_{m(std)} =$ 10.05

Erthwrks Method 8A (CTM-013) Sampling Worksheet

Date: 6/7/2022
Client: Marathon Petroleum
Facility: Detroit
Unit ID: CCR Inter Heater
Erthwrks Tech: MK, JW
Run No: 3

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H ₂ O)	cubic feet	Time (s)	Vac ("H ₂ O)	cubic feet	Time (s)
8	0.00	60	10	0.000	60

Start Time:	18:36
Meter Box ID:	M5-2
DGM y-fact:	0.9890
Atm Press ("Hg)	29.227

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft ³)	ΔV_m (ft ³)	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H ₂ SO ₄ Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 18:36	18:36		137.928	<--- Starting Reading		(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)	
1	18:41:00	0.40	139.780	1.852	74	366	518	177	64	2
2	18:46:00	0.40	141.590	1.810	75	365	519	175	64	2
3	18:51:00	0.40	143.358	1.768	75	366	520	176	65	2
4	18:56:00	0.40	145.120	1.762	76	366	519	177	65	2
5	19:01:00	0.40	146.870	1.750	76	367	521	178	66	2
6	19:06:00	0.40	148.638	1.768	76	366	517	178	66	2
Totals		0.4	10.710		75.3	366.0	519.0	176.8	65.0	2.0

Sample Gas Volume, $V_{m(std)}$
 $V_{m(std)} =$

Attachment D
Example Calculations

Erthwrks QAQC Example Calculations

Example Calculations for System QA : Run 1, CCR InterHtr

Example Calculations for Pollutant : NOx

Variable:	Description:
C_0	Average of the pre- and post-run system cal bias responses from zero gas, ppmv.
C_{Avg}	Average unadjusted gas concentration for test run, ppmv.
C_{Dir}	Measured concentration of the cal gas when introduced in direct mode, ppmv.
C_M	Average of the pre- and post-run system cal bias responses from the upscale gas, ppmv.
C_{MA}	Actual concentration of the upscale calibration gas, ppmv.
CS	Calibration span, ppmv.
C_S	Measured concentration of the cal gas when introduced in the system cal mode, ppmv.
C_V	Manufacturer certified concentration of calibration gas, ppmv.
SB_f	Post-run system bias, percent of calibration span.
SB_i	Pre-run system bias, percent of calibration span.

Analyzer Calibration Error, ACE Eq. 7E-1

$$ACE = \frac{C_{Dir} - C_V}{CS} \times 100$$

$C_{Dir} = 24.78$	ppmv
$C_V = 24.77$	ppmv
$CS = 53.76$	ppmv

ACE = 0.02%

Initial Upscale System Bias, SB_i Eq. 7E-2

$$SB_i = \frac{C_S - C_{Dir}}{CS} \times 100$$

$CS = 53.76$	ppmv
$C_S = 24.74$	ppmv
$C_{Dir} = 24.78$	ppmv

$SB_i = -0.07\%$

Upscale Drift Assessment, D Eq. 7E-4

$$D = ABS|SB_f - SB_i|$$

$SB_i = -0.03\%$
$SB_f = -0.03\%$

D = 0.00%

Effluent Gas Concentration, C_{Gas} Eq. 7E-5

$$C_{Gas} = (C_{Avg} - C_0) \frac{C_{MA}}{C_M - C_0}$$

$C_{Avg} = 21.79$	ppmv
$C_0 = -0.05$	ppmv
$C_{MA} = 24.77$	ppmv
$C_M = 24.76$	ppmv

$C_{Gas} = 21.80$

NO_2 - NO Conversion Efficiency, Eff_{NO_2} Eq. 7E-7

$$Eff_{NO_2} = \frac{C_{Dir}}{C_V} \times 100$$

$C_{Dir} = 57.68$	ppmv
$C_V = 60.52$	ppmv

$Eff_{NO_2} = 95.3\%$



Erthwrks Emission Rate Example Calculations

Example Calculations for Emissions : Run 1, CCR InterHtr

Example Calculations for Pollutant : NOx

Variable:	Description:
%O _{2d}	Oxygen concentration measured on a dry basis, %
F _d	Fuel F Factor for Natural Gas--Method 19 value, scf/MMBtu
MGV	Molar gas volume, volume of gas at standard conditions, scf/lbmol
MW _{NOx}	Molecular Weight of NOx, lb/lbmol
n	Moles, lbmol
PPM _{NOx}	Parts per million, NOx
p _s	Standard Pressure, psi
R	Universal gas constant, ft ³ psi / R lbmol
T _s	Standard Temperature, R
V	Volume, ft ³

Molar Gas Volume (MGV) calculation at standard conditions

Ideal Gas Law

$$MGV = \frac{V}{n} = \frac{R * T_s}{p}$$

T_s = 527.67 R
p = 14.696 psi
R = 10.7316 (ft³*psi/(R* lbmoll))

$$MGV = 385.325 \frac{\text{scf}}{\text{lbmol}}$$

Emission Concentration, C_d

$$C_d = \frac{PPM * MW}{MGV} / 10^6$$

PPM - NOx = 21.80 parts per million
MW - NOx = 46.0055 lb/lb-mol

$$C_d = 2.60E-06 \frac{\text{lb}}{\text{scf}}$$

Emission Rate Calculation, E_(lb/MMBtu)

Eq. 19-1

$$E_{(\text{lb/MMBtu})} = C_d * F_d \frac{20.9}{20.9 - \%O_{2d}}$$

F_d = 8595 scf/MMBtu
%O_{2d} = 6.21 %

$$E_{(\text{lb/MMBtu})} = 0.0318 \frac{\text{lb}}{\text{MMBtu}}$$



Erthwrks RATA Example Calculations

Example Calculations for Relative Accuracy: CCR InterHtr

Example Calculations for Pollutant: NOx - lb/MMBtu

Variable:	Description:
d	Absolute difference between reference method and client CEMS
i	Run number
n	Number of runs
d_{avg}	Mean of the difference between reference method and client CEMS
RM_{avg}	Average of the reference method results for each run
AS	The unit's permit limit or applicable standard

Arithmetic Mean, d_{avg} Eq. 2-3

$$d_{avg} = \frac{1}{n} \sum_{i=1}^n d_i$$

$d_1 = -0.0011$	$d_4 = -0.0008$	$d_7 = 0$	$d_{10} = -0.0010$
$d_2 = -0.0008$	$d_5 = 0$	$d_8 = -0.0011$	$d_{11} = -0.0012$
$d_3 = -0.0012$	$d_6 = -0.0015$	$d_9 = -0.0012$	$d_{12} = 0$
$n =$			9

$d_{avg} = -0.0011$

Standard Deviation, S_d Eq. 2-4

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{[\sum_{i=1}^n d_i]^2}{n}}{n-1}}$$

$S_d = 0.0002$

Confidence Coefficient, CC Eq. 2-5

$$CC = t_{0.975} \frac{S_d}{n^{1/2}} \quad t_{0.975} = 2.306$$

$CC = 0.0002$

Relative Accuracy, RA_{RM} Eq. 2-6

$$RA_{RM} = \frac{|d_{avg}| + |CC|}{RM_{avg}} \times 100$$

$RM_1 = 0.0318$	$RM_4 = 0.0322$	$RM_7 = 0$	$RM_{10} = 0.0338$
$RM_2 = 0.0323$	$RM_5 = 0$	$RM_8 = 0.0322$	$RM_{11} = 0.0337$
$RM_3 = 0.0317$	$RM_6 = 0.0318$	$RM_9 = 0.0330$	$RM_{12} = 0$
$RM_{avg} = 0.0325$			

$RA_{RM} = 3.88\%$



Example Calcs for Run : CRR Inter Heater Run 1

Variable:	Description:
B_{ws}	Proportion of water vapor, by volume, in the gas stream
C_f	Conversion factor, sec/hr
C_p	Pilot coefficient, 0.84
K_p	Velocity equation constant, 5129.4 (ft/min) [(lb/lb-mole)(in Hg) / (R)(in H ₂ O)] ^{0.5}
M_d	Molecular weight of stack gas, dry
M_s	Molecular weight of stack gas, dry, g/g-mole (lb/lb-mole)
M_w	Molecular weight of water, g/g-mole (lb/lb-mole)
P_m	Absolute pressure at the dry gas meter = Barometric Pressure + Δh_{avg} / 13.6, in Hg
T_m	Absolute Temperature at Meter, °R
V_m	Volume measured by DGM, dcf
$V_{m(std)}$	Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscf (dscf)
V_s	Measured concentration of the cal gas when introduced in the system cal mode, ppmv
$V_{wc(std)}$	Volume of water vapor condensed, corrected to standard conditions, scf (scf)
W_f	Final imp weight, g
W_i	Initial imp weight, g
Y	Dry gas meter calibration factor, unitless

Dry Molecular Weight of Stack Gas, M_d Eq. 3-1

$$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

$\%O_2 = 6.23$
 $\%CO_2 = 8.82$
 $\%N_2 = 84.95$
 $\%CO = 0.00$

$M_d = \quad \mathbf{29.66} \quad \text{lb/lb-mol}$

Volume of Water Vapor Collected, $V_{wc(std)}$ Eq. 4-2

$$V_{wc(std)} = K_3(W_f - W_i)$$

$K_3 = 0.04715 \quad (\text{ft}^3/\text{g})$
 $W_i = 2625.60 \quad (\text{g})$
 $W_f = 2818.60 \quad (\text{g})$

$V_{wc(std)} = \quad \mathbf{9.10} \quad \text{ft}^3$

Sample Gas Volume, $V_{m(std)}$ Eq. 4-3

$$V_{m(std)} = \left(\frac{T_{std}}{P_{std}} * Y \right) \left(\frac{V_m * P_m}{T_m} \right)$$

$T_{std} = 528 \quad (^\circ\text{R})$
 $P_{std} = 29.920 \quad (\text{inHg})$
 $V_m = 77.21 \quad (\text{ft}^3)$
 $P_m = 29.28 \quad (\text{in H}_2\text{O})$
 $T_m = 536.625 \quad (^\circ\text{R})$
 $Y = 0.989 \quad (\text{unitless})$

$V_{m(std)} = \quad \mathbf{73.53} \quad \text{ft}^3$

Moisture Content, B_{ws} Eq. 4-4

$$B_{ws} = \frac{V_{wc(std)}}{V_{wc(std)} + V_{m(std)}}$$

$B_{ws} = \quad \mathbf{11.01\%}$

Molecular Weight of Stack Gas, M_s Eq. 2-6

$$M_s = M_d(1 - B_{ws}) + (M_w * B_{ws})$$

$M_w = 18.00 \quad (\text{lb/lb-mole})$

$M_s = \quad \mathbf{28.38}$

Variable:	Description:
Δp_{avg}	Average velocity head of stack gas, mm H ₂ O (in H ₂ O)
A_n	Cross-sectional area of nozzle, ft ²
A	Cross-sectional area of stack, ft ²
B_{ws}	Proportion of water vapor, by volume, in the gas stream
C_f	Conversion factor, sec/hr
C_p	Pilot coefficient, 0.84
K_p	Velocity equation constant, 5129.4 (ft/min) [(lb/lb-mole)(in Hg) / (R)(in H ₂ O)] ^{0.5}
K_s	Constant, 0.09450 for English units
$\Delta H@$	Orifice meter calibration coefficient, in H ₂ O
M_s	Dry molecular weight of stack gas, lb/lb-mole
Q	Dry volumetric stack gas flow rate corrected to standard conditions, dscm/hr (dscf/hr)
P_s	Stack Pressure (Pbar + P _g)(in Hg)
Y_{qa}	Dry gas meter calibration check value, dimensionless
P_{bar}	Barometric pressure at the sampling site, mm Hg (in. Hg)
P_{std}	Standard absolute pressure, 760 mm Hg (29.92 in. Hg)
T_m	Absolute average DGM temperature, K (°R)
T_s	Absolute average stack gas temperature, 293 °K (528 °R)
$T_{s(abs)}$	Average Stack Temperature (°F) + 460, °R
V_m	Volume of gas sample as measured by dry gas meter, dcm (dcf)
$V_{m(std)}$	Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf)
θ	Total sampling time, min
V_s	Measured concentration of the cal gas when introduced in the system cal mode, ppmv.

Average Stack Gas Velocity, V_s

Eq. 2-7

$$V_s = K_p * C_p * \sqrt{\Delta p_{avg}} * \sqrt{\frac{T_{s(abs)}}{P_s * M_s}}$$

$$V_s = 2461.57 \text{ ft/min}$$

$$V_s = 41.026148 \text{ ft/sec}$$

$$K_p = 5129.4$$

$$C_p = 0.84 \text{ unitless}$$

$$P_s = 29.04 \text{ in H}_2\text{O}$$

$$T_{s(abs)} = 1100.375 \text{ °R}$$

$$(\Delta p_{avg})^{1/2} = 0.4944$$

$$M_s = 28.38 \text{ lb/lb-mole}$$

Average Stack Gas Flow, Q_a

$$Q_a = V_s * A$$

$$Q_a = 5.85E+04 \text{ acfm}$$

$$A = 23.76 \text{ ft}^2$$

$$V_s = 2461.57 \text{ ft/min}$$

Wet Standard Stack Gas Flow, Q_{sw}

$$Q_{sw} = Q_a * 60 * \left(\frac{T_{std}}{P_{std}}\right) * \left(\frac{P_s}{T_{s(abs)}}\right)$$

$$Q_a = 1.63E+06 \text{ wscfh}$$

$$P_s = 29.04 \text{ in Hg}$$

$$P_{std} = 29.92 \text{ in Hg}$$

$$T_{s(abs)} = 1100.4 \text{ °R}$$

$$T_{std} = 528 \text{ °R}$$

Average Stack Gas Dry Volumetric Flow Rate, Q

Eq. 2-8

$$Q = C_f * B_{ws} * A * V_s * \frac{T_{std} * P_s}{P_{std} * T_{s(abs)}}$$

Q = 1.45E+06 dscfh

C_f = 3600 sec/hr
 A = 23.76 ft²
 B_{ws} = 0.890 unitless
 P_s = 29.04 in Hg
 P_{std} = 29.92 in Hg
 T_{s(abs)} = 1100.4 °R
 T_{std} = 528 °R
 V_s = 41.03 ft/sec

Percent Isokinetic, I

Eq. 5-8

$$I = \frac{T_s * V_{m(std)} * P_{s(std)} * 100}{T_{(std)} * v_s * \theta * A_n * P_s * 60 * (1 - B_{ws})}$$

I = 91.760936 %

T_s = 1100.375 °R
 V_{m(std)} = 73.53 dscf
 P_s = 29.04 in Hg
 v_s = 41.03 ft/sec
 A_n = 8.73E-04 ft²
 θ = 90 min
 B_{ws} = 0.890 unitless

Post-Test Metering Calibration

Eq. 5-15

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{0.0319 T_m}{\Delta H @ \left(P_{bar} + \frac{\Delta H_{avg}}{13.6} \right) \left(\frac{29}{M_s} \right)}} \sqrt{\Delta H_{avg}}$$

Y_{run1} = 0.9935342
 Y_{run2} = 0.9759803
 Y_{run3} = 0.9770747
 Y_{qa (avg)} = 0.9821964

Run 1: ΔH@ = 1.816 unitless
 T_m = 536.625 °R
 P_{bar} = 29.11 in H₂O
 V_m = 77.21 dcf
 ΔH_{avg} = 2.36 in H₂O

Run 2: ΔH@ = 1.816 unitless
 T_m = 536.1667 °R
 P_{bar} = 29.11 in H₂O
 V_m = 79.68 dcf
 ΔH_{avg} = 2.43 in H₂O

Run 3: ΔH@ = 1.816 unitless
 T_m = 538.75 °R
 P_{bar} = 29.11 in H₂O
 V_m = 80.26 dcf
 ΔH_{avg} = 2.46 in H₂O

Example Calcs for Run : CRR Inter Heater Run 1

Variable:	Description:
m_t	Total mass of particulates, mg
V_{std}	Standard gas volume, %
Q_{sd}	Dry standard stack flow rate, dscfh
Clinker Rate	

Particulate Matter Mass Concentration, C_m

$$C_m = \frac{m_t}{453592} * \frac{1}{V_{std}}$$

$m_t = 6.10$ (mg)
 $V_{std} = 73.53$ (dscf)

$C_m = 1.83E-07$ lb/dscf

Particulate Matter Mass Emission Rate per Hour, E_h

$$E_h = C_m * Q_{sd}$$

$Q_{sd} = 1.45E+06$ (dscfh)

$E_h = 0.27$ lb/hr

Particulate Matter Mass Emission Rate per Day, E_d

$$E_d = E_h * 24$$

$E_d = 6.38$ lb/day

Particulate Matter Mass Emission Rate per Ton Clinker, E_{TC}

$$E_{TC} = \frac{E_h}{\text{Clinker Rate}}$$

Firing Rate = 94.55 (MMbtu/hr)

$E_{TC} = 0.00$ lb/MMbtu

Erthwrks Emission Rate Example Calculations

Example Calculations for Emissions : Run 1, CCR Inter Heater

Example Calculations for Pollutant : H₂SO₄

Variable:	Description:
%O _{2d}	Oxygen concentration measured on a dry basis, %
F _d	Fuel F Factor for Natural Gas--Method 19 value, scf/MMBtu
MGV	Molar gas volume, volume of gas at standard conditions, scf/lbmol
MW	Molecular Weight, lb/lbmol
n	Moles, lbmol
PPM	Parts per million
m _t	Weight of H ₂ SO ₄ , from lab analysis
p _s	Standard Pressure, psi
R	Universal gas constant, ft ³ psi / R lbmol
T _s	Standard Temperature, R
V	Volume, ft ³

Molar Gas Volume (MGV) calculation at standard conditions

Ideal Gas Law

$$MGV = \frac{V}{n} = \frac{R * T_s}{p}$$

$$\begin{aligned} T_s &= 527.67 & R \\ p &= 14.696 & \text{psi} \\ R &= 10.7316 & (\text{ft}^3 * \text{psi} / (\text{R} * \text{lbmol})) \end{aligned}$$

$$MGV = 385.325 \frac{\text{scf}}{\text{lbmol}}$$

Emission Concentration, C_d(lb/scf)

$$C_{d-\text{lb/scf}} = \frac{m_t(\text{lb})}{\text{Train Volume}}$$

$$\begin{aligned} \text{Train Volume} &= 10.26 & \text{scf} \\ m_t(\text{ug}) &= 82.9 & \text{ug} \\ m_t(\text{lb}) &= 1.83\text{E-}07 & \text{lb} \end{aligned}$$

$$C_d(\text{lb/scf}) = 1.781\text{E-}08 \frac{\text{lb}}{\text{scf}}$$

Emission Concentration, C_d(ppm)

$$C_d = \frac{C_d \left(\frac{\text{lb}}{\text{scf}} \right) * 10^6 * \text{MGV}}{\text{MW}}$$

$$\begin{aligned} C_d(\text{lb/scf}) &= 1.78\text{E-}08 & \text{lb/scf} \\ \text{MGV} &= 385.325 & \text{scf/lbmol} \\ \text{MW} &= 98.079 & \text{lb/lb-mol} \end{aligned}$$

$$C_d = 0.07 \text{ ppm}$$



Attachment E
Raw Data Log Records

RECEIVED

AUG 08 2022

AIR QUALITY DIVISION

Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO _x	CO	O ₂	CO ₂
6/7/22 6:51	9049.1.B4	MPC	Detroit	CCR InterHtr		0.02	-0.07	0.00	0.00
6/7/22 6:52	9049.1.B4	MPC	Detroit	CCR InterHtr		0.03	-0.33	10.16	3.36
6/7/22 6:53	9049.1.B4	MPC	Detroit	CCR InterHtr		0.08	-1.60	19.87	8.82
6/7/22 6:54	9049.1.B4	MPC	Detroit	CCR InterHtr		0.06	-1.67	19.87	17.02
6/7/22 6:54	9049.1.B4	MPC	Detroit	CCR InterHtr		0.03	-0.06	19.87	19.72
6/7/22 6:55	9049.1.B4	MPC	Detroit	CCR InterHtr	Direct Cal	0.03	-0.09	19.86	19.77
6/7/22 6:56	9049.1.B4	MPC	Detroit	CCR InterHtr		3.65	9.88	12.38	12.38
6/7/22 6:57	9049.1.B4	MPC	Detroit	CCR InterHtr		46.44	50.75	0.02	0.10
6/7/22 6:58	9049.1.B4	MPC	Detroit	CCR InterHtr		55.26	53.19	0.00	0.00
6/7/22 6:59	9049.1.B4	MPC	Detroit	CCR InterHtr		54.62	52.40	0.01	0.00
6/7/22 7:00	9049.1.B4	MPC	Detroit	CCR InterHtr	Direct Cal	53.43	50.98	0.01	0.00
6/7/22 7:01	9049.1.B4	MPC	Detroit	CCR InterHtr		45.66	48.90	8.88	0.07
6/7/22 7:02	9049.1.B4	MPC	Detroit	CCR InterHtr		19.56	17.92	6.93	6.91
6/7/22 7:03	9049.1.B4	MPC	Detroit	CCR InterHtr		19.47	0.64	6.12	8.33
6/7/22 7:04	9049.1.B4	MPC	Detroit	CCR InterHtr		19.53	-0.20	6.07	8.36
6/7/22 7:05	9049.1.B4	MPC	Detroit	CCR InterHtr		19.68	-0.31	6.07	8.39
6/7/22 7:06	9049.1.B4	MPC	Detroit	CCR InterHtr		19.90	-0.30	6.07	8.38
6/7/22 7:07	9049.1.B4	MPC	Detroit	CCR InterHtr		20.03	-0.25	6.05	8.38
6/7/22 7:08	9049.1.B4	MPC	Detroit	CCR InterHtr		19.95	-0.32	6.04	8.38
6/7/22 7:09	9049.1.B4	MPC	Detroit	CCR InterHtr		19.84	-0.37	6.04	8.41
6/7/22 7:10	9049.1.B4	MPC	Detroit	CCR InterHtr		20.00	-0.45	6.04	8.42
6/7/22 7:11	9049.1.B4	MPC	Detroit	CCR InterHtr		20.21	-0.50	6.00	8.47
6/7/22 7:12	9049.1.B4	MPC	Detroit	CCR InterHtr		20.32	-0.52	6.02	8.49
6/7/22 7:13	9049.1.B4	MPC	Detroit	CCR InterHtr		20.30	-0.52	6.00	8.48
6/7/22 7:14	9049.1.B4	MPC	Detroit	CCR InterHtr		14.96	-0.29	9.95	8.17
6/7/22 7:15	9049.1.B4	MPC	Detroit	CCR InterHtr		1.50	-0.16	18.39	2.09
6/7/22 7:16	9049.1.B4	MPC	Detroit	CCR InterHtr		1.09	-0.43	10.27	8.40
6/7/22 7:17	9049.1.B4	MPC	Detroit	CCR InterHtr		0.62	-0.61	9.92	9.73
6/7/22 7:18	9049.1.B4	MPC	Detroit	CCR InterHtr		0.23	-0.38	9.94	9.75
6/7/22 7:18	9049.1.B4	MPC	Detroit	CCR InterHtr		0.20	-0.27	10.00	9.75
6/7/22 7:19	9049.1.B4	MPC	Detroit	CCR InterHtr	Direct Cal	0.18	-0.28	10.00	10.10
6/7/22 7:20	9049.1.B4	MPC	Detroit	CCR InterHtr		8.45	7.57	2.40	3.25
6/7/22 7:21	9049.1.B4	MPC	Detroit	CCR InterHtr		24.66	24.25	0.03	0.00
6/7/22 7:22	9049.1.B4	MPC	Detroit	CCR InterHtr	Direct Cal	24.78	25.33	0.02	0.00
6/7/22 7:23	9049.1.B4	MPC	Detroit	CCR InterHtr		22.44	20.33	8.88	0.00
6/7/22 7:24	9049.1.B4	MPC	Detroit	CCR InterHtr		3.48	2.42	21.03	0.00
6/7/22 7:25	9049.1.B4	MPC	Detroit	CCR InterHtr		49.35	0.20	21.05	0.00
6/7/22 7:26	9049.1.B4	MPC	Detroit	CCR InterHtr	NOx Conv Eff.	57.68	0.18	21.04	0.00
6/7/22 7:27	9049.1.B4	MPC	Detroit	CCR InterHtr		55.07	0.87	14.89	2.39
6/7/22 7:28	9049.1.B4	MPC	Detroit	CCR InterHtr		25.86	3.30	6.07	8.54
6/7/22 7:29	9049.1.B4	MPC	Detroit	CCR InterHtr		20.34	-0.80	6.01	8.81
6/7/22 7:30	9049.1.B4	MPC	Detroit	CCR InterHtr		18.92	0.29	8.74	8.08
6/7/22 7:31	9049.1.B4	MPC	Detroit	CCR InterHtr		1.95	2.75	9.87	9.64
6/7/22 7:31	9049.1.B4	MPC	Detroit	CCR InterHtr		0.51	-0.85	9.87	9.95
6/7/22 7:32	9049.1.B4	MPC	Detroit	CCR InterHtr	Sys Bias	0.11	-0.10	9.97	9.96
6/7/22 7:33	9049.1.B4	MPC	Detroit	CCR InterHtr		-0.07	-0.08	9.97	10.10
6/7/22 7:34	9049.1.B4	MPC	Detroit	CCR InterHtr		4.17	3.54	4.10	5.62
6/7/22 7:35	9049.1.B4	MPC	Detroit	CCR InterHtr		23.70	22.18	0.14	0.12
6/7/22 7:36	9049.1.B4	MPC	Detroit	CCR InterHtr		23.86	24.64	0.11	0.02
6/7/22 7:37	9049.1.B4	MPC	Detroit	CCR InterHtr	Sys Bias	24.74	25.42	0.10	0.00
6/7/22 7:38	9049.1.B4	MPC	Detroit	CCR InterHtr		24.87	25.20	1.00	0.59
6/7/22 7:39	9049.1.B4	MPC	Detroit	CCR InterHtr		24.35	9.62	6.08	8.20
6/7/22 7:40	9049.1.B4	MPC	Detroit	CCR InterHtr		22.84	0.16	6.16	8.85

