

Report of...

Compliance Emission Sampling

Performed for the...

Michigan Sugar Company
Bay City, Michigan

On...

Gas Fired Boiler #6
(EUBOILER#6)

March 7, 2024

Project #: 022.70

By...

Network Environmental, Inc.
Grand Rapids, MI

Performed For:

**Michigan Sugar Company
122 Uptown Dr.
Suite 300
Bay City, MI 48708
Contact: Meaghan Martuch
Telephone: (989) 686-0161 EXT: 2236
Cell: (989) 780-2550
e-mail: meaghan.martuch@michigansugar.com**

At:

**Michigan Sugar Company
2600 S. Euclid
Bay City, MI 48706**

Performed by:

**Network Environmental, Inc.
2629 Remico, Suite B
Grand Rapids, MI 49519
Contact: David D. Engelhardt
Phone: (616) 530-6330
Fax: (616) 530-0001
e-mail: netenviro@aol.com**

TABLE OF CONTENTS

	<u>Page</u>
I. Introduction	1
II. Presentation of Results	2
II.1 Table 1 – Boiler #6 Carbon Monoxide (CO) Emission Results	2
III. Discussion of Results	3
IV. Source Description	3
V. Sampling and Analytical Protocol	3-5
Figure 1 – CO, O ₂ & CO ₂ Sampling Train Diagram	6
Figure 2 – Air Flow Sampling Train Diagram	7
Figure 3 – Moisture Sampling Train Diagram	8

Appendices

Exhaust Gas Parameters	A
Source Operating Data	B
Data Acquisition System Data	C
Calibration Gas & Analyzer Specification Data	D
Calculations	E
Raw Data	F

I. INTRODUCTION

Network Environmental, Inc. was retained by the Michigan Sugar Company to perform compliance emission sampling at their facility located in Bay City, Michigan. The purpose of the testing was to document compliance with the carbon monoxide (CO) emission limits for Boiler #6 (EUBOILER#6) established in Michigan Department of Environment, Great Lakes and Energy (EGLE) - Air Quality Division Renewable Operating Permit Number: MI-ROP-B1493-2021. MI-ROP-B1493-2021 has established the following emission limits for these boilers:

Source	Pollutant	Limit	Time Period / Operating Scenario
Boiler #6	CO	0.22 Lbs/MMBTU	8 Hour Average
		39.6 Lbs/Hr	Hourly
		86.7 Tons/Year	12 Month Rolling Time Period

The following reference methods were employed to conduct the emission sampling:

- Carbon Monoxide (CO) – U.S. EPA Method 10
- Exhaust Gas Parameters (Air Flow Rate, Temperature, Moisture & Density) – U.S. EPA Methods 1 through 4

The sampling was performed on March 7, 2024 by Stephan K. Byrd, Richard D. Eerdmans and David D. Engelhardt of Network Environmental, Inc. Assisting with the testing were Ms. Meaghan Martuch, Ms Angel Pichla and the operating staff of the facility. Mr. Daniel J. Droste of the Michigan Department of Environment, Great Lakes and Energy (EGLE) - Air Quality Division was present to observe the sampling and source operation.

II. PRESENTATION OF RESULTS

**II.1 TABLE 1
CARBON MONOXIDE (CO) EMISSION RESULTS
BOILER #6 (EUBOILER#6)
MICHIGAN SUGAR COMPANY
BAY CITY, MICHIGAN
MARCH 7, 2024**

Sample	Time	Air Flow Rate DSCFM ⁽¹⁾	CO Concentration PPM ⁽²⁾	CO Mass Emission Rates	
				Lbs/Hr ⁽³⁾	Lbs/MMBTU ⁽⁴⁾
1	09:20-10:20	29,653	119.0	15.34	0.095
2	10:35-11:35	29,601	112.8	14.52	0.089
3	12:30-13:30	30,205	104.5	13.72	0.083
Average		29,820	112.1	14.53	0.089

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (Standard Temperature & Pressure = 68 °F & 29.92 In. Hg).
- (2) PPM = Parts Per Million (v/v) On A Dry Basis
- (3) Lbs/Hr = Pounds of CO Per Hour
- (4) Lbs/MMBTU = Pounds Of CO Per Million BTU Of Heat Input (Calculated Using Equation 2.1 From U. S. EPA Method 19 With An F-Factor of 8710 DSCF/MMBTU).

III. DISCUSSION OF RESULTS

III.1 Boiler #6 CO Emissions – The CO emissions are summarized in Table 1 (Section II.1) as follows:

- Sample
- Time
- Air Flow Rate (DSCFM) – Dry Standard Cubic Feet Per Minute (Standard Temperature and Pressure = 68 °F and 29.92 Inches Hg)
- CO Concentration (PPM) – Parts Per Million (v/v) On A Dry Basis
- CO Emission Rates –
 - Lbs/Hr – Pounds of CO Per Hour
 - Lbs/MMBTU – Pounds of CO Per Million BTU of Heat Input (Calculated Using Equation 2.1 From U.S. EPA Method 19 With An F-Factor of 8710 DSCF/MMBTU)

IV. SOURCE DESCRIPTION

Boiler #6 is a gas-fired boiler with a rated capacity of 150,000 pounds per hour of steam (180 MMBTU per hour heat input). The boiler was manufactured by Nebraska Boiler and is equipped with economizers. Boiler #6 is used to provide process steam and heat to the facility. Operating parameters during the sampling for the boiler can be found in Appendix B.

V. SAMPLING AND ANALYTICAL PROTOCOL

The sampling methods used for the reference method determinations were as follows:

V.1 Carbon Monoxide – The CO sampling was conducted in accordance with U.S. EPA Reference Method 10. A Thermo Environmental Model 48C gas analyzer was used to monitor the Boiler #6 exhaust. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the CO concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 486.0 PPM was used to establish the initial instrument calibration. Calibration gases of 168.0 PPM & 251.0 PPM were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 168.0 PPM gas to determine the system bias. After each sample, a system zero and system injection of 168.0 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified. Three (3) samples were collected from the Boiler #6 exhaust. Each sample was sixty (60) minutes in duration.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. The analyzer averages were corrected for calibration error and drift using formula EQ.7E-5 from 40 CFR Part 60, Appendix A, Method 7E. A diagram of the sampling train is shown in Figure 1.

V.2 Oxygen & Carbon Dioxide – The O₂ & CO₂ sampling was conducted in accordance with U.S. EPA Reference Method 3A. Servomex Model 1400M portable stack gas analyzers were used to monitor the boiler exhaust. A heated probe was used to extract the sample gases from the stack. A heated Teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzers. The analyzers produce instantaneous readouts of the O₂ & CO₂ concentrations (%).

The analyzers were calibrated by direct injection prior to the testing. Span gases of 21.0% O₂ and 21.05% CO₂ were used to establish the initial instrument calibrations. Calibration gases of 11.8% O₂/5.94% CO₂ and 6.05% O₂/11.7% CO₂ were used to determine the calibration error of the analyzers. The sampling system (from the back of the stack probe to the analyzer) was injected using the 6.05% O₂/11.7% CO₂ gas to determine the system bias. After each sample, a system zero and system injection of 6.05% O₂/11.7% CO₂ were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzers were calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. Three (3) samples, each sixty (60) minutes in duration were collected from the boiler exhaust. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis. A diagram of the O₂ and CO₂ sampling train is shown in Figure 1

V.3 Exhaust Gas Parameters – The exhaust gas parameters (air flow rate, temperature, moisture and


density) were determined in conjunction with the other sampling by employing U.S. EPA Methods 1 through 4.

Air flow rates were determined by conducting three (3) velocity traverses (one for each sample) from the boiler exhaust. Moisture was determined by conducting one (1) moisture sample from the boiler exhaust. Gas density was calculated using the moisture, O₂ and CO₂ readings from the analyzers.

All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis. A diagram of the air flow sampling train is shown in Figure 2. A diagram of the moisture sampling train is shown in Figure 3.

V.4 Sampling Location – The sampling location for the Boiler #6 exhaust was on the 72 inch I.D. exhaust. The sampling location was at distances greater than the 8 duct diameter downstream and 2 duct diameters upstream from the nearest disturbances requirement of U.S. EPA Method 1. Three (3) point stratification tests (as described in U.S. EPA Method 7E) have been performed for the exhaust stack on numerous occasions. The stratification tests have always showed no stratification (< 5%), so a single sampling point was used for the gas sampling.

This report was prepared by:




David D. Engelhardt
Vice President

This report was reviewed by:



Stephan K. Byrd
President



9

Figure 1
CO, O₂ & CO₂
Sampling Train





Figure 2
Air Flow
Sampling Train



8




Figure 3
Moisture
Sampling Train