



**Particulate Matter Air Pollutant Compliance  
Emissions Test Report**

**St Marys Cement  
Charlevoix Plant  
Main Kiln and Clinker Cooler Stacks  
Charlevoix, Michigan  
August 30 through September 1, 2022**

**Report Submittal Date  
October 21, 2022**

© Copyright 2022  
All rights reserved in  
Mostardi Platt

**Project No. M223504**



---

## TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY .....	1
1.1 SSOL Results .....	1
1.2 Compliance Results.....	2
2.0 TEST METHODOLOGY .....	2
Method 1 Sample and Velocity Traverse Determination .....	2
Method 2 Volumetric Flow Rate Determination.....	3
Method 3A Oxygen (O <sub>2</sub> )/Carbon Dioxide (CO <sub>2</sub> ) Determination.....	3
Method 5 Filterable Particulate Matter (FPM) Determination.....	3
Method 202 Condensable Particulate Determination.....	4
3.0 TEST RESULT SUMMARIES .....	5
4.0 PARTICULATE MATTER CONTINUOUS PARAMETER MONITORING SYSTEM .....	8
5.0 CERTIFICATION.....	9
APPENDICES	
Appendix A - Test Section Diagrams .....	11
Appendix B - Sample Train Diagrams .....	14
Appendix C - Calculation Nomenclature and Formulas .....	19
Appendix D - Laboratory Analysis Data .....	31
Appendix E - Reference Method Test Data.....	35
Appendix F - Plant Operating Data.....	75
Appendix G - Field Data Sheets .....	87
Appendix H - Calibration Data.....	109
Appendix I - Cylinder Gas Certifications.....	134



## 1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted a compliance particulate test program for St Marys Cement at the Charlevoix Plant in Charlevoix, Michigan on the Main Kiln Stack and Cooler Stack. Main Kiln testing was performed during both “mill on” and “mill off” conditions.

The test locations, test dates, and test parameter are summarized below.

TEST INFORMATION		
Test Locations	Test Dates	Test Parameters
Main Kiln Stack (Mill On)	August 31, 2022	Filterable Particulate Matter (FPM), Condensable Particulate Matter (CPM), Total Particulate Matter (TPM), Particulate Matter less than 10 microns (PM <sub>10</sub> ), and Particulate Matter less than 2.5 microns (PM <sub>2.5</sub> )
Main Kiln Stack (Mill Off)	September 1, 2022	
Clinker Cooler Stack	August 30, 2022	Filterable Particulate Matter (FPM)

The purpose of the test program was to demonstrate compliance with Title 40, *Code of Federal Regulations*, Part 63 (40CFR63), Subpart LLL “*National Emission Standards for Hazardous Air Pollutants (NESHAP) for the Portland Cement Manufacturing Industry and Standards of Performance for Portland Cement Plants.*” Specifically, to demonstrate that each of the below listed sources meet their FPM emission limit and to establish a site-specific operating limit (SSOL) for each emission point’s continuous parameter monitoring system (CPMS). Additionally, PM/PM<sub>10</sub>/PM<sub>2.5</sub> testing was performed in conjunction with the above testing on the Main Kiln Stack in order to demonstrate compliance with Michigan Permit to Install 140-15B and Consent Order AQD No. 2021-09. For reporting purposes, all particulate matter collected (TPM) is considered to be less than PM<sub>10</sub>/PM<sub>2.5</sub>.

### 1.1 SSOL Results

Test Location	Parameter	Emission Rate	Filterable Particulate Matter, % of Emissions Limit	Emission Limit	CPMS 3-run Average	CPMS SSOL <sup>1</sup>
Main Kiln Stack (Mill On)	FPM	0.012 lb/ton	17.1	0.07 lb/ton	5.32 mg/m <sup>3</sup>	20.61
Main Kiln Stack (Mill Off)	FPM	0.019 lb/ton	27.1	0.07 lb/ton	3.62 mg/m <sup>3</sup>	
Clinker Cooler Stack	FPM	0.030 lb/ton	N/A	0.02 lb/ton	1.87 mg/m <sup>3</sup>	

<sup>1</sup> Main Kiln SSOL is prorated based upon the time weighted average for mill on (90%) and mill off (10%) conditions

## 1.2 Compliance Results

Test Location	Parameter	Emission Limit	Test Result (Mill On)	Test Result (Mill Off)
Main Kiln Stack	PM <sub>10</sub> /PM <sub>2.5</sub>	Emission Factor established during test	0.615 lb/ton clinker	0.992 lb/ton clinker

The identifications of the individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION		
Location	Address	Contact
Test Facility	St Marys Cement Charlevoix Cement Plant 16000 Bells Bay Road Charlevoix, Michigan 49720	Ms. Laurie Leaman Environmental Manager (231) 237-1387 <a href="mailto:laurie.leaman@vcimentos.com">laurie.leaman@vcimentos.com</a>
Testing Company Supervisor	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Jacob Howe Project Supervisor 630-993-2100 (phone) <a href="mailto:jhowe@mp-mail.com">jhowe@mp-mail.com</a>

The test crew consisted of Messrs. J. Howe, W. Rogman and C. Buglio.

## 2.0 TEST METHODOLOGY

Emission testing was conducted following the United States Environmental Protection Agency (USEPA) methods specified in 40CFR60, Appendix A and 40CFR51, Appendix M in addition the Mostardi Platt Quality Manual. Schematics of the test section diagrams and sampling trains used are included in Appendix A and B respectively. Calculation nomenclature are included in Appendix C. Laboratory analysis for each test run are included in Appendix D. The computerized reference method test data is included in Appendix E. CPMS data and process data as provided by St Marys Cement are also included in Appendix F.

The following methodologies were used during the test program:

### Method 1 Sample and Velocity Traverse Determination

Test measurement points were selected in accordance with USEPA Method 1, 40CFR60, Appendix A. The characteristics of the measurement location are summarized below.

TEST POINT INFORMATION							
Test Location	Stack Dimensions	No. of Ports	Port Length (Inches)	Upstream Diameters	Downstream Diameters	Test Parameters	Number of Sampling Points
Main Kiln Stack	10.58'	2	6	7.86	15.72	PM/PM <sub>10</sub> /PM <sub>2.5</sub>	12
Clinker Cooler Stack	10.22'	4	6.5	2.0	8.0	PM	12

## **Method 2 Volumetric Flow Rate Determination**

Gas velocity was measured following USEPA Method 2, 40CFR60, Appendix A, for purposes of calculating stack gas volumetric flow rate and emission rates on a lb/hr basis. S-type pitot tubes, 0-10" differential pressure gauge, and K-type thermocouple and temperature readout were used to determine gas velocity at each sample point. All of the equipment used was calibrated in accordance with the specifications of the Method. Copies of field data sheets are included in Appendix G. Calibration data are presented in Appendix H. This testing met the performance specifications as outlined in the Method.

## **Method 3A Oxygen (O<sub>2</sub>)/Carbon Dioxide (CO<sub>2</sub>) Determination**

Flue gas O<sub>2</sub> and CO<sub>2</sub> concentrations for the Main Kiln Stack were determined in accordance with USEPA Method 3A. A Servomex analyzer was used to determine the O<sub>2</sub> and CO<sub>2</sub> concentrations by connecting the analyzer to the exit of the dry gas meter. The O<sub>2</sub> instrument operates in the nominal range of 0% to 25% with the specific range determined by the high-level calibration gas. The CO<sub>2</sub> instrument operates in the nominal range of 0% to 80% with the specific range determined by the high-level calibration gas. High and mid-range calibrations were performed using USEPA Protocol gas. Zero nitrogen (a low ppm pollutant in balance nitrogen calibration gases) was introduced during other instrument calibrations to check instrument zero. Zero and mid-range calibrations were performed using USEPA Protocol gas after each test run. Copies of the gas cylinder certifications are found in Appendix H. For testing on the Clinker Cooler Stack, per section 8.6 of USEPA Method 2, this source is a non-combustion source and a dry molecular weight of 29.0 was utilized.

## **Method 5 Filterable Particulate Matter (FPM) Determination**

FPM runs were performed at the Main Stack during Raw Mill On and Raw Mill Off conditions, while Clinker Cooler runs were performed at one condition in accordance with USEPA Method 5, 40CFR60, Appendix A. Each run was a minimum one hundred twenty (120) minutes in duration and sampled a minimum volume of 2.0 dry standard cubic meters (dscm). Results were reported in lb/hr, and pounds per ton of clinker produced (lb/ton). Results were used to determine the Site-Specific Operating Limit (SSOL).

The particulate matter sampling train was manufactured by Environmental Supply Corporation and meets all specifications required by Method 5. Velocity pressures were determined simultaneously during sampling with an S-type pitot tube and inclined manometer. All temperatures will be measured using K-type thermocouples with calibrated digital temperature indicators. The probe and filter temperatures were maintained at 248°F +/- 25°F throughout sampling.

The filter media are high purity quartz that meet all requirements of Method 5. All sample contact surfaces of the train were washed with HPLC reagent-grade acetone. These washes were placed in sealed and marked containers for analysis.

All sample recoveries were performed at the test site by the test crew. All final particulate sample analyses were performed by Mostardi Platt personnel at the laboratory in Elmhurst, Illinois.

Laboratory analysis data are found in Appendix D. Calibration data are presented in Appendix H.

## Method 202 Condensable Particulate Determination

Stack gas condensable particulate matter concentrations and emission rates were determined in accordance with USEPA Method 202, in conjunction with Method 5 filterable particulate sampling. This method applies to the determination of CPM emissions from stationary sources. It is intended to represent condensable matter as material that condenses after passing through a filter and as measured by this method.

The CPM was collected in impingers after filterable particulate material was collected using Method 202. Compared to the December 17, 1991 promulgated Method 202, this Method includes the addition of a condenser, followed by a water dropout impinger immediately after the final heated filter. One modified Greenburg Smith impinger and an ambient temperature filter follow the water dropout impinger.

CPM was collected in the water dropout, modified Greenburg Smith impinger and ambient filter portion of the sampling train as described in this Method. The impinger contents were purged with nitrogen ( $N_2$ ) immediately after sample collection to remove dissolved sulfur dioxide ( $SO_2$ ) gases from the impingers. The impinger solution was then extracted with deionized water and hexane. The organic and aqueous fractions were dried and the residues weighed. The total of the aqueous, organic, and ambient filter fractions represents the CPM.

All sample recovery was performed at the test site by the test crew. Mostardi Platt personnel at the laboratory in Elmhurst, Illinois, performed all final particulate sample analyses as provided in Appendix D. All of the equipment used was calibrated in accordance with the specifications of the Method. Calibration data are presented in Appendix H.



### 3.0 TEST RESULT SUMMARIES

**Client:** St. Marys Cement  
**Facility:** Charlevoix, Michigan  
**Test Location:** Main Kiln Stack  
**Test Method:** 5/202

	Source Condition Date	Mill On 8/31/22	Mill On 8/31/22	Mill On 8/31/22	
	Start Time	9:30	12:20	14:55	
	End Time	11:45	14:25	17:04	
	Run 1	Run 2	Run 3	Average	
<b>Stack Conditions</b>					
Average Gas Temperature, °F	240.3	239.7	245.0	241.7	
Flue Gas Moisture, percent by volume	11.2%	11.3%	10.9%	11.1%	
Average Flue Pressure, in. Hg	29.33	29.33	29.33	29.33	
Gas Sample Volume, dscf	117.228	115.207	116.973	116.469	
Average Gas Velocity, ft/sec	95.537	93.751	94.916	94.735	
Gas Volumetric Flow Rate, acfm	503,944	494,525	500,669	499,713	
Gas Volumetric Flow Rate, dscfm	330,783	324,587	327,377	327,582	
Gas Volumetric Flow Rate, scfm	372,514	365,856	367,621	368,664	
Average %CO <sub>2</sub> by volume, dry basis	22.2	22.1	22.2	22.2	
Average %O <sub>2</sub> by volume, dry basis	8.2	8.3	8.3	8.3	
Isokinetic Variance	99.3	99.5	100.1	99.6	
Clinker Production Rate, ton/hr	243.82	243.81	243.80	243.81	
CPMS Response, mg/m3	0.30	6.77	8.88	5.32	
<b>Filterable Particulate Matter (Method 5)</b>					
grams collected	0.00392	0.00965	0.01084	0.00814	
grains/acf	0.0003	0.0008	0.0009	0.0007	
grains/dscf	0.0005	0.0013	0.0014	0.0011	
lb/hr	1.463	3.596	4.012	3.024	
lb/1000 lb of stack gas	0.001	0.002	0.002	0.002	
lb/ton of clinker	0.006	0.015	0.016	0.012	
<b>Condensable Particulate Matter (Method 202)</b>					
grams collected	0.30340	0.49053	0.39070	0.39488	
grains/acf	0.0262	0.0431	0.0337	0.0343	
grains/dscf	0.0399	0.0657	0.0515	0.0524	
lb/hr	113.226	182.783	144.619	146.876	
lb/1000 lb of stack gas	0.069	0.112	0.089	0.090	
lb/ton of clinker	0.464	0.750	0.593	0.602	
<b>Total Particulate Matter (5/202)</b>					
grams collected	0.30732	0.50018	0.40154	0.40301	
grains/acf	0.0265	0.0439	0.0346	0.0350	
grains/dscf	0.0404	0.0670	0.0529	0.0534	
lb/hr	114.689	186.379	148.631	149.900	
lb/1000 lb of stack gas	0.070	0.114	0.092	0.092	
lb/ton of clinker	0.470	0.764	0.610	0.615	

Client: St. Marys Cement  
 Facility: Charlevoix, Michigan  
 Test Location: Main Kiln Stack  
 Test Method: 5/202

	Source Condition	Mill Off	Mill Off	Mill Off	
	Date	9/1/22	9/1/22	9/1/22	
	Start Time	8:25	11:10	13:40	
	End Time	10:40	13:15	15:45	
	Run 1	Run 2	Run 3	Average	
<b>Stack Conditions</b>					
Average Gas Temperature, °F	366.6	368.0	367.6	367.4	
Flue Gas Moisture, percent by volume	10.1%	11.8%	11.9%	11.3%	
Average Flue Pressure, in. Hg	29.49	29.49	29.49	29.49	
Gas Sample Volume, dscf	99.147	100.461	98.604	99.404	
Average Gas Velocity, ft/sec	93.726	94.155	93.363	93.748	
Gas Volumetric Flow Rate, acfm	494,392	496,654	492,479	494,508	
Gas Volumetric Flow Rate, dscfm	279,921	275,237	272,797	275,985	
Gas Volumetric Flow Rate, scfm	311,290	312,195	309,726	311,070	
Average %CO <sub>2</sub> by volume, dry basis	24.8	24.9	24.6	24.8	
Average %O <sub>2</sub> by volume, dry basis	6.7	6.7	6.8	6.7	
Isokinetic Variance	99.3	102.3	101.3	101.0	
Clinker Production Rate, ton/hr	220.61	220.62	203.20	214.81	
CPMS Zero, mg/m <sup>3</sup>	1.49	5.22	4.14	3.62	
<b>Filterable Particulate Matter (Method 5)</b>					
grams collected	0.00237	0.00414	0.02647	0.01099	
grains/acf	0.0002	0.0004	0.0023	0.0010	
grains/dscf	0.0004	0.0006	0.0041	0.0017	
lb/hr	0.885	1.500	9.685	4.023	
lb/1000 lb of stack gas	0.001	0.001	0.007	0.003	
lb/ton of clinker	0.004	0.007	0.048	0.019	
<b>Condensable Particulate Matter (Method 202)</b>					
grams collected	0.55350	0.57045	0.58013	0.56803	
grains/acf	0.0488	0.0486	0.0503	0.0492	
grains/dscf	0.0861	0.0876	0.0908	0.0882	
lb/hr	206.676	206.703	212.271	208.550	
lb/1000 lb of stack gas	0.148	0.152	0.155	0.152	
lb/ton of clinker	0.937	0.937	1.045	0.973	
<b>Total Particulate Matter (5/202)</b>					
grams collected	0.55587	0.57459	0.60660	0.57902	
grains/acf	0.0490	0.0490	0.0526	0.0502	
grains/dscf	0.0865	0.0882	0.0949	0.0899	
lb/hr	207.561	208.203	221.956	212.573	
lb/1000 lb of stack gas	0.148	0.153	0.162	0.155	
lb/ton of clinker	0.941	0.944	1.092	0.992	

Client: St. Marys Cement  
 Facility: Charlevoix, Michigan  
 Test Location: Clinker Cooler Stack  
 Test Method: 5

Source Condition	Mill On Date	Mill On 8/30/22	Mill On 8/30/22	Mill On 8/30/22
	Start Time	8:00	10:40	13:02
	End Time	10:08	12:46	15:08
	Run 1	Run 2	Run 3	Average
<b>Stack Conditions</b>				
Average Gas Temperature, °F	265.8	275.2	262.3	267.8
Flue Gas Moisture, percent by volume	1.7%	1.5%	1.4%	1.5%
Average Flue Pressure, in. Hg	29.24	29.24	29.24	29.24
Gas Sample Volume, dscf	105.845	108.848	106.295	106.996
Average Gas Velocity, ft/sec	52.561	54.709	52.472	53.247
Gas Volumetric Flow Rate, acfm	258,705	269,280	258,269	262,085
Gas Volumetric Flow Rate, dscfm	180,822	186,242	181,872	182,979
Gas Volumetric Flow Rate, scfm	183,944	189,022	184,524	185,830
Average %CO <sub>2</sub> by volume, dry basis	0.0	0.0	0.0	0.0
Average %O <sub>2</sub> by volume, dry basis	20.9	20.9	20.9	20.9
Isokinetic Variance	101.5	101.3	101.3	101.4
Clinker Production Rate, ton/hr	251.37	251.36	251.37	251.37
CPMS Response, mg/m <sup>3</sup>	1.70	1.88	2.04	1.87
<b>Filterable Particulate Matter (Method 5)</b>				
grams collected	0.03777	0.03124	0.02968	0.03290
grains/acf	0.0038	0.0031	0.0030	0.0033
grains/dscf	0.0055	0.0044	0.0043	0.0047
lb/hr	8.534	7.069	6.716	7.440
lb/ton of clinker	0.034	0.028	0.027	0.030

## 4.0 PARTICULATE MATTER CONTINUOUS PARAMETER MONITORING SYSTEM

Per St Marys Cement a Relative Accuracy Test Audit (RATA) report summarizing the calibration and monitor certification will be submitted under separate cover for EGLE review. In addition to the monitor certification, the PC MACT requires that all data recorded and used to establish parameters for monitoring are to be submitted, including the following, per 1349(b)(1)(vii):

- Make and Model
  - All units are Sick SP100
- Serial Number
  - Main Stack PM Monitor s/n 17398675 Probe 16408330
  - Clinker PM Monitor s/n 17278571 Probe 17258401
- Analytical Principal
  - The measuring system works according to the *scattered light measurement* principle (i.e., forward dispersion). A laser diode beams the dust particles in the gas flow with modulated light in the visual range (wavelength approximately 650 nanometers [nm]). A highly sensitive detector registers the light scattered by the particles, amplifies the light electrically, and feeds it to the measuring channel of a microprocessor as a central part of the measuring, control, and evaluation electronics. The measuring volume in the gas duct is defined through the intersection of the sender beam and the receiving aperture.
  - Continuous monitoring of the sender output registers the smallest changes in brightness of the light beam sent, which then serves to determine the measurement signal
- Span of Primary Analytical Range
  - The original system specifications were for a range of 0 to 200 milligrams per dry standard cubic meter (mg/dscm)
- Milliamp Value or Digital Equivalent to the Zero Output
  - The monitor output is in milligrams, with zero equal to zero
- Technique to Determine the Zero Value
  - The sender diode is switched off for *zero-point control* so that no signal is received. This means possible *drifts* or zero-point deviations are reliably detected in the overall system (e.g., due to an electronic defect). An error signal is generated when the *zero value* is outside the specified range.
- Average Milliamp or Digital Equivalent Signals Corresponding to Each PM Compliance Run
  - See Appendix A, raw data recorded by the CPMS monitors is attached.

## 5.0 CERTIFICATION

Mostardi Platt is pleased to have been of service to St Marys Cement. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

As the program manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results. The test program was performed in accordance with the test methods and the Mostardi Platt Quality Manual, as applicable.

MOSTARDI PLATT



---

Jacob Howe

Project Manager



---

Eric L. Ehlers

Quality Assurance

---

## APPENDICES

**Appendix A - Test Section Diagrams**


**RECEIVED**

**NOV 02 2022**

**AIR QUALITY DIVISION**

**©Mostardi Platt**

## EQUAL AREA TRAVERSE FOR ROUND DUCTS



Project: St Mary's Cement  
Charlevoix Plant  
Charlevoix, Michigan

Test Location: Main Kiln Stack

Test Dates: August 31 and September 1, 2022

No. Sample Points: 12

Diameter: 10.58 Feet



Flue Area: 92.459 Square Feet

Upstream Diameters: 7.9

Downstream  
Diameters: 15.7



## EQUAL AREA TRAVERSE FOR ROUND DUCTS



Project: St Mary's Cement  
Charlevoix Plant  
Charlevoix, Michigan

Test Location: Clinker Cooler Exhaust

Test Date: August 30, 2022

No. Sample Points: 12

Diameter: 10.22 Feet


Flue Area: 82.03 Square Feet

Upstream Diameters: 2.0


Downstream  
Diameters: 8.0

## Appendix B - Sample Train Diagrams


# USEPA Method 2 – Type S Pitot Tube Manometer Assembly



# USEPA Method 5- Particulate Matter Sample Train Diagram



# USEPA Method 5/202- Filterable/Condensable Particulate Matter



# USEPA Method 3A Extractive Gaseous Sampling Diagram

