DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

FCE Summary Report

Facility :	Morton Salt, In	C.				SRN :	B1824
Location :	180 Sixth St.				<u> </u>	District :	Cadillac
						County :	MANISTEE
City :	MANISTEE	State:	MI Zip Code	: 49660	Complia Status :	nce	Compliance
Source Cla	ass: MAJOR				Staff :	Caryn	Owens
FCE Begin	Date : 4/01/14	•			FCE C Date :	ompletion	4/29/2015
Comments	;:						

List of Partial Compliance Evaluations :

- 5

Activity Date	Activity Type	Compliance Status	Comments
04/29/2015	Scheduled Inspection	Compliance	Scheduled Inspection and Records Review
01/16/2015	ROP Other	Compliance	Scrubber Measurements EUPELLCOOLING Vii.4. No Excursions for Pellet Scrubber. No measurements differed more than +/- 30% from the average baseline determined during the most recent stack test completed in Decemeber 2014.
01/16/2015	ROP Annual Cert	Compliance	2014 Annual Certification MI-ROP -B1824-2008. No Deviations were reported.
01/16/2015	ROP SEMI 2 CERT	Compliance	Semi-Annual Certification MI-ROP -B1824-2008. No Deviations were reported.
01/16/2015	Excess Emissions (CEM)	Compliance	#6 Boiler - 4th quarter - Quaterly EER Summary Report - No exceedances occured during reporting period.
01/16/2015	CAM Excursions/Exceedan ces	Compliance	EU#6 Boiler - There were no CAM Exceedances or Excursions during the reporting period.
12/19/2014	Stack Test	Compliance	Particulate Emissions for Pellet Production / Pretzel Salt Baghouse Total PM, 0.49 lbs/hr, Average PM concentration was 0.0019 gr/dscf. They were below the permitted emission limits of 0.014 gr/dscf.
10/30/2014	ROP Other	Compliance	Responsible Official has changed from David Slivka back to Jacob Blalik.

Activity Date	Activity Type	Compliance Status	Comments
10/28/2014	Stack Test Observation	Compliance	Stack Test observation for particulate testing of the FGPELLPROD process to demonstrate compliance with PTI 54-14.
10/20/2014	Telephone Notes	Compliance	Annual Shut-down was 10/13- 10/17, upon start-up of the boiler on natural gas, the COMS reported a steady opacity of 40%, when they started coal, the opacity stayed the same. Had a technician service the system, and exterior filters were wet and dirty. Changed them and opacity was normal again.
10/16/2014	CEM RATA	Compliance	EU#6BOILER Annual COMS Audit for 2014. All 6-minute opacity readings during meter calibration were below the 15% opacity action limit. The results of the audit were forwarded to TPU for review.
10/16/2014	Stack Test	Compliance	FGPELLPRETZEL Visible Emissions Testing - Completed September 29, 2014. No opacity reading were observed during the visible emissions "Method 9" testing of each side of the building and roof that houses FGPELLPRETZEL.
10/07/2014	Excess Emissions (CEM)	Compliance	#6 Boiler - 3rd quarter - Quaterly EER Summary Report - No exceedances occured during reporting period.
09/19/2014	NSPS (Part 60)	Compliance	10-Day Niotification of Visual Emissions Testing for the Pretzel Salt Process per PTI 54-14. (Initial Method 9 of each side of the building and roof, 36 minutes per side).
08/19/2014	ROP R215 Notification	Compliance	Amending ROP Renewal Application to incorporate PTIs 54- 14 (FGPELLPRETZEL) and 32-14 (EU#6BOILER) into the ROP renewal.
08/08/2014	Malfunction Abatement Plan	Compliance	MAP approval letter mailed 8/13/14
07/14/2014	Excess Emissions (CEM)	Compliance	#6 Boiler - 2nd quarter - Quaterly EER Summary Report - No exceedances occured during reporting period.
07/14/2014	ROP Semi 1 Cert	Compliance	Semi-Annual Certification and Deviation Report for MI-ROP- B1824-2008/2013. No deviations were reported

. .

÷ •

.

Activity Date	Activity Type	Compliance Status	Comments
07/14/2014	CAM Excursions/Exceedan ces	Compliance	Semi-Annual Excursion Report - No Excursions For #6 boiler Reported for condiiton EU#6BOILER, VII.7.
07/14/2014	ROP Other	Compliance	No Excursions for Pellet Scrubber. No measurements differed more than +/- 30% from the average baseline determined during the most recent stack test from 1/1/14 to 6/30/14.
07/14/2014	ROP Other	Compliance	The initial start-up of EUPRETZELSALT began 6/20/14 per Section VII. Reporting in PTI 54-14.
04/10/2014	Excess Emissions (CEM)	Compliance	1st quarter - Quaterly EER Summary Report - No exceedances occured during reporting period.

Name: <u>Augustual Date: 4/29/15</u> Supervisor: ______ Page 3 of