

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Occidental Chemical Corporation	SRN : B1846
Location : 1600 S. Madison St.	District : Cadillac
	County : MASON
City : LUDINGTON State: MI Zip Code : 49431	Compliance Status : Compliance
Source Class : MAJOR	Staff : Rob Dickman
FCE Begin Date : 6/22/2020	FCE Completion Date : 6/22/2021
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/22/2021	On-site Inspection	Compliance	Scheduled inspection of this ROP source.
05/04/2021	Stack Test	Compliance	PM Testing for EUPELLETCBULK. Testing report appears OK. Test results indicated 0.004#/1000# of exhaust gases. Emission limit per the facility ROP is 0.016 #/1000# of exhaust gases. No single testing run in excess of the emissions limit.
03/19/2021	ROP R215 Notification	Compliance	Change in RO from Mr. Dunklow to Mr Brett Vanderlinden
03/16/2021	ROP Annual Cert	Compliance	Several reports contained in a single document. Annual report for 2020. Report appears complete. A total of one deviation reported. The facility secured a permit to install for a new burner which eliminated the deviation. No further action is recommended.
03/16/2021	ROP SEMI 2 CERT	Compliance	A total of one deviation reported. The facility secured a permit to install for a new burner which eliminated the deviation. No further action is recommended.
03/16/2021	CAM Excursions/Exceedances	Compliance	No exceedances of the FGCAM reported
03/16/2021	CAM monitor downtime	Compliance	No monitor downtime for FGCAM.
03/15/2021	MAERS	Compliance	See MAERS for further info.

Activity Date	Activity Type	Compliance Status	Comments
02/12/2021	ROP Other	Compliance	Test Protocol for - Pm Compliance Testing - EUPELLETCBULK, protocol submitted in a timely manner. Testing is scheduled for March 3-4, 2021.
10/20/2020	ROP Semi 1 Cert	Compliance	Several reports contained in a single document. First semi-annual report for 2020. Report appears complete. No deviations noted.
10/20/2020	CAM monitor downtime	Compliance	Several reports contained in one document. No downtime noted for this time period.
10/20/2020	CAM Excursions/Exceedances	Compliance	Several reports contained in one document. No excursions noted for this time period.
08/12/2020	Stack Test	Compliance	Testing for PM on EUDGDCCFIBC. This emission unit is for loading of super sacks and drums. Testing report appears complete and was submitted in a timely manner. Tested emission rates for PM were 0.2 #/hr and 0.03 #/1000# exhaust gases, permitted emission limit for PM are 2.3 #/hr and 0.2 #/1000# exhaust gases. Results demonstrate compliance with emissions limits.
08/12/2020	Stack Test	Compliance	Testing for PM on EUPELLETHNDL. Testing report appears complete and was submitted in a timely manner. Tested emission rate for PM was 0.02 #/1000# exhaust gases, permitted emission limit for PM is 0.03 #/ 1000# exhaust gases. Results demonstrate compliance with emissions limits.

Name: _____

Date: _____

Supervisor: _____