



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
SOUTHEAST MICHIGAN DISTRICT OFFICE



DAN WYANT  
DIRECTOR

March 31, 2015

Mr. Mark L. VanderHeuvel  
DTE - Electric Company, Placid Peaking Station  
4505 King Road  
China, MI 48054-4420

SRN: B2803, Oakland County

Dear Mr. VanderHeuvel:

**VIOLATION NOTICE**

On March 16, 2015, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received a renewable operating permit deviation report from DTE - Electric Company, Placid Peaking Station located at 4912 Edgar, Springfield, Michigan. The purpose of this deviation report is to certify DTE - Electric Company, Placid Peaking Station's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the administrative rules and the conditions of Renewable Operating Permit (ROP) number MI-ROP-B2803-2013.

Per the deviation report, staff determined the following:

Process Description	Rule/Permit Condition Violated	Comments
FGPEAKERS	40 CFR 63.6625(b)(5) of Subpart ZZZZ.	The permittee failed to conduct the annual Continuous Parameter Monitoring System (CPMS) performance evaluation.

This process is subject to the federal National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines. These standards are found in 40 CFR Part 63, Subpart ZZZZ and 40 CFR Part 63 Subpart A. Per 40 CFR 63.6625(b)(5), the permittee must conduct the CPMS equipment performance evaluation at least annually. Per your deviation report, the required performance evaluation was not conducted annually.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by April 21, 2015. The written response should include: the dates the violation occurred; an explanation of the causes and duration of

the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If DTE - Electric Company believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Robert Elmouchi  
Environmental Quality Analyst  
Air Quality Division  
586-753-3736

RE/DC

cc/via e-mail: Mr. Joe Neruda, DTE – Electric Company  
Ms. Lynn Fiedler, DEQ  
Ms. Mary Ann Dolehanty, DEQ  
Ms. Teresa Seidel, DEQ  
Mr. Thomas Hess, DEQ  
Mr. Chris Ethridge, DEQ