CleanAir Engineering 110 Technology Drive Pittsburgh, PA 15275 800-632-1619 cleanair.com





REPORT ON HYDROGEN CHLORIDE TESTING

Trenton Channel Power Plant 4695 West Jefferson Ave Trenton Channel, MI 48183 Unit 9 Stack

DTE Energy One Energy Plaza Detroit Michigan, MI Client Reference No. 4701230436

CleanAir Project No. 13641 A2LA ISO 17025 Certificate No. 4342.01 A2LA / STAC Certificate No. 4342.02 Revision RO, Final Report August 24, 2018

13641 TCPP HCl Report_Q2_2018_R0c.docx 82418 011500 13641

DTE Energy Trenton Channel Power Plant Report on Hydrogen Chloride testing

RECEIVED

CleanAir Project No. 13641 Revision RO, Final Report Page 1

1. PROJECT OVERVIEW

AUG 28 2018

AIR QUALITY DIVISION

Test Program Summary

DTE Energy contracted CleanAir Engineering (CleanAir) to perform air emissions compliance testing on the Unit 9 Stack at the Trenton Channel Power Plant (TCPP) located in Trenton Channel, Michigan. The objective of the test program was to demonstrate quarterly compliance with the hydrogen chloride (HCl) emission limit required by 40 CFR Part 63, Subpart UUUUU. Compliance testing was performed to meet the requirements for testing in the second quarter of 2018.

A summary of the test program results is presented in Table 1-1. Section 2 Results provide a more detailed account of the test conditions and data analysis. Test program information, including the test parameters, onsite schedule and a project discussion, begin at the bottom of this page.

Table 1-1: Summary of Results			
<u>Source</u> Constituent	Sampling Method	Average Emission	Emission Limit ¹
<u>Unit 9 Stack</u> HCI (Ib/MMBtu)	EPA Method 26A EPA M19	3.9E-04	2.0E-03

¹ Emission limit obtained from 40 CFR Part 63, Subpart UUUUU, Table 2.

Test Program Details

Parameters

The test program was performed in accordance with the procedures of EPA Method 26A and the requirements of 40 CFR 63, Subpart UUUUU, Table 2. The test program included the following emission measurements:

- oxygen (O₂)
- carbon dioxide (CO₂)
- hydrogen chloride (HCl)
- flue gas moisture (H₂O)

Sampling was performed using EPA Method 26A (Modified) for HCl measurements. In addition, EPA Method 3 and 4 were combined with the EPA Method 26A sampling system to determine CO₂ and moisture content, respectively. Specific details of the procedures used are included in Section 4 and Appendix A.

DTE Energy	CleanAir Project No. 13641
Trenton Channel Power Plant	Revision R0, Final Report
Report on Hydrogen Chloride testing	Page 2

Schedule

Testing was performed on June 28, 2018. The on-site schedule followed during the test program is outlined in Table 1-2.

Table 1-2:	
Test Schedule	

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Unit 9 Stack	USEPA Method 26A	HCI	06/28/18	08:23	09:23
2	Unit 9 Stack	USEPA Method 26A	HCI	06/28/18	12:53	13:53
3	Unit 9 Stack	USEPA Method 26A	HCI	06/28/18	15:08	16:08

Discussion

A total of three (3) consecutive 60-minute runs were performed. Testing took place at the Unit 9 stack EPA sampling platform.

EPA Method 26A (Modified) was used for HCl measurements. Based on the stack temperature and moisture content of the flue gas, sampling was performed at a constant sample rate (+/- 10%) at a single sampling point during each test run. In accordance with 40 CFR 63, Subpart UUUUU, Table 2, a minimum of 0.75 dry standard cubic meters (dscm) of flue gas were sampled for each test run. Samples were analyzed for chlorides only (halogens not analyzed) using lon Chromatography (IC) by Clean Air Engineering located in Palatine, IL.

EPA Method 3 was combined with the EPA Method 26A (Modified) sampling system. Integrated gas samples were collected during each test run and analyzed for oxygen and carbon dioxide using an instrumental analyzer, calibrated according to EPA Method 3A and 7E procedures.

EPA Method 4 was combined with the EPA Method 26A (Modified) sampling system to determine the moisture content of the flue gas.

The Fc Factor and emissions calculations detailed in EPA Method 19 were used to determine HCI emission rates in units of lb/MMBtu to determine compliance with the HCI emission rate listed in 40 CFR 63, Subpart UUUUU, Table 2 for existing EGUs.

DTE Energy Trenton Channel Power Plant Report on Hydrogen Chloride testing

2. RESULTS

This section summarizes the test program results. Additional detailed results are available in Appendix C.

Table 2-1: Unit 9 Stack – Hydrogen Chloride					
Run No).	1	2	3	Average
Date (2	2018)	Jun 28	Jun 28	Jun 28	
Start Ti	me (approx.)	08:23	12:53	15:08	
Stop Ti	me (approx.)	09:23	13:53	16:08	
Proces	ss Conditions				
P ₁	Operating Load - (MW)	324	324	324	324
P ₂	Steam Load - (Klb/hr)	2,325	2,297	2,310	2,311
F _c ¹	Carbon dioxide-based F-factor (dscf/MMBtu)	1,800	1,800	1,800	1,800
Gas Co	onditions				
O ₂	Oxygen (dry volume %)	6.2	6.4	6.3	6.3
CO2	Carbon dioxide (dry volume %)	13.0	12.7	12.9	12.9
Ts	Sample temperature (°F)	284	294	291	290
B_{w}	Actual water vapor in gas (% by volume)	12.44	12.58	12.58	12.53
Hydrog	en Chloride (HCI) Results				
C_{sd}	HCI Concentration (ppmdv)	0.28	0.30	0.31	0.30
C_a	HCI Concentration (ppmwv)	0.25	0.27	0.27	0.26
E_{Fc}	HCI Rate - Fc-based (lb/MMBtu)	3.7E-04	4.1E-04	4.0E-04	3.9E-04

¹ Fc Factor listed for bituminous coal in EPA Method 19.

3. DESCRIPTION OF INSTALLATION

Process Description

The DTE Energy (DTE) owns and operates the Trenton Channel Power Plant located in Trenton, Michigan. The station currently operates one boiler (Boiler 9A). Boiler 9A is a Combustion Engineering boiler rated at 520 net Megawatts (MW) but based on the current fuel blend used the rating is reduced to a maximum capability of 460 net MW. Sampling was performed while the boiler was operating at a normal operating load.

Particulate emissions are controlled through the use of electrostatic precipitators (ESPs). Boiler 9A also uses Dry Sorbent Injection (DSI-trona) and Activated Carbon Injection (ACI) for control of acid gases, PM, PM10 and NOx and mecury emissions.

The testing reported in this document was performed at the Unit 9 stack EPA sampling platform.

Test Location

Table 3-1 presents the sampling point information. Figure 3-1 shows a diagram of the EPA sampling location. Figure 3-2 shows the layout of the test location and sampling point used. The sampling point was calculated based on EPA Method 1, Table 1-2 criteria (29.6% of diameter).

Table 3-1: Sampling Information							
<u>Source</u> Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
Unit 9 Stack							
	EPA Method 26A						
HCI	(Modified)	1-3	1	1	60	60	3-2

082218 013450

DTE Energy Trenton Channel Power Plant Report on Hydrogen Chloride testing CleanAir Project No. 13641 Revision R0, Final Report Page 5

Figure 3-1: Unit 9 EPA Sampling Location



DTE EnergyCleanAir Project No. 13641Trenton Channel Power PlantRevision RO, Final ReportReport on Hydrogen Chloride testingPage 6

Figure 3-2: Unit 9 Sampling Point Layout



DTE Energy Trenton Channel Power Plant Report on Hydrogen Chloride testing

RECEIVED

CleanAir Project No. 13641 Revision RO, Final Report Page 7

AUG 28 2018

4. METHODOLOGY

AIR QUALITY DIVISION

Procedures and Regulations

The test program sampling measurements followed procedures and regulations outlined by the USEPA and Michigan Department of Environmental Quality (DEQ). These methods appear in detail in Title 40 of the CFR and at https://www.epa.gov/emc.

Appendix A includes diagrams of the sampling apparatus, as well as specifications for sampling, recovery, and analytical procedures. Any modifications to standard test methods are explicitly indicated in this appendix. In accordance with ASTM D7036 requirements, CleanAir included a description of any such modifications along with the full context of the objectives and requirements of the test program in the test protocol (if required) submitted prior to the measurement portion of this project. Modifications to standard methods are not covered by the ISO 17025 and TNI portions of CleanAir's A2LA accreditation.

CleanAir follows specific QA/QC procedures outlined in the individual methods and in USEPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods," EPA/600/R-94/038C. Appendix D contains additional QA/QC measures, as outlined in CleanAir's internal Quality Manual.

Title 40 CFR Part 60, Appendix A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 19	"Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide and Nitrogen Oxide Emission Rates"
Method 26A	"Determination of Hydrogen Halide and Halogen Emissions from Stationary Sources Isokinetic Method"