

Report of...

Boiler MACT Emission Sampling

Performed for the...

Michigan Sugar Company

Sebewaing Michigan

on the

Wet ESP Exhaust

February 8, 2018

Project #: 022.42

By...

Network Environmental, Inc.
Grand Rapids, MI

RECEIVED

MAR 16 2018

AIR QUALITY DIVISION

I. INTRODUCTION

Network Environmental, Inc. was retained by the Michigan Sugar Company of Bay City, Michigan, to perform emission sampling at their Sebewaing, Michigan facility. The purpose of the sampling was to determine compliance with the National Emission Standard for Hazardous Air Pollutants (NESHAP) 40CFR Part 63 Subpart DDDDD (MACT for Industrial, Commercial, Institutional Boilers and Process Heaters). The following is a list of the compounds sampled and corresponding emission limits:

Compounds Sampled	Emission Limit
Carbon Monoxide (CO)	160 PPM @ 3% O ₂ or 0.14 Lbs/MMBTU of Steam Output
Particulate	4.0 E-02 Lbs/MMBTU of Heat Input or 4.2 E-02 Lbs/MMBTU of Steam Output

The test methods used were as follows:

- Carbon Monoxide (CO) – U.S. EPA Method 10
- Particulate – U.S. EPA Method 17
- Oxygen (O₂) & Carbon Dioxide (CO₂) – U.S. EPA Methods 3A
- Exhaust Gas Parameters (air flow rate, temperature, moisture & density) – U.S. EPA Methods 1-4

The sampling was performed on February 8, 2018 by Stephan K. Byrd, R. Scott Cargill and Richard D. Eerdmans of Network Environmental, Inc.. Assisting with the sampling were Mr. Steven Smock and the operating staff of the facility. Mr. Rob Dickman, Mr. Chris Hare and Ms. Kathy Brewer of the Michigan Department of Environmental Quality (MDEQ) - Air Quality Division were present to observe the sampling and source operation.

RECEIVED
MAR 16 2018
AIR QUALITY DIVISION

II. PRESENTATION OF RESULTS

**II.1 TABLE 1
PARTICULATE
EMISSION RESULTS SUMMARY
WET ESP EXHAUST
MICHIGAN SUGAR COMPANY
SEBEWAING, MICHIGAN
FEBRUARY 8, 2018**

Sample	Date	Time	Air Flow Rate DSCFM ⁽¹⁾	Particulate Mass Emission Rate		
				Lbs/Hr ⁽²⁾	Lbs/MMBTU Heat Input ⁽³⁾	Lbs/MMBTU Steam Output ⁽⁴⁾
1	2/8/18	10:08-11:43	55,058	4.78	2.99E-02	3.02E-02
2	2/8/18	12:47-14:22	56,080	5.09	3.22E-02	3.20E-02
3	2/8/18	14:42-16:16	56,087	4.28	2.70E-02	2.82E-02
Average			55,742	4.72	2.97E-02	3.01E-02

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- (2) Lbs/Hr = Pounds of Particulate Per Hour
- (3) Lbs/MMBTU Heat Input = Pounds Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,780 DSCF/MMBTU)
- (4) Lbs/MMBTU Steam Output = Pounds Per Million BTU of Steam Output (Calculated Using 158.48 MMBTU/Hr Of Steam Production For Sample One, 159.07 MMBTU/Hr Of Steam Production For Sample Two and 151.78 MMBTU/Hr Of Steam Production For Sample Three.)
- (5) **Particulate Emission Limit From Part 63 Subpart DDDDD = 4.0E-02 Lbs/MMBTU Of Heat Input OR 4.2E-02 Lbs/MMBTU Of Steam Output**

**II.2 TABLE 2
CARBON MONOXIDE (CO)
EMISSION RESULTS SUMMARY
WET ESP EXHAUST
MICHIGAN SUGAR COMPANY
SEBEWAING, MICHIGAN
FEBRUARY 8, 2018**

Sample	Time	Air Flow Rate DSCFM ⁽¹⁾	CO Concentration		CO Mass Emission Rate		
			PPM ⁽²⁾	PPM @ 3 %O ₂ ⁽³⁾	Lbs/Hr ⁽⁴⁾	Lbs/MMBTU Heat Input ⁽⁵⁾	Lbs/MMBTU Steam Output ⁽⁶⁾
1	08:58-09:58	55,058	66.2	119.7	15.85	0.099	0.097
2	10:13-11:54	56,080	59.3	110.6	14.46	0.091	0.091
3	12:05-13:09	56,087	68.1	127.0	16.61	0.105	0.105
Average		55,742	64.5	119.1	15.64	0.099	0.098

- (1) DSCFM = Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg). PPM = Parts Per Million (v/v) On A Dry Basis
(2) PPM @ 3 %O₂ = Parts Per Million (v/v) On A Dry Basis Corrected To 3 Percent Oxygen
(3) Lbs/Hr = Pounds of CO Per Hour
(4) Lbs/MMBTU Heat Input = Pounds Per Million BTU of Heat Input (Calculated Using U.S. EPA Method 19 With An F-Factor of 9,780 DSCF/MMBTU)
(5) Lbs/MMBTU Steam Output = Pounds Per Million BTU of Steam Output (Calculated Using 163.98 MMBTU/Hr Of Steam Production For Sample One, 159.67 MMBTU/Hr Of Steam Production For Sample Two and 157.69 MMBTU/Hr Of Steam Production For Sample Three.)
(6) **CO Emission Limit From Part 63 Subpart DDDDD = 160 PPM @ 3 %O₂ OR 0.14 Lbs/MMBTU Of Steam Output**

III. DISCUSSION OF RESULTS

The results of the emission sampling are summarized in Tables 1 through 2 (Sections II.1 through II.2). The results are presented as follows:

III.1 Particulate

Table 1 – Particulate Emission Results Summary

- Sample
- Date
- Time
- Air Flow Rate (DSCFM) – Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- Particulate Mass Emission Rate (Lbs/Hr) – Pounds of Particulate Per Hour
- Particulate Mass Emission Rate (Lbs/MMBTU Heat Input) – Pounds of Particulate Per Million BTU of Heat Input (Calculated using Equation 19-1 from U.S. EPA Method 19. The F Factor used for the Lbs/MMBTU calculations was 9,780 DSCF/MMBTU.)
- Particulate Mass Emission Rate (Lbs/MMBTU Steam Output) – Pounds of Particulate Per Million BTU of Steam Output. The BTU/Lb of steam value used (1200 BTU/Lb of Steam) in these calculations was obtained from a Steam Table using steam operating data supplied by Michigan Sugar. The steam table used can be found in Appendix F. Boiler operating data during the testing can be found in Appendix G.

A more detailed breakdown of each individual particulate sample can be found in Appendix A.

III.2 CO

Table 2 – Carbon Monoxide (CO) Emission Results Summary

- Sample
- Time
- Air Flow Rate (DSCFM) - Dry Standard Cubic Feet Per Minute (STP = 68 °F & 29.92 in. Hg)
- CO Concentration (PPM) - Parts Per Million (v/v) on a Dry Basis
- CO Concentration (PPM @ 3 %O₂) - Parts Per Million (v/v) on a Dry Basis Corrected To 3 Percent Oxygen
- CO Mass Emission Rate (Lbs/Hr) - Pounds of CO Per Hour
- CO Mass Emission Rate (Lbs/MMBTU Heat Input) – Pounds of CO Per Million BTU of Heat Input (Calculated using Equation 19-1 from U.S. EPA Method 19. The F Factor used for the Lbs/MMBTU calculations was 9,780 DSCF/MMBTU.)

- CO Mass Emission Rate (Lbs/MMBTU Steam Output) – Pounds of CO Per Million BTU of Steam Output. The BTU/Lb of steam value used (1200 BTU/Lb of Steam) in these calculations was obtained from a Steam Table using steam operating data supplied by Michigan Sugar. The steam table used can be found in Appendix F. Boiler operating data during the testing can be found in Appendix G.

The CO sample data was calibration corrected using Equation 7E-5 from U.S. EPA Method 7E.

III.3 Emission Limits

National Emission Standard for Hazardous Air Pollutants (NESHAP) 40CFR Part 63 Subpart DDDDD (MACT for Industrial, Commercial, Institutional Boilers and Process Heaters) has established the following emission limits for this source:

Compound	Emission Limit
Carbon Monoxide (CO)	160 PPM @ 3% O ₂ or 0.14 Lbs/MMBTU of Steam Output
Particulate	4.0 E-02 Lbs/MMBTU of Heat Input or 4.2 E-02 Lbs/MMBTU of Steam Output

IV. SOURCE DESCRIPTION

There are two (2) boilers at the Sebewaing facility. Both boilers are Wicks "A" frame coal fired stokers. These boilers are as follows:

- Boiler #2 (EUICKESEASTBOIL) - Built in 1940. Designed heat input of approximately 87 MMBTU/Hr
- Boiler #3 (EUICKESWESTBOIL) - Built in 1939. Designed heat input of approximately 87 MMBTU/Hr

These boilers are used for generating process steam. The exhaust gases from these boilers have a common exhaust duct that leads to a wet scrubber followed by a Wet ESP before being emitted to atmosphere. Source operating data during the sampling can be found in Appendix G.

RECEIVED

MAR 16 2018

AIR QUALITY DIVISION

V. SAMPLING AND ANALYTICAL PROTOCOL

The sampling location was on the 60 inch I.D. stack with 2 sample ports in a location that exceeded the 8 duct diameters downstream and 2 duct diameters upstream from the nearest disturbances requirement of U.S. EPA Method 1. Twelve (12) sampling points were used for this source.

V.1 Particulate - The Particulate emission sampling was conducted by employing U.S. EPA Method 17. This is an in stack filtration method. Three (3) samples were collected. The samples were ninety (90) minutes in duration and each had a minimum sample volume of two (2) dry standard cubic meters (DSCM). The samples were collected isokinetically on quartz filters.

The nozzle/probe rinses and filters (front half) were analyzed for particulate by gravimetric analysis in accordance with Method 17. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis. A diagram of the Particulate sampling train is shown in Figure 1.

V.2 Carbon Monoxide - The CO sampling was conducted in accordance with U.S. EPA Reference Method 10. A Thermo Environmental Model 48C gas analyzer was used to monitor the Wet ESP exhaust. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the CO concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 492.5 PPM was used to establish the initial instrument calibration. A calibration gas of 254.0 PPM was used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 254.0 PPM gas to determine the system bias. After each sample, a system zero and system injection of 254.0 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified. Three (3) samples were collected from the Wet ESP exhaust. Each sample was sixty (60) minutes in duration.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. The analyzer averages were corrected for calibration error and drift using formula EQ.7E-5 from 40 CFR Part 60, Appendix A, Method 7E. A diagram of the sampling train is shown in Figure 2.


V.3 Oxygen & Carbon Dioxide - The O₂ & CO₂ sampling was conducted in accordance with U.S. EPA Reference Method 3A. Servomex Model 1400M portable stack gas analyzers were used to monitor the Wet ESP exhaust. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzers. The analyzers produce instantaneous readouts of the O₂ & CO₂ concentrations (%).

The analyzers were calibrated by direct injection prior to the testing. Span gases of 20.96% O₂ and 20.1% CO₂ were used to establish the initial instrument calibrations. Calibration gases of 5.99% O₂/12.02% CO₂ and 12.0% O₂/6.03% CO₂ were used to determine the calibration error of the analyzers. The sampling system (from the back of the stack probe to the analyzers) was injected using the 12.0% O₂/6.03% CO₂ gas to determine the system bias. After each sample, a system zero and system injection of 12.0% O₂/6.03% CO₂ were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzers were calibrated to the output of the data acquisition system (DAS) used to collect the data from the boiler. The analyzer averages were corrected for calibration error and drift using formula EQ.7E-5 from 40 CFR Part 60, Appendix A, Method 7E. A diagram of the sampling train is shown in Figure 2.


V.4 Exhaust Gas Parameters – The exhaust gas parameters (air flow rate, temperature, moisture and density) were determined in conjunction with the other sampling by employing U.S. EPA Methods 1 through 4. Air flow rates, temperatures and moistures were determined using the isokinetic sampling trains. All the quality assurance and quality control procedures listed in the methods were incorporated in the sampling and analysis.

This report was prepared by:




Stephan K. Byrd
President

This report was reviewed by:




David D. Engelhardt
Vice President



8

Figure 1
Particulate Sampling Train



6

Figure 2
CO, O₂ & CO₂
Sampling Train