

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION


FCE Summary Report

Facility : FCA US LLC – Trenton Engine Complex	SRN : B3350
Location : 2300 VAN HORN RD CIMS 453-00-00	District : Detroit
	County : WAYNE
City : TRENTON State: MI Zip Code : 48183	Compliance Status : Compliance
Source Class : MAJOR	Staff : Todd Zynda
FCE Begin Date : 11/14/2017	FCE Completion Date : 11/14/2018
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
11/14/2018	Scheduled Inspection	Compliance	Schedule Inspection
09/25/2018	ROP Semi 1 Cert	Compliance	Received the Semiannual Deviation Report for 01/01/2018 through 06/30/2018. The facility reports one deviation in relation to FGOTHERMACHININGLINES, SC IV.1. The facility reports that on February 9, 2019 a vibration was discovered in the fan unit of Mist Collector B-1. On February 14, 2018 the fan unit was removed from service for repair. The unit required specialized repair and was returned to service on March 4, 2018. During the repair, the fan was not in operation, so no air contaminants were released from the exhaust system. According to FCA the emissions were contained in the housings of various machines. The incident prompted the purchase of at least one backup blower.
04/06/2018	Other	Compliance	2017 MAERS Review
04/06/2018	MAERS	Compliance	Please see MACES report CA_B335043976.
03/21/2018	ROP Annual Cert	Compliance	The company certified that during the entire reporting period (January 1, 2017 through December 31, 2017), that the source was in compliance with all terms and conditions in the ROP.

Activity Date	Activity Type	Compliance Status	Comments
03/21/2018	ROP SEMI 2 CERT	Compliance	Received the Semiannual Deviation Report for 07/01/2017 through 12/31/2017. Zero deviations reported.
01/29/2018	Stack Test	Compliance	Boiler 1 and Boiler 5 stack testing - Emissions are in compliance with MI-ROP-B3350-2014b, FG-BLR1&BLR5, SC I. 1 (CO - 0.084 lb/MMBtu), SC I. 3 (Boiler 1 NOx - 0.10 lb/MMBtu) and SC I. 5 (Boiler 5 NOx - 0.28 lb/MMBtu). Average emissions are reported as follows. Boiler 1 - CO: 0.003 lb/MMBtu, NOx: 0.10 lb/MMBtu; Boiler 5 - CO: 0.006 lb/MMBtu, NOx: 0.11 lb/MMBtu

Name: 

Date: 11/29/18

Supervisor: 