



RECEIVED

APR 11 2023

AIR QUALITY DIVISION

**CONTINUOUS EMISSIONS MONITORING SYSTEM
RELATIVE ACCURACY DETERMINATION**

Performed At

Pharmacia & Upjohn Company, LLC

A subsidiary of Pfizer, Inc

Natural Gas Boilers #9 (EUEBLR43-9-S1), #10 (EUEBLR43-10-S1)

and #11 (EUEBLR43-11-S1)

Kalamazoo, Michigan

Test Date(s)

February 21, 22 and 23, 2023

Report No.


TRC Environmental Corporation Report 521454

Report Submittal Date

March 29, 2023

TRC Environmental Corporation
207C Eisenhower Lane South
Lombard, Illinois 60148
USA

T (312) 533-2042



Report Certification

I certify that to the best of my knowledge:

- Testing data and all corresponding information have been checked for accuracy and completeness.
- Sampling and analysis have been conducted in accordance with the approved protocol and applicable reference methods (as applicable).
- All deviations, method modifications, or sampling and analytical anomalies are summarized in the appropriate report narrative(s).

A handwritten signature in black ink, appearing to read 'Doug Ryan', written over a horizontal line.

Doug Ryan
Midwest Regional Manager – AMS

March 29, 2023

Date

TRC was operating in conformance with the requirements of ASTM D7036-04 during this test program.

A handwritten signature in black ink, appearing to read 'Bruce Randall', written over a horizontal line.

Bruce Randall
TRC Emission Testing Technical Director



TABLE OF CONTENTS

| | |
|---|-----|
| 1.0 INTRODUCTION | 4 |
| 1.1 Project Contact Information..... | 4 |
| 1.2 Facility and Process Description..... | 5 |
| 2.0 SUMMARY OF RESULTS..... | 5 |
| CEMS RATA Test Matrix (Boilers 9, 10 & 11)..... | 5 |
| 3.0 DISCUSSION OF RESULTS | 6 |
| 4.0 TEST PROCEDURES | 6 |
| 4.1 Determination of Sample Point Locations by USEPA Method 1 | 6 |
| 4.2 Determination of the Concentration of Gaseous Pollutants Using a Multi-Pollutant Sampling System..... | 6 |
| 4.2.1 O ₂ Determination by USEPA Method 3A..... | 7 |
| 4.2.2 NO _x Determination by USEPA Method 7E..... | 7 |
| 4.3 Determination of F-Factors by USEPA Method 19 | 7 |
| 5.0 QUALITY ASSURANCE PROCEDURES..... | 8 |
| 6.0 TEST RESULTS SUMMARY | 9 |
| APPENDIX | |
| AETB and QI Information Summary | 17 |
| Qualified Individual Certificate(s)..... | 18 |
| Continuous Emissions Monitoring System (CEMS) and Plant Operating Data..... | 20 |
| Sample Location Information | 50 |
| Sampling Train Diagram | 53 |
| Calculation Nomenclature and Formulas | 54 |
| Processed Field Data Sheets..... | 57 |
| Gaseous Calibration Data | 78 |
| NO ₂ -to-NO Conversion Data..... | 101 |
| Response Time Data..... | 104 |
| Analyzer Interference Data | 106 |
| Calibration Gas Certification Data | 108 |



CONTINUOUS EMISSIONS MONITORING SYSTEM RELATIVE ACCURACY DETERMINATION

1.0 INTRODUCTION

TRC Environmental Corporation (TRC) performed a continuous emissions monitoring system (CEMS) relative accuracy test on February 21, 22 and 23, 2023 on natural gas Boilers #9 (EUEBLR43-9-S1), #10 (EUEBLR43-10-S1) and #11 (EUEBLR43-11-S1) exhaust stacks for Pfizer at the Pharmacia & Upjohn Company, LLC in Kalamazoo, Michigan. The tests were authorized by and performed for Pharmacia & Upjohn Company, LLC.

The purpose of this test program was to evaluate the relative accuracy (RA) of the nitrogen oxides (NO_x), and oxygen (O₂) CEMS on Boilers #9, #10 and #11, while operating at >50% normal load. Emission rates are expressed in terms of the applicable source standard(s). All tests were performed in accordance with methods described in the Code of Federal Regulations, Title 40, Part 60 (40CFR60), Appendix B, Performance Specifications 2, 3 and the TRC Test Protocol 521454, dated December 9, 2022.

1.1 Project Contact Information

| Participants | | |
|-----------------------------------|---|---|
| Test Facility | Pharmacia & Upjohn Company, LLC A subsidiary of Pfizer, Inc 7000 Portage Road Kalamazoo, Michigan 49001-0199 Permit No. MI-ROP-B3610-2021 Facility No. B3610 | Mr. Jeffrey Robey Manager EHS (269) 833-3842 (phone) jeffrey.robey@pfizer.com |
| Air Emissions Testing Body (AETB) | TRC Environmental Corporation 207C Eisenhower Lane South Lombard, Illinois 60148 | Mr. Gregory Rock Field Team Leader (262) 960-3379 (phone) grock@trccompanies.com |

The tests were conducted by Ted Kalisz and Gregory Rock of TRC. Documentation of the on-site ASTM D7036-04 Qualified Individual(s) (QI) can be located in the appendix to this report.

Monica Brothers of the Lansing Michigan Department of EGLE observed the testing.



1.2 Facility and Process Description

Pharmacia & Upjohn Company, owns and operates Boiler #9 designated as EUEBLR43-9-S1 in the Renewable Operating Permit (ROP)# MI-ROP-B3610-2021. One (1) 120,000 pound steam/hr boiler with a maximum nameplate heat input capacity of 144.7 MMBtu/hr for natural gas and 138.3 MMBtu/hr for #2 fuel oil. The boiler primarily burns natural gas with #2 fuel oil as a backup fuel.

The facility also owns and operates two identical boilers designated as EUEBLR43-10-S1 (Boiler #10) and EUEBLR43-11-S1 (Boiler #11) in the ROP# MI-ROP-B3610-2021. Two (2) 120,000 pound steam/hr boilers, each with a maximum nameplate heat input capacity of 143.2 MMBtu/hr for natural gas and 138.5 MMBtu/hr for #2 fuel oil. The boilers primarily burn natural gas with #2 fuel oil as a backup fuel.

Pollution control equipment for each boiler includes low NO_x burners and flue gas recirculation.

2.0 SUMMARY OF RESULTS

The relative accuracies of the CEMS are as follows:

| Load | Parameter | Units | Performance Specifications (40CFR60) | | CEMS Performance Relative Accuracy | | |
|-------|-----------------|----------|---|--|---------------------------------------|----------------------------|-------------------------|
| | | | Specification No. | Acceptance Criteria | Boiler #9 2/21/2023 | Boiler #10 2/22-23/2023 | Boiler #11 2/23/2023 |
| > 50% | NO _x | lb/MMBtu | 2 | RA ≤ 20% of the Reference Method | 9.41 % | 4.71 % | 4.03 % |
| | O ₂ | % | 3 | RA ≤ 1.0% difference | 0.02 % | 0.00 % | 0.01 % |

CEMS RATA Test Matrix (Boilers 9, 10 & 11)

| Parameter | Reference Methods (RM) | No. of Test Runs | Test Run Length (min) |
|-----------------|------------------------|------------------|--------------------------|
| NO _x | 7E, 3A | 10 | 21 |
| O ₂ | 3A | 10 | 21 |



3.0 DISCUSSION OF RESULTS

The complete test results from this program are tabulated in Section 6.0.

The data acquisition and handling system (DAHS) computer printout for the same time periods as the RM testing was used to determine the relative accuracy. The watches of the test crew were synchronized with the CEMS prior to testing.

On February 22nd the Boiler 10 RATA was paused after Run #7. Adverse weather conditions prevented continued work at heights. The Boiler 10 RATA was resumed on February 23rd and runs 8-10 were completed.

No problems were encountered with the testing equipment during the course of the test program. Source operation appeared normal during the entire test program and operated at more than 50 percent of normal load. The CEMS operation appeared normal with no apparent problems during sampling. No changes or problems were encountered that required modification of any procedures presented in the test plan. Operating data was recorded by plant personnel and is appended to this report.

4.0 TEST PROCEDURES

All testing, sampling, analytical, and calibration procedures used for this test program were performed in accordance with the methods presented in the following sections. Where applicable, the Quality Assurance Handbook for Air Pollution Measurement Systems, Volume III, Stationary Source Specific Methods, USEPA 600/R-94/038c, September 1994 was used to supplement procedures.

4.1 Determination of Sample Point Locations by USEPA Method 1

This method is applicable to gas streams flowing in ducts, stacks, and flues and is designed to aid in the representative measurement of pollutant emissions and/or total volumetric flow rates from stationary sources. In order to qualify as an acceptable sample location, it must be located at a position at least two stack or duct equivalent diameters downstream and a half equivalent diameter upstream from any flow disturbance.

4.2 Determination of the Concentration of Gaseous Pollutants Using a Multi-Pollutant Sampling System

Concentrations of the pollutants in the following sub-sections were determined using one sampling system. The number of points at which sample was collected was determined in accordance with 40CFR60 specifications.



A straight-extractive sampling system was used. A data logger continuously recorded pollutant concentrations and generated one-minute averages of those concentrations. All calibrations and system checks were conducted using USEPA Protocol gases. Three-point linearity checks were performed prior to sampling, and in the event of a failing system bias or drift test (and subsequent corrective action). System bias and drift checks were performed using the low-level gas and either the mid- or high-level gas prior to and following each test run.

The Low Concentration Analyzers (those that routinely operate with a calibration span of less than 20 ppm) used by TRC are ambient-level analyzers. Per Section 3.12 of Method 7E, a Manufacturer's Stability Test is not required for ambient-level analyzers. Analyzer interference tests were conducted in accordance with the regulations in effect at the time that TRC placed an analyzer model in service.

4.2.1 O₂ Determination by USEPA Method 3A

This method is applicable for the determination of O₂ concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The O₂ analyzer was equipped with a paramagnetic-based detector.

4.2.2 NO_x Determination by USEPA Method 7E

This method is applicable for the determination of NO_x concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The NO_x analyzer utilized a photomultiplier tube to measure the linear and proportional luminescence caused by the reaction of nitric oxide and ozone.

4.3 Determination of F-Factors by USEPA Method 19

This method is applicable for the determination of the pollutant emission rate using oxygen (O₂) or carbon dioxide (CO₂) concentrations and the appropriate F factor (the ratio of combustion gas volumes to heat inputs) and the pollutant concentration. The appropriate F-Factor was selected from Table 19-2 of Method 19.

RECEIVED

APR 11 2023

AIR QUALITY DIVISION



5.0 QUALITY ASSURANCE PROCEDURES

TRC integrates our Quality Management System (QMS) into every aspect of our testing service. We follow the procedures specified in current published versions of the test Method(s) referenced in this report. Any modifications or deviations are specifically identified in the body of the report. We routinely participate in independent, third party audits of our activities, and maintain:

- Accreditation from the Louisiana Environmental Laboratory Accreditation Program (LELAP).
- Accreditation from the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA) that our operations conform with the requirements of ASTM D 7036 as an Air Emission Testing Body (AETB).

These accreditations demonstrate that our systems for training, equipment maintenance and calibration, document control and project management will fully ensure that project objectives are achieved in a timely and efficient manner with a strict commitment to quality.

All calibrations are performed in accordance with the test Method(s) identified in this report. If a Method allows for more than one calibration approach, or if approved alternatives are available, the calibration documentation in the appendices specifies which approach was used. All measurement devices are calibrated or verified at set intervals against standards traceable to the National Institute of Standards and Technology (NIST). NIST traceability information is available upon request.

ASTM D7036-04 specifies that: *"AETBs shall have and shall apply procedures for estimating the uncertainty of measurement. Conformance with this section may be demonstrated by the use of approved test protocols for all tests. When such protocols are used, reference shall be made to published literature, when available, where estimates of uncertainty for test methods may be found."* TRC conforms with this section by using approved test protocols for all tests.



6.0 TEST RESULTS SUMMARY



RATA Type: Nitrogen Oxides (NO_x), lb/MMBtu
Regulation: 40CFR60
RM Used: 3A, 7E

| | | | | | | | | |
|------------------------|-------------|-----------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Customer: | | Pfizer | | | Project #: | | 521545 | |
| Unit ID: | | Boiler #9 | | | CEM Model: | | Teledyne API T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 470 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM NO _x lb/MMBtu | CEM NO _x lb/MMBtu | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/21/2023 | 8:21 | 8:41 | 0.031 | 0.028 | 0.003 | |
| 1 | 2 | 2/21/2023 | 8:59 | 9:19 | 0.032 | 0.029 | 0.003 | |
| 1 | 3 | 2/21/2023 | 9:37 | 9:57 | 0.032 | 0.029 | 0.003 | |
| 1 | 4 | 2/21/2023 | 10:13 | 10:33 | 0.032 | 0.029 | 0.003 | |
| 1 | 5 | 2/21/2023 | 10:50 | 11:10 | 0.032 | 0.029 | 0.003 | |
| 1 | 6 | 2/21/2023 | 11:25 | 11:45 | 0.032 | 0.029 | 0.003 | |
| 1 | 7 | 2/21/2023 | 12:02 | 12:22 | 0.032 | 0.029 | 0.003 | |
| 1 | 8 | 2/21/2023 | 12:40 | 13:00 | 0.032 | 0.029 | 0.003 | |
| 1 | 9 | 2/21/2023 | 13:15 | 13:35 | 0.032 | 0.029 | 0.003 | |
| 0 | 10 | 2/21/2023 | 13:58 | 14:18 | 0.032 | 0.029 | 0.003 | |

| | |
|---------------------------------|-----------------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 0.032 RM avg |
| Mean CEM Value | 0.029 CEM avg |
| Sum of Differences | 0.027 di |
| Mean Difference | 0.0030 d avg |
| Sum of Differences ² | 0.000 di ² |
| Standard Deviation | 0.000 sd |
| Confidence Coefficient | 0.000 CC |
| RA based on RM | 9.41 % |



RATA Type: Oxygen (O₂), % by volume
Regulation: 40CFR60
RM Used: 3A

| | | | | | | | | |
|------------------------|-------------|-----------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Customer: | | Pfizer | | | Project #: | | 521545 | |
| Unit ID: | | Boiler #9 | | | CEM Model: | | Teledyne API T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 470 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM O ₂ % v/v dry | CEM O ₂ % v/v dry | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/21/2023 | 8:21 | 8:41 | 3.8 | 3.8 | 0.000 | |
| 1 | 2 | 2/21/2023 | 8:59 | 9:19 | 3.8 | 3.9 | -0.100 | |
| 1 | 3 | 2/21/2023 | 9:37 | 9:57 | 3.9 | 3.9 | 0.000 | |
| 1 | 4 | 2/21/2023 | 10:13 | 10:33 | 3.9 | 3.9 | 0.000 | |
| 1 | 5 | 2/21/2023 | 10:50 | 11:10 | 3.9 | 3.9 | 0.000 | |
| 1 | 6 | 2/21/2023 | 11:25 | 11:45 | 3.9 | 3.9 | 0.000 | |
| 1 | 7 | 2/21/2023 | 12:02 | 12:22 | 3.9 | 3.9 | 0.000 | |
| 1 | 8 | 2/21/2023 | 12:40 | 13:00 | 3.9 | 3.9 | 0.000 | |
| 1 | 9 | 2/21/2023 | 13:15 | 13:35 | 3.8 | 3.9 | -0.100 | |
| 0 | 10 | 2/21/2023 | 13:58 | 14:18 | 4.4 | 3.9 | 0.500 | |

| | |
|-------------------------------|------------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 3.867 RM avg |
| Mean CEM Value | 3.889 CEM avg |
| Mean Difference | -0.022 d avg |
| Standard Deviation | 0.044 sd |
| Confidence Coefficient | 0.034 CC |
| RA (Absolute Mean Difference) | 0.02 % vol diff. |



RATA Type: Nitrogen Oxides (NO_x), lb/MMBtu
Regulation: 40CFR60
RM Used: 3A, 7E

| | | | | | | | | |
|------------------------|-------------|------------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Customer: | | Pfizer | | | Project #: | | 521545 | |
| Unit ID: | | Boiler #10 | | | CEM Model: | | TAPI T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 1126 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM NO _x lb/MMBtu | CEM NO _x lb/MMBtu | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/22/2023 | 8:45 | 9:05 | 0.030 | 0.029 | 0.001 | |
| 1 | 2 | 2/22/2023 | 9:24 | 9:44 | 0.030 | 0.029 | 0.001 | |
| 1 | 3 | 2/22/2023 | 10:01 | 10:21 | 0.029 | 0.028 | 0.001 | |
| 0 | 4 | 2/22/2023 | 10:40 | 11:00 | 0.030 | 0.028 | 0.002 | |
| 1 | 5 | 2/22/2023 | 11:19 | 11:39 | 0.029 | 0.028 | 0.001 | |
| 1 | 6 | 2/22/2023 | 11:57 | 12:17 | 0.029 | 0.028 | 0.001 | |
| 1 | 7 | 2/22/2023 | 12:37 | 12:57 | 0.029 | 0.028 | 0.001 | |
| 1 | 8 | 2/23/2023 | 7:11 | 7:31 | 0.028 | 0.027 | 0.001 | |
| 1 | 9 | 2/23/2023 | 7:48 | 8:08 | 0.029 | 0.027 | 0.002 | |
| 1 | 10 | 2/23/2023 | 8:30 | 8:50 | 0.028 | 0.027 | 0.001 | |

| | |
|---------------------------------|---------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 0.029 RM avg |
| Mean CEM Value | 0.028 CEM avg |
| Sum of Differences | 0.010 di |
| Mean Difference | 0.0011 d avg |
| Sum of Differences ² | 0.000 di^2 |
| Standard Deviation | 0.000 sd |
| Confidence Coefficient | 0.000 CC |
| RA based on RM | 4.71 % |



RATA Type: Oxygen (O₂), % by volume
Regulation: 40CFR60
RM Used: 3A

| Customer: | | Pfizer | | | Project #: | | 521545 | |
|------------------------|-------------|------------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Unit ID: | | Boiler #10 | | | CEM Model: | | TAPI T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 1126 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM O ₂ % v/v dry | CEM O ₂ % v/v dry | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/22/2023 | 8:45 | 9:05 | 3.6 | 3.6 | 0.000 | |
| 1 | 2 | 2/22/2023 | 9:24 | 9:44 | 3.6 | 3.6 | 0.000 | |
| 1 | 3 | 2/22/2023 | 10:01 | 10:21 | 3.6 | 3.6 | 0.000 | |
| 0 | 4 | 2/22/2023 | 10:40 | 11:00 | 3.6 | 3.6 | 0.000 | |
| 1 | 5 | 2/22/2023 | 11:19 | 11:39 | 3.6 | 3.6 | 0.000 | |
| 1 | 6 | 2/22/2023 | 11:57 | 12:17 | 3.6 | 3.6 | 0.000 | |
| 1 | 7 | 2/22/2023 | 12:37 | 12:57 | 3.6 | 3.6 | 0.000 | |
| 1 | 8 | 2/23/2023 | 7:11 | 7:31 | 3.6 | 3.6 | 0.000 | |
| 1 | 9 | 2/23/2023 | 7:48 | 8:08 | 3.6 | 3.6 | 0.000 | |
| 1 | 10 | 2/23/2023 | 8:30 | 8:50 | 3.6 | 3.6 | 0.000 | |

| | |
|-------------------------------|------------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 3.600 RM avg |
| Mean CEM Value | 3.600 CEM avg |
| Mean Difference | 0.000 d avg |
| Standard Deviation | 0.000 sd |
| Confidence Coefficient | 0.000 CC |
| RA (Absolute Mean Difference) | 0.00 % vol diff. |



RATA Type: Nitrogen Oxides (NO_x), lb/MMBtu
Regulation: 40CFR60
RM Used: 3A, 7E

| | | | | | | | | |
|------------------------|-------------|------------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Customer: | | Pfizer | | | Project #: | | 521545 | |
| Unit ID: | | Boiler #11 | | | CEM Model: | | TAPI T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 1125 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM NO _x lb/MMBtu | CEM NO _x lb/MMBtu | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/23/2023 | 12:33 | 12:53 | 0.029 | 0.028 | 0.001 | |
| 0 | 2 | 2/23/2023 | 13:07 | 13:27 | 0.029 | 0.025 | 0.004 | |
| 1 | 3 | 2/23/2023 | 13:43 | 14:03 | 0.029 | 0.028 | 0.001 | |
| 1 | 4 | 2/23/2023 | 14:19 | 14:39 | 0.028 | 0.027 | 0.001 | |
| 1 | 5 | 2/23/2023 | 14:54 | 15:14 | 0.028 | 0.027 | 0.001 | |
| 1 | 6 | 2/23/2023 | 15:33 | 15:53 | 0.028 | 0.028 | 0.000 | |
| 1 | 7 | 2/23/2023 | 16:10 | 16:30 | 0.028 | 0.027 | 0.001 | |
| 1 | 8 | 2/23/2023 | 16:45 | 17:05 | 0.028 | 0.027 | 0.001 | |
| 1 | 9 | 2/23/2023 | 17:19 | 17:39 | 0.029 | 0.028 | 0.001 | |
| 1 | 10 | 2/23/2023 | 17:54 | 18:14 | 0.029 | 0.028 | 0.001 | |

| | |
|---------------------------------|---------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 0.028 RM avg |
| Mean CEM Value | 0.028 CEM avg |
| Sum of Differences | 0.008 di |
| Mean Difference | 0.0009 d avg |
| Sum of Differences ² | 0.000 di^2 |
| Standard Deviation | 0.000 sd |
| Confidence Coefficient | 0.000 CC |
| RA based on RM | 4.03 % |



RATA Type: Oxygen (O₂), % by volume
Regulation: 40CFR60
RM Used: 3A

| | | | | | | | | |
|------------------------|-------------|------------|---------------|-------------|-----------------------------------|------------------------------------|--------------------------------|--|
| Customer: | | Pfizer | | | Project #: | | 521545 | |
| Unit ID: | | Boiler #11 | | | CEM Model: | | TAPI T200M | |
| Sample Loc: | | Stack | | | CEM Serial #: | | 1125 | |
| Use? 1 = Y 0 = N | Test Run | Date | Start Time | End Time | RM O ₂ % v/v dry | CEM O ₂ % v/v dry | (RM-CEM) Difference (di) | |
| 1 | 1 | 2/23/2023 | 12:33 | 12:53 | 3.3 | 3.3 | 0.000 | |
| 0 | 2 | 2/23/2023 | 13:07 | 13:27 | 3.2 | 3.3 | -0.100 | |
| 1 | 3 | 2/23/2023 | 13:43 | 14:03 | 3.2 | 3.3 | -0.100 | |
| 1 | 4 | 2/23/2023 | 14:19 | 14:39 | 3.3 | 3.3 | 0.000 | |
| 1 | 5 | 2/23/2023 | 14:54 | 15:14 | 3.3 | 3.3 | 0.000 | |
| 1 | 6 | 2/23/2023 | 15:33 | 15:53 | 3.3 | 3.3 | 0.000 | |
| 1 | 7 | 2/23/2023 | 16:10 | 16:30 | 3.3 | 3.3 | 0.000 | |
| 1 | 8 | 2/23/2023 | 16:45 | 17:05 | 3.3 | 3.3 | 0.000 | |
| 1 | 9 | 2/23/2023 | 17:19 | 17:39 | 3.3 | 3.3 | 0.000 | |
| 1 | 10 | 2/23/2023 | 17:54 | 18:14 | 3.3 | 3.3 | 0.000 | |

| | |
|-------------------------------|------------------|
| n | 9 |
| t(0.975) | 2.306 |
| Mean RM Value | 3.289 RM avg |
| Mean CEM Value | 3.300 CEM avg |
| Mean Difference | -0.011 d avg |
| Standard Deviation | 0.033 sd |
| Confidence Coefficient | 0.026 CC |
| RA (Absolute Mean Difference) | 0.01 % vol diff. |

RECEIVED

APR 11 2023