

# Relative Accuracy Test Audit Test Report

Lansing Board of Water and Light Delta Energy Park Facility EUCTGSC1 Stack Lansing, Michigan 48917 February 6, 2024

Report Submittal Date February 16, 2024

© Copyright 2024 All rights reserved in Mostardi Platt

Project No. M233603C

# TABLE OF CONTENTS

1.0 EXECUTIVE SUMMARY	
2.0 TEST METHODOLOGY	2
Method 3A Oxygen (O2) Determination	
Method 7E Nitrogen Oxides (NOx) Determination	
3.0 TEST RESULT SUMMARIES	4
4.0 CERTIFICATION	6
APPENDICES	
Appendix A - Company AETB Certification	8
Appendix B - QI Certification(s) for Field Personnel	
Appendix C - Test Section Diagram	
Appendix D - Sample Train Diagram	
Appendix E - Calculation Nomenclature and Formulas	
Appendix F - Reference Method Test Data (Computerized Sheets)	
Appendix G - Continuous Emissions Monitoring System Data and Plant Operating Data	
Appendix H - Calibration and Response Time Data	
Appendix I - Calibration Gas Cylinder Data	
Appendix J - NO <sub>2</sub> to NO Converter Efficiency Test	

#### 1.0 EXECUTIVE SUMMARY

Mostardi Platt conducted a Continuous Emissions Monitoring System (CEMS) Relative Accuracy Test Audit (RATA) test program for Lansing Board of Water and Light at the Delta Energy Park Facility in Lansing, Michigan, on the EUCTGSC1 Stack on February 6, 2024. This report summarizes the results of the test program and test methods used in accordance with the Mostardi Platt Protocol M233603C dated September 26, 2023. Mostardi Platt is a self-certified air emissions testing body (AETB). A copy of Mostardi Platt's self-certification can be found in Appendix A. Mostardi Platt is a self-certified air emissions testing body (AETB). A copy of Mostardi Platt's self-certification can be found in Appendix A.

The test location, test date, and test parameters are summarized below.

TEST INFORMATION							
Test Location	Test Date	Test Parameters					
EUCTGSC1 Stack	February 6, 2024	Oxygen (O <sub>2</sub> ) and Nitrogen Oxides (NO <sub>x</sub> )					

The purpose of the test program was to demonstrate the relative accuracies of the EUCTGSC1 Stack  $O_2$  and  $NO_X$  analyzers during the specified operating conditions. The test results from this test program indicate that each CEMS component meets the United States Environmental Protection Agency (USEPA) annual performance specification for relative accuracy as published in 40 Code of Federal Regulations Part 75 (40CFR75).

RATA RESULTS								
Test Location	Date	Parameter	Units	Relative Accuracy Acceptance Criteria	Relative Accuracy (RA)	Bias Adjustment Factor (BAF)		
EUCTGSC1 Stack	1 7/6/74	NOx	lb/mmBtu	≤ 7.5% of the mean reference value	3.03%	1.026		
		O <sub>2</sub>	% dry	≤ 7.5% of the mean reference value	0.83%	N/A		

The gas cylinders used to perform the RATA are summarized below.

	GAS CYLINDER INFORMATION						
Parameter	Gas Vendor	Cylinder Serial Number	Cylinder Value	Expiration Date			
NOx	Airgas	CC349243	0 ppm	1/24/2030			
NOx	Airgas	CC422948	25.46 ppm	8/15/2026			
NOx	Airgas	CC420531	44.93 ppm	8/14/2026			
O <sub>2</sub>	Airgas	CC422948	0%	8/15/2026			
O <sub>2</sub>	Airgas	CC349243	11.75%	1/24/2030			
O <sub>2</sub>	Airgas	CC407478	21.93%	7/7/2030			

No deviations, additions, or exclusions from the test protocol, test methods, the Mostardi Platt Quality Manual, or the ASTM D7036-12 occurred. The specific test conditions encountered did not interfere with the collection of the data.

The identifications of the individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION						
Location	Address	Contact				
Test Coordinator	Lansing Board of Water and Light 1232 Haco Drive P.O. Box 13007 Lansing, Michigan 48912	Nathan Hude Environmental Regulatory Compliance (517) 702-6170 (cell phone)				
Test Facility	Lansing Board of Water and Light Delta Energy Park Facility 3725 South Canal Road Lansing, Michigan 48917 Permit to Install 74-18C	nathan.hude@lbwl.com				
Testing Company Supervisor	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Timothy R. Yanowsky Test Supervisor 630-993-2100 (phone) tyanowsky@mp-mail.com				
Testing Company Personnel		Mr. Jeff Gross Test Technician				

Copies of the QI certifications for test personnel are included in Appendix B.

#### 2.0 TEST METHODOLOGY

Emission testing was conducted following the United States Environmental Protection Agency (USEPA) methods specified in 40CFR75 and 40CFR60, Appendix A in addition to the Mostardi Platt Quality Manual and the test protocol. Schematics of the test section diagrams and sampling trains used are included in Appendix C and D respectively. Calculation and nomenclature are included in Appendix E. Copies of analyzer print-outs for each test run are included in Appendix F. CEM data and process data as provided by Lansing Board of Water and Light are included in Appendix G.

The following methodologies were used during the test program:

## Method 3A Oxygen (O2) Determination

Stack gas  $O_2$  concentrations were determined in accordance with USEPA Method 3A, 40CFR60, Appendix A. An  $O_2$  analyzer was used to determine the  $O_2$  concentrations in the manner specified in the Method. The instrument has a paramagnetic detector and the  $O_2$  operates in the nominal range of 0% to 25% with the specific range determined by the high-level calibration gas of 21.93%. High-range calibrations were performed using USEPA Protocol gas. Zero nitrogen (a low ppm pollutant in balance nitrogen calibration gases) was introduced during other instrument calibrations to check instrument zero. High- and a mid-range %  $O_2$  levels in balance nitrogen were also introduced. Zero and mid-range calibrations were performed using USEPA Protocol gas after each test run. Copies of the gas cylinder certifications are found in Appendix I. This testing met the performance specifications as outlined in the Method.

#### Method 7E Nitrogen Oxides (NO<sub>X</sub>) Determination

Stack gas NO<sub>x</sub> concentrations and emission rates were determined in accordance with USEPA Method 7E, 40CFR60, Appendix A. A Thermo Scientific Model 42iQSL Chemiluminescence Nitrogen Oxides Analyzer was used to determine nitrogen oxides concentrations, in the manner specified in the Method. The instrument operated in the nominal range of 0 ppm to 50 ppm with the specific range determined by the high-level span calibration gas of 44.93 ppm.

The Model 42iQSL High Level is based on the principle that nitric oxide (NO) and ozone (O<sub>3</sub>) react to produce a characteristic luminescence with an intensity linearly proportional to the NO concentration. Infrared light emission results when electronically excited nitrogen dioxide (NO<sub>2</sub>) molecules decay to lower energy states. Specifically,

 $NO_2$  must first be transformed into NO before it can be measured using the chemiluminescent reaction.  $NO_2$  is converted to NO by a molybdenum  $NO_2$ -to-NO converter heated to about 337°C. The flue gas air sample is drawn into the Model 42iQSL High Level through the sample bulkhead. The sample flows through a particulate filter, a capillary, and then to the mode solenoid valve. The solenoid valve routes the sample either straight to the reaction chamber (NO mode) or through the  $NO_2$ -to-NO converter and then to the reaction chamber (NOx mode).

Dry air enters the Model 42iQSL High Level through the dry air bulkhead, through a flow sensor, and then through a silent discharge ozonator. The ozonator generates the necessary ozone concentration needed for the chemiluminescent reaction. The ozone reacts with the NO in the ambient air sample to produce electronically excited NO<sub>2</sub> molecules. A photomultiplier tube (PMT) housed in a thermoelectric cooler detects the NO<sub>2</sub> luminescence.

The NO and  $NO_X$  concentrations calculated in the NO and  $NO_X$  modes are stored in memory. The difference between the concentrations is used to calculate the  $NO_2$  concentration. The Model 42iQSL High Level outputs NO,  $NO_2$ , and  $NO_X$  concentrations to both the front panel display and the analog outputs.

Stack gas was delivered to the analyzer via a Teflon® sampling line, heated to a minimum temperature of 250°F. Excess moisture in the Stack gas was removed using a refrigerated condenser. The entire system was calibrated in accordance with the Method, using USEPA Protocol gases introduced at the probe, before and after each test run. This testing met the performance specifications as outlined in the Method.

A list of calibration gases used and the results of all calibration and other required quality assurance checks are found in Appendix H. Copies of the gas cylinder certifications are found in Appendix I. The  $NO_2$  to NO converter test can be found in Appendix J. This testing met the performance specifications as outlined in the Method.

# 3.0 TEST RESULT SUMMARIES

Client: Lansing Board of Water and Light

Location: EUCTGSC1

Facility: Delta Energy Park

Date: 2/6/24

Project #: M233603

Test Method: 7E, 3A

Fuel Type: Natural Gas

Fuel Factor: 8710

### O2 based NOx lb/mmBtu RATA

**CEM Analyzer Information** 

			C	EM Analyzer	intormation				
NO	NO <sub>x</sub> Monitor/Model: Thermo Scientific 42iQLS					NOx Serial #:	12218718717		
0:	2 Moni	tor/Model:	Thermo Scie	ntific 42iQLS		O2 Serial #:	1#: 1221871871		
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM NO <sub>x</sub> Ib/MMBtu	CEM NO <sub>x</sub> Ib/MMBtu	(RM-CEM) Difference (di)	(RM-CEM) Difference <sup>2</sup> (di <sup>2</sup> )	
1	1	02/06/24	09:44	10:04	0.070	0.068	0.002	0.000004	
1	2	02/06/24	10:16	10:36	0.070	0.068	0.002	0.000004	
1	3	02/06/24	10:52	11:12	0.069	0.068	0.001	0.000001	
1	4	02/06/24	11:29	11:49	0.071	0.069	0.002	0.000004	
1	5	02/06/24	12:05	12:25	0.070	0.069	0.001	0.000001	
1	6	02/06/24	12:46	13:06	0.071	0.069	0.002	0.000004	
1	7	02/06/24	13:25	13:45	0.070	0.068	0.002	0.000004	
1	8	02/06/24	14:11	14:31	0.069	0.067	0.002	0.000004	
1	9	02/06/24	14:46	15:06	0.069	0.067	0.002	0.000004	
0	10	02/06/24	15:21	15:41	0.068	0.066	0.002	0.000004	
				n		9			
				t(0.025)	2.3	306			
		Mean	Reference M	lethod Value	0.	070	RM avg		
			Mea	n CEM Value	0.068		CEM avg		
				f Differences	0.016		di		
			CAPACIO CONTRACTOR CON	n Difference	0.002		d		
		Su	m of Differen	ces Squared	0.000		di <sup>2</sup>		
			Standa	rd Deviation	0.000		sd		
	Con	fidence Co	efficient 2.5%	Error (1-tail)	0.000		СС		
			Relat	ive Accuracy	3.03 RA		RA		
			Bias Adjus	tment Factor	1.	026	BAF		

Client: Lansing Board of Water and Light

Location: EUCTGSC1

Facility: Delta Energy Park Project #: M233603

Date: 2/6/24

Test Method: 3A

### O<sub>2</sub> % (dry) RATA **CEM** Analyzer Information

02	Monit	or/Model:	Thermo Scie	entific 42iQLS		O2 Serial # :	12218718717	
1=accept 0=reject	Test Run	Test Date	Start Time	End Time	RM O <sub>2</sub> % (dry)	CEM O <sub>2</sub> % (dry)	(RM-CEM) Difference (di)	(RM-CEM) Difference <sup>2</sup> (di <sup>2</sup> )
1	1	02/06/24	09:44	10:04	13.8	13.9	-0.1	0.01
1	2	02/06/24	10:16	10:36	13.8	13.9	-0.1	0.01
1	3	02/06/24	10:52	11:12	13.8	13.9	-0.1	0.01
1	4	02/06/24	11:29	11:49	13.8	13.9	-0.1	0.01
1	5	02/06/24	12:05	12:25	13.8	13.9	-0.1	0.01
1	6	02/06/24	12:46	13:06	13.7	13.8	-0.1	0.01
1	7	02/06/24	13:25	13:45	13.8	13.8	0.0	0.00
0	8	02/06/24	14:11	14:31	13.7	13.9	-0.2	0.04
1	9	02/06/24	14:46	15:06	13.8	13.9	-0.1	0.01
1	10	02/06/24	15:21	15:41	13.8	13.9	-0.1	0.01
				n		9		
		B = 74 = 40000		t(0.025)		306		
		Mean		lethod Value	13.789		RM avg	
Mean CEM Value					13.878		CEM avg	
Sum of Differences					-0.800		di	
Mean Difference					-0.089		d	
Sum of Differences Squared					0.080		di <sup>2</sup>	
			No. of Contract of	ard Deviation	0.033		sd	
	Conf	idence Co	efficient 2.5%	6 Error (1-tail)	0.026		cc	
			Relat	ive Accuracy	0.83 RA		RA	

## 4.0 CERTIFICATION

Mostardi Platt is pleased to have been of service to Lansing Board of Water and Light. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

As the program manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results. The test program was performed in accordance with the test protocol, test methods, the Mostardi Platt Quality Manual, and the ASTM D7036-12, as applicable.

MOSTARDI PLATT

Timothy E Yanowsky

cotter Barrer

Program Manager

Scott W. Banach

Quality Assurance

# **APPENDICES**

## Appendix A - Company AETB Certification



March 23, 2012

Effective immediately, Mostardi Platt self-certifies that all Part 75 test projects conform to the ASTM D 7036-04 Standard Practice. The following contact information is provided as required by the Standard:

Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126

630-993-2100

#### tplatt@mp-mail.com

Also, attached is a list of each Qualified Individual (QI) with the type of exam (e.g., Group I, II, III IV and/or V), the date the exam was taken and the name and email address of the exam provider.

Should you have any questions or need additional information, please contact Thomas Platt, P.E. at 630-993-2683.

Approved:

By:

Robert J. Platt Chief Executive Officer

#### **QSTI AETB Import Data**

QI Last Name [REQUIRED]	QI First Name [REQUIRED]	QI Middle Initial	AETB Name [REQUIRED]	AETB Phone Number [REQUIRED]	AETB Email [REQUIRED]	Exam Date mm/dd/yyyy [REQUIRED]	Exam Provider Name [REQUIRED]	Exam Provider Email [REQUIRED]	Comment
eckham	Kenneth	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	5/18/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
enninghoff	Aaron	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	9/8/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
lurton	Stuart	L	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
arlisle	Robert	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/8/2021	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
colangelo	Nicholas	C	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/1/2019	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
oleman	Paul	F	Mostard Platt	630-993-2100	tplatt@mp-mail.com	3/22/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
rivlare	Jeffrey	M	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
rooks	Nate	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	11/9/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
unn	Christian	P	Mostard Platt	630-993-2100	tplatt@mp-mail.com	10/27/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ldridge	Christopher	S	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/18/2021	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
iross	Jeffrey	M	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/19/2024	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
lendricks	Benjamin	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/30/2020	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
lowe	Jacob	W	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/17/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ensen	Christopher	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ones	Kyle	L	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/11/2021	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ossack	Daniel	J	Mostard Platt	630-993-2100	tplatt@mp-mail.com	11/11/2021	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
ukla	Joshua	R	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/4/2019	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ipinski	Michal		Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/31/2020	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
anek	Damian	P	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/19/2021	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
eterson	Mark	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/17/2023	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
etrovich	William	A	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/4/2022	Source Evaluation Society	gstiprogram@gmail.com	Group V (Part 75)
uss	Timothy	E	Mostard Platt	630-993-2100	tplatt@mp-mail.com	4/8/2020	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ands	Stuart	T	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/5/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ather	Michael	P	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/7/2020	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
imon	Ryan	K	Mostard Platt	630-993-2100	tplatt@mp-mail.com	1/19/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
ollars	Richard	1	Mostard Platt	630-993-2100	tplatt@mp-mail.com	7/28/2023	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
orce	Angelo	M	Mostard Platt	630-993-2100	tplatt@mp-mail.com	2/18/2022	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)
rezak	Christopher	S	Mostard Platt	630-993-2100	tplatt@mp-mail.com	4/14/2020	Source Evaluation Society	qstiprogram@gmail.com	Group V (Part 75)

# Appendix B - QI Certification(s) for Field Personnel



# Qualified Individual Jeffrey M. Gross

Has satisfactorily completed the requirements of

**ASTM D 7036 - 04, Section 8.3** 

# Standard Practice for Competence of Air Emission Testing Bodies

Examinations provided by Source Evaluation Society: www.sesnews.org, (919) 544-6338

All Part 75 test methods, under my supervision, shall conform to the company's Quality Manual and to this practice, in all respects.


Passed Group V on 1/19/2024

Expiration Date: Group V on 1/19/2029

Signature:	Wyly How	Date:
Quality Manag	ger: Scotter Barrer	Technical Director: Bayesian W #

## Appendix C - Test Section Diagram

### **GASEOUS TRAVERSE FOR ROUND DUCTS**



Job: Lansing Board of Water and Light

Delta Energy Park Facility

Lansing, Michigan

Date: February 6, 2024

Test Location: EUCTGSC1 Bypass Stack


Stack Diameter: 11.901 Feet

Stack Area: 111.24 Square Feet

No. Sample Points: 3

## Appendix D - Sample Train Diagram

# USEPA Methods 3A and 7E Extractive Gaseous Sampling Diagram



ATD-010 Extractive 3A and 7E

Rev. 1.3

1/1/2021