


RECEIVED

NOV 29 2017

AIR QUALITY DIVISION

**Mercury Low Emitting
Electrical Generating Unit
Demonstration Test Report**

We Energies
Presque Isle Power Plant
TOXECON Outlet Duct
Marquette, Michigan
Project No. M172202P Rev. 1
July 21 through September 1, 2017

mostardi  **platt**



**Mercury Low Emitting Electrical Generating Unit
Demonstration Test Report**

**We Energies
Presque Isle Power Plant
TOXECON Outlet Duct
Marquette, Michigan
July 21 through September 1, 2017**

**Report Resubmittal Date
November 15, 2017**

© Copyright 2017
All rights reserved in
Mostardi Platt

Project No. M172202P Rev. 1

1000 So. Grand Ave. Suite 100
Marquette, Michigan 49855
630-333-1352

1.0 EXECUTIVE SUMMARY

MOSTARDI PLATT conducted a mercury (Hg) low emitting electrical generating unit (LEE) test program for We Energies at the Presque Isle Power Plant in Marquette, Michigan. This report summarizes the results of the test program and test methods used.

The test location, test dates, and test parameter are summarized below.

TEST INFORMATION		
Test Location	Test Dates	Test Parameter
TOXECON Outlet Duct	July 21 through September 1, 2017	Mercury (Hg)

The purpose of this test program was to demonstrate the LEE status per 40CFR63, UUUUU (Utility MATS Rule) Section 63.10005 (h)(1)(ii)(A or B) of the TOXECON Outlet Duct. The test consisted of nine paired Method 30B Hg sampling runs. Each trap pair was sampled for a time frame of between 69-124 total hours. Note that due to the size of each trap set data file, the files are only included in the electronic copy of this test report. The hard copy report includes a separate CD which contains the minute data for each trap set. A standard F_c factor of 1,840 scf/mmBtu for sub-bituminous coal was utilized to calculate emissions on a lb/TBtu basis. Carbon dioxide (CO₂) data was taken from CEM hourly data and corrected from a wet basis to dry basis utilizing a default value factor of 8%. The % CO₂ for each run was then determined based on the weighted average using each units load. Pounds per year emissions were calculated using the average lb/Tbtu emissions, the maximum potential heat input and 8,760 hrs/yr of operation. Selected results of the test program are summarized below.

Parameter	Dates	Lee Demonstration	LEE Demonstration Requirement	Pass/Fail
Hg	7/21/17-9/01/17	1.167 lb/TBtu and 31.0 lb/yr maximum potential to emit	≤ 1.200 lb/TBtu and 87.0 lbs/yr	Pass

The test results from this test program indicate that the Presque Isle Power Plant TOXECON Outlet Duct demonstrated the level to achieve Hg LEE status per 40CFR63, UUUUU Section 63.10005 (h)(1)(ii)(B).

The identifications of individuals associated with the test program are summarized below.

TEST PERSONNEL INFORMATION		
Location	Address	Contact
Test Coordinator	We Energies 333 West Everett Street Environmental Department A231 Milwaukee, Wisconsin 53203	Mr. Rob Bregger (414) 221-2772 (phone) rob.bregger@we-energies.com
Test Facility	We Energies Presque Isle Power Plant 2701 Lakeshore Boulevard, North Marquette, Michigan 49885	Ms. Amanda Studinger (906) 226-5704 (phone) amanda.studinger@we-energies.com
Testing Company Representative	Mostardi Platt 888 Industrial Drive Elmhurst, Illinois 60126	Mr. Pat Lyons Project Manager (630) 993-2100 (phone) plyons@mp-mail.com

2.0 TEST METHODOLOGY

Emission testing was conducted following the methods specified in 40 CFR, Part 60, Appendices A and B, USEPA Method 30B. A drawing depicting the sampling port and test point location is found in Appendix A of this test report, drawings depicting the sampling train is found in Appendix B of this test report, calculation and nomenclature explanations are found in Appendix C of this test report, sample analysis data are found in Appendix D of this test report, mercury sampling QA/QC data are found in Appendix E of this test report, reference method test data are found in Appendix F of this test report, CEMs data are found in Appendix G of this test report, and field data sheets are found in Appendix H of this test report.

The following methodology was used during the test program:

Mercury Determination by Method 30B (Sorbent Trap Method)

Paired trains were utilized sampling one test point at the centroid of the TOXECON Outlet Duct test location.

Per Method 30B sampling, each sample was collected on the paired in-situ sorbent traps. A tube of silica was used to capture remaining moisture prior to the sample reaching the gas metering system. Expected concentrations for the test runs were calculated based on previous Method 30B test data to total approximately between 1000 ng and 1500 ng of Hg collected on each trap during sampling.

The sample train used for this test program was designed by APEX, Inc. and meets all requirements for Method 30B sampling. Each sample was extracted at one sample point, within 10% of the centroid of the stack.

Runs 6 and 7 which were performed from August 11 through August 24 did not meet the QA requirements of Method 30B due to a low spike recoveries. These runs are not included in the test data averages.

The mercury traps were analyzed onsite and offsite utilizing an Ohio Lumex analyzer. A complete summary of emission test results follows the narrative portion of this report.

3.0 TEST RESULTS SUMMARY

Method 30B (Sorbent Trap) Mercury Test Results Summary

We Energies

Presque Isle Power Plant

TOXECON

Test No.	Total Hours Sampled	Operating Days	Start Date	Start Time	End Date	End Time	V _m (standard L)	ng detected	ppb	ug/dscm	ug/wscm	lb/Tbtu (Fc Factor)	
1A	97	4	7/21/2017	6:36	7/25/2017	7:26	1,438.944	1,571.2	0.131	1.092	1.005	0.984	
1B							1,428.944	1,453.4	0.122	1.017	0.936	0.916	
Average								1,512.3	0.126	1.055	0.970	0.950	
2A	69	3	7/25/2017	7:59	7/28/2017	5:18	1,025.413	1,131.2	0.132	1.103	1.015	0.946	
2B							1,026.189	1,006.4	0.118	0.981	0.902	0.841	
Average								1,068.8	0.125	1.042	0.959	0.894	
3A	124	5	7/28/2017	5:35	8/2/2017	9:31	1,838.511	2,833.1	0.185	1.541	1.418	1.365	
3B							1,842.299	2,863.3	0.186	1.554	1.430	1.377	
Average								2,848.2	0.186	1.548	1.424	1.371	
4A	120	5	8/2/2017	10:00	8/7/2017	9:59	1,754.462	2,158.1	0.147	1.230	1.132	1.065	
4B							1,759.769	2,265.7	0.156	1.299	1.195	1.124	
Average								2,221.9	0.152	1.264	1.163	1.094	
5A	94	5	8/7/2017	6:38	8/11/2017	6:40	1,320.091	1,712.8	0.156	1.297	1.194	1.121	
5B							1,308.940	1,561.6	0.143	1.193	1.098	1.031	
Average								1,637.2	0.149	1.245	1.146	1.076	
8A	90	4	8/24/2017	14:08	8/28/2017	8:44	1,473.765	2,292.5	0.186	1.556	1.431	1.359	
8B							1,443.373	2,251.0	0.187	1.560	1.435	1.362	
Average								2,271.8	0.187	1.558	1.433	1.360	
9A	95	5	8/28/2017	9:17	9/1/2017	8:42	1535.788	2,379.2	0.186	1.549	1.425	1.342	
9B							1519.887	2,279.4	0.180	1.500	1.380	1.299	
Average								2,329.3	0.183	1.524	1.402	1.320	
Total Times	689	31	Overall Total Weighted Average										1.167

Maximum Potential to Emit

$$1.167 \text{ lb/Tbtu} * 3 \text{ Units} * \frac{1010 \text{ mmBtu/hr (Maximum Rated Heat Input)}}{1,000,000 \text{ mmBtu/Tbtu}} * 8760 \text{ hr/yr} = 31.0 \text{ lbs/yr}$$

4.0 CERTIFICATION

MOSTARDI PLATT is pleased to have been of service to We Energies. If you have any questions regarding this test report, please do not hesitate to contact us at 630-993-2100.

CERTIFICATION

As project manager, I hereby certify that this test report represents a true and accurate summary of emissions test results and the methodologies employed to obtain those results, and the test program was performed in accordance with the methods specified in this test report.

MOSTARDI PLATT



Pat Lyons

Program Manager



Scott W. Banach

Quality Assurance