


DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Zoetis LLC	SRN : B4288
Location : 333 Portage Street	District : Kalamazoo
	County : KALAMAZOO
City : KALAMAZOO State: MI Zip Code : 49007	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Monica Brothers
FCE Begin Date : 6/1/2020	FCE Completion Date : 6/3/2021
Comments : Facility seemed to be in compliance at the time of inspection.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/03/2021	On-site Inspection	Compliance	Announced, Scheduled, On-site Inspection
02/24/2021	Stack Test	Compliance	Report of visual emissions test (Method 9) for Boiler 5 while operating on fuel oil. All opacity readings were 0% opacity. Test was done in accordance with 40 CFR 60.47c(a).
01/25/2021	NSPS (Part 60)	Compliance	Six month report for EUB214BOILER5. They report no excess emissions and no noncompliance events during the reporting period.
07/30/2020	NSPS (Part 60)	Compliance	Six month report for EUB214BOILER5. They report no excess emissions and no noncompliance events during the reporting period.

Name:  Date: 8/24/21 Supervisor: RIL 8/30/21