



**AIR EMISSION TEST REPORT**

Title AIR EMISSION TEST REPORT FOR THE  
VERIFICATION OF NITROGEN OXIDE EMISSIONS  
FROM A NATURAL GAS FUELED TURBINE

Report Date June 13, 2017

Test Date May 3, 2017

**RECEIVED**

JUN 15 2017

**AIR QUALITY DIV.**

| <b>Facility Information</b> |   |
|-----------------------------|---|
| Name                        | Merit Energy Company – Kalkaska Gas Plant |
| Street Address              | 1080 Prough Road SW                       |
| City, County                | Kalkaska, Kalkaska                        |
| SRN                         | B4292                                     |

| <b>Facility Permit Information</b> |                   |
|------------------------------------|-------------------|
| Permit No.:                        | MI-ROP-B4292-2014 |
| Emission Unit:                     | EU-KGPN-TURB-C    |

| <b>Testing Contractor</b> |   |
|---------------------------|---|
| Company                   | Derenzo Environmental Services              |
| Mailing Address           | 39395 Schoolcraft Road<br>Livonia, MI 48150 |
| Phone                     | (734) 464-3880                              |
| Project No.               | 1701080                                     |

AIR EMISSION TEST REPORT  
FOR THE  
VERIFICATION OF NITROGEN OXIDE EMISSIONS  
FROM A  
NATURAL GAS FUELED TURBINE  
  
MERIT ENERGY – KALKASKA GAS PLANT

## **1.0 INTRODUCTION**

Merit Energy (Merit) owns and operates a natural gas fired turbine and waste heat recovery unit (WHRU) at the Kalkaska Gas Plant in Kalkaska, Kalkaska County, Michigan (Facility SRN: B4292). The natural gas fired turbine and associated WHRU are identified as emission unit EU-KGPN-TURB-C in Renewable Operating Permit (ROP) No. MI-ROP-B4292-2014 issued by the Michigan Department of Environmental Quality (MDEQ). The turbine is also regulated under 40 CFR Part 60, Subpart KKKK, the New Source Performance Standards (NSPS) for Stationary Combustion Turbines.

The conditions of MI-ROP-B4292-2014 specify that:

1. Annual performance tests shall be conducted to demonstrate compliance with nitrogen oxides (NO<sub>x</sub>) emissions of 1.2 lb/MW-hr.
2. The NO<sub>x</sub> testing frequency can be reduced to once every two years if the emission test results are less than or equal to 0.9 lb/MW-hr.

The conditions of 40 CFR Subpart KKKK specify that:

1. For new turbines fired by natural gas with peak heat input rate > 55 million British Thermal Units per hour (MMBtu/hr) and < 850 MMbtu/hr, NO<sub>x</sub> emission standards are 15 ppm at 15% O<sub>2</sub> or 1.2 lb/MW-hr
2. The testing must be performed at any load condition within plus or minus 25 percent of 100 percent of peak load. The testing may be performed at the highest achievable load point, if at least 75 percent of peak load cannot be achieved in practice.

This test report presents the results of emission testing performed by Derenzo Environmental Services (DES) on May 3, 2017. DES representatives Jason Logan and Clay Gaffey performed the field sampling and measurements. Mr. Jeremy Howe of the MDEQ Technical Programs Unit observed portions of the testing project.

**Derenzo Environmental Services**

Merit Energy – Kalkaska Gas Plant  
Air Emission Test Report

June 13, 2017  
Page 2

Questions regarding this emission test report should be directed to:

Jason Logan  
Project Manager  
Derenzo Environmental Services  
39395 Schoolcraft Road  
Livonia, MI 48150  
Ph: (734) 464-3880  
Em: jlogan@derenzo.com

Mr. Sean Craven  
Project Manager  
Merit Energy Company  
1510 East Thomas Road  
Kalkaska, MI 49646  
Ph: (231) 258-6369  
Em: sean.craven@meritenergy.com


**Report Certification**

This test report was prepared by Derenzo Environmental Services based on field sampling data collected by DES personnel. Facility process data were collected and provided by Merit Energy employees or representatives. This test report has been reviewed by Merit Energy representatives and approved for submittal to the MDEQ. A signed ROP report certification (EQP 5736) accompanies this report.

I certify that the testing was conducted in accordance with the specified test methods and submitted test plan unless otherwise specified in this report. I believe the information provided in this report and its attachments are true, accurate, and complete.


Report Prepared By:

Reviewed by:



---

Jason Logan  
Project Manager  
Derenzo Environmental Services



---

Robert L. Harvey, P.E.  
General Manager  
Derenzo Environmental Services

## **2.0 SOURCE AND SAMPLING LOCATION DESCRIPTION**

### **2.1 General Process Description**

Merit operates a gas-fired turbine (EU-KGPN-TURB-C) at the Kalkaska Gas Plant in Kalkaska, Michigan that is fueled exclusively with natural gas. The turbine is used to produce electricity that is used on-site and exported to the power grid. In addition, a natural gas-fired duct burner is used with the WHRU to heat thermal oil for other processes at the facility.

The operating parameters (i.e., turbine load and natural gas use rate) are synchronized with the Great Lakes Power Grid. The turbine control system automatically adjusts power output depending on the needs of the power grid. The WHRU operates as necessary when there is a demand for heated oil in the facility.

### **2.2 Rated Capacities and Air Emission Controls**

The natural gas fueled turbine has a rated heat input of 60.2 MMBtu/hr and the duct burner associated with the WHRU has a rated heat input rate of 28.0 MMBtu/hr. The turbine is equipped with dry low NO<sub>x</sub> combustors that are designed to pre-mix the fuel and combustion air at a controlled ratio that minimizes combustor temperature and NO<sub>x</sub> formation. The exhaust gas is used to heat oil in the WHRU and is released to atmosphere without additional add-on emission controls.

### **2.3 Sampling Locations**

The turbine exhaust gas is released to the atmosphere through a dedicated vertical exhaust stack.

The exhaust stack has an inner diameter of 45 inches and is equipped with two (2) sample ports, opposed 90°, that provide a sampling location 48 inches (~1 duct diameters) upstream and 180 inches (4 duct diameters) downstream from any flow disturbance. This satisfies the USEPA Method 1 criteria for a representative sample location.

Appendix A provides diagrams of the emission test sampling location.

**3.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS**

**3.1 Purpose and Objective of the Tests**

The conditions of Renewable Operating Permit (ROP) No. MI-ROP-B4292-2014 and 40 CFR Part 60 Subpart KKKK require Merit to test nitrogen oxides (NOx) emissions from EU-KGPN-TURB-C annually, or bi-annually, depending on the results of the previous stack test event.

**3.2 Operating Conditions During the Compliance Tests**

The testing was performed while the turbine was operated at maximum achievable operating conditions. Merit representatives provided generator output data (MW) in 15-minute intervals for each test period. The turbine generator output ranged between 4.26 and 4.46 MW for each test period.

Fuel feed rate (cubic feet per minute) was recorded by Merit representatives in 15-minute intervals for each test period. The average fuel consumption rate of the turbine ranged between 891 and 921 scfm. The average fuel consumption rate of the WHRU ranged between 124 and 357 scfm.

Appendix B provides operating records provided by Merit representatives for the test periods.

**3.3 Summary of Air Pollutant Sampling Results**

The gas exhausted from the natural gas fueled turbine (EU-KGPN-TURB-C) was sampled for three (3) one-hour test periods during the compliance testing performed May 3, 2017.

Table 3.1 presents a summary of the average turbine emissions and operating conditions during the test periods. Test results for each one hour sampling period are presented in Table 6.1 of this report.

Table 3.1 Average turbine emissions and operating conditions during the test periods

| Turbine Parameter            | EU-KBPN-TURB-C |
|------------------------------|----------------|
| Generator output (MW)        | 4.36           |
| Turbine fuel use (scfm)      | 903            |
| WHRU fuel use (scfm)         | 226            |
| Exhaust Flowrate (scfm)      | 31,719         |
| NOx Emission Rate (lb/MW-hr) | 0.45           |

#### **4.0 SAMPLING AND ANALYTICAL PROCEDURES**

A test protocol for the air emission testing was reviewed and approved by the MDEQ. This section provides a summary of the sampling and analytical procedures that were used during the testing periods.

##### **4.1 Summary of Sampling Methods**

|                  |  |
|------------------|--|
| USEPA Method 1   | Exhaust gas velocity measurement locations were determined based on the physical stack arrangement and requirements in USEPA Method 1  |
| USEPA Method 2   | Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube. |
| USEPA Method 3A  | Exhaust gas O <sub>2</sub> and CO <sub>2</sub> content was determined using zirconia ion/paramagnetic and infrared instrumental analyzers, respectively.   |
| USEPA Method 4   | Exhaust gas moisture was determined based on the water weight gain in chilled impingers.   |
| USEPA Method 7E  | Exhaust gas NO <sub>x</sub> concentration was determined using chemiluminescence instrumental analyzer.  |
| USEPA Method 205 | Verification of Dilution Systems for Field Instrument Calibrations   |

##### **4.2 Exhaust Gas Velocity Determination (USEPA Method 2)**

The turbine exhaust stack gas velocity and volumetric flowrate was determined using USEPA Method 2 prior to and after each test. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube.

Appendix C provides exhaust gas flowrate calculations and field data sheets.

##### **4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)**

CO<sub>2</sub> and O<sub>2</sub> content in the turbine exhaust gas stream was measured continuously throughout each test period in accordance with USEPA Method 3A. The CO<sub>2</sub> content of the exhaust was monitored using a single beam single wavelength (SBSW) infrared gas analyzer. The O<sub>2</sub> content of the exhaust was monitored using a gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the turbine exhaust gas stream was extracted from the stack using a stainless steel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O<sub>2</sub> and CO<sub>2</sub> concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

Appendix D provides O<sub>2</sub> and CO<sub>2</sub> calculation sheets. Raw instrument response data are provided in Appendix E.

#### **4.4 Exhaust Gas Moisture Content (USEPA Method 4)**

Moisture content of the turbine exhaust gas was determined in accordance with USEPA Method 4 using a chilled impinger sampling train. The moisture sampling was performed concurrently with the instrumental analyzer sampling. During each sampling period a gas sample was extracted at a constant rate from the source where moisture was removed from the sampled gas stream using impingers that were submersed in an ice bath. At the conclusion of each sampling period, the moisture gain in the impingers was determined gravimetrically by weighing each impinger to determine net weight gain.

#### **4.5 NO<sub>x</sub> Concentration Measurements (USEPA Method 7E)**

NO<sub>x</sub> pollutant concentrations in the turbine exhaust gas streams were determined using a Thermo Environmental Instruments, Inc. (TEI) Model 42c High Level chemiluminescence NO<sub>x</sub> analyzer.

Throughout each test period, a continuous sample of the turbine exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816 data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix D provides NO<sub>x</sub> calculation sheets. Raw instrument response data are provided in Appendix E.

## **5.0 QA/QC ACTIVITIES**

### **5.1 Exhaust Gas Flow**

Prior to arriving onsite, the instruments used during the source test to measure exhaust gas properties and velocity (barometer, pyrometer, and Pitot tube) were calibrated to specifications outlined in the sampling methods.

The Pitot tube and connective tubing were leak-checked prior to each traverse to verify the integrity of the measurement system.

The absence of significant cyclonic flow for the exhaust configurations were verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

### **5.2 NO<sub>x</sub> Converter Efficiency Test**

The NO<sub>2</sub> – NO conversion efficiency of the chemiluminescence NO<sub>x</sub> analyzer was verified prior to the testing program. A USEPA Protocol 1 certified concentration of NO<sub>2</sub> was injected directly into the analyzer, following the initial three-point calibration, to verify the analyzer's conversion efficiency. The analyzer's NO<sub>2</sub> – NO converter uses a catalyst at high temperatures to convert the NO<sub>2</sub> to NO for measurement. The conversion efficiency of the analyzer is deemed acceptable if the measured NO<sub>x</sub> concentration is at least 90% of the expected value.

The NO<sub>2</sub> – NO conversion efficiency test satisfied the USEPA Method 7E criteria (measured NO<sub>x</sub> concentration was 98% of the expected value, i.e., greater than 90% of the expected value as required by Method 7E).

### **5.3 Gas Divider Certification (USEPA Method 205)**

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (within the last 12 months) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivers calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.



#### **5.4 Instrumental Analyzer Interference Check**

The instrumental analyzers used to measure NO<sub>x</sub>, O<sub>2</sub> and CO<sub>2</sub> have had an interference response test performed prior to their use in the field, pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 2.5% of the span for all measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

#### **5.5 Instrument Calibration and System Bias Checks**

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the NO<sub>x</sub>, CO<sub>2</sub> and O<sub>2</sub> analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the stainless steel sampling probe prior to the particulate filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO<sub>2</sub>, O<sub>2</sub>, and NO<sub>x</sub> in nitrogen and zeroed using hydrocarbon free nitrogen. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

#### **5.6 Determination of Exhaust Gas Stratification**

A stratification test was performed for the turbine exhaust stack. The stainless steel sample probe was positioned at twelve (12) sample point across the stack diameter. Pollutant concentration data were recorded at each sample point for a minimum of twice the maximum system response time.

The recorded concentration data for the turbine exhaust stack indicated that the measured NO<sub>x</sub> concentrations were stratified (i.e. varied by more than 10% of the mean). Therefore, the sampling for each one-hour test period was performed at 12 points and each point was sampled for an equal amount of time (i.e. 5 minutes per point).

#### **5.7 Meter Box Calibrations**

The dry gas metering console, which was used for exhaust gas moisture content sampling, was calibrated prior to and after the testing program. This calibration uses the critical orifice calibration technique presented in USEPA Method 5. The metering console calibration exhibited no data outside the acceptable ranges presented in USEPA Method 5.

The digital pyrometer in the metering console was calibrated using a NIST traceable Omega® Model CL 23A temperature calibrator.

Appendix F presents test equipment quality assurance data for the emission test equipment (NO<sub>2</sub> – NO conversion efficiency test data, instrument calibration and system bias check records, calibration gas and gas divider certifications, interference test results, meter box calibration records, Pitot tube calibration records).

## **6.0 RESULTS**

### **6.1 Test Results and Allowable Emission Limits**

Turbine operating data and air pollutant emission measurement results for each one-hour test period are presented in Table 6.1.

The tests were performed with the gas fired turbine operating at approximately 81.6% load. The measured NO<sub>x</sub> emission rate for EU-KGPN-TURB-C is less than 1.2 lb/MW-hr as required by the Renewable Operating Permit (ROP) No. MI-ROP-B4292-2014 and 40 CFR Part 60 Subpart KKKK.

Based on these test results, the measured emission rate is less than 0.9 lb/MW-hr and the required testing frequency remains once every two years.

### **6.2 Variations from Normal Sampling Procedures or Operating Conditions**

The testing for all pollutants was performed in accordance with the associated test methods and approved test protocol. The turbine was operated maximum achievable operating conditions and no variations from the normal operating conditions occurred during the test periods.

During Test 2 the sample probe fell out of the turbine exhaust stack. Testing was paused at 10:50 and resumed at 10:56 once the issue was corrected and a representative exhaust gas sample was reestablished.

**Derenzo Environmental Services**Merit Energy – Kalkaska Gas Plant  
Air Emission Test ReportJune 13, 2017  
Page 10Table 6.1 Summary of EU-KGPN-TURB-C Test Results  
Merit Energy – Kalkaska Gas Plant, Kalkaska, Kalkaska County, Michigan

| Test No.  | 1         | 2            | 3           | Test        |
|---|-----------|--------------|-------------|-------------|
| Test Date   | 5/3/17    | 5/3/17       | 5/3/17      | Avg.        |
| Test Period (24-hr clock)                             | 8:35-9:35 | 10:00-11:06* | 11:25-12:25 |             |
| Turbine Output (MW)                                   | 4.40      | 4.37         | 4.31        | 4.36        |
| Turbine Fuel Consumption (scfm)                       | 910       | 901          | 897         | 903         |
| WHRU Fuel Consumption (scfm)                          | 243       | 228          | 208         | 226         |
| <b>Exhaust gas composition</b>                        |           |              |             |             |
| CO <sub>2</sub> content (% vol)                       | 3.87      | 3.66         | 3.67        | 3.73        |
| O <sub>2</sub> content (% vol)                        | 14.4      | 14.8         | 14.8        | 14.64       |
| Moisture (% vol)                                      | 7.5       | 7.3          | 7.2         | 7.3         |
| <b>Exhaust gas flowrate</b>                           |           |              |             |             |
| Standard conditions (scfm)                            | 31,120    | 32,275       | 31,761      | 31,719      |
| Dry basis (dscfm)                                     | 28,770    | 29,930       | 29,485      | 29,395      |
| <b>Nitrogen oxides emission rates</b>                 |           |              |             |             |
| NO <sub>x</sub> conc. (ppmvd)                         | 10.2      | 8.82         | 9.10        | 9.36        |
| NO <sub>x</sub> emissions (lb/hr NO <sub>2</sub> )    | 2.10      | 1.89         | 1.92        | 1.97        |
| NO <sub>x</sub> emissions (lb/MW-hr NO <sub>2</sub> ) | 0.48      | 0.43         | 0.45        | 0.45        |
| <i>NO<sub>x</sub> permit limit (lb/MW-hr)</i>         |           |              |             | <i>1.20</i> |

---

\*Test paused at 10:50, resumed at 10:56