

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

<b>Facility :</b> CLOVERLAND ELECTRIC COOPERATIVE - DAFTER	<b>SRN :</b> B6107
<b>Location :</b> 2535 W HIGHWAY M-28	<b>District :</b> Upper Peninsula
	<b>County :</b> CHIPPEWA
<b>City :</b> DAFTER <b>State:</b> MI <b>Zip Code :</b> 49724	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> SM OPT OUT	<b>Staff :</b> Ed Lancaster
<b>FCE Begin Date :</b> 10/1/2014	<b>FCE Completion Date :</b> 9/29/2015
<b>Comments :</b> Company appears to be in compliance as of this date after review of company records and inspection.	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
09/22/2015	Scheduled Inspection	Compliance	Conducted schedule, unannounced inspection.
05/18/2015	MAERS	Compliance	Received company's 2014 electronic submittal. No changes made to report.
02/20/2015	Stack Test	Compliance	Purpose of the December 9, 2014 test was to evaluate compliance of two peaker units with the RICE MACT Subpart ZZZZ. EUENGINE-4 passed the CO limit with an average result of 12.0 ppmvd (limit is 23). EUENGINE-5 passed the CO limit with an average result of 5.0 ppmvd.

Name: Ed Lancaster

Date: 9/29/15

Supervisor: \_\_\_\_\_