

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: On-site Inspection

B692373121

FACILITY: Warner Oil Inc. DBA Roost Oil		SRN / ID: B6923
LOCATION: 6651 S EDON RD, READING		DISTRICT: Jackson
CITY: READING		COUNTY: HILLSDALE
CONTACT:		ACTIVITY DATE: 08/07/2024
STAFF: Brian Carley	COMPLIANCE STATUS: Compliance	SOURCE CLASS:
SUBJECT: Unannounced on-site inspection		
RESOLVED COMPLAINTS:		

Facility Contact: Glenn Snyder, Manager
Phone: 517-283-2300
Email: gsnyder@warneroil.com

Facility Owner: Mark Loveberry
Phone: 1-800-622-2137
Email: mloveberry@warneroil.com

Purpose

I arrived at the facility and met with Mr. Snyder. I explained to Mr. Snyder the purpose of my visit is to verify compliance with state and federal rules.

Background

This facility is subject to 40 CFR 63, Subpart CCCCCC for Gasoline Dispensing Facilities. They have 6 tanks total: Two 17,000 gallons, two 15,000 gallons, and two 20,000 gallons. These tanks are exempt from needing an air permit per Rules 284(d) and (g). They sell regular and premium gas, off-road diesel, and on-road diesel.

Compliance Inspection

I ask for how much fuel they have sold for the 2023 calendar year and Mr. Snyder told me that they had sold 117,380.841 gallons of regular gas, 141,166 gallons of premium gas, 297,400.090 gallons of off-road diesel, and 550,747.000 gallons of on-road diesel. Since their average throughput is greater than 10,000 gallons but less than 100,000 gallons per month, they are only required to keep records of gasoline throughput. Per 40 CFR 63.11124 (a)(3), they were not required to submit an Initial Notification or a Notification of Compliance Status.

Compliance Determination

I determined that they are in compliance with the requirements of Subpart CCCCCC and state rules at this time. I thanked him for his time and left.

NAME Brian Carley

DATE 8/15/2024

SUPERVISOR SC