DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility :	ANR Storage Company - Excelsior Compressor Station					SRN :	B7196	
Location :	4936 State Rd	NE					District :	Cadillac
							County :	KALKASKA
City: K	ALKASKA	State:	MI	Zip Code :	49646	Comp Status	liance s :	Compliance
Source Clas	s: MAJOR					Staf	ff: JodiLi	indgren
FCE Begin [Date : 5/1/2021					FCE Date	Completion	7/14/2022
Comments :								

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
07/14/2022	Other	Compliance	Records Review. Facility inspection reported separately
05/10/2022 On-site Inspection		Compliance	Onsite inspection activities for FY 2022 FCE. Data review to be completed and reported independently. sgl
04/04/2022	ROP Other	Compliance	CEDRI REPORTING
03/15/2022	MACT (Part 63)	Compliance	MACT HHH 2021 2nd semi- annual report. The CVS is current with NDE LDAR testing. It was last performed 3/10/2021 and will be valid until 3/9/2026. The CVS had no reports of leaks nor defects with the AVO inspection, no permanent or semi-permanent seals were broken, and the bypass valves remained closed and lock during the reporting period. The last CMS certification was completed on 3/10/2021. During the reporting period, the glycol dehydrator had 131 hrs of operations, no excursions nor excess emissions events occurred, no malfunctions, downtime, nor repairs were reported for any monitoring equipment or process equipment. The 2021 annual and 2nd Semi- annual ROP certification reports and MACT DDDDD report were submitted on the same certification report.

Activity Date	Activity Type	Compliance Status	Comments
03/15/2022	MACT (Part 63)	Compliance	No deviations of MACT DDDDD requirements were reports. The recent tune-up dates were reported as: EUEXHTR-A - 2/3/2021, EUEXHTR-B - 2/3/2021, and EUEXBOILER - 3/3/2021
03/14/2022	ROP Annual Cert	Compliance	MI-ROP-B7196-2017 2021 Annual Certification was submitted timely and properly certified with no deviations reported.
03/14/2022	8/14/2022 ROP SEMI 2 CERT		MI-ROP-B7196-2017 2021 2nd Semi-annual Certification was submitted timely and properly certified with no deviations reported.
03/11/2022	MAERS	Compliance	See MAERS for further Info. ROP Cert Form Received 3-14-22
03/01/2022	ROP R215 Notification	Compliance	Change in RO from Keith Mossman to Eric Hunter
09/15/2021	ROP Semi 1 Cert	Compliance	MI-ROP-B7196-2017 2021 1st Semi-annual Certification submitted timely and properly certified with no deviations reported reporting period (1/1/2021-6/30/2021). The 2021 1st semi-annual MACT report were submitted in the same certification report.
09/15/2021	MACT (Part 63)	Compliance	MACT HHH 2021 1st semi-annual report. The CVS is current with NDE LDAR testing. It was last performed 3/4/2020 and will be valid until 3/3/2025. The CVS had no reports of leaks nor defects with the AVO inspection, no permanent or semi-permanent seals were broken, and the bypass valves remained closed and lock during the reporting period. The last CMS certification was completed on 11/24/2020. During the reporting period, the glycol dehydrator did not operate, no excursions nor excess emissions events occurred, no malfunctions, downtime, nor repairs were reported for any monitoring equipment or process equipment. The 2021 1st Semi- annual ROP certification report was submitted 0n the same certification report.

Name: Cod

Y

Date: