



TRAINING & TECHNICAL SERVICES

5440 Alder Drive
Houston, TX 77081

Phone: 800-836-7333
Fax: 713-664-6444
E-mail: emissions@ceconet.com

Emissions Test Report

One(1) Caterpillar G3516 Spark-Ignited Engine
ID No. EGBLGEN-C (SN# 3RC10643)

Permit Testing

TRANS CANADA CORPORATION – ANR STORAGE COMPANY
BLUE LAKE GAS STORAGE COMPANY
MANCELONA, MI

Permit Number: MI-ROP-B7198-2008
Test Date: August 28, 2013
Test Report Date: September 23, 2013

RECEIVED
OCT 01 2013
AIR QUALITY DIV.

The contents of this document relate only to the items tested. I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

CECO Test Leader:

Brad Jones

Brad Jones
Senior Project Engineer
CECO Training & Technical Services

This report may not be reproduced in full, or in part, without the written approval of TransCanada Corporation.

Table of Contents

Revision History	3
Project Information	3
Contact Information	3
Facility Information	3
Testing Group Information	3
Introduction	4
Process Description.....	4
Test Purpose and Objectives	4
Summary of Results	4
Table 1: Summary of Results: EGBLGEN-C (SN# 3RC10643) Caterpillar G3516.....	4
Methodology and Sampling Procedures	5
Methodology	5
Sampling System.....	5
Figure 1: Sampling System Schematic	6
Instrument Specifications.....	7
Description of Sampling Point.....	9
Appendices.....	10
Appendix A: Emission Calculations	10
Emissions Source Operational Data.....	16
Appendix B: Fuel Calculations	19
Appendix C: Sampling System Calibration Data.....	24
Bias Corrections	27
Appendix D: Reference Method QA/QC	29
Appendix E: Raw Data	34
Appendix F: Calibration Certificates.....	60
Appendix G: Visual Engine Documentation.....	65
Picture of Engine.....	66
Picture of Engine Plate.....	66
Appendix H: Test Personnel Qualifications/Attendees.....	67
Appendix I: Notes	71
Appendix J: Enthalpy Analytical, Inc. Analytical Report (0813-166).....	73

Introduction

CECO Training & Technical Services, a division of Compressor Engineering Corporation, conducted source emissions testing for volatile organic compounds (VOCs) at the TransCanada Corporation, Blue Lake Gas Storage Company on one (1) Caterpillar G3516 natural gas-fired, four stroke, lean burn internal combustion generator engine, rated at 1,125 brake horsepower (BHP). The performance of this test fulfilled the requirements outlined in Permit. This test report details the test purpose, objectives, testing procedures, including sampling and analysis methodology, and test results of the source emissions testing conducted on August 28, 2013.

Process Description

The Caterpillar G3516 reciprocating engine with a catalytic oxidizer is a natural gas-fired, four stroke, lean burn internal combustion engine driving an auxiliary generator for critical facility power.

Test Purpose and Objectives

The purpose of this test was to conduct the required three (3) 60-minute test runs to measure the selected emission species at the maximum achievable load. This test was conducted in fulfillment of Permit. The objective was to determine the emission concentrations of VOCs. TABLE 1 presents the emission units and emission species measured during the testing along with the permitted emissions limits.

Summary of Results

Pollutant	pounds / hour	
	Permitted	Emitted *
VOCs	0.9	ND

* Zero or negative numbers treated as non-detect (ND)

Table 1: Summary of Results: EGBLGEN-C (SN# 3RC10643) Caterpillar G3516




Figure 1: Sampling System Schematic

Sample Flow Rate: 2.5 Liters/Minute
Response Time (90% FSD): < 1.2 seconds
Linearity: Up to 10,000 ppm within 1% FSD

Manufacturer: Vaisala
Model: PTU300
Serial Number: D2120007
Barometric pressure
Pressure range 500 ... 1100 hPa
Accuracy 500 ... 1100 hPa 500
Linearity +/-0.05 hPa
Hysteresis +/-0.03 hPa
Repeatability +/-0.03 hPa
Calibration uncertainty +/-0.07 hPa
Accuracy at +20 deg C +/-0.10 hPa
Temperature Dependence +/-0.1 hPa
Total accuracy (-40 ... +60 deg C/-40 ... +140 deg F) +/-0.15 hPa
Relative humidity
Measurement range 0 ... 100 % RH
Accuracy (including non-linearity, hysteresis and repeatability)
at +15 ... +25 deg C +/-1 %RH (0 ... 90 % RH)
 +/-1.7 %RH (90 ... 100 %RH)
at -20 ... +40 deg C +/--(1.0 + 0.008 x reading) %RH
at -40 ... +60 deg C +/--(1.5 + 0.015 x reading) %RH
Factory calibration uncertainty (+20 deg C)
(Defined as +/-2 std deviation limits. Small variations possible)
 +/- 0.6 % RH (0 ... 40 %RH)
 +/- 1.0 % RH (40 ... 97 %RH)
Sensor: Vaisala HUMICAP(c) 180(R)
Response time (90 %) at +20 deg C (+68 deg F)
Temperature
Measurement range, all probes -40 ... +60 deg C (-40 ... +140 deg F)
Accuracy at +20 deg C (+68 deg F) +/- 0.2 deg C (+/- 0.4 deg F)
Temperature units deg C, deg F
Temperature sensor: PT100 RTD 1/3 Class B IEC 751