

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ANR Pipeline Co. South Chester Compressor Station	SRN : B7219
Location : 6327 Old State Rd.	District : Gaylord
	County : OTSEGO
City : JOHANNESBUR G	State: MI Zip Code : 49751 Compliance Status : Compliance
Source Class : MAJOR	Staff : Gloria Torello
FCE Begin Date : 1/1/2016	FCE Completion Date : 1/12/2017
Comments : FCE 2017	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/03/2017	ROP Semi 1 Cert	Compliance	January-June 2016 Semiannual Cert. During the reporting period all monitoring and associated recordkeeping requirements in the ROP were reported as met with no deviations.
12/22/2016	MACT (Part 63)	Compliance	40 CFR, Part 63, Subpart HHH.
11/10/2016	Scheduled Inspection	Compliance	2017 FCE.
05/31/2016	MAERS	Compliance	2015 MAERS. In Source updated ROP number. FGSCENG, the compressor engines, have a NOx limit of 72.9 pounds per hour (319 tpy). The 2015 MAERS reported source wide NOx emissions of 95.8 tons. The ROP does not have source wide limits.
04/25/2016	MACT (Part 63)	Compliance	Compliance Status Report, 40 CFR, Part 63, Subpart HHH, MI-ROP-B7219-2012a. Report includes: LDAR Assessment Results, and Glycol Dehydration System Condenser Performance Curve.
03/09/2016	ROP SEMI 2 CERT	Compliance	July-December 2015 Semiannual Cert. ROP No. MI-B7219-2012a. Semiannual Report Certification July-December 2015.
03/08/2016	MACT (Part 63)	Compliance	40 CFR Part 63, Subpart DDDDD Notification of Compliance Status

Activity Date	Activity Type	Compliance Status	Comments
03/08/2016	ROP Annual Cert	Compliance	2015 Annual Cert. South Chester Compressor Station, MI-ROP-B7219-2012a. Annual Compliance Certification 2015. Zero deviations reported for the year.
01/19/2016	Other	Compliance	CDX CEDRI Dataflow - Submission Available to View ANR Pipeline South Chester

Name: *Gloria Inella* Date: 3-7-17

Supervisor: *[Signature]*