

ANR Pipeline Company

Emission Performance Test Report Ozone Season Monitoring R336.1818(4)(a)(ii)

ANR Pipeline – Woolfolk Compressor Station (SRN: B7220)

October 11, 2017

Emissions Test Report

Unit EUWL009, One Ingersoll Rand KVG-123 Gas Fired Internal Combustion Reciprocating Engine

Permit No.: MI-ROP-B7220-2017

ANR Pipeline Company Woolfolk Compressor Station Big Rapids, Michigan

Date:

October 11, 2017

Prepared for:

Michigan Department of Environmental

Quality - Air Quality Division

Prepared by:

Roy S. Cannon

Air Compliance Team (832) 320-5465

Ozone Season Monitoring for R336.1818(4)(a)(ii)
Portable Analyzer Monitoring for NOx
ANR – Woolfolk Compressor Station (SRN: B7220)

October 11, 201

1. Introduction

- 1.1. The Air Compliance Team of TransCanada's US Pipelines Central conducted monitoring at ANR Woolfolk Compressor Station (SRN: B7220) pursuant to the Compliance Plan ANR submitted to comply with R336.1818(3)(a). The Compliance Plan has been approved by the MDEQ.
- 1.2. The purpose of the monitoring was to comply with the ozone season monitoring requirement in the ANR Compliance Plan and is in accordance with R336.1818(4)(a)(ii)(A)(2). The monitoring demonstrates compliance with the projected NOx emission rate in the ANR Compliance Plan. As such, the following parameter was determined:
 - 1.2.1. Woolfolk Unit #2009: 20.5 g/bhp-hr of NOx
- 1.3. Facilities Information:

ANR Woolfolk Compressor Station 11750 150th Avenue Big Rapids, MI 49307

Environmental Contact: Chris Waltman 700 Louisiana Street Houston, TX 77002 (715) 758-3341

2. Process Description

2.1. Woolfolk compressor station operates nine NOx SIP affected engines; 2001 through 2005 are Ingersoll-Rand KVG-103, 1,000 HP each and 2006 through 2009 are Ingersoll-Rand KVG-123, 1,320 HP each. All engines are natural gas fired, reciprocating internal combustion engine used in Natural Gas Transmission. More specifically, the engine is used in the compression of natural gas from an initial "suction" pressure to a final "discharge" pressure, which creates the pressure gradient necessary to transport natural gas through ANR Pipeline's interstate pipeline system

3. Methodology

3.1. American Society of Testing and Materials test method D6522-00: Standard Test Method for Determination of Nitrogen Oxides, Carbon Monoxide, and Oxygen Concentrations in Emissions from Natural Gas-Fired Reciprocating Engines, Combustion Turbines, Boilers, and Process Heaters Using Portable Analyzers was employed for determination of comphance with Section 1.2.1.

4. Sample System

4.1. Sample system components, as outlined in Method D6522-00, were utilized for monitoring. These components include, but are not limited to, sample probe, heated sample line, sample transport lines, calibration assembly, moisture removal system, particulate filter, sample pump, sample flow rate control, gas analyzer, data recorder, and external interference gas scrubber.

5. Sample Location

- 5.1. Sampling location was selected as specified in sections 10.1.1 and 10.1.2 of Method D6522-00 at a location of five duct diameters downstream of any flow disturbance and three duct diameters upstream of the discharge to atmosphere.
- 5.2. All the stratification sampling for all the units showed a variance in concentration of less of 5%, therefore, as per section 10.1.4 of Method D6522-00, sampling was taken from a single point located in the center of the stack.

6. Sample Time

- 6.1. Momitoring was conducted during normal engine operation, i.e. not during periods of startul shutdown, or malfunction. Each engine was monitored at the maximum load achievable based upon pipeline and ambient conditions.
- 6.2. Each engine was sampled at three 30-minutes test runs. Samples were taken at a frequency of once per minute.

7. Results

7.1. Results of the monitoring demonstrated that the unit tested below the permitted levels of 20.5 g/BHP-hr. Detailed emissions summaries and calibration records can be found in the following pages.

Test Summary

General Information

Unit Information

Unit No.: 2006 to 2009

Company: TransCanada US Pipelines

Station: ANR Woolfolk

Manufacturer: INGERSOLL RAND

Model: KVG-123

Rated BHP: 1,320

Rated RPM: 330

		General Data		
Unit	2006	2007	2008	2009
Test Date				9/14/17
	· · · · · · · · · · · · · · · · · · ·	Operating Data	<u> </u>	
Horsepower				1,242
Speed				331
% Load				94.1%
% Torque				93.9%
Fuel Use (scfh)				11,749
	•	Emissions Data		
NOx Limit	20.5 g/bhp-hr			
NOx (ppm)				1,158.9
NO _X (ppm@ 15% O ₂)				430.5
NO _x (lb/hr)				19.4
NO _X (g/bhp-hr)				7.1
NO _x (TPY)				85.1
O ₂ (%)				5.0