
**COMPLIANCE TEST REPORT
ANR PIPELINE
WOOLFOLK COMPRESSOR STATION GAS
EUWL017**

April 5, 2022

Prepared for:



TC Energy's ANR Pipeline Company
Big Rapids, MI


Prepared by:



Environmental Quality Management, Inc.
1280 Arrowhead Court
Suite 2
Crown Point, IN 46307
(219) 661-9900
www.eqm.com

PN: 050812.0010

April 2022





PREFACE

I, Karl Mast, do hereby certify that the source emissions testing conducted at TC Energy in Big Rapids, MI was performed in accordance with the procedures set forth by the United States Environmental Protection Agency, and that the data and results submitted within this report are an exact representation of the testing.

A handwritten signature in black ink that reads 'Karl Mast' in a cursive style.

Karl Mast
Test Supervisor

I, Karl Mast, do hereby attest that all work on this project was performed under my direct supervision, and that this report accurately and authentically presents the source emissions testing conducted at ANR's Woolfolk Compressor Station in Big Rapids, MI.

A handwritten signature in black ink that reads 'Karl Mast' in a cursive style.

Karl Mast
Test Supervisor

RECEIVED

JUN 07 2022



SUMMARY

The compliance testing was performed on the Engine EUWL017 system in fulfillment of the Renewable Operating Permit MI-ROP-B7220-2017A, Section D.V requirements issued by the Michigan Environment, Great Lakes & Energy (MEGLE), Air Quality Division. The results of the testing are summarized in the following table.

Unit 17-NO _x Test Summary Results						
Parameter	Run 1	Run 2	Run 3	Average	Limit	Pass/Fail
Lb/Hr	24.15	23.58	24.37	24.03	85.7	Pass
Gr/bhp-hr	3.07	2.95	3.06	3.03	9.7	Pass



CONTENTS

Preface..... ii

Summary iii

1 Introduction..... 1

2 Test Results Summary 2

3 Facility and Process Conditions..... 4

4 Test Procedures..... 7

5 Quality Assurance Procedures 10

6 Conclusions 11

TABLES

1 NOx Test Results Summary..... 2

2 Operating Parameters/Ambient Conditions, Emission Concentrations/Calculated Mass Emissions, Concentrations/Calculated Flows..... 3

3 Production Data 4

4 Unit 17 General Information..... 5

FIGURES

1 Unit 17 Flow Schematic..... 6

APPENDICES

- A – Field Test Data
- B – Process Operating Data
- C – Gas Certifications
- D – Example Calculation
- E – Correspondence



1. INTRODUCTION

This report presents the results of the source emissions testing conducted by Environmental Quality Management, Inc. (EQM) for TC Energy's ANR Storage Company's (ANR) Woolfolk Compressor Station, near Big Rapids, MI.

The primary purpose of this testing program was to conduct emissions testing to determine compliance on the internal combustion reciprocating engine, labeled EUWL017 (Unit 17) in fulfillment with the Renewable Operating Permit MI-ROP-B7220-2017A requirements issued by the Michigan Department of Environment, Great Lakes, and Energy (MEGLE).

The following report provides information pertaining to TC Energy's process operations, and Compliance testing. The Compliance testing conducted on Unit 17 was performed on April 5, 2022, from 8:42 A.M. to 11:41 A.M.

The following requirements were specific for the testing program:

1. Equipment calibrations performed and calibration data provided.
2. Three (3) one (1) -hour, minimum, NO_x and O₂ test runs performed at the Unit 17 pursuant to EPA Reference methods as described in 40 CFR, Part 60, Appendix A.
3. Process manufacturing operations maintained at 100% of capacities based on pipeline conditions. Production and fuel consumption rates recorded during the emissions testing periods.
4. All testing and analyses performed in accordance with current EPA test methodologies and analytical procedures for NO_x and O₂ emissions determinations.
5. Stratification was found to be less than 5% in the engine exhaust.

The testing program was approved by and/or coordinated with Tyrah Lydia, TC Energy's ANR Pipeline Company. The emission testing was overseen by Karl Mast, Manager, Emission Measurement, EQM, performed by Zach Hill, Field Activity Team Leader, EQM. The emission testing was observed by Chris Robinson, MEGLE.



2. TEST RESULTS SUMMARY

The compliance testing was performed on Unit 17 in accordance with the requirements in permit MI-ROP-B7220-2017A, Section D.V issued by the Michigan EGLE, Air Quality Division. A summary of the test results is given below:

Table 1. Unit 17-NO_x Test Summary Results						
Parameter	Run 1	Run 2	Run 3	Average	Limit	Pass/Fail
Lb/Hr	24.15	23.58	24.37	24.03	85.7	Pass
Gr/bhp-hr	3.07	2.95	3.06	3.03	9.7	Pass

Based on the information provided above, the Unit 17 met the acceptance criteria during the course of the testing. A complete list of performance parameters for each test run that was performed at the stack sampling locations can be found in Table 2-4.

Additional testing information may be found in Appendix A.



Table 2. Operating Parameters and Ambient Conditions, Emissions Concentrations/Calculated Mass Emissions & Emissions Concentrations & Flows - Unit 17

Run	1	2	3	
Date	04/05/22	04/05/22	04/05/22	
Time	8:42	9:42	10:42	
Engine Operating Conditions	HS-HT	HS-HT	HS-HT	Averages
Unit Horsepower from Control Panel	3,568.0	3,623.0	3,612.0	3,601.0
Unit Speed (rpm)	441.0	440.0	439.0	440.0
Compressor Suction Pressure (PSIG)	313.0	317.0	315.0	315.0
Compressor Suction Temperature (°F)	28.4	28.0	27.8	28.1
Compressor Discharge Pressure (PSIG)	622.0	627.0	624.0	624.3
Compressor Discharge Temperature (°F)	126.4	127.5	128.1	127.3
Compressor Flow (MMSCF/D)	103.6	105.9	104.9	104.8
% Load HP	89.2	90.6	90.3	90.0
% Load RPM	103.8	103.5	103.3	103.5
% Torque	86.0	87.5	87.4	87.0
Heat Rate (BTU(LHV)/HP-hr)	6,626.4	6,565.7	6,551.0	6,581.1
Ambient Conditions				
Ambient Temperature (°F)	35.70	37.20	36.90	36.60
Barometric Pressure (psi)	14.04	14.04	14.05	14.04
Ambient Relative Humidity (%)	98.00	97.00	94.00	96.33
Absolute Humidity (grains/LB)	64.73	68.06	65.11	65.97
Emissions Concentrations & Calculated Mass Emissions				
NO _x ppm (BIAS Corrected)	274.23	267.74	277.73	273.23
NO _x g/BHP-HR	3.07	2.95	3.06	3.03
NO _x LB/HR	24.15	23.58	24.37	24.03
NO _x (ppm @ 15% O ₂)	250.85	243.40	252.87	249.04
NO _x LB/MMBTU	0.92	0.90	0.93	0.92
NO _x Tons/Year	105.78	103.27	106.72	105.26
NO _x LB/SCF Fuel	9.853E-04	9.561E-04	9.933E-04	0.00
NO _x LB/MMSCF Fuel	9.853337E+02	9.560853E+02	9.932895E+02	9.782362E+02
% O ₂ (BIAS Corrected)	14.45	14.41	14.42	14.43
Calculated Flows				
Exhaust Flow Method 19 (scfm)	12,268	12,267	12,221	12,252
Fuel Flow Measurements				
Fuel Flow From Screen(MSCFH)	24.56	24.71	24.58	24.62
** BASED ON FUEL SPECIFIC DRY F-FACTOR CALCULATION	Run 1	Run 2	Run 3	
* BASED ON CARBON BALANCE (STOICH. + O ₂)				
- A/F IS TOTAL MASS RATIO				



3. PROCESS DESCRIPTION

TC Energy’s ANR Woolfolk Compressor Station is located in Big Rapids, Michigan and operates an affected engine. Units EUWL017 is a Cooper Bessemer 12Q145HM natural gas fired internal combustion reciprocating engine rated at 4,000 hp and 425 rpm.

The Cooper Bessemer 12Q145HM is a two-stroke lean burn natural gas fired internal combustion reciprocating engine driving gas compressors. The energy released during the combustion process drives integral reciprocating gas compressors, thus raising the pressure of the incoming natural gas to move the gas to its destination or to another compressor station.

The following tables provide a summary of the production rates for the Unit 17 during the test:

Table 3. Unit 17 Plant Data		
Run No.	Horsepower	RPM
1	3,568.0	441.0
2	3,623.0	440.0
3	3,612.0	439.0
Average	3,601.0	440.0
Rated	4000	425
Percent (%) Load	90.0	103.5



Table 4. Unit 17 General Information

General Information

Date:

Company:

Station:

Unit:

Engine Type:

Serial Number:

Rated RPM: RPM

Rated BHP: BHP

Permit Limits

	ppm@15%	g/Bhp-Hr	lb/hr	TPY
NOx:		9.75	85.7	
CO:				
VOC:				
H2CO:				

Limits are actually listed as average values

Fuel Gas Analysis

Constituent	Mole Percent
Nitrogen	0.638
Carbon Dioxide	0.313
Methane	91.453
Ethane	7.170
Propane	0.356
I-Butane	0.027
N-Butane	0.029
I-Pentane	0.006
N-Pentane	0.003
Hexane +	0.005
Total	100.000

Fuel Meter Type


Enter Type from List Below

Orifice Meter (upstream pressure tap):	<input type="text" value="1"/>
Orifice Meter (downstream pressure tap):	<input type="text" value="2"/>
Electronic Flow Meter (EFM):	<input type="text" value="3"/>
Venturi (Nozzle) Meter:	<input type="text" value="4"/>
Roots Meter w/ Accumulator:	<input type="text" value="5"/>

Pipe ID:

Orifice ID:

Figure 1. Flow Schematic



Additional Information pertaining to the Fuel Flows may be found in Appendix B.



4. TEST PROCEDURES

EQM and EQM's affiliates and subcontractors use current U.S. EPA accepted testing methodologies in their Air Quality Programs as listed in the U.S. Code of Federal Regulations, Title 40, Part 60, Appendix A. For this testing program, the following specific methodologies were utilized:

- U.S. EPA Method 3A – Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)
- U.S. EPA Method 7E – Determination of Nitrogen Oxides Emissions From Stationary Sources (Instrumental Analyzer Procedure)
- U.S. EPA Method 19 – Determination of Stack Gas volumetric flow Rate by Fuel “F” Factor and heat Input

USEPA Methods 3A, 7E and 19 were performed at the Exhaust Stack sampling location by continuously extracting a gas sample from the stack through a single point stainless steel sample probe. The extracted sample was pulled through a series of filters to remove any particulate matter. Directly after the probe, the sample was conditioned by a series of refrigeration dryers to remove moisture from the gas stream. After the refrigeration dryers, the sample was transported through a Teflon® line to the analyzers. The flow of the stack gas sample was regulated at a constant rate to minimize drift.

At the start of the day, each monitor was checked for calibration error by introducing zero, mid-range and high-range EPA Protocol 1 gases to the measurement system at a point upstream of the analyzers. In this report, the calibration error test is referred to as instrument calibration. The gas was injected into the sampling valve located at the outlet of the sampling probe. The bias test was conducted before and after each consecutive test run by introducing zero and upscale calibration gases for each monitor. The upscale calibration gases used for each monitor were the high calibration gases.

Measurement System Performance Specifications were as follows:

- Analyzer Calibration Error - Less than +/- 2% of the span of the zero, mid-range and high-range calibration gases.
- Sampling System Bias - Less than +/-5% of the span for the zero, mid-range and high-range calibration gases.
- Zero Drift - Less than +/-3% of the span over the period of each test run.
- Calibration Drift - Less than +/-3% of the span over the period of each set of runs.



Calculations that were used in this testing event for the Unit No. 1 are as follows:

Calibration Correction

$$C_{GAS} = (C_R - C_O) \frac{C_{MA}}{C_M - C_O}$$

Where:

- CGAS: Corrected flue gas concentration (ppmvd)
- CR: Flue gas concentration (ppmvd)
- CO: Average of initial and final zero checks (ppmvd)
- CM: Average of initial and final span checks (ppmvd)
- CMA: Actual concentration of span gas (ppmvd)

EPA F-Factor

$$F_d = \frac{[(3.64 \cdot H_{Wt\%} \cdot 100) + (1.53 \cdot C_{Wt\%} \cdot 100)]}{GCV} \cdot 10^6$$

$$+ \frac{[(0.14 \cdot N_{2Wt\%} \cdot 100) - (0.46 \cdot O_{2Wt\%} \cdot 100)]}{GCV} \cdot 10^6$$

$\rho_{FuelGas}$

Where:

- F_d: Fuel specific F-factor, dscf/MMBtu
- H_{Wt%}: Hydrogen weight percent
- C_{Wt%}: Carbon weight percent
- N_{2Wt%}: Nitrogen weight percent
- O_{2Wt%}: Oxygen weight percent
- GCV: Heating value of the fuel, BTU/dscf
- ρ_{Fuel Gas}: Density of the fuel gas, lb/scf

Mass Emissions Calculations Lb/Hr

$$NOx \frac{g}{bhp-hr} = C_d \times F_d \times \frac{20.9}{20.9 - \%O_2} \times Q_h \times \frac{GCV}{10^6}$$



Where:

- C_d : Pollutant concentration, lb/scf
- F_d : Fuel specific F-factor, dscf/MMBtu
- Q_h : Fuel flow, scf/hr
- $\%O_2$: Oxygen concentration in percent, measured on a dry basis
- GCV : Upper dry heating value of fuel, Btu/dscf

To Convert from:	To	Multiply by:
ppm NO _x	lb/scf	1.194 x 10 ⁻⁷

NO_x Corrected to 15% O₂

$$Em = NO_x \left(\frac{5.9}{20.9 - \%O_2} \right)$$

Where:

- E_m : Pollutant concentration corrected to 15% O₂, ppm
- NO_x : Pollutant concentration, ppm
- $\%O_2$: Oxygen concentration in percent, measured on a dry basis

Mass Emissions Calculations g/bhr/hr

$$NO_x \frac{g}{bhp-hr} = C_d \times F_d \times \frac{20.9}{20.9 - \%O_2} \times Q_h \times \frac{GCV}{10^6} \times \frac{453.6}{Bhp}$$

Where:

- C_d : Pollutant concentration, lb/scf
- F_d : Fuel specific F-factor, dscf/MMBtu
- Q_h : Fuel flow, scf/hr
- $\%O_2$: Oxygen concentration in percent, measured on a dry basis
- GCV : Upper dry heating value of fuel, Btu/dscf



No testing or sample recovery procedure deviations or errors occurred during the onsite sampling phase of the testing program. No significant process deviations or upsets occurred during the emissions testing periods.

The emissions test data and supporting data collected during the field sampling can be found in Appendix A of this report.



5. QUALITY ASSURANCE PROCEDURES

Each reference method presented in the U.S. Code of Federal Regulations details the instrument calibration requirements, sample recovery and analysis, data reduction and verification, types of equipment required, and the appropriate sampling and analytical procedures to ensure maximum performance and accuracy. EQM and EQM's affiliates and subcontractors adhere to the guidelines for quality control set forth by the United States Environmental Protection Agency. These procedures are outlined in the following documents:

- Code of Federal Regulations, Title 40, Part 51
- Code of Federal Regulations, Title 40, Part 60
- Quality Assurance Handbook, Volume 1, EPA 600/9-76-005
- Quality Assurance Handbook, Volume 2, EPA 600/4-77-027a
- Quality Assurance Handbook, Volume 3, EPA 600/4-77-027b



6. CONCLUSIONS

An Emissions Test was conducted on the Engine Unit 17 at TC Energy's ANR Pipeline Company's Woolfolk Compressor Station located in Big Rapids, MI. The testing was conducted on April 5, 2022.

During the course of the testing, the Engine Unit 17 conformed to the requirements of Code Of Federal Regulations, Title 40, Part 60, Appendix A.

The usefulness and/or significance of the emissions values presented in this document as they relate to the compliance status of the Engine Unit 17 emissions shall be determined by others.

For additional information pertaining to the testing program see Appendix D of this report.

RECEIVED

JUN 07 2022



A. FIELD TEST DATA