

**COMPLIANCE TEST REPORT
ANR PIPELINE COMPANY
WOOLFOLK COMPRESSOR STATION
ENGINE EUWL006**

RECEIVED
AUG 10 2022
AIR QUALITY DIVISION

June 28, 2022

Prepared for:



TC Energy ANR Pipeline Company
Woolfolk Compressor Station
11039 150th Avenue
Big Rapids, MI 49307
Mecosta County
Permit MI-ROP-B7220-2017a

Prepared by:



Environmental Quality Management, Inc.
1280 Arrowhead Court
Suite 2
Crown Point, IN 46307
(219) 661-9900
www.eqm.com

PN: 050812.0020

July 2022



PREFACE

I, Karl Mast, do hereby certify that the source emissions testing conducted at TC Energy in Big Rapids, MI was performed in accordance with the procedures set forth by the United States Environmental Protection Agency, and that the data and results submitted within this report are an exact representation of the testing.

Karl Mast
Test Supervisor

I, Karl Mast, do hereby attest that all work on this project was performed under my direct supervision, and that this report accurately and authentically presents the source emissions testing conducted at ANR's Woolfolk Compressor Station located in Big Rapids, MI.

Karl Mast
Test Supervisor



SUMMARY

The compliance emissions testing program was performed on Unit EUWL006 due to a catalyst switch to comply with flexible groups FG-RICE-818-WLENGINES and RICE MACT in the permit and are subject to 40 CFR Part 63, Subpart ZZZZ requirement specified in Permit MI-ROP-B7220-2017a. A summary of the test results is given below:

H₂CO % Destruction Efficiency					
Unit	Run 1	Run 2	Run 3	Average	Limit
EUWL006	91.35	91.70	91.61	91.56	>76%



CONTENTS

Preface ii

Summary iii

1 Introduction 1

2 Test Results Summary 2

3 Facility and Process Conditions 5

4 Test Procedures 7

5 Quality Assurance Procedures 12

6 Conclusions 13

TABLES

1 H₂CO Test Results Summary 2

2 EUWL006-Operating & Ambient Conditions 3

3 EUWL006 Emissions Concentrations, Calculated Mass Emissions,
Concentrations & Flows 4

4 Process Data 5

5 EUWL006 General Information 6

1 USEPA Method 320 Sampling Train 11

APPENDICES

- A – Field Data
- B – Prism Data Package
- C – Process Operating Data
- D – Correspondence
- E – Sample Calculations



1. INTRODUCTION

This report presents the results of the source emissions testing conducted by Environmental Quality Management, Inc. (EQM) for TC Energy's ANR Pipeline (ANR) Woolfolk Compressor, near Big Rapids, MI, which is located in Mecosta County. The primary purpose of this testing program was to conduct emissions testing to determine compliance with flexible groups FG-RICE-818-WLENGINES and RICE MACT in the permit and are subject to 40 CFR Part 63, Subpart ZZZZ requirement specified in Permit MI-ROP-B7220-2017a for the Unit EUWL006 (Unit 6) engine at ANR's gas compressor facility.

To ensure that compliance with the emission limits is maintained, the Air Compliance Team of TC Energy's ANR contracted Environmental Quality Management, Inc. (EQM) to perform source emissions testing on the eight units. The primary purpose of this testing program was to conduct emissions testing to determine compliance with the permit at ANR's gas compressor facility.

EQM's responsibility was to conduct and oversee the compliance testing for the Formaldehyde (H₂CO) emission rates and perform data reduction for conformance evaluation. ANR's responsibility was to maintain process operating parameters and to assist in providing process operating data per compliance test requirements. EQM contracted the services of Prism Analytical Technologies out of Mount Pleasant, MI for the Method 320.

The following report provides information pertaining to TC Energy's process operations, and Compliance testing. The Compliance testing conducted on Unit 6 was performed on June 28, 2022 from 8:40 A.M. to 12:07 P.M.

The following requirements were specific for the testing program:

1. Equipment calibrations performed and calibration data provided.
2. Three (3) sixty (60) –minute H₂CO test runs performed at the Unit 6 pursuant to EPA, Title 40, Code of Federal Regulations, Part 60 (40 CFR 60), Appendix A.
3. Process operations conditions maintained within 10% rated load during the emissions testing periods.
4. All testing and analyses performed in accordance with current EPA test methodologies and analytical procedures for H₂CO emissions



determinations via Extractive Fourier transform infrared (FTIR) spectrometry.

The testing program was approved by and/or coordinated with Shawn Flannigan, Alliant Environmental, LLC, consultant to TC Energy's ANR Pipeline. The emission testing was performed by Karl Mast, Project Manager, EQM, Zach Hill, Field Activities Lead, EQM, Garrett Cox, Test Technician, EQM and Trevor Tilmann, Prism Analytical Technologies. The emission testing was observed by Chris Robinson, Michigan EGLE.

RECEIVED

AUG 10 2022

AIR QUALITY DIVISION



2. TEST RESULTS SUMMARY

The compliance testing was performed on Unit 6 system in accordance with the requirements of the Code of Federal Regulations, Title 40, Part 60, Appendix A, and the Permit MI-ROP-B7220-2017a requirements. A summary of the test results is given below:

Table 1. H₂CO % Destruction Efficiency					
Unit	Run 1	Run 2	Run 3	Average	Limit
EUWL006	91.35	91.70	91.61	91.56	>76%

Based on the information provided above, all eight units met the acceptance criteria during the course of the testing. A complete list of performance parameters for each test run that was performed at the stack sampling locations can be found in Tables 2-5.



Table 2 . Engine Operating and Ambient Conditions -Unit EUWL006

Run	1	2	3	
Date	06/28/22	06/28/22	06/28/22	
Time	8:40	9:55	11:07	
Engine Operating Conditions	HS-HT	HS-HT	HS-HT	Averages
Unit Horsepower from Control Panel	1,235.0	1,240.0	1,230.0	1,235.0
Unit Speed (rpm)	326.0	330.0	331.0	329.0
% Load RPM	98.8	100.0	100.3	99.7
Compressor Suction Pressure (PSIG)	542.0	540.0	545.0	542.3
Compressor Suction Temperature (°F)	54.5	57.3	58.4	56.7
Compressor Discharge Pressure (PSIG)	788.0	786.0	783.0	785.7
Compressor Flow (MMSCF/D)	64.9	64.6	65.7	65.1
% Load HP	93.6	93.9	93.2	93.6
% Torque	94.7	93.9	92.9	93.8
Heat Rate (BTU/HP-hr)	9,258.1	9,228.6	9,256.5	9,247.7
Ambient Conditions				
Ambient Temperature (°F)	68.00	71.00	75.00	71.33
Barometric Pressure (psi)	14.15	14.14	14.12	14.13
Ambient Relative Humidity (%)	62.00	60.00	53.00	58.33
Absolute Humidity (grains/LB)	136.09	146.34	148.10	143.51



Table 3. Emissions Concentrations, Calculated Mass Emissions, Concentrations & Flows -Unit EUWL006

Run	1	2	3	
Date	06/28/22	06/28/22	06/28/22	
Time	8:40	9:55	11:07	
Emissions Concentrations & Calculated Mass Emissions				
H ₂ CO Inlet ppmw	6.90	6.44	6.31	6.55
H ₂ CO Inlet (ppmw @ 15% O ₂)	2.42	2.28	2.24	2.32
H ₂ CO Outlet ppmw	0.57	0.52	0.49	0.53
H ₂ CO Outlet (ppmw @ 15% O ₂)	0.21	0.19	0.19	0.20
H ₂ CO % Removal Limit is 76%	91.35	91.70	91.61	91.56
H ₂ O ppm (% FTIR)	15.29	15.22	14.49	15.00
% O ₂ Inlet (raw measured wet)	4.07	4.26	4.30	4.21
% O ₂ Outlet (raw measured wet)	4.82	4.71	5.53	5.02
% O ₂ (BIAS Corrected Dry)	5.06	5.06	5.10	5.07
Calculated Flows				
Fuel Flow - (SCFM)	197.33	197.50	196.50	197.11
Fuel Flow - (SCFH)	11,840	11,850	11,790	11,827
Exhaust Flow (LB/HR)	10,379.8	10,376.5	10,346.3	10,368
Exhaust Flow (WSCFM)	2,722.8	2,711.6	2,802.6	2,746
Air Flow (WSCFM)	2,343	2,344	2,339	2,342
Exhaust Flow Method 19 (scfm)	2,416	2,417	2,412	2,415
Exhaust Flow Method 19 (lbm/min)	112	112	112	112
Exhaust Flow Carbon Balance (lbm/min)	196.63	196.73	196.23	197
Air flow Beshouri (scfm)	2,558.22	2,559.51	2,553.04	2,557
Fuel Flow Measurements				
Fuel Flow From Screen(MSCFH)	11.84	11.85	11.79	11.83
** BASED ON FUEL SPECIFIC DRY F-FACTOR CALCULATION	Run 1	Run 2	Run 3	
* BASED ON CARBON BALANCE (STOICH. + O2)				
- A / F IS TOTAL MASS RATIO				



3. FACILITY AND PROCESS DESCRIPTION

TC Energy’s ANR Woolfolk Compressor Station is located in Big Rapids, MI. The facility operates six Ingersoll-Rand Compressor Engine labeled EUWL001, EUWL002, EUWL003, EUWL006, EUWL005 and EUWL006. The engines 1-5 are four stroke, rich burn, natural gas fired reciprocating compressor engine, Model KVG-103, 1000 horsepower, and used to compress natural gas for transport via natural gas pipeline. Engine 6 is a four stroke, rich burn, natural gas fired reciprocating compressor engine, Model KVG-123, 1320 horsepower, and also is used to compress natural gas for transport via natural gas pipeline. The units are subject to the RICE MACT and Rule 818 and are subject to 40 CFR Part 63, Subpart ZZZZ requirements. Engine EUWL006 was the subject of this testing.

Process data is specified in Table 4. General engine information is located in Table 5.

Table 4. Process Data (Horsepower)					
Unit	Run 1	Run 2	Run 3	Average	Rated
EUWL006	1,235.0	1,240.0	1,230.0	1,235.0	1320



Table 5. Unit EUWL006 General Information

General Information

Date:

Company:

Station:

Unit:

Engine Type:

Rated RPM: RPM

Rated BHP: BHP

Permit Limits

	ppm@15%	g/Bhp-Hr	lb/hr	TPY
NOx:				
CO:				
VOC:				
H2CO:	>78 DE			

Limits are actually listed as average values

Fuel Meter Type

Enter Type from List Below

- Orifice Meter (upstream pressure tap):
- Orifice Meter (downstream pressure tap):
- Electronic Flow Meter (EFM):
- Venturi (Nozzle) Meter:
- Roots Meter w/ Accumulator:

Pipe I.D.:

Orifice I.D.:



4. TEST PROCEDURES

EQM and EQM's affiliates and subcontractors use current U.S. EPA accepted testing methodologies in their Air Quality Programs as listed in the U.S. Code of Federal Regulations, Title 40, Part 60, Appendix A. For this testing program, the following specific methodologies were utilized:

- U.S. EPA Method 3A – Determination of Oxygen and Carbon Dioxide Concentrations in Emissions From Stationary Sources (Instrumental Analyzer Procedure)
- U.S. EPA Method 19– Determination of Volumetric Flow Rate From Stationary Sources
- U.S. EPA Method 320– Determination of Formaldehyde From Stationary Sources (Extractive Fourier Transform infrared (FTIR) Spectrometry)

USEPA Methods 3A and 19 were performed at the Exhaust Stack sampling location by continuously extracting a gas sample from the stack through a single point stainless steel sample probe. The extracted sample was pulled through a series of filters to remove any particulate matter. Directly after the probe, the sample was conditioned by a series of refrigeration dryers to remove moisture from the gas stream. After the refrigeration dryers, the sample was transported through a Teflon® line to the analyzers. The flow of the stack gas sample was regulated at a constant rate to minimize drift.

At the start of the day, each monitor was checked for calibration error by introducing zero, mid-range and high-range EPA Protocol 1 gases to the measurement system at a point upstream of the analyzers. In this report, the calibration error test is referred to as instrument calibration. The gas was injected into the sampling valve located at the outlet of the sampling probe. The bias test was conducted before and after each consecutive test run by introducing zero and upscale calibration gases for each monitor. The upscale calibration gases used for each monitor were the high calibration gases.

Measurement System Performance Specifications were as follows:

- Analyzer Calibration Error - Less than +/- 2% of the span of the zero, mid-range and high-range calibration gases.
- Sampling System Bias - Less than +/-5% of the span for the zero, mid-range and high-range calibration gases.
- Zero Drift - Less than +/-3% of the span over the period of each test run.
- Calibration Drift - Less than +/-3% of the span over the period of each set of runs.



USEPA Method 320 was performed at the Exhaust Stack sampling locations by using MKS MultiGas 2030 FTIR spectrometers. The FTIRs were equipped with temperature-controlled, 5.11 meter multipass gas cells maintained at 191 °C. Gas flows and sampling system pressures were monitored using rotameters and pressure transducers. All data were collected at 0.5 cm⁻¹ resolution. Each spectrum was derived from the coaddition of 64 scans, with a new data point generated approximately every one minute. Additional information may be found in Appendix B.

USEPA Method 3A was performed to quantify the concentrations levels of Oxygen (O₂) from the Engine 6 to correct formaldehyde concentration for Oxygen. Post catalyst oxygen determination were made by EQM. Additional information may be found in Appendix A and Appendix B.

Calculations that were used in this testing event for the Unit 6 are as follows:

Calibration Correction

$$C_{GAS} = (C_R - C_O) \frac{C_{MA}}{C_M - C_O}$$

Where:

- C_{GAS}: Corrected flue gas concentration (ppmvd)
- C_R: Flue gas concentration (ppmvd)
- C_O: Average of initial and final zero checks (ppmvd)
- C_M: Average of initial and final span checks (ppmvd)
- C_{MA}: Actual concentration of span gas (ppmvd)

EPA F-Factor

$$F_d = \frac{[(3.64 \cdot H_{W\%} \cdot 100) + (1.53 \cdot C_{W\%} \cdot 100)]}{GCV} \cdot 10^6$$

$$+ \frac{[(0.14 \cdot N_{2W\%} \cdot 100) - (0.46 \cdot O_{2W\%} \cdot 100)]}{GCV} \cdot 10^6$$

ρ_{FuelGas}



Where:

- F_d : Fuel specific F-factor, dscf/MMBtu
- $H_{wt\%}$: Hydrogen weight percent
- $C_{wt\%}$: Carbon weight percent
- $N_{2wt\%}$: Nitrogen weight percent
- $O_{2wt\%}$: Oxygen weight percent
- GCV : Heating value of the fuel, BTU/dscf
- $\rho_{Fuel Gas}$: Density of the fuel gas, lb/scf

Formaldehyde Removal Efficiency, RE (%)

$$RE = \left(\frac{\text{Inlet Formaldehyde} - \text{Outlet Formaldehyde}}{\text{Inlet Formaldehyde}} \right) \times 100$$

Where:

Inlet Formaldehyde = Inlet formaldehyde concentration at 15% O2

Outlet Formaldehyde = Inlet formaldehyde concentration at 15% O2

Inlet Analyzer Drift Correction

$$C_{gas} = (C_{Ave} - CO) \left(\frac{C_{ma}}{C_m - C_o} \right)$$

Where:

- C_{GAS} : Average effluent gas concentration adjusted for bias
- C_{Ave} : Average unadjusted gas concentration indicated by data recorder for the test run
- C_o : Average of initial and final zero checks
- C_M : Actual concentration of the upscale calibration gas
- C_{MA} : Average of initial and final system calibration bias check responses for the upscale calibration gas

Outlet Analyzer Drift Correction

$$C_{gas} = (C_{Ave} - CO) \left(\frac{C_{ma}}{C_m - C_o} \right)$$



Where:

- C_{GAS} : Average effluent gas concentration adjusted for bias
- C_{Ave} : Average unadjusted gas concentration indicated by data recorder for the test run
- C_O : Average of initial and final zero checks (ppmvd)
- C_M : Actual concentration of the upscale calibration gas
- C_{MA} : Average of initial and final system calibration bias check responses for the upscale calibration gas

Inlet Concentration, C_1 (corrected to 15% O_2)

$$Conc.i_{(Std.O_2)} = Conc.i_{(MeasuredO_2)} \left(\frac{20.9\% - Std.O_2\%}{20.9\% - Measured O_2\%} \right)$$

Where:

- $Conc.i_{(Std.O_2)}$ =Concentration at standard O_2 level
- $Conc.i_{(MeasuredO_2)}$ =Concentration measured at O_2 level
- $Std.O_2\%$ =Oxygen concentration at standard level
- $Measured O_2\%$ =Oxygen concentration at measured level




Figure 1. USEPA Method 320 Sampling Train



5. QUALITY ASSURANCE PROCEDURES

Each reference method presented in the U.S. Code of Federal Regulations details the instrument calibration requirements, sample recovery and analysis, data reduction and verification, types of equipment required, and the appropriate sampling and analytical procedures to ensure maximum performance and accuracy. EQM and EQM's affiliates and subcontractors adhere to the guidelines for quality control set forth by the United States Environmental Protection Agency. These procedures are outlined in the following documents:

- Code of Federal Regulations, Title 40, Part 51
- Code of Federal Regulations, Title 40, Part 60
- Quality Assurance Handbook, Volume 1, EPA 600/9-76-005
- Quality Assurance Handbook, Volume 2, EPA 600/4-77-027a
- Quality Assurance Handbook, Volume 3, EPA 600/4-77-027b



6. CONCLUSIONS

An Emissions Test was conducted on the internal combustion compressor engines labeled Unit EUWL006 at TC Energy's ANR Pipeline Company's Woolfolk Compressor Station located in Big Rapids, Michigan. The testing was conducted on June 28, 2022.

During the course of the testing, the eight engines conformed to the requirements of flexible groups FG-RICE-818-WLENGINES and RICE MACT in the permit and are subject to 40 CFR Part 63, Subpart ZZZZ requirement..

The usefulness and/or significance of the emissions values presented in this document as they relate to the compliance status of the emissions shall be determined by others.

For additional information pertaining to the testing program see Appendix D of this report



A. PRISM DATA PACKAGE