

**Survey of Source Emissions  
for:**

**Weyerhaeuser  
4111 West Four Mile Road  
Grayling, MI 49738**

**Sources:  
EUPRESSLINE Biofilter**

**FGDRYERS RTO**

**Relative Accuracy Test Audit (RATA)**

**EGLE Renewable Operating Permit No.  
MI-ROP-B7302-2016c**

**Test Date: November 28-29, 2023  
Project ID: 2311520004**



**Environmental Services Company, Inc.**

**Arkansas  
Little Rock & Springdale**

**New Mexico  
Carlsbad & Albuquerque**

**1-888-ESC-First (3477)  
www.esclabs.com**

**REVIEWED AND CERTIFIED BY:**

**Baxter  
Woosley**

Digitally signed by Baxter  
Woosley  
Date: 2024.01.12  
09:09:53 -06'00'

**BAXTER S. WOOSLEY, AIR PROJECTS MANAGER/QSTI**

*This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.*

*Results relate only to the sources tested in the scope of this project.*

**RECEIVED**

**JAN 24 2024**

**AIR QUALITY DIVISION**

# Table of Contents

<b>1.0</b>	<b>Introduction.....</b>	<b>3</b>
1.1	Summary of Test Program .....	3
1.2	Regulatory Information.....	3
1.3	Source Information.....	3
1.4	Test Location and Facility Contact .....	3
1.5	Regulatory Contact.....	3
1.6	Test Company and Personnel.....	4
1.7	Site-Specific Test Plan and Testing Notes .....	4
<b>2.0</b>	<b>Summary of Results.....</b>	<b>5</b>
2.1	Results Table.....	5
2.1.1	Summary of Results .....	6
2.1.2	EUPRESSLINE Biofilter VOC RATA .....	7
2.1.3	FGDRYERS RTO VOC RATA .....	9
2.1.4	FGDRYERS RTO CO RATA.....	11
2.2	Data Summary.....	13
2.2.1	Data Summary – EUPRESSLINE Biofilter .....	14
2.2.2	Run 1 Calculations – EUPRESSLINE Biofilter.....	20
2.2.3	Data Summary – FGDRYERS RTO .....	24
2.2.4	Run 1 Calculations – FGDRYERS RTO .....	36
<b>3.0</b>	<b>Facility and Sampling Location Descriptions.....</b>	<b>45</b>
3.1	Process Description and Operation .....	45
3.2	CEMS Description .....	46
3.3	Flue Gas Sampling Locations .....	46
3.4	Stack Schematics.....	47
3.4	Operating Data .....	52
<b>4.0</b>	<b>Sampling and Analytical Procedures .....</b>	<b>56</b>
4.1	Sampling Methods .....	56
4.1.1	U.S. EPA Method 1 .....	56
4.1.2	U.S. EPA Method 3A .....	56
4.1.3	U.S. EPA Method 10 .....	56
4.1.4	U.S. EPA Method 25A .....	56
4.1.5	U.S. EPA Method 320 .....	57
4.1.6	U.S. EPA Performance Specification 4 .....	57
4.1.7	U.S. EPA Performance Specification 6 .....	57
4.1.8	U.S. EPA Performance Specification 8 .....	57
<b>5.0</b>	<b>Quality Assurance/Quality Control (QA/QC).....</b>	<b>58</b>
5.1	Quality Assurance (QA).....	58
5.2	Testing Limitations .....	59
<b>Appendix A:</b>	<b>Field Data.....</b>	<b>60</b>
Appendix A-1	EUPRESSLINE Biofilter Field Data.....	61
Appendix A-2	FGDRYERS RTO Field Data.....	84
<b>Appendix B:</b>	<b>Quality Assurance Data .....</b>	<b>176</b>
<b>Appendix C:</b>	<b>Project Manager Resumes.....</b>	<b>196</b>
<b>Appendix D:</b>	<b>Correspondence.....</b>	<b>202</b>

# 1.0 Introduction

## 1.1 Summary of Test Program

At the request of Mr. Tim Tadlock of Weyerhaeuser, Environmental Services Company, Inc. (ESC) performed a Relative Accuracy Test Audit (RATA) at Weyerhaeuser's Grayling, Michigan facility. The scope of work consisted of testing the EUPRESSLINE Biofilter and FGDRYERS RTO continuous emissions monitoring systems (CEMS). RATAs were conducted on both the EUPRESSLINE Biofilter Volatile Organic Compound monitor (VOC CEMS) and the FGDRYERS RTO VOC and Carbon Monoxide monitor (VOC /CO CEMS).

## 1.2 Regulatory Information

Permit No.	EGLE Renewable Operating Permit No. MI-ROP-B7302-2016c
Regulatory Citation	40 CF Part 60
Regulatory Information	US EPA Region 5

## 1.3 Source Information

Source names:	EUPRESSLINE Biofilter	FGDRYERS RTO
Source ID:	SVBIOFILTER	SVRTOSTACK
Target Parameters:	VOC	CO, VOC

## 1.4 Test Location and Facility Contact

Mr. Tim Tadlock  
timothy.tadlock@weyerhaeuser.com  
Weyerhaeuser  
4111 West Four Mile Road  
Grayling, Michigan 49378  
Phone: (989) 348-3411

## 1.5 Regulatory Contact

Mr. Trevor Drost  
drostt@michigan.gov  
Michigan Department of Environment, Great Lakes & Energy  
(EGLE) Phone: (517) 245-5781

Ms. Sharon LeBlanc  
Environmental Quality Analyst  
Michigan Department of Environment, Great Lakes, and Energy  
Air Quality Division  
Phone: (989) 217-0055  
Email: LeBlancS@michigan.gov

## **1.6 Test Company and Personnel**

Environmental Services Company, Inc.  
13715 West Markham  
Little Rock, AR 72211  
Phone: (501) 221-2565

Project Manager  
Steve Woosley  
steve@esclabs.com

Field Team Leader  
Baxter Woosley  
tbaxterw@esclabs.com

## **1.7 Site-Specific Test Plan and Testing Notes**

All testing was performed in accordance with the Site-Specific Test Plan (SSTP) submitted to Michigan Department of Environment, Great Lakes and Energy dated October 26, 2023. Prior to sampling ESC Labs and Weyerhaeuser petitioned EGLE for several variances in testing that were originally planned in the SSTP. The variations included not running EPA Method 326 for MDI, the use of EPA Method 320 for determining moisture content on the EUPRESSLINE Biofilter, and utilizing section 8.6 of US EPA Method 2. This section was used to eliminate the use of US EPA Method 3A on EUPRESSLINE Biofilter. Section 8.6 of US EPA Method 2 states, " For processes emitting essentially air, an analysis need not be conducted: use a dry molecular weight of 29.0."

## **2.0 Summary of Results**

### **2.1 Results Table**

On November 28-29, 2023, ESC performed relative accuracy test audits (RATA's) on the EUPRESSLINE Biofilter and FGDRYERS RTO continuous emission monitoring systems (CEMS) at the Weyerhaeuser facility in Grayling, Michigan to determine compliance with EGLE Renewable Operating Permit No. MI-ROP-B7302-2016c, and provisions of the 40 CFR 60.

The summary of results from the testing compared to EGLE permit limits are summarized in the table in section 2.1.1. Section 2.2 of the report contains all field data and calculated results for each run and the calculations used in this sampling program.

### 2.1.1 Summary of Results

This page intentionally left blank.

**2.1.2 EUPRESSLINE Biofilter VOC RATA**

**Summary of Results - VOC RATA**

Date: 11/28/23				<b>t-values</b>	
Customer: Weyerhaeuser				<b># of runs</b>	<b>t-value</b>
Emission Unit: EUPRESSLINE Biofilter Outlet				9	2.306
ESC Personnel: RSW, RM, TKB, JM, TS, NAM				10	2.262
Reference Methods: 25A and 320				11	2.228
Number of Test Runs: 10				12	2.201
t-value (97.5% confidence): 2.262				13	2.179

		Calculated Data	CERM Data	Differences
		VOC lbs/hr as carbon	VOC lbs/hr as carbon	Differences, lbs/hr
Run #	Run Time			
1	1058-1119	8.70	8.83	0.13
2	1120-1141	6.95	7.50	0.55
3	1142-1203	6.89	7.99	1.10
4	1211-1232	5.29	6.58	1.29
5	1300-1321	7.74	6.26	-1.48
6	1322-1343	8.81	7.84	-0.97
7*	1408-1429	7.11	8.44	1.33
8	1430-1451	6.54	7.15	0.61
9	1451-1518	4.82	5.89	1.07
10	1533-1554	4.09	5.20	1.11
<b>Averages:</b>		<b>6.65</b>	<b>7.03</b>	<b>0.38</b>
				Standard Deviation: 0.99
				Confidence Coefficient: 0.70

\*Run 7 excluded from RATA

VOC Relative Accuracy		
<b>5.56%</b>	Based on Applicable Standard	<b>Pass</b>



**2.1.3 FGDRYERS RTO VOC RATA**

**Summary of Results - VOC RATA**

Date: 11/29/23				<b>t-values</b>	
Customer: Weyerhaeuser				<b># of runs</b>	<b>t-value</b>
Emission Unit: FGDRYERS RTO Outlet				9	2.306
ESC Personnel: RSW, TKB, JMITS, NAM				10	2.262
Reference Methods: 25A and 4				11	2.228
Number of Test Runs: 12				12	2.201
t-value (97.5% confidence): 2.201				13	2.179

		Calculated Data	CERM Data	Differences
		VOC lbs/hr as carbon	VOC lbs/hr as carbon	Differences, lbs/hr
Run #	Run Time			
1	1308-1329	0.24	0.90	0.66
2	1330-1351	0.51	1.17	0.66
3	1352-1413	0.79	1.40	0.61
4	1428-1449	1.09	2.52	1.43
5	1450-1511	1.19	2.54	1.35
6	1512-1533	1.11	2.47	1.36
7*	1631-1652	0.72	3.04	2.32
8	1653-1714	0.65	2.69	2.04
9	1715-1736	0.66	2.55	1.89
10	1745-1806	1.37	2.98	1.61
11*	1807-1828	1.47	4.05	2.58
12*	1829-1850	1.40	3.77	2.37
<b>Averages:</b>		<b>0.84</b>	<b>2.14</b>	<b>1.29</b>
				<b>Standard Deviation:</b>
				0.63
				<b>Confidence Coefficient</b>
				0.40

\* Runs not included in Relative accuracy calculation

VOC Relative Accuracy		
<b>9.11%</b>	Based on Applicable Standard	<b>Pass</b>

**2.1.4 FGDRYERS RTO CO RATA**

**Summary of Results - CO RATA**

Date: 11/29/23			
Customer: Weyerhaeuser			
Emission Unit: FGDRYERS RTO Outlet			
ESC Personnel: RSW, TKB, JMTS, NAM			
Reference Methods: 2, 4 and 10			
Number of Test Runs: 12			
t-value (97.5% confidence): 2.201			

		t-values	
		# of runs	t-value
		9	2.306
		10	2.262
		11	2.228
		12	2.201
		13	2.179

		Calculated Data	CERM Data	Differences
		CO lbs/hr	CO lbs/hr	Differences, lbs/hr
Run #	Run Time			
1	1308-1329	9.36	7.33	-2.03
2	1330-1351	18.09	12.47	-5.62
3*	1352-1413	22.27	14.49	-7.78
4	1428-1449	49.93	44.75	-5.18
5	1450-1511	61.07	56.08	-4.99
6	1512-1533	61.59	57.08	-4.51
7*	1631-1652	84.24	78.06	-6.18
8*	1653-1714	73.65	65.61	-8.04
9	1715-1736	58.91	53.50	-5.41
10	1745-1806	60.55	58.88	-1.67
11	1807-1828	68.38	66.85	-1.53
12	1829-1850	69.85	72.90	3.05
<b>Averages:</b>		<b>50.86</b>	<b>47.76</b>	<b>-3.10</b>
			<b>Standard Deviation:</b>	1.79
			<b>Confidence Coefficient</b>	1.13

\* Runs not included in Relative accuracy calculation

CO Relative Accuracy		
<b>2.87%</b>	Based on Applicable Standard	<b>Pass</b>

## **2.2 Data Summary**

The following provides a detailed summary of the field data, calculated data, and calculations.

### 2.2.1 Data Summary – EUPRESSLINE Biofilter

**USEPA Method 25A  
Data Summary  
Volatile Organic Compounds**

VOC's		Run #1	Run #2	Run #3	Run #4	Run #5	Run #6	Run #7	Run #8	Run #9	Run #10
	Emission Unit:									EUPRESSLINE Biofilter Outlet	
	Date:	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23	11/28/23
	Start Time:	1058	1120	1142	1211	1233	1255	1408	1430	1451	1533
	Stop Time:	1119	1141	1203	1232	1254	1316	1429	1451	1518	1554
C <sub>c3h8(wet)</sub>	Average VOC concentration as propane indicated by the gas analyzer, ppmvw	15.01	13.57	14.32	11.70	15.58	17.45	14.86	12.87	9.89	8.90
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero VOC's calibration gas, ppmvd	1.02	1.02	1.02	1.45	1.45	1.45	1.44	1.44	1.44	1.47
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale VOC's calibration gas, ppmvd	51.58	51.58	51.58	51.25	51.25	51.25	50.66	50.66	50.66	50.66
C <sub>ma</sub>	Actual concentration of the upscale VOC's calibration gas, ppmvd	50.10	50.10	50.10	50.10	50.10	50.10	50.10	50.10	50.10	50.10
C <sub>c3h8(corrected)</sub>	VOC concentration as carbon, ppmvw	13.86	12.44	13.18	10.31	14.22	16.10	13.66	11.64	8.60	7.58
B <sub>ws</sub>	Water vapor in the gas stream, proportion by volume	0.0060	0.0054	0.0056	0.0057	0.0054	0.0057	0.0056	0.0055	0.0055	0.0060
C <sub>c3h8(dry)</sub>	VOC concentration as propane, ppmvd	13.95	12.50	13.25	10.37	14.30	16.19	13.73	11.70	8.64	7.62
C <sub>voc</sub>	VOC concentration as carbon, ppmvd	41.84	37.51	39.76	31.11	42.89	48.57	41.20	35.11	25.93	22.86
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	6,673,789.01	5,947,323.30	5,563,949.04	5,458,419.62	5,789,912.58	5,819,312.09	5,539,771.10	5,974,083.60	5,962,536.93	5,738,266.50
E <sub>voc</sub>	VOC emission rate as carbon, lbs/hr	8.70	6.95	6.89	5.29	7.74	8.81	7.11	6.54	4.82	4.09

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
Identification:		EUPRESSLINE Biofilter Outlet		
	Date:	11/28/23	11/28/23	11/28/23
	Start Time:	1015	1030	1145
	Stop Time:	1020	1035	1150
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.8899	0.7927	0.7416
$D_s$	Stack diameter, ft.	7.0000	7.0000	7.0000
$T_s$	Average stack temperature, °F	77	77	77
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.68	28.68	28.68
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.0060	0.0054	0.0056
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.0000	29.0000	29.0000
$P_s$	Absolute stack gas pressure, in. Hg	28.6825	28.6825	28.6825
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	28.9340	28.9406	28.9384
$A$	Area of the stack, ft <sup>2</sup>	38.4846	38.4846	38.4846
$V_s$	Velocity in the stack, ft/sec	51.3961	45.7845	42.8268
$V_{acfm}$	Velocity in the stack, acfm	118,677.55	105,719.89	98,890.36
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	6,673,789.01	5,947,323.30	5,563,949.04



**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #4</b>	<b>Run #5</b>	<b>Run #6</b>
Identification:		EUPRESSLINE Biofilter Outlet		
	Date:	11/28/23	11/28/23	11/28/23
	Start Time:	1225	1300	1345
	Stop Time:	1230	1305	1350
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.7268	0.7704	0.7756
$D_s$	Stack diameter, ft.	7.0000	7.0000	7.0000
$T_s$	Average stack temperature, °F	76	75	77
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.68	28.68	28.68
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.0057	0.0054	0.0057
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.0000	29.0000	29.0000
$P_s$	Absolute stack gas pressure, in. Hg	28.6825	28.6825	28.6825
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	28.9378	28.9411	28.9378
$A$	Area of the stack, ft <sup>2</sup>	38.4846	38.4846	38.4846
$V_s$	Velocity in the stack, ft/sec	41.9240	44.4151	44.7791
$V_{acfm}$	Velocity in the stack, acfm	96,805.62	102,557.79	103,398.38
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	5,458,419.62	5,789,912.58	5,819,312.09

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #7</b>	<b>Run #8</b>	<b>Run #9</b>
Identification:		EUPRESSLINE Biofilter Outlet		
	Date:	11/28/23	11/28/23	11/28/23
	Start Time:	1415	1440	1510
	Stop Time:	1420	1445	1515
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.7375	0.7951	0.7940
$D_s$	Stack diameter, ft.	7.0000	7.0000	7.0000
$T_s$	Average stack temperature, °F	76	75	76
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.68	28.68	28.68
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.0056	0.0055	0.0055
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.0000	29.0000	29.0000
$P_s$	Absolute stack gas pressure, in. Hg	28.6825	28.6825	28.6825
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	28.9382	28.9392	28.9394
$A$	Area of the stack, ft <sup>2</sup>	38.4846	38.4846	38.4846
$V_s$	Velocity in the stack, ft/sec	42.5423	45.8465	45.8104
$V_{acfm}$	Velocity in the stack, acfm	98,233.48	105,862.96	105,779.60
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	5,539,771.10	5,974,083.60	5,962,536.93

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #10</b>	<b>Run #11</b>	<b>Run #12</b>
Identification:		EUPRESSLINE Biofilter Outlet		
	Date:	11/28/23	--	--
	Start Time:	1555	--	--
	Stop Time:	1600	--	--
$C_p$	Pitot correction factor, dimensionless	0.84	--	--
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.7625	--	--
$D_s$	Stack diameter, ft.	7.0000	--	--
$T_s$	Average stack temperature, °F	73	--	--
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.68	--	--
$P_g$	Stack static pressure, in. Hg	0.00	--	--
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.0060	--	--
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.0000	--	--
$P_s$	Absolute stack gas pressure, in. Hg	28.6825	--	--
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	28.9342	--	--
$A$	Area of the stack, ft <sup>2</sup>	38.4846	--	--
$V_s$	Velocity in the stack, ft/sec	43.8818	--	--
$V_{acfm}$	Velocity in the stack, acfm	101,326.45	--	--
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	5,738,266.50	--	--

### 2.2.2 Run 1 Calculations – EUPRESSLINE Biofilter

### VOC RATA AS Calculations

**CEM VOC concentrations ( $CEM_{avg}$ ), lbs/hr =**  $CEM_{avg}$

where,

$CEM_{avg}$  8.830 = Average of client VOC data over a given run time, lbs/hr

**VOC concentration as carbon ( $C_{c(dry)}$ ), ppmvd =**  $\frac{3C_{c3h8(wet)}}{(1 - B_{ws})}$

where,

$C_{c3h8(wet)}$  15.01 = VOC concentration as propane, ppmvw  
 $B_{ws}$  0.0060 = Water vapor in the gas stream, proportion by volume  
 $C_{c(dry)}$  41.84 = VOC concentration as carbon, ppmvd

**VOC emission rate as carbon ( $E_{voc}$ ), lbs/hr =**  $\frac{C_{c(dry)} \times 12 \times Q_{std}}{385.1E06}$

where,

$C_{c(dry)}$  41.84 = VOC concentration as carbon, ppmvd  
 $Q_{std}$  6,673,789.01 = Volume of metered gas sample, dscf  
 $E_{voc}$  8.70 = VOC emission rate as carbon, lbs/hr

**Confidence coefficient (CC) =**  $t_{0.975} \frac{S_d}{\sqrt{n}}$

where,

$T_{0.975}$  2.262 = t-value for n-1 degrees of freedom  
 $S_d$  0.99 = Standard deviation of the difference of the reference method  
and CEM  
 $\sqrt{n}$  3.2 = square root of the number of data points (runs)  
 $CC$  0.70 = Confidence coefficient

**Relative accuracy (RA), % =**  $\frac{|\bar{d}| + |CC|}{RM}$

where,

$|\bar{d}|$  0.38 = Absolute value of the mean of the differences  
 $|CC|$  0.70 = Absolute value of the confidence coefficient  
 $\overline{AS}$  19.50 = Applicable standard  
 $RA$  5.56 = Relative accuracy of CEM CO monitor, percent of applicable standard

### Method 2

**Absolute stack gas pressure ( $P_s$ ), in. Hg =**  $P_{bar} + P_g$

where,

$P_{bar}$  28.68 = Barometric pressure at sampling site, in. Hg  
 $P_g$  0.00 = Stack static pressure, in. Hg  
 $P_s$  28.68 = Absolute stack gas pressure, in. Hg

**Wet molecular weight of stack gasses ( $M_s$ ), lb/lb-mole =**  $M_d(1 - B_{ws}) + 18.0B_{ws}$

where,

$M_d$  29.0000 = Dry molecular weight of stack gasses, lb/lb-mole  
 $B_{ws}$  0.0060 = Water vapor in the gas stream, proportion by volume  
 $M_s$  28.9340 = Wet molecular weight of stack gasses, lb/lb-mole

**Area of stack ( $A$ ), ft<sup>2</sup> =**  $\left(\frac{D_s}{2}\right)^2 \times 3.1416$

where,

$D_s$  7.0000 = Stack diameter or dimensions, ft  
 $A$  38.4846 = Area of stack, ft<sup>2</sup>

**Velocity in the stack ( $V_s$ ), ft/sec =**  $85.49C_p \sqrt{\Delta P_{avg}} \sqrt{\frac{460 + T_s}{P_s M_s}}$

where,

$C_p$  0.84 = Pitot correction factor, dimensionless  
 $\sqrt{\Delta P}$  0.8899 = Average of the square roots of the pressure heads, in. H<sub>2</sub>O  
 $T_s$  77 = Average stack temperature, °F  
 $P_s$  28.68 = Absolute stack gas pressure, in. Hg  
 $M_s$  28.9340 = Wet molecular weight of stack gasses, lb/lb-mole  
 $V_s$  51.40 = Velocity in the stack, ft/sec

**Velocity in the stack ( $V_{acfm}$ ), acfm =**  $60 \times A \times V_s$

where,

$A$  38.4846 = Area of stack, ft<sup>2</sup>  
 $V_s$  51.40 = Velocity in the stack, ft/sec  
 $V_{acfm}$  118,677.55 = Velocity in the stack, acfm

Stack gas dry volumetric flow rate ( $Q_{std}$ ), dscf/hr =

$$3600(1 - B_{ws})V_s A \left[ \frac{528}{460 + T_s} \times \frac{P_s}{29.92} \right]$$

where,

$B_{ws} \frac{0.0060}{51.40}$  = Water vapor in the gas stream, proportion by volume

$V_s \frac{38.4846}{77}$  = Velocity in the stack, ft/sec

$A \frac{28.68}{6,673,789.01}$  = Area of stack, ft<sup>2</sup>

$T_s$  = Average stack temperature, °F

$P_s$  = Absolute stack gas pressure, in. Hg

$Q_{std} 6,673,789.01$  = Stack gas dry volumetric flow rate, dscf/hr

### 2.2.3 Data Summary – FGDRYERS RTO



**USEPA Methodology  
Data Summary**

Methods 2-4		Run #1	Run #2	Run #3	Run #4
	Emission Unit:			FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23	11/29/23
	Start Time:	1315	1435	1635	1745
	Stop Time:	1355	1515	1715	1825
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84	0.840
$D_s$	Stack diameter, ft.	8.7500	8.7500	8.7500	8.7500
$T_m$	Average meter temperature	55	66	65	65
$\Delta H$	Average pressure differential across the orifice meter, in. H <sub>2</sub> O	1.8000	1.8000	1.7000	1.7000
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.26	28.26	28.26	28.26
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00	0.00
$V_{ic}$	Total volume of liquid collected in the impingers and silica gel, mls	168.6	308.5	237.6	314.1
$V_m$	Volume of gas sample as measured by the dry gas meter	28.518	28.600	27.610	28.715
$T_{min}$	Total sampling time, minutes	40.00	40.00	40.00	40.00
$Y$	Dry gas meter calibration factor, dimensionless	0.991	0.991	0.991	0.991
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	16.23	13.67	13.76	13.72
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	4.29	6.89	6.74	6.79
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	79.49	79.44	79.50	79.49
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.3348	29.6487	29.6292	29.6352
$V_{w(std)}$	Volume of water vapor in the gas sample, dry gas meter, cf	7.9360	14.5211	11.1838	14.7847
$P_s$	Absolute stack gas pressure, in. Hg	28.2615	28.2615	28.2615	28.2600
$V_{m(std)}$	Volume of metered gas sample, dry standard	27.5051	27.0069	26.0777	27.1401
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.2239	0.3497	0.3001	0.3526

**USEPA Method 3A  
Data Summary  
Oxygen and Carbon Dioxide**

<b>Oxygen</b>		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>	<b>Run #4</b>
Emission Unit:				FGDRYERS RTO Outlet	
Date:		11/29/23	11/29/23	11/29/23	11/29/23
Start Time:		1308	1428	1631	1745
Stop Time:		1413	1533	1736	1840
C	Average oxygen concentration indicated by the gas analyzer, % dry	16.01	13.39	13.49	13.56
C <sub>o</sub>	Average of initial and final system the zero oxygen calibration gas, % dry	0.11	0.08	0.26	0.21
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale oxygen calibration gas, % dry	9.97	9.88	9.93	10.00
C <sub>ma</sub>	Actual concentration of the upscale oxygen calibration gas, % dry	10.06	10.06	10.06	10.06
C <sub>o2</sub>	Oxygen concentration, % dry	16.23	13.67	13.76	13.72
<b>Carbon Dioxide</b>		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>	<b>Run #4</b>
C	Average carbon dioxide concentration indicated by the gas analyzer, % dry	4.31	6.86	6.69	6.72
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero carbon dioxide calibration gas, % dry	0.11	0.17	0.16	0.16
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon dioxide calibration gas, % dry	8.20	8.19	8.16	8.13
C <sub>ma</sub>	Actual concentration of the upscale carbon dioxide calibration gas, % dry	8.25	8.25	8.25	8.25
C <sub>co2</sub>	Carbon dioxide concentration, % dry	4.29	6.89	6.74	6.79

**USEPA Method 25A  
Data Summary  
Volatile Organic Compounds**

VOC's		Run #1	Run #2	Run #3	Run #4	Run #5	Run #6
	Emission Unit:						
	Date:	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23
	Start Time:	1308	1330	1352	1428	1450	1512
	Stop Time:	1329	1351	1413	1449	1511	1533
C <sub>c3h8(wet)</sub>	Average VOC concentration as propane indicated by the gas analyzer, ppmvw	0.84	1.39	1.99	2.20	2.34	2.28
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero VOC's calibration gas, ppmvd	0.36	0.36	0.36	0.33	0.33	0.33
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale VOC's calibration gas, ppmvd	50.96	50.96	50.96	51.77	51.77	51.77
C <sub>ma</sub>	Actual concentration of the upscale VOC's calibration gas, ppmvd	50.10	50.10	50.10	50.10	50.10	50.10
C <sub>c3h8(corrected)</sub>	VOC concentration as carbon, ppmvw	0.48	1.02	1.61	1.82	1.96	1.90
B <sub>ws</sub>	Water vapor in the gas stream, proportion by volume	0.2239	0.2239	0.2239	0.3497	0.3497	0.3497
C <sub>c3h8(dry)</sub>	VOC concentration as propane, ppmvd	0.62	1.32	2.08	2.80	3.01	2.92
C <sub>voc</sub>	VOC concentration as carbon, ppmvd	1.85	3.95	6.23	8.40	9.03	8.76
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	4,082,272.42	4,119,795.24	4,058,760.64	4,176,461.32	4,222,029.80	4,055,518.22
E <sub>voc</sub>	VOC emission rate as carbon, lbs/hr	0.24	0.51	0.79	1.09	1.19	1.11

**USEPA Method 25A  
Data Summary  
Volatile Organic Compounds**

VOC's		Run #7	Run #8	Run #9	Run #10	Run #11	Run #12
Emission Unit:		FGDRYERS RTO Outlet					
Date:		11/29/23	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23
Start Time:		1631	1653	1715	1745	1807	1829
Stop Time:		1652	1714	1736	1806	1828	1850
C <sub>c3h8(wet)</sub>	Average VOC concentration as propane indicated by the gas analyzer, ppmvw	1.43	1.33	1.36	2.69	2.90	2.87
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero VOC's calibration gas, ppmvd	0.21	0.21	0.21	0.36	0.36	0.36
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale VOC's calibration gas, ppmvd	52.25	52.25	52.25	51.00	51.00	51.00
C <sub>ma</sub>	Actual concentration of the upscale VOC's calibration gas, ppmvd	50.10	50.10	50.10	50.10	50.10	50.10
C <sub>c3h8(corrected)</sub>	VOC concentration as carbon, ppmvw	1.18	1.08	1.10	2.31	2.51	2.48
B <sub>ws</sub>	Water vapor in the gas stream, proportion by volume	0.3001	0.3001	0.3001	0.3526	0.3526	0.3526
C <sub>c3h8(dry)</sub>	VOC concentration as propane, ppmvd	1.68	1.54	1.58	3.57	3.88	3.83
C <sub>voc</sub>	VOC concentration as carbon, ppmvd	5.05	4.61	4.73	10.70	11.65	11.50
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	4,579,812.72	4,527,875.67	4,447,403.73	4,101,165.18	4,044,346.65	3,891,575.27
E <sub>voc</sub>	VOC emission rate as carbon, lbs/hr	0.72	0.65	0.66	1.37	1.47	1.40

**USEPA Method 10  
Data Summary  
Carbon Monoxide**

<b>CO</b>		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>	<b>Run #4</b>	<b>Run #5</b>	<b>Run #6</b>
	Emission Unit:					FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23
	Start Time:	1308	1330	1352	1428	1450	1512
	Stop Time:	1329	1351	1413	1449	1511	1533
C	Average carbon monoxide concentration indicated by the gas analyzer, ppmvd	57.37	85.53	100.23	194.53	228.27	237.99
C <sub>0</sub>	Average of initial and final system calibration bias check responses for the zero carbon monoxide calibration gas, ppmvd	26.59	26.59	26.59	33.80	33.80	33.80
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon monoxide calibration gas, ppmvd	524.28	524.28	524.28	532.38	532.38	532.38
C <sub>ma</sub>	Actual concentration of the upscale carbon monoxide calibration gas, ppmvd	510.00	510.00	510.00	510.00	510.00	510.00
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	4,082,272.42	4,119,795.24	4,058,760.64	4,176,461.32	4,222,029.80	4,055,518.22
C <sub>co</sub>	Carbon monoxide concentration, ppmvd	31.54	60.40	75.47	164.41	198.93	208.87
E <sub>co</sub>	Carbon monoxide emission rate, lbs/hr	9.36	18.09	22.27	49.93	61.07	61.59

**USEPA Method 10  
Data Summary  
Carbon Monoxide**

<b>CO</b>		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>	<b>Run #4</b>	<b>Run #5</b>	<b>Run #6</b>
	Emission Unit:					FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23
	Start Time:	1308	1330	1352	1428	1450	1512
	Stop Time:	1329	1351	1413	1449	1511	1533
C	Average carbon monoxide concentration indicated by the gas analyzer, ppmvd	57.37	85.53	100.23	194.53	228.27	237.99
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero carbon monoxide calibration gas, ppmvd	26.59	26.59	26.59	33.80	33.80	33.80
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon monoxide calibration gas, ppmvd	524.28	524.28	524.28	532.38	532.38	532.38
C <sub>ma</sub>	Actual concentration of the upscale carbon monoxide calibration gas, ppmvd	510.00	510.00	510.00	510.00	510.00	510.00
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	4,082,272.42	4,119,795.24	4,058,760.64	4,176,461.32	4,222,029.80	4,055,518.22
C <sub>co</sub>	Carbon monoxide concentration, ppmvd	31.54	60.40	75.47	164.41	198.93	208.87
E <sub>co</sub>	Carbon monoxide emission rate, lbs/hr	9.36	18.09	22.27	49.93	61.07	61.59

**USEPA Method 10  
Data Summary  
Carbon Monoxide**

<b>CO</b>		<b>Run #7</b>	<b>Run #8</b>	<b>Run #9</b>	<b>Run #10</b>	<b>Run #11</b>	<b>Run #12</b>
	Emission Unit:					FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23	11/29/23
	Start Time:	1631	1653	1715	1745	1807	1829
	Stop Time:	1652	1714	1736	1806	1828	1850
C	Average carbon monoxide concentration indicated by the gas analyzer, ppmvd	275.47	246.91	206.37	224.50	253.33	267.34
C <sub>o</sub>	Average of initial and final system calibration bias check responses for the zero carbon monoxide calibration gas, ppmvd	28.60	28.60	28.60	26.08	26.08	26.08
C <sub>m</sub>	Average of initial and final system calibration bias check responses for the upscale carbon monoxide calibration gas, ppmvd	526.28	526.28	526.28	524.49	524.49	524.49
C <sub>ma</sub>	Actual concentration of the upscale carbon monoxide calibration gas, ppmvd	510.00	510.00	510.00	510.00	510.00	510.00
Q <sub>std</sub>	Stack gas dry volumetric flow rate, dscf/hr	4,579,812.72	4,527,875.67	4,447,403.73	4,101,165.18	4,044,346.65	3,891,575.27
C <sub>co</sub>	Carbon monoxide concentration, ppmvd	252.98	223.71	182.17	203.04	232.54	246.87
E <sub>co</sub>	Carbon monoxide emission rate, lbs/hr	84.24	73.65	58.91	60.55	68.38	69.85

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #1</b>	<b>Run #2</b>	<b>Run #3</b>
	Identification:		FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23
	Start Time:	1321	1335	1355
	Stop Time:	1326	1340	1400
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.4734	0.4757	0.4697
$D_s$	Stack diameter, ft.	8.7500	8.7500	8.7500
$T_s$	Average stack temperature, °F	183	177	180
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.26	28.26	28.26
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.2239	0.2239	0.2239
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	16.23	16.23	16.23
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	4.29	4.29	4.29
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	79.49	79.49	79.49
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.3348	29.3348	29.3348
$P_s$	Absolute stack gas pressure, in. Hg	28.2615	28.2615	28.2615
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	26.7967	26.7967	26.7967
A	Area of the stack, ft <sup>2</sup>	60.1322	60.1322	60.1322
$V_s$	Velocity in the stack, ft/sec	31.3217	31.3392	31.0112
$V_{acfm}$	Velocity in the stack, acfm	113,006.70	113,069.73	111,886.15
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	4,082,272.42	4,119,795.24	4,058,760.64



**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #4</b>	<b>Run #5</b>	<b>Run #6</b>
Identification:			FGDRYERS RTO Outlet	
Date:		11/29/23	11/29/23	11/29/23
Start Time:		1435	1505	1520
Stop Time:		1440	1510	1525
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.5740	0.5870	0.5579
$D_s$	Stack diameter, ft.	8.7500	8.7500	8.7500
$T_s$	Average stack temperature, °F	204	220	206
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.26	28.26	28.26
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.3497	0.3497	0.3497
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	13.67	13.67	13.67
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	6.89	6.89	6.89
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	79.44	79.44	79.44
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.6487	29.6487	29.6487
$P_s$	Absolute stack gas pressure, in. Hg	28.2615	28.2615	28.2615
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	25.5755	25.5755	25.5755
A	Area of the stack, ft <sup>2</sup>	60.1322	60.1322	60.1322
$V_s$	Velocity in the stack, ft/sec	39.5195	40.8827	38.4509
$V_{acfm}$	Velocity in the stack, acfm	142,583.60	147,502.10	138,728.15
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	4,176,461.32	4,222,029.80	4,055,518.22

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #7</b>	<b>Run #8</b>	<b>Run #9</b>
Identification:			FGDRYERS RTO Outlet	
Date:		11/29/23	11/29/23	11/29/23
Start Time:		1640	1700	1725
Stop Time:		1645	1705	1730
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.6048	0.5976	0.5855
$D_s$	Stack diameter, ft.	8.7500	8.7500	8.7500
$T_s$	Average stack temperature, °F	235	234	231
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.26	28.26	28.26
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.3001	0.3001	0.3001
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	13.76	13.76	13.76
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	6.74	6.74	6.74
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	79.50	79.50	79.50
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.6292	29.6292	29.6292
$P_s$	Absolute stack gas pressure, in. Hg	28.2615	28.2615	28.2615
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	26.1388	26.1388	26.1388
A	Area of the stack, ft <sup>2</sup>	60.1322	60.1322	60.1322
$V_s$	Velocity in the stack, ft/sec	42.1257	41.6031	40.6613
$V_{acfm}$	Velocity in the stack, acfm	151,986.70	150,100.95	146,703.27
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	4,579,812.72	4,527,875.67	4,447,403.73

**USEPA Method 2  
Data Summary  
Volumetric Flow Rate**

		<b>Run #10</b>	<b>Run #11</b>	<b>Run #12</b>
	Identification:		FGDRYERS RTO Outlet	
	Date:	11/29/23	11/29/23	11/29/23
	Start Time:	1800	1815	1835
	Stop Time:	1805	1820	1840
$C_p$	Pitot correction factor, dimensionless	0.84	0.84	0.84
$\sqrt{\Delta P}$	Average of the square roots of the pressure heads, in. H <sub>2</sub> O	0.5795	0.5727	0.5487
$D_s$	Stack diameter, ft.	8.7500	8.7500	8.7500
$T_s$	Average stack temperature, °F	237	240	234
$P_{bar}$	Barometric pressure at sampling site, in. Hg	28.26	28.26	28.26
$P_g$	Stack static pressure, in. Hg	0.00	0.00	0.00
$B_{ws}$	Water vapor in the gas stream, proportion by volume	0.3526	0.3526	0.3526
%O <sub>2</sub>	Percent O <sub>2</sub> by volume, dry basis	13.72	13.72	13.72
%CO <sub>2</sub>	Percent CO <sub>2</sub> by volume, dry basis	6.79	6.79	6.79
%CO+N <sub>2</sub>	Percent CO+N <sub>2</sub> by volume, dry basis	79.49	79.49	79.49
$M_d$	Dry molecular weight of stack gasses, lb/lb-mole	29.6354	29.6354	29.6354
$P_s$	Absolute stack gas pressure, in. Hg	28.2615	28.2615	28.2615
$M_s$	Wet molecular weight of stack gasses, lb/lb-mole	25.5322	25.5322	25.5322
A	Area of the stack, ft <sup>2</sup>	60.1322	60.1322	60.1322
$V_s$	Velocity in the stack, ft/sec	40.9000	40.5069	38.6427
$V_{acfm}$	Velocity in the stack, acfm	147,564.33	146,146.28	139,420.38
$Q_{std}$	Stack gas dry volumetric flow rate, dscf/hr	4,101,165.18	4,044,346.65	3,891,575.27

**2.2.4 Run 1 Calculations – FGDRYERS RTO**

### CO RATA AS Calculations

**CEM CO concentrations ( $CEM_{avg}$ ), lbs/hr =**  $CEM_{avg}$

where,

$CEM_{avg}$  7.330 = Average of client CO data over a given run time, lbs/hr

**Oxygen concentration ( $C_{o2}$ ), % =**  $(C_{a(o2)} - C_{0(o2)}) \left( \frac{C_{ma(o2)}}{C_{m(o2)} - C_{0(o2)}} \right)$

where,

$C_{a(o2)}$  16.01 = Average oxygen concentration indicated by the gas analyzer, % dry  
 $C_{0(o2)}$  0.11 = Average of the initial and final system calibration bias check responses for the zero calibration gas, % dry  
 $C_{ma(o2)}$  10.06 = Actual concentration of the upscale calibration gas, % dry  
 $C_{m(o2)}$  9.97 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, % dry  
 $C_{o2}$  16.23 = Oxygen concentration, % dry

**Carbon dioxide concentration ( $C_{co2}$ ), % =**  $(C_{a(co2)} - C_{0(co2)}) \left( \frac{C_{ma(co2)}}{C_{m(co2)} - C_{0(co2)}} \right)$

where,

$C_{a(co2)}$  4.31 = Average carbon dioxide concentration indicated by the gas analyzer, % dry  
 $C_{0(co2)}$  0.11 = Average of the initial and final system calibration bias check responses for the zero calibration gas, % dry  
 $C_{ma(co2)}$  8.25 = Actual concentration of the upscale calibration gas, % dry  
8.20 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, % dry  
 $C_{m(co2)}$  8.20  
 $C_{co2}$  4.29 = Carbon dioxide concentration, % dry

**Carbon monoxide concentration ( $C_{co}$ ), ppmvd =**  $(C_{a(co)} - C_{0(co)}) \left( \frac{C_{ma(co)}}{C_{m(co)} - C_{0(co)}} \right)$

where,

$C_{a(co)}$  57.37 = Average carbon monoxide concentration indicated by the gas analyzer, ppm  
 $C_{0(co)}$  26.59 = Average of the initial and final system calibration bias check responses for the zero calibration gas, ppmvd  
 $C_{ma(co)}$  510.00 = Actual concentration of the upscale calibration gas, ppmvd  
524.28 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, ppmvd  
 $C_{m(co)}$  524.28  
 $C_{co}$  31.54 = Carbon monoxide concentration, ppmvd

**Carbon monoxide emission rate ( $E_{co}$ ), lbs/hr =** 
$$\left( \frac{C_{co} \times 28 \times Q_{std}}{385100000} \right)$$

where,

$C_{co}$  31.54 = Carbon monoxide concentration, ppmvd  
 $Q_{std}$  4,082,272.42 = Stack gas dry volumetric flow rate, dscf/hr  
 $E_{co}$  9.36 = Carbon monoxide emission rate, lbs/hr

**Confidence coefficient (CC) =** 
$$t_{0.975} \frac{S_d}{\sqrt{n}}$$

where,

$T_{0.975}$  2.201 = t-value for n-1 degrees of freedom  
 $S_d$  1.79 = Standard deviation of the difference of the reference method and CEM  
 $\sqrt{n}$  3.5 = square root of the number of data points (runs)  
 $CC$  1.13 = Confidence coefficient

**Relative accuracy (RA), % =** 
$$\frac{|\bar{d}| + |CC|}{\overline{RM}}$$

where,

$|\bar{d}|$  3.10 = Absolute value of the mean of the differences  
 $|CC|$  1.13 = Absolute value of the confidence coefficient  
 $\overline{AS}$  147.30 = Applicable standard  
 $RA$  2.87 = Relative accuracy of CEM CO monitor, percent of applicable standard

**Methods 2 and 4**

**Dry molecular weight of stack gasses ( $M_d$ ), lb/lb-mole =** 
$$0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%CO + N_2)$$

where,

$C_{co2}$  16.23 = Carbon dioxide concentration, % dry  
 $C_{o2}$  4.29 = Oxygen concentration, % dry  
 $C_{co+n2}$  79.49 = Carbon monoxide plus nitrogen concentrations, % dry  
 $M_d$  29.3348 = Dry molecular weight of stack gasses, lb/lb-mole

**Volume of water vapor in the gas sample ( $V_{w(std)}$ ), dscf =** 
$$0.04707 * V_{ic}$$

where,

$V_{ic}$  168.6 = Total volume of liquid collected in impingers and silica gel, mls  
 $V_{w(std)}$  7.9360 = Volume of water vapor in the gas sample, dscf

**Volume of metered gas sample ( $V_{m(std)}$ ), dscf =**

where,

$$17.64 V_m Y \frac{P_{bar} + \left(\frac{\Delta H}{13.6}\right)}{460 + T_m}$$

$V_m$  28.518 = Volume of gas sample as measured by dry gas meter, cf  
 $Y$  0.991 = Dry gas meter calibration factor, dimensionless  
 $P_{bar}$  28.26 = Barometric pressure at sampling site, in. Hg  
 $\Delta H$  1.800 = Average pressure differential across the orifice meter, in. H<sub>2</sub>O  
 $T_m$  55 = Average meter temperature, °F  
 $V_{m(std)}$  27.5051 = Volume of metered gas sample, dscf

**Water vapor in the gas stream ( $B_{ws}$ ), proportion by volume =**

where,

$$\frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}}$$

$V_{w(std)}$  7.9360 = Volume of water vapor in the gas sample, dscf  
 $V_{m(std)}$  27.5051 = Volume of metered gas sample, dscf  
 $B_{ws}$  0.2239 = Water vapor in the gas stream, proportion by volume

**Absolute stack gas pressure ( $P_s$ ), in. Hg =**

$$P_{bar} + P_g$$

where,

$P_{bar}$  28.26 = Barometric pressure at sampling site, in. Hg  
 $P_g$  0.00 = Stack static pressure, in. Hg  
 $P_s$  28.26 = Absolute stack gas pressure, in. Hg

**Wet molecular weight of stack gasses ( $M_s$ ), lb/lb-mole =**

$$M_d (1 - B_{ws}) + 18.0 B_{ws}$$

where,

$M_d$  29.3348 = Dry molecular weight of stack gasses, lb/lb-mole  
 $B_{ws}$  0.2239 = Water vapor in the gas stream, proportion by volume  
 $M_s$  26.7967 = Wet molecular weight of stack gasses, lb/lb-mole

**Area of stack (A), ft<sup>2</sup> =**

$$\left(\frac{D_s}{2}\right)^2 \times 3.1416$$

where,

$D_s$  8.7500 = Stack diameter or dimensions, ft  
 $A$  60.1322 = Area of stack, ft<sup>2</sup>

Velocity in the stack ( $V_s$ ), ft/sec =

$$85.49 C_p \sqrt{\Delta P_{avg}} \sqrt{\frac{460 + T_s}{P_s M_s}}$$

where,

$C_p$  0.84 = Pitot correction factor, dimensionless  
 $\sqrt{\Delta P}$  0.4734 = Average of the square roots of the pressure heads, in. H<sub>2</sub>O  
 $T_s$  183 = Average stack temperature, °F  
 $P_s$  28.26 = Absolute stack gas pressure, in. Hg  
 $M_s$  26.7967 = Wet molecular weight of stack gasses, lb/lb-mole  
 $V_s$  31.32 = Velocity in the stack, ft/sec

Velocity in the stack ( $V_{acfm}$ ), acfm =

$$60 \times A \times V_s$$

where,

$A$  60.1322 = Area of stack, ft<sup>2</sup>  
 $V_s$  31.32 = Velocity in the stack, ft/sec  
 $V_{acfm}$  113,006.70 = Velocity in the stack, acfm

Stack gas dry volumetric flow rate ( $Q_{std}$ ), dscf/hr =

$$3600 (1 - B_{ws}) V_s A \left[ \frac{528}{460 + T_s} \times \frac{P_s}{29.92} \right]$$

where,

$B_{ws}$  0.2239 = Water vapor in the gas stream, proportion by volume  
 $V_s$  31.32 = Velocity in the stack, ft/sec  
 $A$  60.1322 = Area of stack, ft<sup>2</sup>  
 $T_s$  183 = Average stack temperature, °F  
 $P_s$  28.26 = Absolute stack gas pressure, in. Hg  
 $Q_{std}$  4,082,272.42 = Stack gas dry volumetric flow rate, dscf/hr



### VOC RATA AS Calculations

**CEM VOC concentrations ( $CEM_{avg}$ ), lbs/hr =**  $CEM_{avg}$

where,

$CEM_{avg}$  7.330 = Average of client VOC data over a given run time, lbs/hr

**Oxygen concentration ( $C_{o2}$ ), % =**  $(C_{a(o2)} - C_{0(o2)}) \left( \frac{C_{ma(o2)}}{C_{m(o2)} - C_{0(o2)}} \right)$

where,

$C_{a(o2)}$  16.01 = Average oxygen concentration indicated by the gas analyzer, % dry  
 $C_{0(o2)}$  0.11 = Average of the initial and final system calibration bias check responses for the zero calibration gas, % dry  
 $C_{ma(o2)}$  10.06 = Actual concentration of the upscale calibration gas, % dry  
 $C_{m(o2)}$  9.97 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, % dry  
 $C_{o2}$  16.23 = Oxygen concentration, % dry

**Carbon dioxide concentration ( $C_{co2}$ ), % =**  $(C_{a(co2)} - C_{0(co2)}) \left( \frac{C_{ma(co2)}}{C_{m(co2)} - C_{0(co2)}} \right)$

where,

$C_{a(co2)}$  4.31 = Average carbon dioxide concentration indicated by the gas analyzer, % dry  
 $C_{0(co2)}$  0.11 = Average of the initial and final system calibration bias check responses for the zero calibration gas, % dry  
 $C_{ma(co2)}$  8.25 = Actual concentration of the upscale calibration gas, % dry  
8.20 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, % dry  
 $C_{m(co2)}$  8.20 = Average of the initial and final system calibration bias check responses for the upscale calibration gas, % dry  
 $C_{co2}$  4.29 = Carbon dioxide concentration, % dry

**VOC concentration as carbon ( $C_{c(dry)}$ ), ppmvd =**  $\frac{3C_{c3h8(wet)}}{(1 - B_{ws})}$

where,

$C_{c3h8(wet)}$  0.62 = VOC concentration as propane, ppmvw  
 $B_{ws}$  0.2239 = Water vapor in the gas stream, proportion by volume  
 $C_{c(dry)}$  1.85 = VOC concentration as carbon, ppmvd

**VOC emission rate as carbon ( $E_{voc}$ ), lbs/hr =**  $\frac{C_{c(dry)} \times 12 \times Q_{std}}{385.1E06}$

where,

$C_{c(dry)}$  1.85 = VOC concentration as carbon, ppmvd  
 $Q_{std}$  4,082,272.42 = Volume of metered gas sample, dscf  
 $E_{voc}$  0.24 = VOC emission rate as carbon, lbs/hr

Confidence coefficient (CC) =

$$t_{0.975} \frac{S_d}{\sqrt{n}}$$

where,

$$T_{0.975} \frac{2.201}{0.63} = \text{t-value for } n-1 \text{ degrees of freedom}$$

$$S_d = \text{Standard deviation of the difference of the reference method and CEM}$$

$$\sqrt{n} \frac{3.5}{0.40} = \text{square root of the number of data points (runs)}$$

$$CC = \text{Confidence coefficient}$$

Relative accuracy (RA), % =

$$\frac{|\bar{d}| + |CC|}{RM}$$

where,

$$|\bar{d}| \frac{1.29}{0.40} = \text{Absolute value of the mean of the differences}$$

$$|CC| \frac{0.40}{18.60} = \text{Absolute value of the confidence coefficient}$$

$$AS \frac{18.60}{9.11} = \text{Applicable standard}$$

$$RA \frac{9.11}{18.60} = \text{Relative accuracy of CEM CO monitor, percent of applicable standard}$$

#### Methods 2 and 4

Dry molecular weight of stack gasses ( $M_d$ ), lb/lb-mole =  $0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%CO + N_2)$

where,

$$C_{CO_2} \frac{16.23}{4.29} = \text{Carbon dioxide concentration, \% dry}$$

$$C_{O_2} \frac{4.29}{79.49} = \text{Oxygen concentration, \% dry}$$

$$C_{CO+N_2} \frac{79.49}{29.3348} = \text{Carbon monoxide plus nitrogen concentrations, \% dry}$$

$$M_d \frac{29.3348}{29.3348} = \text{Dry molecular weight of stack gasses, lb/lb-mole}$$

Volume of water vapor in the gas sample ( $V_{w(std)}$ ), dscf =  $0.04707 * V_{ic}$

where,

$$V_{ic} \frac{168.6}{7.9360} = \text{Total volume of liquid collected in impingers and silica gel, mls}$$

$$V_{w(std)} \frac{7.9360}{7.9360} = \text{Volume of water vapor in the gas sample, dscf}$$

Volume of metered gas sample ( $V_{m(std)}$ ), dscf =

where,

$$17.64 V_m Y \frac{P_{bar} + \left(\frac{\Delta H}{13.6}\right)}{460 + T_m}$$

$$V_m \frac{28.518}{0.991} = \text{Volume of gas sample as measured by dry gas meter, cf}$$

$$Y \frac{0.991}{28.26} = \text{Dry gas meter calibration factor, dimensionless}$$

$$P_{bar} \frac{28.26}{1.800} = \text{Barometric pressure at sampling site, in. Hg}$$

$$\Delta H \frac{1.800}{55} = \text{Average pressure differential across the orifice meter, in. H}_2\text{O}$$

$$T_m \frac{55}{27.5051} = \text{Average meter temperature, } ^\circ\text{F}$$

$$V_{m(std)} \frac{27.5051}{27.5051} = \text{Volume of metered gas sample, dscf}$$

**Water vapor in the gas stream ( $B_{ws}$ ), proportion by volume =** 
$$\frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}}$$

where,

$V_{w(std)} \frac{7.9360}{27.5051}$  = Volume of water vapor in the gas sample, dscf

$V_{m(std)} \frac{27.5051}{27.5051}$  = Volume of metered gas sample, dscf

$B_{ws} \frac{0.2239}{0.2239}$  = Water vapor in the gas stream, proportion by volume

**Absolute stack gas pressure ( $P_s$ ), in. Hg =** 
$$P_{bar} + P_g$$

where,

$P_{bar} \frac{28.26}{28.26}$  = Barometric pressure at sampling site, in. Hg

$P_g \frac{0.00}{0.00}$  = Stack static pressure, in. Hg

$P_s \frac{28.26}{28.26}$  = Absolute stack gas pressure, in. Hg

**Wet molecular weight of stack gasses ( $M_s$ ), lb/lb-mole =** 
$$M_d(1 - B_{ws}) + 18.0B_{ws}$$

where,

$M_d \frac{29.3348}{29.3348}$  = Dry molecular weight of stack gasses, lb/lb-mole

$B_{ws} \frac{0.2239}{0.2239}$  = Water vapor in the gas stream, proportion by volume

$M_s \frac{26.7967}{26.7967}$  = Wet molecular weight of stack gasses, lb/lb-mole

**Area of stack ( $A$ ), ft<sup>2</sup> =** 
$$\left(\frac{D_s}{2}\right)^2 \times 3.1416$$

where,

$D_s \frac{8.7500}{8.7500}$  = Stack diameter or dimensions, ft

$A \frac{60.1322}{60.1322}$  = Area of stack, ft<sup>2</sup>

**Velocity in the stack ( $V_s$ ), ft/sec =** 
$$85.49C_p \sqrt{\Delta P_{avg}} \sqrt{\frac{460 + T_s}{P_s M_s}}$$

where,

$C_p \frac{0.84}{0.84}$  = Pitot correction factor, dimensionless

$\sqrt{\Delta P} \frac{0.4734}{0.4734}$  = Average of the square roots of the pressure heads, in. H<sub>2</sub>O

$T_s \frac{183}{183}$  = Average stack temperature, °F

$P_s \frac{28.26}{28.26}$  = Absolute stack gas pressure, in. Hg

$M_s \frac{26.7967}{26.7967}$  = Wet molecular weight of stack gasses, lb/lb-mole

$V_s \frac{31.32}{31.32}$  = Velocity in the stack, ft/sec

<p><b>Velocity in the stack (<math>V_{acfm}</math>), acfm =</b></p> <p>where,</p> <p><math>A \frac{60.1322}{31.32} =</math> Area of stack, ft<sup>2</sup></p> <p><math>V_s \frac{60.1322}{31.32} =</math> Velocity in the stack, ft/sec</p> <p><math>V_{acfm} \frac{60.1322}{31.32} =</math> Velocity in the stack, acfm</p>	<p><math>60 \times A \times V_s</math></p>
<p><b>Stack gas dry volumetric flow rate (<math>Q_{std}</math>), dscf/hr =</b></p> <p>where,</p> <p><math>B_{ws} \frac{0.2239}{31.32} =</math> Water vapor in the gas stream, proportion by volume</p> <p><math>V_s \frac{0.2239}{31.32} =</math> Velocity in the stack, ft/sec</p> <p><math>A \frac{0.2239}{31.32} =</math> Area of stack, ft<sup>2</sup></p> <p><math>T_s \frac{0.2239}{183} =</math> Average stack temperature, °F</p> <p><math>P_s \frac{0.2239}{28.26} =</math> Absolute stack gas pressure, in. Hg</p> <p><math>Q_{std} \frac{0.2239}{4,082,272.42} =</math> Stack gas dry volumetric flow rate, dscf/hr</p>	<p><math>3600(1 - B_{ws})V_s A \left[ \frac{528}{460 + T_s} \times \frac{P_s}{29.92} \right]</math></p>

## 3.0 Facility and Sampling Location Descriptions

### 3.1 Process Description and Operation

Weyerhaeuser manufactures oriented-strand board (OSB) at its facility in Grayling, Michigan. Wood logs are sorted by species and stored in the wood yard. Logs are transferred to heated vats to clean and thaw (in winter months) the wood. The wood logs are conveyed from the vats to a debarking machine that removes the outer layers of the logs. A ring-strander cuts the logs into thin wood chips (strands). The strands are conveyed to a storage bin where they are fed into four wood-fired dryers. The dryers remove moisture from the strands to product-specific content. The strands exit the dryers and are sorted according to size using shaker screens.

The fine strands are collected and used as fuel in the dryers and RTOs. The larger strands are conveyed to a blending area where wax and resins are added for adhesion purposes. The strands are then layered, at different angles for strength, onto an 8-foot-wide conveyor belt. The layered strands are cut into 8-foot-by-24-foot sections and formed into mats. The mats are stacked and the press is used to heat and compact the strands to form OSB. Depending on the thickness of the product (i.e., 7/16 or 3/8 inch) up to 16 mats can be compacted in less than 4 minutes. The OSB is cut, labeled, and prepared for shipment.

As part of the manufacturing process, emissions are generated by wood debarking and stranding, conveyance, drying, binding, pressing, milling, and painting (sides of wood). Weyerhaeuser operates pollution control equipment to control the discharge of pollutants to the atmosphere. The biofilter, wet electrostatic precipitator (WESP), and RTOs control emissions from the drying and pressing operations.

The VOC CERMS installed on the EUPRESSLINE Biofilter, and the VOC and CO CERMS and COMS on the FGDRYERS RTO exhaust stacks are used to evaluate continuous compliance with permit limits.

The pages included in Section 3.4 of this report detail the production/throughput data maintained by the facility during the testing program, which were provided to ESC after the completion of the sampling event.

## **3.2 CEMS Description**

### **EUPRESSLINE Biofilter Outlet**

The VOC monitor is a California Analytical Instruments, Inc., Model 600 HFID, Serial Number B05010. The system extracts sample gas through a heated sample probe and heated filter connected to the monitor by a heated sample line. The VOC analyzer measures total hydrocarbons using a flame ionization detector (FID). The VOC monitor operates on a single range/span of 0 to 100 parts per million (ppm).

The flowrate monitor is a Teledyne UltraFlow Model 150, Serial number 1501355. The air flowrate is measured by ultrasonic methods. The flow monitoring system uses 20% oxygen and 0% carbon dioxide for the flowrate calculations.

### **FGDRYERS RTO Outlet**

The VOC monitor is a California Analytical Instruments, Inc., Model 600 HFID, Serial Number B05011. The system extracts sample gas through a heated sample probe and heated filter connected to the monitor by a heated sample line. The VOC analyzer measures total hydrocarbons using a FID. The VOC monitor operates on a dual range span: 0 to 100 ppm and 1 to 1,000 ppm.


The CO monitor is a California Analytical Instruments, Inc., Model 601, Serial Number B06014-M. The system extracts sample gas through a heated sample probe and heated filter connected to the gas conditioning system by a heated sample line. Moisture is removed from the sample before the sample is analyzed. The CO analyzer measures carbon monoxide concentration by non-dispersive infrared analysis. The analyzer has a span of 1 to 1,000 ppm.

The flowrate monitor is a Teledyne Ultraflow Model 150, Serial Number 1501354. The air flowrate is measured by ultrasonic methods. The flowrate monitoring system uses 20% oxygen and 1% carbon dioxide for the flowrate calculations.

## **3.3 Flue Gas Sampling Locations**


Gas stream sampling was conducted in accordance with U.S. EPA Method 1 for the sources tested. Attached in Section 3.3 are the schematics of the sampling locations and traverse points that provide a representative sample of the sources.

## 3.4 Stack Schematics




Weyerhaeuser - Grayling, MI  
EUPRESSLINE Biofilter  
Side View






<u>Sample Point</u>	<u>Location</u>
1 and 9	5.7"
2 and 10	11.8"
3 and 11	19.3"
4 and 12	30.1"
5 and 13	59.9"
6 and 14	70.7"
7 and 15	78.2"
8 and 16	84.3"

Weyerhaeuser - Grayling, MI  
 EUPRESSLINE Biofilter  
 Sample Points



Weyerhaeuser - Grayling, MI  
FGDRYERS RTO  
Side View



<u>Sample Point</u>	<u>Location</u>
1, 8, 9 and 16	9.9"
2, 7, 10 and 15	17.5"
3, 6, 11 and 14	26.9"
4, 5, 12 and 13	40.4"

Weyerhaeuser - Grayling, MI  
 FGDRYERS RTO  
 Sample Points