



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
JACKSON DISTRICT OFFICE



C. HEIDI GREYER  
DIRECTOR

March 20, 2018

**CERTIFIED MAIL 7010 0290 0000 3734 2750**  
**RETURN RECEIPT REQUESTED**

Mr. George Gancsos Jr.  
Henry Ford Allegiance Health  
205 N. East Avenue  
Jackson, MI 49201

SRN: A2236, Jackson County

Dear Mr. Gancsos Jr.:

**VIOLATION NOTICE**

On March 8, 2018, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an inspection of Henry Ford Allegiance Health (Company) located at 205 N. East Avenue, Jackson, Michigan. The purpose of this inspection was to determine the Company's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
Three (3) emergency engines each rated at 1500KW fired by No. 2 fuel oil with a faceplate date of 2006 to 2008.	40 CFR Part 60, Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines	No indication that the Company has filed the required initial notification form or conducted required performance testing. No indication that the engines carry an EPA certification.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by April 10, 2018. The written response should include: the date the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If the Company believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of Henry Ford Allegiance Health. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Mike Kovalchick  
Senior Environmental Engineer  
Air Quality Division  
517-416-5025

cc/via e-mail: Ms. Mary Ann Dolehanty, DEQ  
Mr. Craig Fitzner, DEQ  
Mr. Chris Ethridge, DEQ  
Mr. Thomas Hess, DEQ  
Mr. Scott Miller, DEQ