

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Selfridge Air National Guard Base	SRN : F3254
Location : Selfridge Air National Guard, MI 48045 127th Wing/Environment Mgmt Office	District : Warren
	County : MACOMB
City : MOUNT CLEMENS	State: MI Zip Code : 48045 Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Kerry Kelly
FCE Begin Date : 8/1/2022	FCE Completion Date : 9/8/2023
Comments : Based on information gathered from the inspection on 8/22/2023, SANGB is in compliance with the applicable requirements evaluated.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/22/2023	On-site Inspection	Compliance	Based on information gathered from this inspection, SANGB is in compliance with the applicable requirements evaluated.
05/08/2023	MAERS	Compliance	MAERS Report Submission. Audit complete. Facility is using MAERS factors for AGE, natural gas fired heating equipment, and some fuel storage operations. Emissions calculations were provided for EUs for which MAERS emission factors were not used. 2022 MAERS reported throughputs for AGE, heaters, cold cleaners, and fuel storage equipment are less than the respective 12-month rolling throughput limits in PTI 523-96A.
09/06/2022	On-site Inspection	Non Compliance	FY 2022 targeted inspection. SANGB exceeded the 450,000 kW hours per 12-month time period limit for diesel generators in SC 4.1, starting with the 12-month period ending September 2021. A notice of violation was issued November 22, 2021 for the exceedance. Resolution is pending.

Name: K. Kelly

Date: 9/8/2023

Supervisor: Joyce