


DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : FERRIS STATE UNIVERSITY	SRN : K2155
Location : 625 S WARREN AVE	District : Grand Rapids
	County : MECOSTA
City : BIG RAPIDS State: MI Zip Code : 49307	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Steve Lachance
FCE Begin Date : 9/8/2013	FCE Completion Date : 9/9/2014
Comments : FCE for FY '014	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
09/03/2014	Scheduled Inspection	Compliance	Scheduled but Unannounced Inspection; FCE for FY '014. Field dates 9-3-14 and 9-8-14. See CA_K215526742.
03/31/2014	Stack Test	Non Compliance	Emission Sampling report for turbine and turbine/duct burner; originally indicates marginal non-compliance with NOx limit for Turbine-only, 100% operations (ppm). Facility re-tested in October 2013; see 12-13-13 Stack Test Report Summary. (SLachance, 3/31/14)
03/31/2014	Stack Test	Compliance	Emission Sampling of Turbine No. 2 on 10/15 and 10/16/2013; PTI application 5-14 submitted and issued in response to ACTUAL ALLOWED NSPS Limit. NOx limit in original permit was not supported by NSPS. Facility has now demonstrated compliance with newly-issued (corrected) permit limit. (SLachance, 3/31/14)
03/21/2014	MAERS	Compliance	See e-notes in MAERS Audit Console (SLachance, 3-21-14)
10/16/2013	Stack Test Observation	Compliance	Two Days of Stack Test Observations- FGCOGEN (SLachance, 10/17/13)

Name:  Date: 9-9-14 Supervisor: 