

EXECUTIVE SUMMARY

Chase Young Environmental Testing Inc (CYET) was retained by Central Michigan University (CMU) [SRN: K2460] to conduct emission testing at the EUGASTURBINE at their facility located at 1720 East Campus Drive in Mount Pleasant, Michigan 48859 in Isabella County. The emissions test program was conducted on October 19, 2022 and was performed in accordance with CYET project number 221643 Emission Test Plan as well as the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Air Quality Division (AQD) acceptance letter.

The emissions test program was conducted to determine compliance with MI-ROP-K2460-2021 issued by the Michigan department of Environment, Great Lakes, and Energy (EGLE). EUGASTURBINE is part of the Flexible Group FGPOWERPLANT and is subject to the emission limits of the MI-ROP-K2460-2021 and 40 CFR Part 60, Subpart GG. The emission limit for EUGASTURBINE is 167 ppmv NOx @15% O2 corrected to ISO standard day conditions.

Table 1
EUGASTURBINE Overall Emission Summary
Test Date: October 19, 2022

Condition	kW	NOx ppmv @15% O ₂ Corrected to ISO Standard Day Conditions
100% Load	3,200 kW	102
75% Load	2,400 kW	108
50% Load	1,600 kW	90
30% Load	960 kW	70



TABLE OF CONTENTS

1.]	INTRODUCTION	. 5
1.A 1.B 1.C 1.L	PURPOSE OF TESTING	5
2. 5	SUMMARY OF RESULTS	. 7
2.F 2.F 2.C	APPLICABLE PERMIT	8
3.	SOURCE DESCRIPTION	. 8
3.A 3.E 3.C 3.E 3.E	PROCESS FLOW DIAGRAM	8 8
4. 5	SAMPLING AND ANALYTICAL PROCEDURES	. 8
4.A 4.E 4.C 4.E	RECOVERY AND ANALYTICAL PROCEDURES	10
5.	TEST RESULTS AND DISCUSSION	10
5.A 5.E 5.C 5.E 5.E 5.E 5.C 5.E	DISCUSSION OF RESULTS SAMPLING PROCEDURE VARIATIONS PROCESS OR CONTROL DEVICE UPSETS CONTROL DEVICE MAINTENANCE RE-TEST AUDIT SAMPLE ANALYSES CALIBRATION SHEETS	11 11 11 11 11 11
5.I 5.J	FIELD DATA SHEETS	12



TABLE OF CONTENTS (continued)

APPENDIX A - EMISSION RESULTS TABLES

lable l	EUGASTURBINE Overall Emission Summary
Table 2	Test Personnel
Table 3	Reporting Units and Emission Limits
Table 4	EUGASTURBINE NOx Emission Rates, 100% Load
Table 5	EUGASTURBINE NOx Emission Rates, 75% Load
Table 6	EUGASTURBINE NOx Emission Rates, 50% Load
Table 7	EUGASTURBINE NOx Emission Rates, 30% Load

APPENDIX B - FIGURES

Figure 1 – EUGASTURBINE Exhaust Stack Diagram Figure 2 – USEPA Method 3A/7E Sampling Train Diagram

ADDITIONAL APPENDICES

A man din C	Field and Commuter Commuted Description of Field Nature
Appendix C	Field and Computer-Generated Raw Data and Field Notes
Appendix D	Equipment Calibration and Span Gas Documents
Appendix E	Example Calculations
Appendix F	Process Flow Diagram and Process Data
Appendix G	EGLE AQD Test Plan Acceptance Letter

RECEIVED

NOV 07 2022

AIR QUALITY DIVISION



1. Introduction

Chase Young Environmental Testing Inc (CYET) was retained by Central Michigan University (CMU) [SRN: K2460] to conduct emission testing at the EUGASTURBINE at their facility located at 1720 East Campus Drive in Mount Pleasant, Michigan 48859 in Isabella County. The emissions test program was conducted on October 19, 2022 and was performed in accordance with CYET project number 221643 Emission Test Plan as well as the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Air Quality Division (AQD) acceptance letter. The purpose of this report is to document the results of the test program.

The test program was conducted to determine compliance with MI-ROP-K2460-2021 issued by the Michigan department of Environment, Great Lakes, and Energy (EGLE). EUGASTURBINE is part of the Flexible Group FGPOWERPLANT and is subject to the emission limits of the MI-ROP-K2460-2021 and 40 CFR Part 60, Subpart GG.

1.a Identification, Location, and Dates of Test

Sampling and analysis for the emission test program was conducted on October 19, 2022 at the CMU Plant located in Mount Pleasant, MI.

Testing on the EUGASTURBINE consisted of a single 36-minute test run and eleven 21-minute test runs. Three test runs were performed at each of four different load settings (30% peak load, 50% peak load, 75% peak load, and 90-100% peak load).

1.b Purpose of Testing

AQD issued Renewable Operating Permit No. MI-ROP-K2460-2021 to CMU on March 3, 2021. This permit limits emissions as summarized by Table 2.

Table 2
Reporting Units and Emission Limits

Unit ID/ Source Name	Parameter	Reporting Units	Emission Limit	Emission Limit Reference
EUGASTURBINE	NO_x	ppmvd @15% O ₂ and ISO standard	167	MI-ROP-K2460-2021 40 CFR Part 60, Subpart
		Day Conditions		GG



1.c Source Description

EUGASTURBINE is a natural gas or fuel oil fired turbine, 3,130 KW output (40 MMBTU/hr input) for campus electric generation. This emission unit is subject to 40 CFR Part 60, Subparts A and GG. (PTI 32-05). It is part of the flexible group ID FGPOWERPLANT in PTI 32-05.

Figure 1 present the test ports and traverse/sampling point locations used.

1.d Test Program Contacts

The contact for the source and test report is:

Mr. John Fernandez Supervisor Utilities/Operations Central Michigan University Fernalj@cmich.edu (989) 774-4437

Names and affiliations for personnel who were present during the testing program are summarized by Table 3.



Table 3
Test Personnel

l est Personnel				
Name, Title, and Email	Affiliation	Telephone		
Mr. John Fernandez Supervisor Utilities/Operations Fernalj@cmich.edu	Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859	(989) 774-4437		
Mr. Michael Walton Director of Energy and Utilities Waltolmj@cmich.edu	Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859	(989) 774-1566		
Mr. Tharen Foster Utilities/Operations	Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859	(989) 774-4437		
Mr. Brandon Chase Senior Environmental Engineer bchase@cyetinc.com	CYET 28744 Groveland Street Madison Heights, MI 48071	(248) 506-0107		
Mr. Matthew Young Senior Project Manager myoung@cyetinc.com	CYET 28744 Groveland Street Madison Heights, MI 48071	(586) 744-9133		
Mr. Benjamin Witkopp Environmental Quality Analyst WitkoppB@michigan.gov	Technical Programs Unit Air Quality Division – Field Operations Michigan Dept of Environment, Great Lakes & Energy	(989) 295-1612		

2. Summary of Results

Sections 2.a through 2.d summarize the results of the emissions compliance test program.

2.a Operating Data

Process data monitored during the emissions test program include:

- KW output unit set point,
- natural gas usage, ccf

Process operating data is included in Appendix F.



2.b Applicable Permit

The applicable permit for this emissions test program is Renewable Operating Permit (ROP) No. MI-ROP-K2460-2021.

2.c Results

The overall results of the emission test program are summarized by Table 1 (see Section 5.a, and Appendix A). Emission limits are presented in Table 2 (see section 1.b, and Appendix A). Detailed emission rates are presented in Tables 4-7 in Appendix A.

3. Source Description

Sections 3.a through 3.e provide a detailed description of the process.

3.a Process Description

Natural gas or fuel oil fired turbine, 3,130 KW output (40 MMBTU/hr input) for campus electric generation. This emission unit is subject to 40 CFR Part 60, Subparts A and GG. (PTI 32-05).

3.b Process Flow Diagram

Due to the simplicity of the process, a process flow diagram is not necessary.

3.c Raw and Finished Materials

Raw material used is natural gas. The finished product is electricity.

3.d Process Capacity

The natural gas or fuel oil fired turbine is rated at 3,130 KW output (40 MMBTU/hr input) for campus electric generation. This emission unit is subject to 40 CFR Part 60, Subparts A and GG. (PTI 32-05).

3.e Process Instrumentation

Process data monitored during the emissions test program include:

- KW output unit set point,
- natural gas usage, ccf

Process operating data is included in Appendix F.

4. Sampling and Analytical Procedures

Sections 4.a through 4.d provide a summary of the sampling and analytical procedures used.



4.a Sampling Train and Field Procedures

Sampling and analysis procedures followed the methods codified at 40 CFR 60, Appendix A:

- Method 1 "Sample and Velocity Traverses for Stationary Sources" was used to determine the sampling locations and the stack traverse points.
- Method 3A "Determination of Oxygen and Carbon Dioxide Concentrations in emissions from stationary sources" (Instrumental Analyzer Procedure) was used to determine the oxygen concentration of the exhaust gas.
- Method 7E "Determination of Nitrogen Oxides Emissions from Stationary Sources" (Instrumental Analyzer Procedure) was used to determine the nitrogen oxide concentration of the exhaust gas.

USEPA Method 1 was utilized to determine the necessary sampling points in which to collect the air pollutants. Twelve sampling points were used for the stratification test which was performed during Run 1.

The NOx and O_2 content of the gas stream was measured using a Teledyne API 200EH NOx and O_2 gas analyzer. The gas stream was drawn through a stainless-steel probe with a heated in-line filter to remove any particulate, a heated Teflon® sample line, through a refrigerated Teflon® sample conditioner to remove the moisture from the sample before it entered the analyzer. Data was recorded on a PC equipped with data acquisition software. Recorded NOx and O_2 concentrations were averaged and reported for the duration of each test (as drift corrected per Method 7E). A drawing of the sampling train used for the testing program is presented as Figure 2.

In accordance with Method 7E, a 3-point (zero, mid, and high) bias check and calibration check was performed on the analyzer prior to initiating the test program. Following each test run, a 2-point (zero and high) calibration drift check was performed. The analyzer was operated at the 0-25% range for O_2 and 0-500 ppm range for NOx.

A stratification test was performed on Run 1 as specified in Method 7E. The probe was marked for 12 sampling points using Method 1. Each point was sampled for 3 minutes (twice the sample response time of 90 seconds), for a total of 36 minutes. The NOx and O_2 concentrations were averaged for each sample point. NOx concentrations were then corrected to $15\% O_2$. The oxygen corrected NOx concentrations for each sampling point were compared with the overall average oxygen corrected NOx concentration for Run 1. None of the sampling points differed by greater than 5% from the overall average, therefore a single sampling point located at the centroid of the stack was used for Runs 2 through 12 as specified in Method 7E and 40 CFR Part 60, \S 60.335 (a)(5)(ii)(B).



NOx Concentrations were normalized to ISO Standard Day conditions using the equation from §60.335(b)(1)) below:

 $NO_xISO=(NO_{xo})(Pr/Po)^{0.5}(e)^{19*(Ho-0.633)}(288 \text{ °K/Ta})^{1.53}$

Where:

NO_{xo} = Mean observed NOx concentration, ppmvd @15%O₂

Pr = Reference Pressure (29.92 in Hg)

Po = Observed Pressure (barometric pressure for date of test, in. Hg)

Ho = Observed humidity of ambient air, g H₂O/g air

e = Transcendental constant (2.718)

Ta = ambient temperature, °K

4.b Recovery and Analytical Procedures

This test program did not include laboratory samples, consequently, sample recovery and analysis are not applicable to this test program.

4.c Sampling Ports

A diagram of the stack indicating traverse point and sampling locations and stack dimensions is included as Figure 1.

4.d Traverse Points

A diagram of the stack indicating traverse point and sampling locations and stack dimensions is included as Figure 1.

5. Test Results and Discussion

Sections 5.a through 5.k provide a summary of the test results.

RECEIVED NOV 07 2022

AIR QUALITY DIVISION



5.a Results Tabulation

The overall results of the emissions test program are summarized by Table 1. Detailed results for the emissions test program are summarized by Tables 4-7 in Appendix A.

Table 1
EUGASTURBINE Overall Emission Summary
Test Date: October 19, 2022

Condition	kW	NOx ppmv @15% O ₂ Corrected to ISO Standard Day Conditions
100% Load	3,200 kW	102
75% Load	2,400 kW	108
50% Load	1,600 kW	90
30% Load	960 kW	70

5.b Discussion of Results

EUGASTURBINE emission rates for NOx ppmv @15%O2 corrected to ISO standard day conditions are in compliance with permit limits at all conditions tested. The emission limit for EUGASTURBINE is 167 ppmv NOx @15% O₂ corrected to ISO standard day conditions.

5.c Sampling Procedure Variations

Ambient air was used as upscale gas to calibrate the oxygen analyzer, as specified in the USEPA Method 3A FAQ.

https://www.epa.gov/sites/default/files/2016-08/documents/method03a faq.pdf

5.d Process or Control Device Upsets

No upset conditions occurred during testing.

5.e Control Device Maintenance

There was no control equipment maintenance performed during the emissions test program.

5.f Re-Test

The emissions test program was not a re-test.

5.g Audit Sample Analyses

No audit samples were collected as part of the test program.



5.h Calibration Sheets

Relevant equipment calibration documents are provided in Appendix D.

5.i Sample Calculations

Sample calculations are provided in Appendix E.

5.j Field Data Sheets

Field documents relevant to the emissions test program are presented in Appendix C.

5.k Laboratory Data

There are no laboratory results for this test program.

MEASUREMENT UNCERTAINTY STATEMENT

Both qualitative and quantitative factors contribute to field measurement uncertainty and should be taken into consideration when interpreting the results contained within this report. Whenever possible, CYET personnel reduce the impact of these uncertainty factors through the use of approved and validated test methods. In addition, CYET personnel perform routine instrument and equipment calibrations and ensure that the calibration standards, instruments, and equipment used during test events meet, at a minimum, test method specifications as well as the specifications of our Quality Manual and ASTM D 7036-04. The limitations of the various methods, instruments, equipment, and materials utilized during this test have been reasonably considered, but the ultimate impact of the cumulative uncertainty of this project is not fully identified within the results of this report.

REPORT SIGNATURES

CYET operated in conformance with the requirements of ASTM D7036-04 during this emissions test project and this emissions test report:

This report was prepared by

Brandon Chase

Senior Environmental Engineer

This report was reviewed by:

Matthew Young

Senior Project Manager

Appendix A – Emission Results Tables

Table 1 EUGASTURBINE Overall Emission Summary Test Date: October 19, 2022

Condition	kW	NOx ppmv @15% O ₂ Corrected to ISO Standard Day Conditions
100% Load	3,200 kW	102
75% Load	2,400 kW	108
50% Load	1,600 kW	90
30% Load	960 kW	70

Table 2
Reporting Units and Emission Limits

Unit ID/ Source Name	Parameter	Reporting Units	Emission Limit	Emission Limit Reference
EUGASTURBINE	NO_x	ppmvd @15% O ₂ and ISO standard Day Conditions	167	MI-ROP-K2460-2021 40 CFR Part 60, Subpart GG

Table 3
Test Personnel

Test Personner				
Name, Title, and Email	Affiliation	Telephone		
Mr. John Fernandez Supervisor Utilities/Operations Fernalj@cmich.edu Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859		(989) 774-4437		
Mr. Michael Walton Director of Energy and Utilities Walto1mj@cmich.edu	Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859	(989) 774-1566		
Mr. Tharen Foster Utilities/Operations	Central Michigan University 1720 East Campus Drive Mount Pleasant, Michigan 48859	(989) 774-4437		
Mr. Brandon Chase Senior Environmental Engineer bchase@cyetinc.com	CYET 28744 Groveland Street Madison Heights, MI 48071	(248) 506-0107		
Mr. Matthew Young Senior Project Manager myoung@cyetinc.com	CYET 28744 Groveland Street Madison Heights, MI 48071	(586) 744-9133		
Mr. Benjamin Witkopp Environmental Quality Analyst WitkoppB@michigan.gov	Technical Programs Unit Air Quality Division – Field Operations Michigan Dept of Environment, Great Lakes & Energy	(989) 295-1612		

RECEIVED
NOV 07 2022
AIR QUALITY DIVISION