

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

N061243385

| | | |
|--|-------------------------------|---------------------------|
| FACILITY: HIAWATHA LOG HOMES INC | | SRN / ID: N0612 |
| LOCATION: HWY M 28 E, WETMORE | | DISTRICT: Upper Peninsula |
| CITY: WETMORE | | COUNTY: ALGER |
| CONTACT: Gary Bufe , Sales | | ACTIVITY DATE: 02/22/2018 |
| STAFF: Sydney Bruestle | COMPLIANCE STATUS: Compliance | SOURCE CLASS: MINOR |
| SUBJECT: Onsite inspection to verify compliance with PTI 489-83 and all other applicable state and federal air quality regulations | | |
| RESOLVED COMPLAINTS: | | |

I (Sydney Bruestle) performed an onsite inspection of Hiawatha Log Homes located at E10003 M28 East Wetmore, MI 49895. While onsite I met with Gary Bufe, Director of Business Development. He gave me an overview of the processes found at the facility.

The Facility manufacturers log homes and has one active permit to install (PTI) with the Air Quality Division. PTI 483-83 covers a 4 mmBTU/hr wood fired boiler. The boiler is only allowed to burn wood as fuel. The boiler was operating at the time of my inspection. PTI 483-83 limits the opacity of the boiler to a 6 minute average of 20% or less (Special Condition 11). To verify compliance I performed an EPA method 9 visible emissions reading while onsite (attached to the hard file). The highest observed 6 minute average opacity during my reading was 12.08%.

At the time of my inspection the facility appeared to be in compliance with PTI 483-83 and all other applicable state and federal air quality regulations.

NAME Sydney BruestleDATE 3/12/18SUPERVISOR Eff