

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION  
**ACTIVITY REPORT: On-site Inspection**

N068260127

<b>FACILITY:</b> Manistee County Medical Care Facility		<b>SRN / ID:</b> N0682
<b>LOCATION:</b> 1505 East Parkdale Avenue, MANISTEE		<b>DISTRICT:</b> Cadillac
<b>CITY:</b> MANISTEE		<b>COUNTY:</b> MANISTEE
<b>CONTACT:</b> Joe Coleman , Administrator		<b>ACTIVITY DATE:</b> 09/23/2021
<b>STAFF:</b> Rob Dickman	<b>COMPLIANCE STATUS:</b> Compliance	<b>SOURCE CLASS:</b> MINOR
<b>SUBJECT:</b> Scheduled inspection of this minor source.		
<b>RESOLVED COMPLAINTS:</b>		

Inspected this facility with respect to Permit to Install 770-83. This permit is for four oil-fired boilers used to heat the facility. I met with Nick, Maintenance Manager at the facility. He was able to direct me to where these boilers were but had been removed several years ago and replaced with four identical natural gas fired boilers. Inspection of these boilers indicated a heat input maximum of 900,000 BTU/hour which makes them exempt from permitting per Rule 336.1282(2)(b)(i).

As the permitted equipment has been removed and replaced by exempt equipment, it is recommended that this permit be voided.

NAME 

DATE \_\_\_\_\_

SUPERVISOR \_\_\_\_\_