


A Division of Ervin Industries, Inc.

915 Tabor Street
Adrian, Michigan 49221
(517) 265-6118
FAX (517) 265-5636

ERVIN
AMASTEEL

September 2, 2015

Eric Grinstern
Environmental Quality Specialist
MDEQ - AQD
Grand Rapids District Office
350 Ottawa Ave, N.W
Unit 10
Grand Rapids, MI 49503



Mr. Grinstern:


On 8/14/15 Ervin Amasteel Adrian received a violation notice from an inspection conducted on 6/8/15. In the notice there were four citations identified corrective action and response.

1. EU0004 - Reviewed with management that if a dust collector has a failure and is subsequently shut down, the associated emission unit cannot be ran to an alternative control device without a PTI. The impeller for the control device associated with EU0004 has been replaced, restarted and ran to date without any further failures. Additionally a PTI to move the associated emission unit from the control device to another has been completed, and the work planned for mid-2016.

Reviewed/Retrained on ISO 14001 procedure (based on R.O.P. requirements) with management and maintenance personnel for proper action to be taken when readings are out of tolerance.

2. EU0007 - Reviewed/Retrained on ISO 14001 procedure (based on R.O.P. requirements) with management and maintenance personnel for proper action to be taken when readings are out of tolerance.
3. EU0005 - Reviewed/Retrained on ISO 14001 procedure (based on R.O.P. requirements) with management and maintenance personnel for proper action to be taken when readings are out of tolerance.

We trust that the information presented for the cited items will address/meet the State of Michigan's expectations.

Thank you,

Richard Payne
Plant Engineer

Encl.: (7)

cc: Jim Lemon
File