



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
KALAMAZOO DISTRICT OFFICE



C. HEIDI GREYER  
DIRECTOR

July 25, 2018

Mr. David Koster  
Holland Board of Public Works  
491 East 48th Street  
Holland, Michigan 49423

SRN: N2586, Allegan County

Dear Mr. Koster:

**VIOLATION NOTICE**

On July 20, 2018, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), conducted an emission report review of Holland Board of Public Works (Facility), located at 491 East 48th Street, Holland, Michigan. The purpose of this review was to determine the Facility's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Renewable Operating Permit Number MI-ROP-N2586-2015a.

During the review, staff of the AQD observed the following:

Process Description	Rule/Permit Condition Violated	Comments
EUTURBINE9	MI-ROP-N2586-2015a, EUTURBINE9 SC.I.1	It was reported that on June 29, 2018, the Facility exceeded the 22 ppm NOx emission limit. The exceedance occurred over a seven hour period and emissions ranged from 168.2 ppm to 210 ppm of NOx.

The records provided demonstrate that actual emissions of nitrogen oxide (NOx) from the EUTURBINE9 process equipment ranged from 168.2 parts per million (ppm) to 210 ppm over a seven hour period. The conditions of MI-ROP-N2586-2015a limit the emissions of NOx to 22 ppm.

Mr. David Koster  
Page 2  
July 25, 2018


Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by August 15, 2018 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to the DEQ, AQD, 7953 Adobe Road, Kalamazoo, Michigan 49009; and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor, at the DEQ, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If the Facility believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of the Facility. If you have any questions regarding the violation or the actions necessary to bring this Facility into compliance, please contact me at the telephone number listed below.

Sincerely,



Cody Yazzie  
Environmental Engineer  
Air Quality Division  
269-567-3554

CY:CF

cc: Ms. Judy Visscher, Holland Board of Public Works  
Ms. Mary Ann Dolehanty, DEQ  
Mr. Craig Fitzner, DEQ  
Mr. Christopher Ethridge, DEQ  
Ms. Jenine Camilleri, DEQ  
Ms. Mary Douglas, DEQ