



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
WARREN DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

March 15, 2022

VIA E-MAIL

Mr. Benjamin Parrotta
Manager, Transmission and Storage Operations
DT Midstream – Washington 10 Compressor Station
12700 30 Mile Road
Washington Township, Michigan 48095

SRN: N3391, Macomb County

Dear Mr. Parrotta:

VIOLATION NOTICE

On January 19, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of DT Midstream – Washington 10 Compressor Station located at 12700 30 Mile Road, Washington Township, Michigan. The purpose of this inspection was to determine DT Midstream – Washington 10 Compressor Station's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Renewable Operating Permit (ROP) number MI-ROP-N3391-2017a.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
EUENGINE4	FGENGINES2 SC III.6 and VIII of MI-ROP-N3391-2017a	The pre-catalyst sampling port for EUENGINE4 was open while the engine was running and testing was not being conducted.
FGENGINES2	FGENGINES2 SC VI.2 and VI.8 of MI-ROP-N3391-2017a	Based on the catalyst temperature provided, it appears DT Midstream is taking one catalyst temperature reading every hour an engine is running, not every 15 minutes as required in SC VI.2 and VI.8.

Mr. Benjamin Parrotta
DT Midstream – Washington 10 Compressor Station
Page 2
March 15, 2022

This process is also subject to the federal National Emission Standards for Hazardous Air Pollutants (NESHAP) for Stationary Reciprocating Internal Combustion Engines. These standards are found in 40 CFR Part 63, Subpart ZZZZ.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by April 5, 2022 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Please submit the written response to EGLE, AQD, Warren District, at 27700 Donald Court, Warren, Michigan 48092 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If DT Midstream believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my inspection of DT Midstream – Washington 10 Compressor Station. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Kerry Kelly
Senior Environmental Quality Analyst
Air Quality Division
586-506-9817

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Joyce Zhu, EGLE
Mr. Darrell Grassmyer, DT Midstream
Ms. Kimberly Walker, DT Midstream