

DEPARTMENT OF ENVIRONMENTAL QUALITY
 AIR QUALITY DIVISION
 ACTIVITY REPORT: Self Initiated Inspection

N350732688

FACILITY: KRIST OIL CO		SRN / ID: N3507
LOCATION: 303 SELDEN RD, IRON RIVER		DISTRICT: Upper Peninsula
CITY: IRON RIVER		COUNTY: IRON
CONTACT: Krist Atanasoff, President		ACTIVITY DATE: 12/18/2015
STAFF: Joel Asher	COMPLIANCE STATUS: Unknown	
SUBJECT: Waste oil furnace		SOURCE CLASS:
RESOLVED COMPLAINTS:		


On 12/18/2015 an unannounced inspection was conducted at this facility.

An inspection conducted on 11/10/15 was conducted and waste oil sample KRIST1 was collected and submitted for laboratory analysis. All criteria for the sample were found to be in compliance except for the flash point. The compliance limit is a minimum of 100 degrees F. The analysis showed the flash point to be 68 degrees F. This information was forwarded to Mr. Atanasoff on 12/3/2015. It was felt a flash point that low was unlikely, however it should be followed up.

On 12/17/2015. Mr. Atanasoff emailed me the results of an independent sample he took on 12/7/2015. This report showed the flash point to be >176 F.

On 12/18/2015 I took two additional samples from the waste oil tank, KRIST1 and KRIST2. Each sample will be sent to a different laboratory. One to the lab previously used (ALS Environmental) and the other to Merit Laboratories.

Final determination of the facility's compliance with PTI #45-02 will be made upon receipt of the analysis from each laboratory.

NAME  DATE 12/22/15 SUPERVISOR _____