



Genesee Power Station Limited Partnership

G-5310 NORTH DORT HIGHWAY,
FLINT, MICHIGAN 48505
(810) 785-4144
(810) 785-2905 (FAX)

April 30, 2024

Matt Karl
Senior Environmental Quality Analyst
EGLE – Air Quality Division
525 W. Allegan, South Tower, 1st Floor
P.O. Box 30242
Lansing, Michigan 48909

Submitted via email: KarlM@michigan.gov

RE: Genesee Power Station, LP (SRN N3570) Response to Violation Notice dated April 18, 2024

Dear Matt:

This letter is in response to the violation notice (VN) issued to the Genesee Power Station, LP (GPS) on April 18, 2024. The VN was issued as a result of records submitted to the Michigan Department of Environment, Great Lakes, and Energy (EGLE) to comply with a follow-up request from a site audit conducted by EGLE on April 3, 2024. This citing is as follows:

Process Description	Rule/Permit Condition Violated	Comments
EUBOILER	Special Condition (SC) 1.6 / R. 336.2810, 40 CFR 52.21(j)	Exceeded the NO _x emission limit of 0.20 lb/MMBtu based on a 24-hour rolling average on February 27 and 28, 2024.
EUBOILER	Rule 912/General Condition 25	Failure to provide notice of the emission limit exceedance within 2 days and provide a 10 day follow up report.

GPS has since determined that there was no actual exceedance of the NO_x lb/mmBtu 24-hour rolling average and therefore also, was not required to submit prompt notice to EGLE under Rule 912, General Condition 25. The data submitted to EGLE on April 11, 2024, was incorrect and in error as the calculations at the time of data download were using an incorrect fuel factor (Fd) to calculate the NO_x lb/mmBtu hourly and 24-hour rolling averages. This submittal provides the explanation for how this error happened and provides supporting evidence to that fact.

The day of the EGLE inspection, April 3, 2024, Corporate Environmental Support remotely accessed the plant shared drive files to be ready to provide the “ROP Recordkeeping” spreadsheet if requested. This spreadsheet tracks compliance to permit condition EUBOILER VI.8, and is also set up to calculate a monthly fuel factor to be used for emission rate calculations. It was found that the fuel usage did not look correct and that the Fd calculation seemed too high for February 2024; however, the fixes to the macro and linkages within the spreadsheet could not be worked on remotely. When the plant Environmental, Health & Safety (EHS) Coordinator got back from vacation, it was determined that the spreadsheet needed to be

reviewed and corrected. The Fd error was traced to how the fuels spreadsheet macro totals the daily fuel use to a monthly value. The recordkeeping spreadsheet was then corrected to reflect the proper Fd for February 2024 (9244).

The fuel factor is changed monthly within the continuous emission monitoring system (CEMS) data handling and acquisition system (DAHS), called StackVision™, to reflect the most current fuel mix. This factor, along with the heat input capacity by fuel type, is calculated within the first week of every month utilizing the monthly fuel throughput values and the default 40 CFR Part 75, Appendix A fuel factor defaults. That fuel factor is then used prospectively in the DAHS data rate calculations for units of lb/mmBtu and lb/hr for NO_x, CO, and SO₂.

The CEM DAHS vendor, ESC Spectrum, performs weekly data checks, prepares the Excess Emission Reports (EERS) for submission to EGLE, as well as creates the upload files for the quarterly Electronic Data Reports (EDR) submission to the U.S. Environmental Protection Agency (EPA). During their data review, they noticed that the fuel factors had not been updated for January or February 2024. On March 28, 2024, GPS sent ESC the fuel factor values (from the ROP recordkeeping sheet) to be entered into the CEM DAHS. Unfortunately, the wrong value had been calculated for February 2024 on the ROP Spreadsheet (due to the error described in the preceding paragraph). A value of 10,260 was provided to ESC to enter into the DAHS for February, which they did on April 3rd. When ESC entered the data in for the month, they did it in the “data lab” portion of the StackVision software (different than where the plant enters the data), and it changed the historic rate calculation values when the system updated.

On April 8, 2024, GPS downloaded the data reports from the DAHS in order to provide the information requested by EGLE. On April 11, 2024, when conducting a corporate review of the reports for submission it was noticed the 24-hour Rolling Report was showing exceedances for the NO_x 24-hour rolling average for the time-period 2/27/24 10:00 to 2/28/24 15:00. This was unexpected and an absolute surprise as the DAHS is set up to notify the plant operations, plant EHS, and Corporate Environmental Support whenever emissions are approaching an exceedance (warning limit set at 0.19) as well as when there is an actual exceedance. Actual email from 2/27/24 shown below:

-----Original Message-----

From: stackvision@cmsenergy.com <stackvision@cmsenergy.com>

Sent: Tuesday, February 27, 2024 5:02 PM

To: KATHRYN M. CUNNINGHAM <kathryn.cunningham@cmsenergy.com>;

Roxanna.woodard@cmsenergy.com; gps.sv@consumersenergy.onmicrosoft.com

Subject: Warning Alarm: NO_x lb/MMbtu 24-Hour Rolling Average

The parameter NO_x#MM60 has reached 0.190636315179202 lb/MMbtu for its 24-hour rolling average over the period 022624, 1700 to 022724, 1659. This exceeds the warning limit of 0.19 lb/hr.

The weekly reviews by vendor ESC also never flagged an exceedance (see email in Attachment 1.0). Furthermore, the plant operators are very diligent about monitoring the hourly and 24-hour rolling averages. The control room is required to keep a log of the hourly values on their own excel spreadsheet for each day of operation and no exceedances were noted for 2/27/24 or 2/28/24. The operator's spreadsheet for these days is contained in Attachment 2.0. Boiler tuning was being conducted on these days and hourly NO_x values were running high, so operators were paying special attention to the rolling average to ensure they would not exceed the limit. Several high-level warning alarms came in that day; however, an exceedance alarm was not generated on that day. Please see Attachment 3.0 for the alarm reports from the DAHS.

As part of the investigation into why the reports generated on 4/8/24 were showing an exceedance, the reports were re-downloaded, and this time, the hourly and 24-hour lb/mmBtu values were different and no exceedances were flagged. The reports were downloaded into an excel format and the plant was told they may need formatting (for better print structure) prior to saving in PDF format for submission. Later in the day on April 11, 2024, the response was submitted to EGLE; apparently with the old, incorrect PDF file from April 8, 2024, vs. the new correct information downloaded on April 11, 2024.

In summary, when researching what caused a report to show an exceedance, GPS traced it back to an interval of time when an incorrect fuel factor was being utilized in the calculations and showing up in downloaded reports, and then human error of simply attaching the wrong report from the electronic file folder to the email submission to EGLE. A timeline of events is presented below:

3/28/24 – GPS directs ESC to change the fuel factor for February to 10,260 scf/mmBtu

4/3/24 – EGLE AQ conducted a “pop-in” inspection. A records request email received that afternoon.

4/3/24 – ESC changes the Fuel Factor (Fd) to 10,260. This action retro-actively caused an alarm to show up for exceedance from 2/27/24, 10am to 2/28/24, 3pm as the Feb Fd value was incorrect. (There is no tracking mechanism within the DAHS that shows what date alarms “pop up” on the alarm screen. (note that the alarm was acknowledged on 4/13/24 in the Alarms Report, Attachment 3)

4/8/24 – Site generates inspection follow-up reports for Regulator (hourly and 24-hour roll averages). Report shows exceedances for NOx lb/mmBtu.

4/10/24 – ESC changes Feb. Fd from 10,260 to the correct value of 9,244 (Note In fact that the monthly ROP recordkeeping sheet that Roxanna sent with the submission, filename: EUBOILER_3_Heat Input capacity by Fuel Type, shows the correct calculated fuel factor for February.)

4/11/24 – Reports are re-generated for regulatory submission. However, the incorrect reports (the ones generated on 4/8/24 vs. 4/11/24) were inadvertently submitted to the agency via email.

The CEM DAHS is set up to automatically record when anything is manually changed in the StackVision software and also records the login ID of who made the change. Evidence of the Fd changes logged into the system is contained in Attachment 4.0. At the end of the quarter, once the EDRs and the EER/Downtime Reports have been generated, ESC “locks down” the data so it cannot be inadvertently changed through the daily data processing application. It is internal procedure that if there are any DAHS changes that require re-submission of a report to a regulatory agency, that change requires documented management approval. The quarterly Excess Emissions and Downtime Reports for Q1 2024 will not be reporting any gaseous emission exceedances as the quarterly reports have now been through the proper internal QAQC process and we will be attesting to its truth and accuracy.

A re-submission of the hourly and 24-hour average data for NOx and CO from the original site inspection request accompanies this submission, as both the lb/mmBtu and lb/hr values are affected by the fuel factor and is contain in Attachment 5.0. Also included in this submission is the newly requested data from the VN for the historic data back to April 11, 2022, included in Attachment 6.0 (and also attached in excel format in email).

As a side note, the plant ceased firing of Tire Derived Fuel (TDF) in February 2024. As a result of that action, the plant will be using the default fuel factor code of 9,240 for wood fuel.

GPS vigorously monitors compliance to the ROP limits and takes its reporting obligations to EGLE very seriously. It is unfortunate that a recordkeeping error (that was caught internally) indicated an exceedance which never really existed. This error would not have made it through the Quarterly Data Reporting Quality Assurance/Quality Control (QAQC) review regime for reports due 4/30/24 (EDRs and EERs). It comes down to a slight human error issue of submitting a report containing outdated and incorrect information. With this in mind, GPS respectfully requests that EGLE rescind the VN as there was actually no permit deviation, exceedance, violation of a permit condition, or impact to the environment. If it is not possible to retract the VN, then GPS respectfully requests that EGLE provide GPS with written agreement that no limits were exceeded and confirmation of closure of the VN.

Please contact me at (517) 375-3043 if you have any questions or require further information concerning the contents of this submittal. If you email me, please be sure to include the Plant Manager, Mr. Thomas Clift (thomas.clift@NSCE.com) and the plant EHS Coordinator Ms. Roxanna Woodard (Roxanna.woodard@NSCE.com) in all correspondence. A signed ROP Certification form accompanies this submission.

Sincerely,



Kathryn M. Cunningham, P.E, Principal Engineer
Kathryn.cunningham@cmsenergy.com

Attachments

- Certification Form
- 1.0 ESC Weekly report 2/28/2024
- 2.0 Operator Log for 2/27/2024 and 02/28/2024
- 3.0 StackVision Alarms
- 4.0 StackVision Log
- 5.0 Resubmission of Hourly and 24 hr data for February/March of 2024
- 6.0 Data download reports of Hourly and 24-hour data for NOx from April 11, 2022 to February 1, 2024.

Cc: Jenine Camilleri, EGLE – hard copy mail
Email cc:

T.Clift – NorthStar
R. Woodard – NorthStar
Brad Myott, EGLE

Annette Switzer, EGLE
Christopher Ethridge, EGLE
Bob Byrnes, EGLE



MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY
AIR QUALITY DIVISION

**RENEWABLE OPERATING PERMIT
REPORT CERTIFICATION**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environment, Great Lakes, and Energy, Air Quality Division upon request.

Source Name Genesee Power Station Limited Partnership County Genesee
Source Address 5310 North Dort Highway City Flint
AQD Source ID (SRN) N3570 ROP No. MI ROP N3570-2023 ROP Section No. _____

Please check the appropriate box(es):

☐ **Annual Compliance Certification (Pursuant to Rule 213(4)(c))**

Reporting period (provide inclusive dates): From _____ To _____

- ☐ 1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.
- ☐ 2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

☐ **Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))**

Reporting period (provide inclusive dates): From _____ To _____

- ☐ 1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.
- ☐ 2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

☒ **Other Report Certification**

Reporting period (provide inclusive dates): From NA To NA


Additional monitoring reports or other applicable documents required by the ROP are attached as described:

Re-submission of emissions data per 04/03/2024 Inspection information request

Response to VN 20240418

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

Thomas A Clift General Manager (810) 785 - 4144 x222
Name of Responsible Official (print or type) Title Phone Number


Signature of Responsible Official

04/30/2024
Date

Genesee Power Station StackVision Data Review

AM Ally Moreau <amoreau@escspectrum.com>
To: KATHRYN M. CUNNINGHAM

Retention Policy: Corporate E-mail (Retention: 3 year)
You forwarded this message on 2/28/2024 10:54 AM.

Reply Reply All Forward

Wed 2/28/2024 10:54 AM

Data Review.pdf 79 KB	NOXPPM Control Chart.pdf 54 KB	O2 Control Chart.pdf 53 KB	Downtime Report.pdf 2 KB	FLOWSCFH Control Chart.pdf 53 KB	HEATIN Control Chart.pdf 54 KB
Opacity Downtime Events - Duration.pdf 3 KB	Opacity Exceedance Events.pdf 2 KB	SO2PPM Control Chart.pdf 46 KB			

Please let me know if you have any questions.

Genesee Power Station						
P75 - Full CEMS, P60						
2/21/2024 to 2/27/2024						
PN	Daily Process Flow completed through 02/27/24	Gas Operating Hours	Opacity Operating Hours	TDF Operating Hours	Wood Operating Hours	Unit Operating Hours
		1Q24: 0 2Q24: 0 3Q24: 0 4Q24: 0	1Q24: 1,392 2Q24: 0 3Q24: 0 4Q24: 0	1Q24: 239 2Q24: 0 3Q24: 0 4Q24: 0	1Q24: 1,392 2Q24: 0 3Q24: 0 4Q24: 0	1Q24: 1,392 2Q24: 0 3Q24: 0 4Q24: 0
Date	Operation	Average Data Review	Alarm History Review	Calibrations	QA	
2/21	online	no current data anomalies noted	STXFLOW calibration drift alarm 02/22 SO2PPM calibration drift alarm 02/25 NOXa/MM, COa/MM approaching exceedance 02/27	COPPM, INTCHK, NOXPPM, O2, OPACITY, SO2PPM, STXFLOW P60 None P60 None Maintenance 1 mm SO2PPM 02/25 h/t STXFLOW 02/27 h/t	P75 Linearity: NOXPPM: 12.0000% - 0.001 SO2PPM: 12.0000% - 0.001 O2: 12.0000% - 0.001 COa: COPPM: 12.0000% - 0.001 Frequency: every QA quarter	Flow to Load: 1Q24 Low: 100% - 8.50% (1,254 usable hours) Heat to Load: 100% - 4.20%
2/22	online					
2/23	online					Mid: 100% - 1.40% (14 usable hours)
2/24	online					
2/25	online					Leak Test: 12/06/23 Frequency: every QA quarter
2/26	online				P75 RATA: FLOWSCFH: 02/12/24 BAF 1.023 12.0000% - 0.001 BAF 1.023 NOXPPM: 02/12/24 BAF 1.023 O2: 02/12/24 BAF 1.023 SO2PPM: 02/12/24 BAF 1.023	
2/27	online					

Attachment 2.0

Operator Log for 2/27/2024 and 02/28/2024

Date	Hr	S/F	KPPH	MN		S/P	BM	Fuel Demand	FD	damper	O2%	ID Fan	Cycle Timer	Shake Timer	MW	27					28					TAF	CO 24hr avg	Nox 24 avg				
				pres	point											OUTPUT %	demand	SP	OUTPUT	O2	damper	Minutes	Seconds	OUTPUT	28							
27-Feb	0:00	110	1245	1250	5.5	4.7	3.6	19.7	4.6	6.4	4	6	10.2	0.171	0.190	0.9	37.3	41.4	1.4	105	0.184	0.174										
	1:00	110	1251	1250	3.5	2.6	3.6	21.1	4.4	6.3	4	6	10.1	0.167	0.185	0.8	36.7	40.8	1.4	104	0.184	0.174										
	2:00	110	1246	1250	5.3	4.3	3.6	20.1	4.8	6.4	4	6	10.1	0.167	0.178	0.7	36.7	39.1	1.4	104	0.185	0.174										
	3:00	110	1248	1250	4.9	3.5	3.6	19.5	5.0	6.3	4	6	10.2	0.168	0.201	0.7	37.2	44.2	1.4	104	0.188	0.174										
	4:00	111	1250	1250	4.6	3.2	3.6	17.9	4.7	5.5	4	6	10.1	0.164	0.270	0.9	38.0	62.4	1.4	96	0.190	0.173										
	5:00	111	1253	1250	2.8	1.3	3.6	18.6	3.9	5.4	4	6	10.1	0.174	0.256	0.8	37.8	55.6	1.4	97	0.193	0.174										
	6:00	111	1248	1250	4.3	2.9	3.6	16.3	3.9	5.6	4	6	10.2	0.186	0.218	0.7	40.1	47.0	1.4	96	0.194	0.174										
	7:00	252	1256	1250	45.4	46	3.6	56.2	7.8	47.0	4	6	29.3	0.166	0.413	3.8	55.5	138.4	1.4	321	0.202	0.175										
	8:00	267	1268	1250	37.8	38.1	3.8	56.3	8.1	51.0	4	6	31.2	0.239	0.571	5.4	123.0	293.5	1.3	325	0.217	0.178										
	9:00	268	1254	1250	41.3	41.6	3.8	54.5	8.1	52.8	4	6	31.2	0.236	0.573	1.3	115.1	279.0	1.4	328	0.233	0.181										
	10:00	267	1257	1250	39.6	39.6	3.8	55.7	7.8	56.0	4	6	31.2	0.246	0.645	1.1	120.1	314.7	1.3	328	0.253	0.184										
	11:00	221	1250	1250	31.1	31.1	3.8	46.8	7.8	31.1	4	6	25.1	0.228	0.481	1.0	102.7	216.3	1.4	274	0.266	0.186										
	12:00	221	1251	1250	30.1	30.3	3.8	46.3	7.4	31.0	4	6	25.1	0.196	0.354	0.8	78.3	141.1	1.4	274	0.274	0.187										
	13:00	221	1250	1250	30.3	30.2	3.8	48.3	7.7	32.1	4	6	25.1	0.203	0.363	0.9	81.5	145.8	1.4	282	0.283	0.188										
	14:00	222	12152	1250	30.0	30.2	3.8	47.6	7.6	31.0	4	6	25.1	0.196	0.362	0.9	81.0	149.5	1.4	276	0.293	0.188										
	15:00	222	1254	1250	29.5	29.1	3.8	46.9	7.6	30.0	4	6	25.2	0.198	0.327	0.8	78.2	129.0	1.4	274	0.299	0.189										
	16:00	222	1252	1250	30.1	30.2	3.5	48.5	7.7	33.5	4	6	25.1	0.209	0.313	0.8	82.9	124.2	1.4	286	0.305	0.191										
	17:00	123	1291	1250	0.0	-5.0	3.5	20.7	4.1	6.1	4	6	11.6	0.178	0.164	0.7	57.3	52.7	1.4	103	0.307	0.191										
	18:00	110	1250	1250	2.0	-5.0	3.7	18.3	5.3	5.7	5	6	10.1	0.160	0.250	0.4	34.7	54.1	1.4	105	0.304	0.191										
	19:00	112	1250	1250	3.3	1.3	3.7	20.0	4.9	5.8	5	6	10.1	0.164	0.158	0.4	35.5	34.2	1.4	106	0.303	0.190										
	20:00	112	1247	1250	4.4	2.6	3.7	18.1	4.7	6.0	5	6	10.1	0.161	0.164	0.4	35.4	35.7	1.3	102	0.303	0.189										
	21:00	112	1248	1250	3.4	1.6	3.7	21.2	4.6	6.1	5	6	10.1	0.161	0.168	0.4	35.3	37.0	1.3	104	0.302	0.188										
	22:00	112	1248	1250	4.3	2.7	3.7	19.1	4.0	6.2	5	6	10.2	0.162	0.158	0.4	35.6	34.7	1.4	105	0.299	0.187										
23:00	111	1251	1250	3.4	1.3	3.7	19.3	4.8	5.9	5	6	10.2	0.164	0.177	0.4	36.1	38.8	1.4	106	0.297	0.186											
28-Feb	0:00	111	1247	1250	4.4	2.6	3.7	19.3	4.4	6.1	5	6	10.1	0.161	0.171	0.4	35.6	37.6	1.4	105	0.297	0.186										
	1:00	111	1251	1250	3.5	1.7	3.7	19.7	4.1	6.1	5	6	10.1	0.164	0.190	0.4	36.2	42.2	1.4	105	0.297	0.186										
	2:00	111	1249	1250	4.2	2.5	3.7	20.2	4.7	6.2	5	6	10.1	0.167	0.180	0.4	36.8	39.6	1.4	105	0.297	0.186										
	3:00	110	1245	1250	5.6	4.3	3.8	20.4	4.4	6.7	4	6	10.1	0.151	0.217	0.4	33.7	48.5	1.4	106	0.298	0.185										
	4:00	111	1252	1250	3.7	1.6	3.8	20.0	4.8	6.4	4	6	10.2	0.149	0.256	0.5	35.1	60.2	1.4	108	0.297	0.184										
	5:00	112	1250	1250	4.7	3.5	3.7	24.6	3.6	7.0	5	6	10.3	0.143	0.244	0.4	32.2	54.8	1.4	109	0.297	0.183										
	6:00	111	1250	1250	4.8	3.5	3.7	19.9	4.8	6.9	5	6	10.3	0.143	0.214	0.4	30.9	46.3	1.4	111	0.296	0.181										
	7:00	228	1253	1250	40.4	40.7	3.9	52.5	7.6	45.7	4	6	26.3	0.205	0.414	0.9	72.7	146.4	1.4	300	0.296	0.183										
	8:00	219	1252	1250	32.1	32.0	3.9	49.5	7.6	39.8	4	6	24.9	0.208	0.359	1.0	91.1	156.4	0.9	285	0.288	0.182										
	9:00	219	1253	1250	31.3	31.4	3.9	47.0	6.7	35.4	4	6	25.1	0.204	0.247	0.9	84.6	102.8	1.0	283	0.274	0.180										
	10:00	219	1254	1250	30.1	30.3	3.9	48.2	8.0	35.8	4	6	24.8	0.188	0.289	0.8	76.9	118.4	1.0	287	0.259	0.178										
	11:00	216	1257	1250	30.1	30.3	3.9	43.5	7.2	28.6	4	6	24.9	0.211	0.177	1.0	86.6	72.1	1.0	269	0.247	0.177										
	12:00	255	1257	1250	41.0	41.4	3.9	50.5	7.1	43.9	4	6	29.8	0.182	0.209	0.8	74.7	85.6	1.0	303	0.240	0.176										
	13:00	265	1250	1250	42.2	42.7	3.9	54.4	7.8	53.7	4	6	31.0	0.213	0.456	1.0	404.9	224.7	1.0	322	0.244	0.177										
	14:00	267	1248	1250	40.9	41.1	3.9	56.0	8.7	66.2	4	6	31.0	0.232	0.334	1.1	111.5	160.9	1.0	332	0.243	0.178										
	15:00	213	1225	1250	33.4	33.7	4.2	50.0	8.2	39.2	4	6	24.3	0.197	0.464	0.9	89.7	211.5	1.0	296	0.249	0.178										
	16:00	264	1254	1250	43.1	43.8	4.2	55.2	8.2	50.6	4	6	30.1	0.184	0.178	0.9	75.5	73.1	1.0	326	0.249	0.178										
	17:00	264	1254	1250	41.9	42.6	4.3	53.6	8.3	50.3	4	6	31.2	0.224	0.385	1.0	105.9	181.6	1.0	318	0.243	0.177										
	18:00	112	1254	1250	0.0	-5.0	3.9	17.8	5.3	5.7	4	6	10.4	0.167	0.291	0.7	66.7	116.7	1.0	100	0.254	0.180										
	19:00	111	1255	1250	4.3	2.9	3.8	19.9	6.3	6.5	4	6	10.3	0.143	0.265	0.4	31.4	58.2	1.1	110	0.259	0.179										
	20:00	112	1250	1250	4.6	3.5	3.8	20.7	6.0	6.6	4	6	10.3	0.172	0.129	0.4	35.8	26.9	1.2	110	0.257	0.179										
	21:00	112	1248	1250	5.4	4.4	3.8	20.0	5.0	6.5	4	6	10.2	0.168	0.165	0.4	35.1	34.6	1.2	110	0.257	0.179										
	22:00	112	1250	1250	4.7	3.5	3.8	19.4	5.8	6.3	4	6	10.2	0.168	0.141	0.4	35.1	29.5	1.2	108	0.256	0.180										
23:00	112	1251	1250	4.7	3.7	3.8	18.8	5.7	6.6	4	6	10.2	0.164	0.147	0.4	34.7	30.9	1.2	109	0.255	0.180											

Attachment 3.0
Stack Vision Alarms Report

Alarm History

Plant: GENESEE POWER STATION LP
Source(s): UNIT1
Report Period: 02/26/2024 00:00 Through 02/28/2024 23:59

kmcunnin Apr 25



Note that alarm was responded to after the time period of the false exceedance, giving credence to evidence that the alarm was generated in April. It is policy that operators acknowledge alarms with a memo before closing.

System Alarms

No System Alarms to report for selected time period.

Data Alarms

Source: UNIT1		Parameter: NOX#MM60	
02/27/24 10:00	EXCEALM	024h	EXCEEDANCE DATA WARNING
Alarm Time: 02/27/24 10:00		Value: 0.207	
RTN Time: 02/28/24 03:00		Acknowledge Time: 04/13/24 16:42	
Acknowledged by: Planta			
Reason Code: 03 - EE - Process problems			
Action Code: 11 - Other Corrective Action			
Memo: STORM Testing onsite to take boiler readings... Ran high emissions at elevated load for said testing. Lowered load to control emissions. No permit limits were exceeded.			
02/27/24 15:00	WARNALM	024H	APPROACHING EXCEEDANCE
Alarm Time: 02/27/24 15:00		Value: 0.191	
RTN Time: 02/27/24 15:59		Acknowledge Time: 02/27/24 18:03	
Acknowledged by: Planta			
Reason Code: 04 - EE - Other known causes			
Action Code: 11 - Other Corrective Action			
Memo: Tuning boiler... have since ramped down load, burning urea, giving extra air.			
02/27/24 16:00	WARNALM	024H	APPROACHING EXCEEDANCE
Alarm Time: 02/27/24 16:00		Value: 0.191	
RTN Time: 02/27/24 16:59		Acknowledge Time: 02/27/24 18:03	
Acknowledged by: Planta			
Reason Code: 04 - EE - Other known causes			
Action Code: 11 - Other Corrective Action			
Memo: Tuning boiler... have since ramped down load, burning urea, giving extra air.			
02/27/24 17:00	WARNALM	024H	APPROACHING EXCEEDANCE
Alarm Time: 02/27/24 17:00		Value: 0.191	
RTN Time: 02/27/24 17:59		Acknowledge Time: 02/27/24 18:03	
Acknowledged by: Planta			
Reason Code: 04 - EE - Other known causes			
Action Code: 11 - Other Corrective Action			
Memo: Tuning boiler... have since ramped down load, burning urea, giving extra air.			

Application Alarms

ESC Support

Attachment 4.0
CEM DAHS StackVision Log

LogBook

Search

04/03/2024... Data edited in DataLab es...
DataLab UNIT1

04/03/2024... Data edited in DataLab es...
DataLab UNIT1

03/27/2024... Cylinder Replace de...
Cylinde...

03/27/2024... Cylinder Replace de...
Cylinde...

03/27/2024... Cylinder Replace de...
Cylinde...

03/27/2024... Cylinder Replace de...
Cylinde...

03/15/2024... Manual Phase Links and Un... de...
Cylinde...

03/15/2024... Cylinder Replace de...
Cylinde...

03/15/2024... Cylinder Add de...
Cylinde...

03/11/2024... Cylinder Replace de...
Cylinde...

03/11/2024... Cylinder Add de...
Cylinde...

03/06/2024... Cylinder Replace de...
Cylinde...

03/06/2024... Cylinder Replace de...
Cylinde...

Title:
Data edited in DataLab

Entry Type: DataLab

Source(s): UNIT1

Component(s):

Locked? ☐ User: escsupport

Event Information:
Start Date: 04/03/2024 07:51 Duration: 0:00 End Date: 04/03/2024 07:51

Entry:
Edited by escsupport (esc support) on Wednesday, April 03 2024 at 07:51
escsupport said, 'adjusted FEB FUELFACt/esc/am'
Using interval 001H, the following were changed:
02/1/2024 00:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 01:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 02:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 03:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 04:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 05:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 06:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 07:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 08:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 09:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 10:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 11:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 12:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 13:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 14:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 15:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 16:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 17:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 18:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 19:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 20:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 21:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 22:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/1/2024 23:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/2/2024 00:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/2/2024 01:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/2/2024 02:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/2/2024 03:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True
02/2/2024 04:00:00 UNIT1:FUELFACt - DataValue=9240=>10260, Locked=False=>True

Attachments:

LogBook

Title:

Data edited in DataLab

Entry Type:

Source(s):

Component(s):

DataLab

UNIT1

Locked?

User: escsupport

Event Information:

Start Date:

04/10/2024

15:25

Duration:

0:00

End Date:

04/10/2024

15:25

Entry:

Edited by escsupport (esc support) on Wednesday, April 10 2024 at 15:25

escsupport said, 'changed FEB FUELFACT/esc/iam'
Using interval 001H, the following were changed:
02/1/2024 00:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 01:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 02:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 03:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 04:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 05:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 06:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 07:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 08:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 09:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 10:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 11:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 12:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 13:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 14:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 15:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 16:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 17:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 18:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 19:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 20:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 21:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 22:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/1/2024 23:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/2/2024 00:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/2/2024 01:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/2/2024 02:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/2/2024 03:00:00 UNIT1:FUELFACT - DataValue=10260=>9244
02/2/2024 04:00:00 UNIT1:FUELFACT - DataValue=10260=>9244

Attachments:

Name	Attached Date	Description	In Database
------	---------------	-------------	-------------

Attachment 5.0
Resubmission of Hourly and 24 hr data for February/March of 2024

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1				
		CO#/HR (LB/HR)	CO#/MM (LB/MMBTU)	NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)	SO2#/H60 (LB/HR)
Parameter						
02/01/24	00:00	44.0	0.194	39.7	0.179	0.5
02/01/24	01:00	44.0	0.194	39.7	0.179	0.5
02/01/24	02:00	43.5	0.192	39.6	0.179	0.5
02/01/24	03:00	43.9	0.194	39.9	0.179	0.5
02/01/24	04:00	43.9	0.194	39.9	0.180	0.5
02/01/24	05:00	44.0	0.195	40.0	0.180	0.5
02/01/24	06:00	44.6	0.197	40.0	0.180	0.5
02/01/24	07:00	45.9	0.203	39.8	0.179	0.5
02/01/24	08:00	46.8	0.207	39.6	0.178	0.5
02/01/24	09:00	47.2	0.209	39.5	0.178	0.5
02/01/24	10:00	50.7	0.214	40.5	0.177	0.5
02/01/24	11:00	60.0	0.229	42.6	0.178	0.5
02/01/24	12:00	67.5	0.241	45.3	0.179	0.6
02/01/24	13:00	70.0	0.245	45.2	0.176	0.6
02/01/24	14:00	70.7	0.248	44.6	0.173	0.6
02/01/24	15:00	71.1	0.249	44.1	0.170	0.6
02/01/24	16:00	71.6	0.250	43.7	0.168	0.6
02/01/24	17:00	72.0	0.252	43.5	0.167	0.6
02/01/24	18:00	72.2	0.252	43.4	0.166	0.6
02/01/24	19:00	72.0	0.251	43.4	0.166	0.6
02/01/24	20:00	71.9	0.250	43.4	0.166	0.6
02/01/24	21:00	71.5	0.248	43.5	0.166	0.6
02/01/24	22:00	71.3	0.247	43.5	0.166	0.6
02/01/24	23:00	71.0	0.246	43.6	0.166	0.6
02/02/24	00:00	70.7	0.245	43.7	0.167	0.6
02/02/24	01:00	70.3	0.244	43.9	0.168	0.6
02/02/24	02:00	70.3	0.243	44.1	0.169	0.6
02/02/24	03:00	69.9	0.242	43.9	0.168	0.6
02/02/24	04:00	69.9	0.242	43.8	0.168	0.6
02/02/24	05:00	69.8	0.242	43.7	0.168	0.6
02/02/24	06:00	69.4	0.240	43.8	0.168	0.6
02/02/24	07:00	68.2	0.236	44.0	0.169	0.6
02/02/24	08:00	67.6	0.233	44.1	0.170	0.6
02/02/24	09:00	67.0	0.230	44.3	0.171	0.6
02/02/24	10:00	63.5	0.225	43.3	0.172	0.6
02/02/24	11:00	54.1	0.210	41.1	0.171	0.5
02/02/24	12:00	47.1	0.200	38.3	0.170	0.5
02/02/24	13:00	44.5	0.196	38.4	0.172	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/02/24	14:00	43.5	0.192	38.9	0.175	0.5
02/02/24	15:00	43.3	0.192	39.5	0.178	0.5
02/02/24	16:00	42.8	0.191	39.9	0.181	0.5
02/02/24	17:00	42.8	0.191	39.9	0.181	0.5
02/02/24	18:00	42.6	0.191	40.0	0.182	0.5
02/02/24	19:00	43.2	0.194	39.8	0.182	0.5
02/02/24	20:00	43.8	0.197	39.7	0.181	0.5
02/02/24	21:00	44.5	0.201	39.5	0.181	0.5
02/02/24	22:00	45.0	0.203	39.4	0.181	0.5
02/02/24	23:00	45.2	0.204	39.3	0.180	0.5
02/03/24	00:00	45.5	0.206	39.1	0.180	0.5
02/03/24	01:00	45.8	0.207	39.0	0.180	0.5
02/03/24	02:00	46.3	0.210	38.7	0.179	0.5
02/03/24	03:00	46.7	0.212	38.6	0.178	0.5
02/03/24	04:00	46.9	0.213	38.5	0.178	0.5
02/03/24	05:00	47.5	0.215	38.3	0.177	0.5
02/03/24	06:00	47.9	0.217	38.1	0.175	0.5
02/03/24	07:00	48.3	0.218	37.9	0.174	0.5
02/03/24	08:00	48.5	0.219	37.9	0.174	0.5
02/03/24	09:00	48.8	0.220	37.8	0.173	0.5
02/03/24	10:00	48.6	0.219	37.8	0.174	0.5
02/03/24	11:00	48.8	0.220	37.8	0.173	0.5
02/03/24	12:00	48.7	0.220	37.8	0.174	0.5
02/03/24	13:00	49.1	0.222	37.7	0.173	0.5
02/03/24	14:00	49.6	0.224	37.4	0.172	0.5
02/03/24	15:00	49.8	0.224	37.3	0.171	0.5
02/03/24	16:00	49.7	0.223	37.3	0.171	0.5
02/03/24	17:00	49.4	0.222	37.3	0.171	0.5
02/03/24	18:00	49.8	0.223	37.3	0.170	0.5
02/03/24	19:00	49.4	0.221	37.3	0.170	0.5
02/03/24	20:00	48.8	0.218	37.4	0.170	0.5
02/03/24	21:00	48.5	0.216	37.4	0.170	0.5
02/03/24	22:00	48.2	0.215	37.6	0.171	0.5
02/03/24	23:00	48.1	0.215	37.6	0.171	0.5
02/04/24	00:00	48.0	0.214	37.6	0.171	0.5
02/04/24	01:00	48.0	0.214	37.6	0.171	0.5
02/04/24	02:00	48.0	0.214	37.7	0.171	0.5
02/04/24	03:00	47.6	0.212	37.7	0.171	0.5
02/04/24	04:00	47.5	0.212	37.7	0.171	0.5
02/04/24	05:00	47.1	0.210	37.7	0.171	0.5
02/04/24	06:00	46.9	0.209	37.8	0.172	0.5
02/04/24	07:00	46.8	0.209	37.8	0.172	0.5
02/04/24	08:00	46.7	0.210	37.9	0.173	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/04/24	09:00	46.7	0.209	37.9	0.173	0.5
02/04/24	10:00	46.9	0.210	37.8	0.172	0.5
02/04/24	11:00	47.1	0.211	37.7	0.172	0.5
02/04/24	12:00	47.7	0.213	37.5	0.171	0.5
02/04/24	13:00	47.5	0.212	37.6	0.171	0.5
02/04/24	14:00	47.3	0.210	38.0	0.172	0.5
02/04/24	15:00	47.4	0.211	37.9	0.172	0.5
02/04/24	16:00	47.6	0.212	37.9	0.171	0.5
02/04/24	17:00	48.0	0.213	37.8	0.171	0.5
02/04/24	18:00	47.9	0.212	37.7	0.170	0.5
02/04/24	19:00	48.1	0.213	37.7	0.170	0.5
02/04/24	20:00	48.0	0.213	37.7	0.170	0.5
02/04/24	21:00	47.9	0.212	37.7	0.170	0.5
02/04/24	22:00	47.6	0.211	37.8	0.170	0.5
02/04/24	23:00	47.5	0.210	37.9	0.171	0.5
02/05/24	00:00	47.5	0.210	37.9	0.171	0.5
02/05/24	01:00	48.0	0.212	37.7	0.170	0.5
02/05/24	02:00	47.9	0.211	37.6	0.169	0.5
02/05/24	03:00	47.9	0.211	37.6	0.169	0.5
02/05/24	04:00	47.5	0.208	37.7	0.168	0.5
02/05/24	05:00	47.1	0.206	37.8	0.168	0.5
02/05/24	06:00	47.0	0.205	37.9	0.168	0.5
02/05/24	07:00	49.1	0.214	37.9	0.168	0.5
02/05/24	08:00	48.8	0.212	38.0	0.168	0.5
02/05/24	09:00	48.6	0.211	38.1	0.168	0.5
02/05/24	10:00	48.5	0.210	38.2	0.168	0.5
02/05/24	11:00	48.5	0.210	38.2	0.168	0.5
02/05/24	12:00	47.7	0.206	38.4	0.169	0.5
02/05/24	13:00	47.5	0.205	38.4	0.169	0.5
02/05/24	14:00	47.0	0.204	38.3	0.169	0.5
02/05/24	15:00	47.7	0.206	38.4	0.169	0.5
02/05/24	16:00	47.0	0.204	38.5	0.170	0.5
02/05/24	17:00	46.8	0.203	38.7	0.171	0.5
02/05/24	18:00	46.6	0.202	38.9	0.172	0.5
02/05/24	19:00	46.8	0.203	38.9	0.173	0.5
02/05/24	20:00	47.3	0.205	38.8	0.172	0.5
02/05/24	21:00	47.9	0.208	38.7	0.172	0.5
02/05/24	22:00	48.8	0.212	38.6	0.171	0.5
02/05/24	23:00	48.7	0.211	38.6	0.171	0.5
02/06/24	00:00	48.4	0.210	38.7	0.171	0.5
02/06/24	01:00	48.5	0.210	38.8	0.171	0.5
02/06/24	02:00	47.9	0.208	38.9	0.172	0.5
02/06/24	03:00	47.9	0.208	39.0	0.173	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/06/24	04:00	48.4	0.212	38.9	0.173	0.5
02/06/24	05:00	49.0	0.215	38.8	0.174	0.5
02/06/24	06:00	49.4	0.218	38.7	0.174	0.5
02/06/24	07:00	47.5	0.210	38.7	0.175	0.5
02/06/24	08:00	47.9	0.213	38.7	0.175	0.5
02/06/24	09:00	48.5	0.216	38.5	0.175	0.5
02/06/24	10:00	48.7	0.218	38.4	0.175	0.5
02/06/24	11:00	49.0	0.220	38.3	0.175	0.5
02/06/24	12:00	49.8	0.223	38.2	0.174	0.5
02/06/24	13:00	49.7	0.222	38.3	0.174	0.5
02/06/24	14:00	49.3	0.220	38.4	0.174	0.5
02/06/24	15:00	48.1	0.216	38.5	0.175	0.5
02/06/24	16:00	47.8	0.214	38.5	0.175	0.5
02/06/24	17:00	48.4	0.217	38.3	0.174	0.5
02/06/24	18:00	48.7	0.219	38.2	0.174	0.5
02/06/24	19:00	48.7	0.219	38.1	0.174	0.5
02/06/24	20:00	48.5	0.218	38.2	0.174	0.5
02/06/24	21:00	48.3	0.218	38.3	0.175	0.5
02/06/24	22:00	47.7	0.215	38.4	0.176	0.5
02/06/24	23:00	47.8	0.216	38.4	0.176	0.5
02/07/24	00:00	47.8	0.217	38.3	0.176	0.5
02/07/24	01:00	47.6	0.217	38.3	0.177	0.5
02/07/24	02:00	47.8	0.219	38.2	0.177	0.5
02/07/24	03:00	48.0	0.219	38.4	0.178	0.5
02/07/24	04:00	48.2	0.220	38.4	0.178	0.5
02/07/24	05:00	48.2	0.220	38.4	0.178	0.5
02/07/24	06:00	48.2	0.220	38.4	0.178	0.5
02/07/24	07:00	48.2	0.220	38.4	0.178	0.5
02/07/24	08:00	48.5	0.222	38.3	0.177	0.5
02/07/24	09:00	48.4	0.221	38.4	0.177	0.5
02/07/24	10:00	48.8	0.223	38.3	0.177	0.5
02/07/24	11:00	48.6	0.222	38.4	0.177	0.5
02/07/24	12:00	48.7	0.223	38.5	0.178	0.5
02/07/24	13:00	49.2	0.226	38.3	0.178	0.5
02/07/24	14:00	49.7	0.229	38.2	0.178	0.5
02/07/24	15:00	51.4	0.237	38.1	0.178	0.5
02/07/24	16:00	52.1	0.240	38.2	0.179	0.5
02/07/24	17:00	52.2	0.241	38.2	0.179	0.5
02/07/24	18:00	52.5	0.243	38.2	0.179	0.5
02/07/24	19:00	52.4	0.242	38.1	0.179	0.5
02/07/24	20:00	52.3	0.242	38.2	0.180	0.5
02/07/24	21:00	52.1	0.241	38.2	0.180	0.5
02/07/24	22:00	52.3	0.242	38.1	0.180	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/07/24	23:00	52.8	0.245	38.0	0.179	0.5
02/08/24	00:00	53.2	0.246	37.9	0.179	0.5
02/08/24	01:00	53.3	0.247	37.8	0.178	0.5
02/08/24	02:00	54.1	0.250	37.8	0.177	0.5
02/08/24	03:00	54.4	0.251	37.5	0.176	0.5
02/08/24	04:00	54.7	0.252	37.3	0.175	0.5
02/08/24	05:00	54.8	0.253	37.3	0.175	0.5
02/08/24	06:00	54.9	0.253	37.2	0.175	0.5
02/08/24	07:00	55.0	0.253	37.2	0.175	0.5
02/08/24	08:00	54.9	0.253	37.2	0.175	0.5
02/08/24	09:00	55.1	0.254	37.2	0.174	0.5
02/08/24	10:00	55.2	0.254	37.2	0.174	0.5
02/08/24	11:00	55.7	0.254	37.5	0.174	0.5
02/08/24	12:00	63.7	0.266	39.6	0.175	0.5
02/08/24	13:00	80.1	0.290	42.7	0.176	0.5
02/08/24	14:00	83.7	0.295	43.7	0.176	0.5
02/08/24	15:00	82.6	0.291	43.4	0.175	0.5
02/08/24	16:00	82.5	0.290	43.1	0.173	0.5
02/08/24	17:00	81.3	0.285	43.1	0.174	0.5
02/08/24	18:00	80.2	0.280	43.2	0.174	0.5
02/08/24	19:00	79.7	0.277	43.0	0.173	0.5
02/08/24	20:00	79.3	0.275	42.9	0.172	0.5
02/08/24	21:00	79.0	0.274	42.8	0.171	0.5
02/08/24	22:00	78.5	0.271	42.7	0.171	0.5
02/08/24	23:00	77.9	0.268	42.7	0.171	0.5
02/09/24	00:00	77.6	0.267	42.6	0.170	0.5
02/09/24	01:00	77.3	0.265	42.5	0.170	0.5
02/09/24	02:00	76.8	0.263	42.3	0.169	0.5
02/09/24	03:00	77.1	0.264	42.5	0.169	0.5
02/09/24	04:00	76.8	0.263	42.6	0.170	0.5
02/09/24	05:00	76.7	0.262	42.7	0.170	0.5
02/09/24	06:00	76.2	0.260	42.8	0.171	0.5
02/09/24	07:00	76.0	0.259	42.8	0.171	0.5
02/09/24	08:00	76.2	0.260	42.8	0.170	0.5
02/09/24	09:00	75.7	0.258	42.9	0.171	0.5
02/09/24	10:00	75.0	0.255	43.2	0.172	0.5
02/09/24	11:00	75.2	0.255	42.8	0.171	0.5
02/09/24	12:00	80.5	0.266	42.6	0.170	0.5
02/09/24	13:00	76.5	0.261	42.9	0.172	0.5
02/09/24	14:00	76.1	0.257	45.4	0.175	0.5
02/09/24	15:00	75.1	0.250	45.6	0.174	0.5
02/09/24	16:00	77.5	0.260	45.3	0.172	0.5
02/09/24	17:00	78.5	0.265	45.3	0.172	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/09/24	18:00	79.6	0.270	45.2	0.171	0.5
02/09/24	19:00	81.0	0.276	45.5	0.172	0.6
02/09/24	20:00	81.1	0.276	45.7	0.173	0.6
02/09/24	21:00	81.0	0.276	45.9	0.174	0.6
02/09/24	22:00	80.9	0.275	46.1	0.175	0.6
02/09/24	23:00	80.7	0.275	46.3	0.177	0.6
02/10/24	00:00	80.2	0.273	46.6	0.178	0.6
02/10/24	01:00	79.9	0.272	46.7	0.179	0.6
02/10/24	02:00	80.0	0.272	47.1	0.181	0.6
02/10/24	03:00	79.0	0.268	47.2	0.182	0.6
02/10/24	04:00	78.8	0.267	47.2	0.182	0.6
02/10/24	05:00	78.8	0.267	47.2	0.182	0.6
02/10/24	06:00	78.7	0.267	47.2	0.182	0.6
02/10/24	07:00	79.0	0.268	47.3	0.182	0.6
02/10/24	08:00	78.5	0.266	47.4	0.183	0.6
02/10/24	09:00	78.8	0.267	47.3	0.182	0.6
02/10/24	10:00	79.3	0.270	47.2	0.182	0.6
02/10/24	11:00	78.9	0.269	47.3	0.183	0.6
02/10/24	12:00	65.3	0.246	45.3	0.182	0.5
02/10/24	13:00	53.2	0.228	41.8	0.179	0.5
02/10/24	14:00	51.1	0.231	38.3	0.176	0.5
02/10/24	15:00	52.1	0.237	38.2	0.178	0.5
02/10/24	16:00	50.5	0.231	38.5	0.180	0.5
02/10/24	17:00	50.5	0.231	38.4	0.179	0.5
02/10/24	18:00	50.3	0.230	38.6	0.180	0.5
02/10/24	19:00	49.1	0.226	38.5	0.181	0.4
02/10/24	20:00	49.4	0.227	38.4	0.180	0.4
02/10/24	21:00	49.6	0.228	38.4	0.180	0.4
02/10/24	22:00	49.7	0.228	38.3	0.180	0.4
02/10/24	23:00	49.8	0.229	38.4	0.180	0.4
02/11/24	00:00	49.8	0.228	38.4	0.180	0.4
02/11/24	01:00	49.9	0.229	38.5	0.180	0.4
02/11/24	02:00	49.7	0.228	38.5	0.180	0.4
02/11/24	03:00	49.9	0.229	38.4	0.179	0.4
02/11/24	04:00	49.8	0.228	38.4	0.179	0.4
02/11/24	05:00	49.5	0.227	38.5	0.180	0.4
02/11/24	06:00	49.5	0.227	38.5	0.180	0.4
02/11/24	07:00	49.3	0.227	38.4	0.180	0.4
02/11/24	08:00	49.1	0.226	38.4	0.180	0.4
02/11/24	09:00	48.7	0.224	38.5	0.181	0.4
02/11/24	10:00	48.6	0.224	38.5	0.181	0.4
02/11/24	11:00	48.5	0.223	38.5	0.181	0.4
02/11/24	12:00	48.8	0.224	38.5	0.181	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/11/24	13:00	48.7	0.224	38.6	0.181	0.4
02/11/24	14:00	48.8	0.225	38.6	0.181	0.4
02/11/24	15:00	49.1	0.226	38.5	0.181	0.4
02/11/24	16:00	48.7	0.225	38.6	0.181	0.4
02/11/24	17:00	48.9	0.225	38.6	0.182	0.4
02/11/24	18:00	49.0	0.226	38.6	0.181	0.4
02/11/24	19:00	49.3	0.227	38.5	0.181	0.4
02/11/24	20:00	49.5	0.228	38.5	0.181	0.4
02/11/24	21:00	49.6	0.228	38.5	0.181	0.4
02/11/24	22:00	49.7	0.229	38.6	0.181	0.4
02/11/24	23:00	50.0	0.230	38.5	0.180	0.4
02/12/24	00:00	50.3	0.231	38.4	0.180	0.4
02/12/24	01:00	51.9	0.238	38.3	0.179	0.4
02/12/24	02:00	51.1	0.235	38.3	0.180	0.4
02/12/24	03:00	51.1	0.235	38.4	0.180	0.4
02/12/24	04:00	51.7	0.238	38.3	0.180	0.4
02/12/24	05:00	52.0	0.239	38.2	0.179	0.4
02/12/24	06:00	52.3	0.240	38.1	0.179	0.4
02/12/24	07:00	52.0	0.239	38.2	0.179	0.4
02/12/24	08:00	52.0	0.239	38.2	0.179	0.4
02/12/24	09:00	52.2	0.239	38.2	0.179	0.4
02/12/24	10:00	52.2	0.239	38.3	0.179	0.5
02/12/24	11:00	52.0	0.239	38.3	0.179	0.5
02/12/24	12:00	51.2	0.235	38.4	0.180	0.5
02/12/24	13:00	50.5	0.232	38.5	0.180	0.5
02/12/24	14:00	49.1	0.227	38.4	0.181	0.4
02/12/24	15:00	49.2	0.226	38.7	0.181	0.5
02/12/24	16:00	48.7	0.224	38.7	0.181	0.5
02/12/24	17:00	47.9	0.220	38.8	0.182	0.5
02/12/24	18:00	47.2	0.217	38.9	0.183	0.5
02/12/24	19:00	46.6	0.215	39.0	0.183	0.5
02/12/24	20:00	46.2	0.213	39.1	0.184	0.5
02/12/24	21:00	46.2	0.213	39.0	0.183	0.5
02/12/24	22:00	46.3	0.214	38.8	0.183	0.4
02/12/24	23:00	46.1	0.213	38.8	0.183	0.4
02/13/24	00:00	46.0	0.212	38.8	0.183	0.4
02/13/24	01:00	44.3	0.205	38.8	0.183	0.4
02/13/24	02:00	45.8	0.212	38.7	0.182	0.4
02/13/24	03:00	46.0	0.213	38.5	0.181	0.4
02/13/24	04:00	45.6	0.211	38.5	0.181	0.4
02/13/24	05:00	45.4	0.210	38.6	0.182	0.4
02/13/24	06:00	45.1	0.208	38.5	0.182	0.4
02/13/24	07:00	44.8	0.207	38.5	0.182	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/13/24	08:00	44.8	0.207	38.4	0.181	0.4
02/13/24	09:00	44.6	0.206	38.4	0.181	0.4
02/13/24	10:00	44.3	0.205	38.4	0.181	0.4
02/13/24	11:00	44.0	0.203	38.4	0.181	0.4
02/13/24	12:00	44.2	0.205	38.3	0.181	0.4
02/13/24	13:00	48.2	0.214	39.0	0.180	0.5
02/13/24	14:00	48.8	0.216	38.6	0.178	0.5
02/13/24	15:00	48.9	0.217	38.3	0.177	0.5
02/13/24	16:00	49.4	0.219	38.1	0.176	0.5
02/13/24	17:00	49.7	0.220	38.1	0.176	0.5
02/13/24	18:00	49.8	0.221	38.0	0.175	0.5
02/13/24	19:00	50.0	0.222	38.0	0.175	0.5
02/13/24	20:00	50.2	0.223	37.9	0.175	0.5
02/13/24	21:00	50.5	0.224	37.8	0.174	0.5
02/13/24	22:00	50.6	0.225	37.8	0.174	0.5
02/13/24	23:00	50.9	0.226	37.7	0.174	0.5
02/14/24	00:00	51.2	0.227	37.6	0.173	0.5
02/14/24	01:00	52.4	0.232	37.6	0.173	0.5
02/14/24	02:00	51.0	0.227	37.7	0.174	0.5
02/14/24	03:00	50.7	0.225	37.8	0.174	0.5
02/14/24	04:00	50.2	0.223	37.9	0.175	0.5
02/14/24	05:00	50.1	0.223	37.9	0.175	0.5
02/14/24	06:00	50.1	0.223	37.9	0.175	0.5
02/14/24	07:00	50.0	0.222	37.9	0.175	0.5
02/14/24	08:00	49.8	0.221	38.0	0.175	0.5
02/14/24	09:00	49.9	0.221	38.0	0.176	0.5
02/14/24	10:00	49.8	0.221	38.0	0.176	0.5
02/14/24	11:00	50.0	0.222	38.0	0.175	0.5
02/14/24	12:00	50.0	0.222	38.1	0.176	0.5
02/14/24	13:00	46.5	0.215	37.3	0.176	0.4
02/14/24	14:00	46.5	0.215	37.7	0.178	0.4
02/14/24	15:00	46.1	0.213	37.8	0.178	0.4
02/14/24	16:00	46.0	0.213	37.9	0.178	0.4
02/14/24	17:00	46.0	0.212	37.9	0.178	0.4
02/14/24	18:00	45.8	0.211	37.9	0.178	0.4
02/14/24	19:00	45.5	0.210	37.9	0.178	0.4
02/14/24	20:00	45.1	0.208	38.0	0.178	0.4
02/14/24	21:00	44.6	0.206	38.1	0.179	0.4
02/14/24	22:00	44.4	0.204	38.2	0.179	0.4
02/14/24	23:00	43.8	0.202	38.3	0.180	0.4
02/15/24	00:00	43.6	0.201	38.3	0.180	0.4
02/15/24	01:00	42.3	0.195	38.4	0.181	0.4
02/15/24	02:00	43.0	0.198	38.4	0.181	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/15/24	03:00	43.3	0.199	38.3	0.180	0.4
02/15/24	04:00	43.7	0.201	38.2	0.179	0.4
02/15/24	05:00	43.8	0.201	38.2	0.179	0.4
02/15/24	06:00	44.3	0.203	38.1	0.178	0.4
02/15/24	07:00	44.8	0.206	38.0	0.178	0.4
02/15/24	08:00	45.2	0.207	37.9	0.177	0.4
02/15/24	09:00	45.4	0.208	37.9	0.177	0.4
02/15/24	10:00	46.2	0.212	37.7	0.176	0.4
02/15/24	11:00	46.7	0.214	37.7	0.176	0.4
02/15/24	12:00	47.3	0.216	37.6	0.175	0.5
02/15/24	13:00	48.3	0.220	37.6	0.175	0.5
02/15/24	14:00	48.1	0.219	37.7	0.175	0.5
02/15/24	15:00	47.7	0.217	37.9	0.176	0.5
02/15/24	16:00	47.6	0.217	38.0	0.176	0.5
02/15/24	17:00	47.7	0.217	38.0	0.176	0.5
02/15/24	18:00	47.9	0.217	38.1	0.176	0.5
02/15/24	19:00	48.2	0.218	38.2	0.177	0.5
02/15/24	20:00	48.4	0.219	38.3	0.177	0.5
02/15/24	21:00	48.7	0.220	38.4	0.177	0.5
02/15/24	22:00	48.9	0.221	38.5	0.177	0.5
02/15/24	23:00	49.4	0.223	38.6	0.177	0.5
02/16/24	00:00	49.7	0.225	38.5	0.177	0.5
02/16/24	01:00	50.2	0.227	38.5	0.177	0.5
02/16/24	02:00	50.7	0.229	38.5	0.177	0.5
02/16/24	03:00	51.0	0.230	38.5	0.177	0.5
02/16/24	04:00	51.1	0.231	38.6	0.177	0.5
02/16/24	05:00	51.2	0.231	38.6	0.177	0.5
02/16/24	06:00	51.0	0.230	38.8	0.178	0.5
02/16/24	07:00	50.7	0.228	39.0	0.179	0.5
02/16/24	08:00	50.7	0.228	39.2	0.180	0.5
02/16/24	09:00	50.5	0.227	39.3	0.180	0.5
02/16/24	10:00	49.8	0.224	39.5	0.181	0.5
02/16/24	11:00	51.3	0.225	40.5	0.181	0.5
02/16/24	12:00	50.3	0.220	40.6	0.182	0.5
02/16/24	13:00	49.3	0.217	40.5	0.182	0.5
02/16/24	14:00	49.0	0.216	40.4	0.182	0.5
02/16/24	15:00	48.9	0.216	40.3	0.182	0.5
02/16/24	16:00	48.6	0.215	40.3	0.183	0.5
02/16/24	17:00	48.4	0.214	40.4	0.183	0.5
02/16/24	18:00	48.7	0.216	40.2	0.183	0.5
02/16/24	19:00	48.9	0.218	40.0	0.182	0.5
02/16/24	20:00	49.1	0.219	39.8	0.182	0.5
02/16/24	21:00	49.7	0.222	39.6	0.181	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/16/24	22:00	50.1	0.224	39.4	0.180	0.5
02/16/24	23:00	50.0	0.224	39.3	0.180	0.5
02/17/24	00:00	49.7	0.223	39.4	0.180	0.5
02/17/24	01:00	49.3	0.221	39.3	0.181	0.5
02/17/24	02:00	49.0	0.220	39.4	0.181	0.5
02/17/24	03:00	49.3	0.222	39.4	0.181	0.5
02/17/24	04:00	49.7	0.224	39.3	0.181	0.5
02/17/24	05:00	50.2	0.226	39.2	0.181	0.5
02/17/24	06:00	50.7	0.229	39.1	0.180	0.5
02/17/24	07:00	51.2	0.231	38.9	0.180	0.5
02/17/24	08:00	51.3	0.232	38.9	0.180	0.5
02/17/24	09:00	51.4	0.232	38.9	0.180	0.5
02/17/24	10:00	51.6	0.234	38.9	0.180	0.5
02/17/24	11:00	49.8	0.232	38.1	0.180	0.5
02/17/24	12:00	50.4	0.235	38.2	0.182	0.5
02/17/24	13:00	50.4	0.236	38.2	0.182	0.5
02/17/24	14:00	51.5	0.239	38.4	0.182	0.5
02/17/24	15:00	51.3	0.238	38.5	0.182	0.5
02/17/24	16:00	51.2	0.237	38.5	0.183	0.5
02/17/24	17:00	51.4	0.238	38.5	0.182	0.5
02/17/24	18:00	51.0	0.236	38.6	0.183	0.5
02/17/24	19:00	50.9	0.236	38.7	0.183	0.5
02/17/24	20:00	50.9	0.236	38.7	0.183	0.5
02/17/24	21:00	50.2	0.233	38.8	0.183	0.5
02/17/24	22:00	50.0	0.231	38.8	0.183	0.5
02/17/24	23:00	49.7	0.230	38.8	0.183	0.5
02/18/24	00:00	49.9	0.231	38.8	0.183	0.5
02/18/24	01:00	49.9	0.231	38.8	0.183	0.5
02/18/24	02:00	49.2	0.228	38.9	0.184	0.5
02/18/24	03:00	48.5	0.225	38.9	0.184	0.5
02/18/24	04:00	48.1	0.223	38.9	0.184	0.5
02/18/24	05:00	47.9	0.222	38.8	0.183	0.5
02/18/24	06:00	47.8	0.221	38.8	0.183	0.5
02/18/24	07:00	47.6	0.220	38.8	0.183	0.5
02/18/24	08:00	48.0	0.222	38.7	0.182	0.5
02/18/24	09:00	48.2	0.223	38.6	0.182	0.5
02/18/24	10:00	47.8	0.221	38.6	0.182	0.5
02/18/24	11:00	47.6	0.220	38.6	0.182	0.5
02/18/24	12:00	47.3	0.218	38.6	0.182	0.5
02/18/24	13:00	47.3	0.218	38.7	0.182	0.5
02/18/24	14:00	46.4	0.214	38.7	0.182	0.5
02/18/24	15:00	46.8	0.216	38.6	0.181	0.5
02/18/24	16:00	47.3	0.218	38.4	0.180	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/18/24	17:00	47.6	0.220	38.4	0.180	0.5
02/18/24	18:00	48.1	0.222	38.3	0.180	0.5
02/18/24	19:00	48.4	0.223	38.3	0.180	0.5
02/18/24	20:00	48.7	0.225	38.3	0.180	0.5
02/18/24	21:00	49.0	0.226	38.3	0.180	0.5
02/18/24	22:00	49.1	0.227	38.4	0.180	0.5
02/18/24	23:00	49.6	0.229	38.3	0.180	0.5
02/19/24	00:00	50.2	0.232	38.3	0.180	0.5
02/19/24	01:00	51.4	0.237	38.2	0.179	0.5
02/19/24	02:00	52.2	0.241	38.1	0.179	0.5
02/19/24	03:00	52.4	0.242	38.2	0.179	0.5
02/19/24	04:00	53.0	0.244	38.1	0.179	0.5
02/19/24	05:00	53.0	0.245	38.2	0.179	0.5
02/19/24	06:00	52.8	0.244	38.4	0.180	0.5
02/19/24	07:00	52.9	0.245	38.4	0.181	0.5
02/19/24	08:00	52.7	0.244	38.5	0.181	0.5
02/19/24	09:00	52.6	0.244	38.6	0.182	0.5
02/19/24	10:00	53.2	0.247	38.5	0.181	0.5
02/19/24	11:00	53.5	0.248	38.4	0.181	0.5
02/19/24	12:00	54.2	0.252	38.4	0.181	0.5
02/19/24	13:00	54.6	0.253	38.2	0.180	0.5
02/19/24	14:00	55.3	0.256	38.0	0.179	0.5
02/19/24	15:00	57.8	0.265	37.9	0.177	0.5
02/19/24	16:00	57.4	0.262	37.7	0.176	0.5
02/19/24	17:00	57.6	0.262	37.6	0.175	0.5
02/19/24	18:00	57.0	0.259	37.7	0.175	0.5
02/19/24	19:00	56.4	0.256	37.7	0.175	0.5
02/19/24	20:00	56.2	0.254	37.7	0.175	0.5
02/19/24	21:00	56.0	0.253	37.7	0.174	0.5
02/19/24	22:00	55.8	0.252	37.7	0.174	0.5
02/19/24	23:00	55.2	0.249	37.7	0.174	0.5
02/20/24	00:00	54.5	0.245	37.9	0.174	0.5
02/20/24	01:00	53.5	0.241	38.1	0.175	0.5
02/20/24	02:00	54.6	0.245	38.1	0.175	0.5
02/20/24	03:00	54.7	0.245	38.2	0.176	0.5
02/20/24	04:00	54.1	0.243	38.3	0.176	0.5
02/20/24	05:00	54.3	0.244	38.3	0.176	0.5
02/20/24	06:00	54.0	0.242	38.3	0.176	0.5
02/20/24	07:00	54.0	0.242	38.3	0.176	0.5
02/20/24	08:00	53.7	0.241	38.4	0.176	0.5
02/20/24	09:00	54.1	0.242	38.3	0.176	0.6
02/20/24	10:00	54.1	0.242	38.3	0.176	0.6
02/20/24	11:00	54.2	0.243	38.2	0.175	0.6

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/20/24	12:00	53.9	0.242	38.2	0.176	0.6
02/20/24	13:00	54.4	0.240	39.0	0.176	0.6
02/20/24	14:00	54.6	0.240	38.7	0.175	0.6
02/20/24	15:00	52.4	0.233	38.7	0.176	0.6
02/20/24	16:00	52.7	0.235	39.0	0.177	0.6
02/20/24	17:00	52.2	0.234	39.1	0.179	0.6
02/20/24	18:00	52.3	0.235	39.1	0.179	0.6
02/20/24	19:00	52.6	0.237	39.0	0.180	0.6
02/20/24	20:00	53.1	0.240	39.0	0.180	0.5
02/20/24	21:00	53.3	0.242	39.0	0.180	0.5
02/20/24	22:00	53.0	0.241	39.0	0.181	0.5
02/20/24	23:00	53.1	0.241	39.1	0.182	0.5
02/21/24	00:00	53.3	0.243	39.0	0.182	0.5
02/21/24	01:00	53.6	0.245	38.8	0.181	0.5
02/21/24	02:00	51.9	0.237	38.9	0.182	0.5
02/21/24	03:00	53.1	0.242	38.7	0.180	0.5
02/21/24	04:00	53.6	0.245	38.6	0.180	0.5
02/21/24	05:00	53.1	0.242	38.7	0.180	0.5
02/21/24	06:00	53.3	0.244	38.6	0.180	0.5
02/21/24	07:00	53.7	0.245	38.7	0.180	0.5
02/21/24	08:00	53.9	0.246	38.8	0.181	0.5
02/21/24	09:00	53.4	0.244	38.8	0.181	0.5
02/21/24	10:00	53.3	0.244	38.9	0.182	0.5
02/21/24	11:00	53.0	0.242	39.1	0.182	0.5
02/21/24	12:00	53.0	0.242	39.0	0.182	0.5
02/21/24	13:00	52.9	0.246	38.1	0.181	0.5
02/21/24	14:00	52.6	0.245	38.4	0.183	0.5
02/21/24	15:00	54.2	0.251	38.6	0.183	0.5
02/21/24	16:00	54.5	0.253	38.5	0.183	0.5
02/21/24	17:00	55.2	0.256	38.4	0.182	0.5
02/21/24	18:00	55.6	0.257	38.4	0.182	0.5
02/21/24	19:00	55.9	0.259	38.5	0.182	0.5
02/21/24	20:00	55.4	0.257	38.6	0.183	0.5
02/21/24	21:00	55.3	0.256	38.8	0.184	0.5
02/21/24	22:00	56.0	0.259	38.7	0.183	0.5
02/21/24	23:00	56.9	0.263	38.6	0.182	0.5
02/22/24	00:00	57.3	0.265	38.5	0.181	0.5
02/22/24	01:00	57.4	0.264	38.6	0.181	0.5
02/22/24	02:00	57.9	0.267	38.5	0.181	0.5
02/22/24	03:00	56.9	0.263	38.6	0.182	0.5
02/22/24	04:00	57.1	0.264	38.6	0.182	0.5
02/22/24	05:00	57.1	0.264	38.5	0.182	0.5
02/22/24	06:00	57.1	0.263	38.5	0.181	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/22/24	07:00	56.6	0.261	38.6	0.182	0.5
02/22/24	08:00	57.1	0.263	38.6	0.181	0.5
02/22/24	09:00	57.7	0.265	38.6	0.181	0.5
02/22/24	10:00	57.8	0.266	38.7	0.181	0.5
02/22/24	11:00	58.2	0.267	38.6	0.181	0.5
02/22/24	12:00	58.6	0.268	38.6	0.180	0.5
02/22/24	13:00	58.1	0.266	39.0	0.182	0.5
02/22/24	14:00	58.3	0.267	38.9	0.182	0.5
02/22/24	15:00	57.2	0.262	38.7	0.181	0.5
02/22/24	16:00	56.9	0.260	38.6	0.180	0.5
02/22/24	17:00	56.0	0.255	38.6	0.179	0.6
02/22/24	18:00	55.5	0.253	38.4	0.178	0.6
02/22/24	19:00	55.1	0.251	38.2	0.177	0.7
02/22/24	20:00	54.5	0.248	38.0	0.176	0.7
02/22/24	21:00	53.9	0.244	37.8	0.175	0.8
02/22/24	22:00	53.0	0.240	37.7	0.174	0.9
02/22/24	23:00	52.7	0.238	37.5	0.173	1.0
02/23/24	00:00	52.0	0.235	37.3	0.172	1.1
02/23/24	01:00	50.8	0.229	37.1	0.171	1.2
02/23/24	02:00	49.8	0.225	36.7	0.169	1.3
02/23/24	03:00	50.6	0.228	36.6	0.168	1.4
02/23/24	04:00	49.2	0.221	36.5	0.167	1.6
02/23/24	05:00	49.0	0.220	36.3	0.166	1.7
02/23/24	06:00	48.5	0.218	36.1	0.165	1.8
02/23/24	07:00	48.2	0.216	35.8	0.164	2.0
02/23/24	08:00	47.5	0.213	35.6	0.163	2.1
02/23/24	09:00	47.2	0.212	35.4	0.162	2.1
02/23/24	10:00	55.2	0.228	36.4	0.162	2.5
02/23/24	11:00	70.1	0.250	39.9	0.164	3.0
02/23/24	12:00	75.1	0.257	41.8	0.165	3.1
02/23/24	13:00	74.0	0.252	41.8	0.165	3.3
02/23/24	14:00	72.5	0.246	41.9	0.166	3.4
02/23/24	15:00	71.1	0.241	41.9	0.167	3.6
02/23/24	16:00	70.7	0.239	42.0	0.168	3.8
02/23/24	17:00	70.7	0.240	42.0	0.168	3.9
02/23/24	18:00	70.2	0.238	42.0	0.169	4.1
02/23/24	19:00	69.4	0.235	42.1	0.170	4.3
02/23/24	20:00	69.0	0.233	42.1	0.170	4.4
02/23/24	21:00	68.6	0.231	42.1	0.171	4.6
02/23/24	22:00	68.4	0.231	42.1	0.171	4.7
02/23/24	23:00	67.7	0.228	42.3	0.172	4.7
02/24/24	00:00	67.4	0.227	42.3	0.173	4.8
02/24/24	01:00	67.7	0.229	42.3	0.173	4.8

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/24/24	02:00	67.5	0.228	42.7	0.175	4.9
02/24/24	03:00	66.6	0.225	42.8	0.176	4.9
02/24/24	04:00	67.0	0.228	42.8	0.177	5.0
02/24/24	05:00	67.0	0.228	42.9	0.177	5.0
02/24/24	06:00	67.3	0.230	42.9	0.178	5.0
02/24/24	07:00	66.8	0.228	43.0	0.179	5.1
02/24/24	08:00	67.1	0.230	43.1	0.179	5.3
02/24/24	09:00	67.1	0.230	43.1	0.180	5.4
02/24/24	10:00	58.5	0.211	42.0	0.180	5.1
02/24/24	11:00	43.4	0.189	38.4	0.178	4.8
02/24/24	12:00	38.6	0.184	36.4	0.176	4.8
02/24/24	13:00	39.5	0.188	36.2	0.175	4.8
02/24/24	14:00	39.7	0.189	36.1	0.175	4.8
02/24/24	15:00	40.0	0.190	36.2	0.175	4.9
02/24/24	16:00	40.0	0.190	36.2	0.175	5.0
02/24/24	17:00	40.0	0.190	36.4	0.175	5.0
02/24/24	18:00	40.3	0.190	36.4	0.175	5.0
02/24/24	19:00	40.4	0.191	36.4	0.175	5.0
02/24/24	20:00	40.7	0.193	36.4	0.175	5.0
02/24/24	21:00	41.1	0.195	36.3	0.175	4.9
02/24/24	22:00	41.7	0.197	36.3	0.175	5.0
02/24/24	23:00	42.3	0.200	36.4	0.175	5.0
02/25/24	00:00	42.9	0.202	36.5	0.175	5.1
02/25/24	01:00	43.2	0.204	36.6	0.176	5.2
02/25/24	02:00	42.9	0.203	36.5	0.175	5.1
02/25/24	03:00	43.3	0.204	36.5	0.175	5.3
02/25/24	04:00	43.0	0.202	36.5	0.175	5.3
02/25/24	05:00	42.8	0.201	36.5	0.175	5.4
02/25/24	06:00	42.6	0.200	36.5	0.174	5.5
02/25/24	07:00	43.0	0.201	36.4	0.174	5.6
02/25/24	08:00	42.9	0.201	36.3	0.173	5.7
02/25/24	09:00	42.7	0.199	36.2	0.172	5.8
02/25/24	10:00	42.8	0.199	36.1	0.171	6.0
02/25/24	11:00	42.3	0.197	36.0	0.171	6.1
02/25/24	12:00	41.8	0.194	36.1	0.171	6.3
02/25/24	13:00	41.7	0.193	36.2	0.171	6.5
02/25/24	14:00	41.5	0.192	36.4	0.172	6.7
02/25/24	15:00	41.9	0.193	36.5	0.172	6.9
02/25/24	16:00	41.5	0.191	36.6	0.172	7.1
02/25/24	17:00	41.1	0.189	36.6	0.172	7.2
02/25/24	18:00	40.9	0.189	36.7	0.173	7.4
02/25/24	19:00	41.2	0.190	36.8	0.173	7.5
02/25/24	20:00	41.2	0.190	36.8	0.173	7.7

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/25/24	21:00	41.5	0.191	36.8	0.173	8.0
02/25/24	22:00	41.3	0.190	36.8	0.173	8.1
02/25/24	23:00	41.2	0.190	36.7	0.172	8.4
02/26/24	00:00	40.8	0.187	36.7	0.172	8.6
02/26/24	01:00	40.4	0.185	36.7	0.172	8.7
02/26/24	02:00	40.2	0.184	36.7	0.172	8.9
02/26/24	03:00	40.0	0.184	36.7	0.172	9.2
02/26/24	04:00	40.1	0.184	36.8	0.172	9.5
02/26/24	05:00	40.5	0.185	36.7	0.172	9.6
02/26/24	06:00	40.9	0.187	36.7	0.171	9.7
02/26/24	07:00	40.9	0.187	36.7	0.171	9.8
02/26/24	08:00	40.6	0.186	36.8	0.172	9.9
02/26/24	09:00	40.2	0.184	36.9	0.172	9.9
02/26/24	10:00	39.8	0.182	37.0	0.173	10.0
02/26/24	11:00	39.3	0.180	37.1	0.174	10.0
02/26/24	12:00	38.5	0.177	37.1	0.174	10.0
02/26/24	13:00	37.4	0.172	37.1	0.175	9.9
02/26/24	14:00	37.8	0.174	36.9	0.174	9.9
02/26/24	15:00	36.9	0.171	36.7	0.173	9.8
02/26/24	16:00	36.8	0.171	36.6	0.173	9.7
02/26/24	17:00	38.8	0.179	36.6	0.172	9.7
02/26/24	18:00	39.2	0.180	36.6	0.172	9.5
02/26/24	19:00	39.3	0.181	36.6	0.172	9.2
02/26/24	20:00	39.5	0.182	36.8	0.173	8.9
02/26/24	21:00	39.8	0.183	36.9	0.174	8.4
02/26/24	22:00	40.1	0.185	37.1	0.174	8.1
02/26/24	23:00	40.0	0.184	37.2	0.175	7.6
02/27/24	00:00	40.1	0.184	37.2	0.174	7.2
02/27/24	01:00	40.5	0.185	37.2	0.174	6.9
02/27/24	02:00	41.1	0.188	37.2	0.174	6.5
02/27/24	03:00	41.7	0.190	37.2	0.174	6.0
02/27/24	04:00	42.4	0.194	37.2	0.174	5.4
02/27/24	05:00	42.5	0.194	37.4	0.175	5.0
02/27/24	06:00	46.3	0.202	38.3	0.175	4.9
02/27/24	07:00	56.8	0.217	42.0	0.178	4.7
02/27/24	08:00	66.9	0.233	45.3	0.181	4.3
02/27/24	09:00	78.8	0.253	48.8	0.184	4.0
02/27/24	10:00	86.4	0.266	51.5	0.186	3.5
02/27/24	11:00	91.1	0.274	53.2	0.187	3.3
02/27/24	12:00	95.9	0.283	55.0	0.188	3.0
02/27/24	13:00	101.2	0.293	56.8	0.188	2.7
02/27/24	14:00	104.9	0.299	58.6	0.190	2.4
02/27/24	15:00	108.9	0.306	60.4	0.191	2.0

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/27/24	16:00	110.0	0.307	61.3	0.191	1.7
02/27/24	17:00	109.2	0.304	61.2	0.191	1.3
02/27/24	18:00	109.1	0.303	61.1	0.190	1.2
02/27/24	19:00	109.0	0.303	61.0	0.189	1.2
02/27/24	20:00	108.9	0.302	60.8	0.188	1.1
02/27/24	21:00	108.3	0.299	60.6	0.187	1.1
02/27/24	22:00	108.0	0.298	60.5	0.186	1.1
02/27/24	23:00	107.9	0.297	60.4	0.186	1.0
02/28/24	00:00	107.9	0.297	60.4	0.186	1.0
02/28/24	01:00	107.9	0.297	60.4	0.186	1.0
02/28/24	02:00	108.1	0.298	60.3	0.185	1.0
02/28/24	03:00	108.0	0.297	60.2	0.184	1.0
02/28/24	04:00	108.0	0.297	59.9	0.183	1.0
02/28/24	05:00	108.0	0.296	59.5	0.181	1.0
02/28/24	06:00	108.3	0.297	60.3	0.183	0.8
02/28/24	07:00	102.5	0.288	58.9	0.182	0.7
02/28/24	08:00	95.0	0.274	57.7	0.180	0.7
02/28/24	09:00	86.7	0.259	55.9	0.178	0.6
02/28/24	10:00	80.6	0.247	55.2	0.177	0.6
02/28/24	11:00	78.3	0.241	55.0	0.177	0.6
02/28/24	12:00	81.6	0.244	56.0	0.177	0.6
02/28/24	13:00	82.1	0.243	57.3	0.178	0.7
02/28/24	14:00	85.6	0.249	57.8	0.178	0.7
02/28/24	15:00	83.4	0.243	57.5	0.177	0.7
02/28/24	16:00	88.9	0.253	59.5	0.179	0.7
02/28/24	17:00	91.5	0.254	60.8	0.180	0.7
02/28/24	18:00	92.5	0.259	60.6	0.179	0.7
02/28/24	19:00	92.2	0.257	60.7	0.179	0.7
02/28/24	20:00	92.1	0.257	60.7	0.179	0.7
02/28/24	21:00	91.9	0.256	60.6	0.180	0.7
02/28/24	22:00	91.5	0.255	60.6	0.180	0.7
02/28/24	23:00	91.3	0.255	60.5	0.180	0.7
02/29/24	00:00	90.8	0.253	60.5	0.180	0.7
02/29/24	01:00	90.8	0.253	60.4	0.180	0.7
02/29/24	02:00	90.1	0.250	60.4	0.180	0.7
02/29/24	03:00	89.3	0.247	60.4	0.180	0.7
02/29/24	04:00	88.1	0.242	60.5	0.181	0.7
02/29/24	05:00	87.5	0.239	60.7	0.182	0.7
02/29/24	06:00	85.7	0.235	60.0	0.180	0.7
02/29/24	07:00	84.7	0.233	58.9	0.178	0.7
02/29/24	08:00	91.9	0.247	59.0	0.177	0.7
02/29/24	09:00	100.5	0.263	59.4	0.177	0.7
02/29/24	10:00	118.6	0.300	59.0	0.175	0.7

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/29/24	11:00	125.8	0.319	58.2	0.173	0.7
02/29/24	12:00	125.8	0.319	58.2	0.173	0.7
02/29/24	13:00	116.7	0.301	55.9	0.171	0.7
02/29/24	14:00	110.2	0.288	53.4	0.169	0.6
02/29/24	15:00	102.5	0.274	51.2	0.167	0.6
02/29/24	16:00	100.2	0.271	49.5	0.166	0.6
02/29/24	17:00	93.6	0.260	46.4	0.164	0.6
02/29/24	18:00	89.7	0.253	45.0	0.163	0.6
02/29/24	19:00	88.5	0.248	45.0	0.164	0.6
02/29/24	20:00	88.5	0.248	44.8	0.163	0.6
02/29/24	21:00	88.2	0.247	44.6	0.163	0.6
02/29/24	22:00	88.0	0.246	44.5	0.162	0.6
02/29/24	23:00	87.8	0.246	44.3	0.162	0.6
03/01/24	00:00	87.5	0.245	44.2	0.161	0.5
03/01/24	01:00	87.3	0.244	44.1	0.161	0.5
03/01/24	02:00	87.2	0.244	43.9	0.161	0.5
03/01/24	03:00	88.5	0.249	43.7	0.160	0.5
03/01/24	04:00	87.7	0.246	43.7	0.160	0.5
03/01/24	05:00	87.7	0.246	43.6	0.160	0.5
03/01/24	06:00	87.4	0.245	43.7	0.161	0.5
03/01/24	07:00	87.6	0.245	43.9	0.161	0.6
03/01/24	08:00	93.2	0.254	45.0	0.162	0.6
03/01/24	09:00	88.1	0.243	45.3	0.162	0.6
03/01/24	10:00	81.2	0.227	45.8	0.163	0.6
03/01/24	11:00	67.8	0.198	46.3	0.163	0.6
03/01/24	12:00	63.9	0.184	48.0	0.165	0.6
03/01/24	13:00	72.6	0.200	50.1	0.166	0.6
03/01/24	14:00	83.1	0.219	52.0	0.167	0.6
03/01/24	15:00	93.3	0.235	54.3	0.168	0.6
03/01/24	16:00	96.8	0.241	55.5	0.167	0.6
03/01/24	17:00	97.4	0.244	55.6	0.167	0.6
03/01/24	18:00	98.2	0.248	55.5	0.167	0.6
03/01/24	19:00	98.9	0.252	55.3	0.167	0.6
03/01/24	20:00	99.5	0.255	55.3	0.166	0.6
03/01/24	21:00	100.1	0.258	55.3	0.166	0.6
03/01/24	22:00	100.6	0.260	55.3	0.166	0.6
03/01/24	23:00	101.0	0.262	55.3	0.166	0.6
03/02/24	00:00	101.5	0.265	55.2	0.166	0.6
03/02/24	01:00	101.8	0.266	55.3	0.166	0.6
03/02/24	02:00	102.1	0.267	55.4	0.167	0.6
03/02/24	03:00	100.6	0.261	55.7	0.168	0.6
03/02/24	04:00	100.8	0.262	55.7	0.169	0.6
03/02/24	05:00	100.9	0.263	55.7	0.169	0.6

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/02/24	06:00	101.1	0.264	55.6	0.169	0.6
03/02/24	07:00	98.1	0.260	54.4	0.169	0.6
03/02/24	08:00	88.4	0.245	51.9	0.167	0.6
03/02/24	09:00	83.9	0.241	49.3	0.166	0.5
03/02/24	10:00	78.6	0.235	46.6	0.165	0.5
03/02/24	11:00	72.4	0.227	44.2	0.164	0.5
03/02/24	12:00	66.9	0.221	41.6	0.163	0.5
03/02/24	13:00	59.1	0.211	38.8	0.162	0.4
03/02/24	14:00	49.6	0.198	36.2	0.162	0.4
03/02/24	15:00	40.3	0.186	33.9	0.162	0.4
03/02/24	16:00	37.6	0.184	32.5	0.162	0.4
03/02/24	17:00	37.5	0.184	32.5	0.162	0.4
03/02/24	18:00	37.2	0.182	32.6	0.162	0.4
03/02/24	19:00	37.1	0.181	32.7	0.162	0.4
03/02/24	20:00	36.8	0.180	32.7	0.163	0.4
03/02/24	21:00	36.4	0.178	32.8	0.163	0.4
03/02/24	22:00	36.2	0.177	32.9	0.164	0.4
03/02/24	23:00	36.3	0.177	32.9	0.164	0.4
03/03/24	00:00	36.2	0.177	32.9	0.164	0.4
03/03/24	01:00	37.1	0.180	32.9	0.163	0.4
03/03/24	02:00	36.6	0.179	32.7	0.163	0.4
03/03/24	03:00	36.9	0.180	32.7	0.163	0.4
03/03/24	04:00	37.0	0.181	32.6	0.163	0.4
03/03/24	05:00	37.3	0.182	32.6	0.162	0.4
03/03/24	06:00	37.4	0.183	32.5	0.162	0.4
03/03/24	07:00	37.7	0.183	32.4	0.161	0.4
03/03/24	08:00	38.0	0.185	32.4	0.161	0.4
03/03/24	09:00	37.8	0.184	32.3	0.161	0.4
03/03/24	10:00	37.9	0.185	32.2	0.160	0.4
03/03/24	11:00	37.9	0.185	32.3	0.161	0.4
03/03/24	12:00	37.8	0.184	32.3	0.160	0.4
03/03/24	13:00	37.8	0.184	32.2	0.160	0.4
03/03/24	14:00	38.8	0.189	32.2	0.160	0.4
03/03/24	15:00	38.3	0.187	32.1	0.160	0.4
03/03/24	16:00	38.3	0.186	32.2	0.160	0.4
03/03/24	17:00	38.1	0.186	32.2	0.160	0.4
03/03/24	18:00	38.0	0.185	32.2	0.161	0.4
03/03/24	19:00	37.5	0.183	32.4	0.161	0.4
03/03/24	20:00	37.3	0.182	32.5	0.162	0.4
03/03/24	21:00	37.2	0.181	32.5	0.162	0.4
03/03/24	22:00	37.1	0.181	32.6	0.162	0.4
03/03/24	23:00	37.0	0.180	32.6	0.163	0.4
03/04/24	00:00	36.8	0.179	32.8	0.163	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/04/24	01:00	36.1	0.177	32.8	0.164	0.4
03/04/24	02:00	36.8	0.179	32.9	0.164	0.4
03/04/24	03:00	36.7	0.178	33.0	0.164	0.4
03/04/24	04:00	36.7	0.179	33.1	0.164	0.4
03/04/24	05:00	36.7	0.179	33.1	0.164	0.4
03/04/24	06:00	36.6	0.178	33.2	0.165	0.4
03/04/24	07:00	36.6	0.177	33.2	0.166	0.4
03/04/24	08:00	36.3	0.176	33.3	0.167	0.4
03/04/24	09:00	36.0	0.177	33.4	0.167	0.4
03/04/24	10:00	36.4	0.179	33.4	0.168	0.4
03/04/24	11:00	36.2	0.179	33.5	0.168	0.4
03/04/24	12:00	36.3	0.180	33.4	0.168	0.4
03/04/24	13:00	36.4	0.181	33.4	0.169	0.4
03/04/24	14:00	37.1	0.180	33.5	0.169	0.4
03/04/24	15:00	36.2	0.180	33.4	0.169	0.4
03/04/24	16:00	36.1	0.180	33.5	0.170	0.4
03/04/24	17:00	36.2	0.182	33.5	0.171	0.4
03/04/24	18:00	36.5	0.185	33.4	0.171	0.4
03/04/24	19:00	36.8	0.187	33.5	0.172	0.4
03/04/24	20:00	37.1	0.189	33.4	0.172	0.4
03/04/24	21:00	37.0	0.190	33.3	0.172	0.4
03/04/24	22:00	37.3	0.191	33.2	0.172	0.4
03/04/24	23:00	37.3	0.191	33.2	0.173	0.4
03/05/24	00:00	37.2	0.192	33.2	0.173	0.4
03/05/24	01:00	37.3	0.191	33.3	0.174	0.4
03/05/24	02:00	37.4	0.191	33.3	0.174	0.4
03/05/24	03:00	36.6	0.191	33.3	0.175	0.4
03/05/24	04:00	36.5	0.190	33.3	0.175	0.4
03/05/24	05:00	36.7	0.192	33.2	0.175	0.4
03/05/24	06:00	36.8	0.192	33.1	0.175	0.4
03/05/24	07:00	36.8	0.192	33.1	0.175	0.4
03/05/24	08:00	36.6	0.191	33.2	0.176	0.4
03/05/24	09:00	36.7	0.192	33.2	0.176	0.4
03/05/24	10:00	36.6	0.192	33.1	0.176	0.4
03/05/24	11:00	37.0	0.194	33.1	0.176	0.4
03/05/24	12:00	37.2	0.195	33.0	0.176	0.4
03/05/24	13:00	37.5	0.197	32.9	0.176	0.4
03/05/24	14:00	39.2	0.200	33.5	0.176	0.4
03/05/24	15:00	39.5	0.200	33.7	0.176	0.4
03/05/24	16:00	39.5	0.200	33.7	0.176	0.4
03/05/24	17:00	39.6	0.200	33.7	0.176	0.4
03/05/24	18:00	39.4	0.199	33.9	0.176	0.4
03/05/24	19:00	39.5	0.199	33.8	0.176	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/05/24	20:00	39.6	0.200	33.8	0.176	0.4
03/05/24	21:00	40.1	0.202	33.9	0.176	0.4
03/05/24	22:00	40.6	0.204	34.0	0.176	0.4
03/05/24	23:00	41.2	0.206	34.0	0.175	0.4
03/06/24	00:00	41.8	0.209	34.0	0.175	0.4
03/06/24	01:00	42.2	0.211	34.0	0.175	0.4
03/06/24	02:00	43.1	0.215	34.1	0.175	0.4
03/06/24	03:00	43.7	0.218	34.0	0.174	0.4
03/06/24	04:00	44.2	0.220	33.9	0.174	0.4
03/06/24	05:00	44.0	0.219	34.0	0.174	0.4
03/06/24	06:00	44.4	0.221	34.1	0.174	0.4
03/06/24	07:00	45.1	0.224	34.1	0.174	0.4
03/06/24	08:00	45.8	0.228	34.1	0.174	0.4
03/06/24	09:00	46.0	0.228	34.1	0.174	0.4
03/06/24	10:00	46.0	0.228	34.1	0.174	0.4
03/06/24	11:00	46.0	0.228	34.1	0.174	0.4
03/06/24	12:00	46.0	0.228	34.1	0.174	0.4
03/06/24	13:00	46.0	0.228	34.1	0.174	0.4
03/06/24	14:00	46.0	0.228	34.1	0.174	0.4
03/06/24	15:00	46.0	0.228	34.1	0.174	0.4
03/06/24	16:00	46.0	0.228	34.3	0.174	0.4
03/06/24	17:00	47.3	0.235	34.5	0.175	0.5
03/06/24	18:00	47.1	0.234	34.6	0.176	0.4
03/06/24	19:00	47.1	0.234	34.8	0.176	0.4
03/06/24	20:00	47.3	0.235	34.2	0.177	0.4
03/06/24	21:00	45.4	0.232	34.0	0.177	0.4
03/06/24	22:00	45.4	0.232	34.0	0.177	0.4
03/06/24	23:00	45.6	0.233	34.0	0.177	0.4
03/07/24	00:00	45.5	0.233	34.0	0.177	0.4
03/07/24	01:00	45.6	0.233	34.1	0.177	0.3
03/07/24	02:00	45.5	0.233	34.1	0.177	0.3
03/07/24	03:00	46.2	0.235	34.2	0.177	0.3
03/07/24	04:00	46.2	0.236	34.2	0.177	0.3
03/07/24	05:00	46.0	0.235	34.2	0.178	0.3
03/07/24	06:00	46.1	0.236	34.1	0.177	0.3
03/07/24	07:00	45.9	0.235	34.1	0.178	0.3
03/07/24	08:00	46.1	0.236	34.0	0.177	0.3
03/07/24	09:00	45.3	0.232	34.0	0.177	0.2
03/07/24	10:00	45.6	0.234	33.9	0.177	0.2
03/07/24	11:00	46.4	0.237	33.9	0.176	0.2
03/07/24	12:00	46.9	0.240	33.9	0.176	0.2
03/07/24	13:00	47.0	0.240	33.9	0.176	0.2
03/07/24	14:00	48.2	0.245	34.1	0.177	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/07/24	15:00	48.0	0.244	34.2	0.177	0.2
03/07/24	16:00	48.2	0.244	34.2	0.177	0.1
03/07/24	17:00	47.2	0.238	34.2	0.176	0.1
03/07/24	18:00	47.4	0.238	34.2	0.176	0.1
03/07/24	19:00	47.2	0.237	34.3	0.176	0.1
03/07/24	20:00	47.0	0.237	34.3	0.176	0.1
03/07/24	21:00	46.7	0.235	34.3	0.176	0.1
03/07/24	22:00	46.4	0.234	34.4	0.177	0.1
03/07/24	23:00	46.6	0.235	34.4	0.177	0.1
03/08/24	00:00	47.1	0.237	34.4	0.176	0.1
03/08/24	01:00	47.2	0.237	34.4	0.177	0.1
03/08/24	02:00	47.9	0.241	34.5	0.177	0.1
03/08/24	03:00	47.3	0.238	34.5	0.177	0.1
03/08/24	04:00	46.9	0.237	34.6	0.178	0.1
03/08/24	05:00	47.0	0.237	34.6	0.178	0.1
03/08/24	06:00	47.1	0.237	34.6	0.178	0.1
03/08/24	07:00	47.6	0.240	34.6	0.178	0.1
03/08/24	08:00	47.4	0.239	34.7	0.179	0.1
03/08/24	09:00	47.6	0.240	34.7	0.179	0.1
03/08/24	10:00	47.5	0.239	34.8	0.179	0.1
03/08/24	11:00	47.0	0.237	34.9	0.180	0.1
03/08/24	12:00	47.2	0.238	35.0	0.180	0.1
03/08/24	13:00	47.2	0.238	35.0	0.180	0.1
03/08/24	14:00	45.7	0.232	34.9	0.180	0.1
03/08/24	15:00	45.7	0.232	34.8	0.180	0.1
03/08/24	16:00	45.9	0.233	34.7	0.180	0.1
03/08/24	17:00	45.6	0.233	34.7	0.180	0.1
03/08/24	18:00	45.7	0.233	34.6	0.180	0.1
03/08/24	19:00	46.1	0.235	34.4	0.179	0.1
03/08/24	20:00	46.4	0.237	34.3	0.178	0.1
03/08/24	21:00	46.9	0.239	34.2	0.177	0.1
03/08/24	22:00	47.7	0.242	34.1	0.176	0.1
03/08/24	23:00	48.0	0.243	34.0	0.175	0.1
03/09/24	00:00	47.9	0.242	33.9	0.175	0.1
03/09/24	01:00	49.0	0.246	33.7	0.173	0.1
03/09/24	02:00	48.8	0.244	33.7	0.172	0.1
03/09/24	03:00	48.9	0.244	33.7	0.172	0.1
03/09/24	04:00	49.3	0.245	33.6	0.170	0.1
03/09/24	05:00	49.1	0.244	33.6	0.170	0.1
03/09/24	06:00	48.5	0.240	33.7	0.170	0.1
03/09/24	07:00	47.9	0.237	33.9	0.171	0.1
03/09/24	08:00	47.5	0.235	34.0	0.171	0.1
03/09/24	09:00	47.0	0.232	34.0	0.171	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/09/24	10:00	46.4	0.229	34.1	0.172	0.1
03/09/24	11:00	45.7	0.226	34.2	0.172	0.1
03/09/24	12:00	44.7	0.221	34.2	0.173	0.1
03/09/24	13:00	46.5	0.223	34.8	0.172	0.1
03/09/24	14:00	46.7	0.223	34.6	0.169	0.1
03/09/24	15:00	47.4	0.226	34.2	0.167	0.1
03/09/24	16:00	47.0	0.224	34.2	0.167	0.1
03/09/24	17:00	46.8	0.222	34.3	0.167	0.1
03/09/24	18:00	46.4	0.220	34.4	0.167	0.1
03/09/24	19:00	45.6	0.216	34.5	0.168	0.1
03/09/24	20:00	45.1	0.213	34.7	0.169	0.1
03/09/24	21:00	44.7	0.211	34.8	0.169	0.1
03/09/24	22:00	43.9	0.207	34.9	0.170	0.1
03/09/24	23:00	43.2	0.204	35.0	0.171	0.1
03/10/24	00:00	42.6	0.202	35.2	0.172	0.1
03/10/24	01:00	41.2	0.196	35.4	0.174	0.1
03/10/24	02:00	40.9	0.195	35.5	0.174	0.1
03/10/24	03:00	40.6	0.193	35.6	0.175	0.1
03/10/24	04:00	40.3	0.192	35.7	0.175	0.1
03/10/24	05:00	40.2	0.192	35.7	0.176	0.1
03/10/24	06:00	40.5	0.193	35.7	0.176	0.1
03/10/24	07:00	40.7	0.194	35.5	0.175	0.1
03/10/24	08:00	40.7	0.194	35.5	0.175	0.1
03/10/24	09:00	40.5	0.193	35.5	0.175	0.1
03/10/24	10:00	40.8	0.195	35.5	0.175	0.1
03/10/24	11:00	41.1	0.196	35.5	0.174	0.1
03/10/24	12:00	41.3	0.197	35.5	0.174	0.1
03/10/24	13:00	40.1	0.197	34.7	0.174	0.1
03/10/24	14:00	39.6	0.196	34.9	0.176	0.1
03/10/24	15:00	38.4	0.191	35.2	0.178	0.1
03/10/24	16:00	38.2	0.189	35.3	0.179	0.1
03/10/24	17:00	38.0	0.188	35.3	0.178	0.1
03/10/24	18:00	38.3	0.189	35.3	0.178	0.1
03/10/24	19:00	38.6	0.191	35.3	0.178	0.1
03/10/24	20:00	38.7	0.191	35.2	0.177	0.1
03/10/24	21:00	38.8	0.191	35.2	0.177	0.1
03/10/24	22:00	38.9	0.192	35.1	0.177	0.1
03/10/24	23:00	39.2	0.193	35.0	0.176	0.1
03/11/24	00:00	39.3	0.194	34.9	0.176	0.1
03/11/24	01:00	40.3	0.198	34.9	0.176	0.1
03/11/24	02:00	40.0	0.198	34.8	0.175	0.1
03/11/24	03:00	40.2	0.199	34.7	0.175	0.1
03/11/24	04:00	40.2	0.199	34.7	0.175	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/11/24	05:00	40.4	0.201	34.7	0.175	0.1
03/11/24	06:00	40.5	0.201	34.6	0.175	0.1
03/11/24	07:00	40.7	0.203	34.5	0.175	0.1
03/11/24	08:00	41.0	0.204	34.5	0.175	0.1
03/11/24	09:00	41.5	0.206	34.4	0.174	0.1
03/11/24	10:00	41.7	0.207	34.4	0.174	0.1
03/11/24	11:00	41.8	0.208	34.4	0.174	0.1
03/11/24	12:00	41.6	0.207	34.4	0.175	0.1
03/11/24	13:00	40.7	0.203	34.6	0.176	0.1
03/11/24	14:00	41.3	0.205	34.8	0.176	0.1
03/11/24	15:00	41.3	0.206	34.9	0.177	0.1
03/11/24	16:00	41.5	0.207	34.9	0.177	0.1
03/11/24	17:00	41.6	0.208	35.0	0.178	0.1
03/11/24	18:00	41.3	0.207	35.1	0.179	0.1
03/11/24	19:00	41.3	0.207	35.0	0.179	0.1
03/11/24	20:00	41.4	0.208	35.0	0.179	0.1
03/11/24	21:00	41.7	0.210	34.9	0.179	0.1
03/11/24	22:00	41.6	0.209	35.0	0.179	0.1
03/11/24	23:00	41.4	0.209	35.0	0.180	0.1
03/12/24	00:00	41.2	0.208	35.0	0.180	0.1
03/12/24	01:00	40.9	0.206	35.1	0.181	0.1
03/12/24	02:00	40.8	0.206	35.1	0.181	0.1
03/12/24	03:00	40.5	0.205	35.0	0.181	0.1
03/12/24	04:00	40.2	0.204	35.0	0.181	0.1
03/12/24	05:00	39.8	0.202	35.0	0.181	0.1
03/12/24	06:00	39.6	0.201	35.0	0.181	0.1
03/12/24	07:00	39.9	0.202	34.9	0.180	0.1
03/12/24	08:00	40.1	0.203	34.9	0.180	0.1
03/12/24	09:00	40.0	0.203	34.9	0.181	0.1
03/12/24	10:00	39.9	0.202	35.0	0.181	0.1
03/12/24	11:00	39.9	0.203	34.9	0.181	0.1
03/12/24	12:00	41.3	0.207	35.1	0.180	0.2
03/12/24	13:00	42.9	0.210	35.3	0.178	0.2
03/12/24	14:00	42.9	0.211	35.0	0.177	0.2
03/12/24	15:00	43.3	0.213	35.0	0.177	0.2
03/12/24	16:00	43.2	0.212	35.0	0.177	0.2
03/12/24	17:00	43.7	0.215	34.9	0.176	0.2
03/12/24	18:00	44.3	0.217	34.8	0.175	0.2
03/12/24	19:00	44.7	0.219	34.8	0.175	0.2
03/12/24	20:00	44.9	0.220	34.9	0.176	0.2
03/12/24	21:00	44.8	0.219	35.0	0.176	0.2
03/12/24	22:00	44.7	0.219	35.1	0.176	0.2
03/12/24	23:00	45.0	0.220	35.1	0.176	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/13/24	00:00	45.3	0.221	35.1	0.176	0.2
03/13/24	01:00	45.6	0.222	35.1	0.176	0.2
03/13/24	02:00	45.3	0.221	35.2	0.177	0.2
03/13/24	03:00	45.6	0.222	35.3	0.177	0.2
03/13/24	04:00	45.9	0.223	35.4	0.177	0.2
03/13/24	05:00	46.1	0.224	35.4	0.177	0.2
03/13/24	06:00	45.7	0.223	35.6	0.178	0.2
03/13/24	07:00	45.2	0.220	35.8	0.179	0.2
03/13/24	08:00	44.9	0.219	35.8	0.179	0.2
03/13/24	09:00	44.8	0.218	35.8	0.180	0.2
03/13/24	10:00	44.8	0.219	35.8	0.180	0.2
03/13/24	11:00	44.4	0.217	36.0	0.181	0.2
03/13/24	12:00	43.4	0.215	35.7	0.181	0.2
03/13/24	13:00	41.8	0.212	35.3	0.183	0.2
03/13/24	14:00	42.1	0.213	35.5	0.183	0.2
03/13/24	15:00	41.9	0.212	35.4	0.183	0.2
03/13/24	16:00	42.2	0.213	35.2	0.182	0.2
03/13/24	17:00	41.8	0.212	35.2	0.182	0.2
03/13/24	18:00	41.4	0.210	35.2	0.182	0.2
03/13/24	19:00	41.0	0.208	35.2	0.182	0.1
03/13/24	20:00	40.8	0.207	35.1	0.182	0.1
03/13/24	21:00	40.9	0.208	35.1	0.182	0.1
03/13/24	22:00	41.2	0.210	34.9	0.181	0.1
03/13/24	23:00	41.2	0.210	34.8	0.181	0.1
03/14/24	00:00	41.4	0.211	34.7	0.180	0.1
03/14/24	01:00	42.0	0.214	34.5	0.179	0.1
03/14/24	02:00	42.3	0.216	34.3	0.178	0.1
03/14/24	03:00	42.4	0.217	34.1	0.178	0.1
03/14/24	04:00	42.4	0.217	34.0	0.177	0.1
03/14/24	05:00	42.5	0.218	33.9	0.177	0.1
03/14/24	06:00	43.1	0.220	33.8	0.176	0.1
03/14/24	07:00	42.8	0.219	33.8	0.176	0.1
03/14/24	08:00	42.4	0.217	33.9	0.177	0.1
03/14/24	09:00	42.3	0.216	33.9	0.177	0.1
03/14/24	10:00	42.4	0.217	33.9	0.177	0.1
03/14/24	11:00	42.5	0.217	33.9	0.176	0.1
03/14/24	12:00	42.5	0.217	33.9	0.176	0.1
03/14/24	13:00	43.2	0.220	33.9	0.176	0.1
03/14/24	14:00	42.7	0.217	34.0	0.176	0.1
03/14/24	15:00	42.6	0.217	34.1	0.176	0.1
03/14/24	16:00	42.3	0.215	34.2	0.177	0.1
03/14/24	17:00	42.2	0.214	34.3	0.177	0.1
03/14/24	18:00	42.2	0.214	34.3	0.177	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/14/24	19:00	42.4	0.215	34.3	0.177	0.1
03/14/24	20:00	42.3	0.214	34.4	0.177	0.1
03/14/24	21:00	42.0	0.212	34.4	0.177	0.1
03/14/24	22:00	41.8	0.211	34.5	0.177	0.1
03/14/24	23:00	41.4	0.209	34.6	0.178	0.1
03/15/24	00:00	41.2	0.208	34.6	0.178	0.1
03/15/24	01:00	40.5	0.204	34.8	0.179	0.1
03/15/24	02:00	40.1	0.202	34.9	0.179	0.1
03/15/24	03:00	40.0	0.202	34.9	0.179	0.1
03/15/24	04:00	40.4	0.203	35.0	0.179	0.1
03/15/24	05:00	40.2	0.203	35.0	0.180	0.1
03/15/24	06:00	40.2	0.203	35.1	0.180	0.1
03/15/24	07:00	40.1	0.202	35.2	0.181	0.1
03/15/24	08:00	40.1	0.203	35.2	0.181	0.1
03/15/24	09:00	39.9	0.201	35.2	0.181	0.1
03/15/24	10:00	41.3	0.203	36.0	0.181	0.1
03/15/24	11:00	40.8	0.200	36.1	0.181	0.2
03/15/24	12:00	41.1	0.201	35.8	0.179	0.2
03/15/24	13:00	40.7	0.200	35.7	0.179	0.2
03/15/24	14:00	40.3	0.198	35.4	0.178	0.2
03/15/24	15:00	39.8	0.196	35.5	0.179	0.2
03/15/24	16:00	39.5	0.195	35.5	0.179	0.2
03/15/24	17:00	39.0	0.193	35.4	0.179	0.2
03/15/24	18:00	38.6	0.191	35.4	0.179	0.2
03/15/24	19:00	38.3	0.190	35.4	0.180	0.2
03/15/24	20:00	38.0	0.189	35.4	0.180	0.2
03/15/24	21:00	38.1	0.189	35.3	0.180	0.2
03/15/24	22:00	38.1	0.190	35.2	0.180	0.2
03/15/24	23:00	38.2	0.190	35.2	0.179	0.2
03/16/24	00:00	38.1	0.190	35.1	0.179	0.2
03/16/24	01:00	38.6	0.192	35.0	0.179	0.2
03/16/24	02:00	39.1	0.195	35.0	0.179	0.2
03/16/24	03:00	39.2	0.195	35.0	0.179	0.2
03/16/24	04:00	39.2	0.195	35.0	0.178	0.2
03/16/24	05:00	39.5	0.196	34.9	0.178	0.2
03/16/24	06:00	39.3	0.195	34.9	0.177	0.2
03/16/24	07:00	39.8	0.197	34.8	0.176	0.2
03/16/24	08:00	40.5	0.200	34.6	0.176	0.2
03/16/24	09:00	40.9	0.202	34.6	0.175	0.2
03/16/24	10:00	39.3	0.200	33.8	0.175	0.2
03/16/24	11:00	39.7	0.203	33.7	0.176	0.1
03/16/24	12:00	40.1	0.205	33.9	0.177	0.1
03/16/24	13:00	39.8	0.204	34.1	0.178	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/16/24	14:00	39.8	0.204	34.1	0.178	0.2
03/16/24	15:00	39.9	0.205	34.1	0.178	0.2
03/16/24	16:00	40.1	0.205	34.0	0.178	0.2
03/16/24	17:00	40.3	0.206	34.1	0.178	0.2
03/16/24	18:00	40.4	0.206	34.1	0.178	0.2
03/16/24	19:00	40.3	0.205	34.1	0.177	0.2
03/16/24	20:00	40.9	0.208	34.1	0.177	0.2
03/16/24	21:00	40.7	0.207	34.3	0.178	0.2
03/16/24	22:00	41.0	0.209	34.3	0.178	0.2
03/16/24	23:00	41.0	0.208	34.4	0.178	0.2
03/17/24	00:00	41.2	0.210	34.4	0.178	0.2
03/17/24	01:00	40.2	0.205	34.5	0.179	0.2
03/17/24	02:00	41.4	0.210	34.6	0.179	0.2
03/17/24	03:00	40.9	0.208	34.7	0.180	0.2
03/17/24	04:00	40.5	0.205	34.8	0.180	0.2
03/17/24	05:00	40.3	0.204	34.8	0.180	0.2
03/17/24	06:00	40.5	0.205	34.8	0.180	0.2
03/17/24	07:00	40.2	0.204	34.8	0.180	0.2
03/17/24	08:00	40.0	0.203	34.7	0.180	0.2
03/17/24	09:00	40.2	0.204	34.6	0.179	0.2
03/17/24	10:00	40.4	0.205	34.4	0.178	0.2
03/17/24	11:00	40.7	0.206	34.3	0.177	0.2
03/17/24	12:00	40.4	0.203	34.2	0.176	0.2
03/17/24	13:00	41.1	0.206	34.1	0.175	0.2
03/17/24	14:00	41.5	0.207	34.1	0.174	0.2
03/17/24	15:00	41.8	0.209	34.0	0.174	0.2
03/17/24	16:00	41.8	0.209	34.0	0.173	0.2
03/17/24	17:00	42.0	0.210	33.9	0.173	0.2
03/17/24	18:00	42.5	0.212	33.9	0.172	0.2
03/17/24	19:00	43.0	0.214	33.7	0.171	0.2
03/17/24	20:00	42.6	0.212	33.7	0.171	0.2
03/17/24	21:00	42.6	0.212	33.6	0.170	0.2
03/17/24	22:00	42.0	0.208	33.7	0.170	0.1
03/17/24	23:00	41.9	0.208	33.7	0.171	0.1
03/18/24	00:00	41.4	0.205	33.7	0.171	0.1
03/18/24	01:00	43.0	0.212	33.9	0.171	0.2
03/18/24	02:00	41.2	0.204	33.8	0.171	0.1
03/18/24	03:00	41.4	0.205	33.7	0.171	0.1
03/18/24	04:00	41.1	0.204	33.8	0.171	0.1
03/18/24	05:00	40.8	0.202	33.8	0.171	0.1
03/18/24	06:00	40.5	0.201	33.9	0.171	0.1
03/18/24	07:00	40.4	0.200	33.9	0.171	0.1
03/18/24	08:00	40.3	0.200	33.9	0.172	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/18/24	09:00	40.0	0.198	34.0	0.172	0.1
03/18/24	10:00	39.9	0.198	34.0	0.172	0.1
03/18/24	11:00	39.7	0.197	34.1	0.173	0.1
03/18/24	12:00	39.4	0.196	34.3	0.173	0.1
03/18/24	13:00	39.7	0.197	34.1	0.173	0.1
03/18/24	14:00	39.1	0.194	34.1	0.173	0.1
03/18/24	15:00	38.9	0.193	34.1	0.173	0.1
03/18/24	16:00	38.8	0.193	34.2	0.174	0.1
03/18/24	17:00	38.4	0.191	34.3	0.174	0.1
03/18/24	18:00	37.9	0.189	34.4	0.175	0.1
03/18/24	19:00	37.7	0.188	34.5	0.176	0.1
03/18/24	20:00	37.6	0.188	34.6	0.176	0.1
03/18/24	21:00	37.8	0.189	34.6	0.177	0.1
03/18/24	22:00	38.3	0.191	34.6	0.177	0.1
03/18/24	23:00	38.6	0.193	34.6	0.176	0.1
03/19/24	00:00	38.7	0.193	34.6	0.176	0.1
03/19/24	01:00	37.4	0.187	34.5	0.176	0.1
03/19/24	02:00	37.8	0.189	34.5	0.176	0.1
03/19/24	03:00	38.0	0.190	34.5	0.176	0.1
03/19/24	04:00	38.1	0.190	34.6	0.176	0.1
03/19/24	05:00	38.5	0.192	34.6	0.176	0.1
03/19/24	06:00	38.4	0.192	34.7	0.177	0.1
03/19/24	07:00	39.6	0.198	34.6	0.176	0.1
03/19/24	08:00	40.0	0.200	34.7	0.177	0.1
03/19/24	09:00	40.6	0.202	34.7	0.177	0.1
03/19/24	10:00	40.7	0.203	34.8	0.177	0.1
03/19/24	11:00	41.4	0.207	34.7	0.177	0.1
03/19/24	12:00	42.0	0.209	34.8	0.177	0.1
03/19/24	13:00	42.6	0.206	35.6	0.177	0.2
03/19/24	14:00	43.7	0.212	35.5	0.176	0.2
03/19/24	15:00	44.5	0.216	35.4	0.175	0.2
03/19/24	16:00	45.5	0.220	35.2	0.174	0.2
03/19/24	17:00	46.1	0.224	35.0	0.173	0.2
03/19/24	18:00	46.5	0.226	34.8	0.172	0.2
03/19/24	19:00	46.9	0.228	34.7	0.172	0.2
03/19/24	20:00	47.2	0.229	34.7	0.171	0.2
03/19/24	21:00	47.4	0.230	34.7	0.171	0.2
03/19/24	22:00	47.6	0.231	34.6	0.171	0.2
03/19/24	23:00	47.8	0.231	34.6	0.171	0.2
03/20/24	00:00	48.0	0.233	34.6	0.170	0.2
03/20/24	01:00	48.0	0.233	34.5	0.171	0.2
03/20/24	02:00	48.5	0.235	34.5	0.170	0.2
03/20/24	03:00	48.9	0.237	34.4	0.170	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/20/24	04:00	48.7	0.236	34.3	0.170	0.2
03/20/24	05:00	48.5	0.236	34.2	0.169	0.2
03/20/24	06:00	48.5	0.236	34.1	0.169	0.2
03/20/24	07:00	47.8	0.233	34.1	0.169	0.2
03/20/24	08:00	47.9	0.233	33.9	0.168	0.2
03/20/24	09:00	47.1	0.229	34.0	0.168	0.2
03/20/24	10:00	47.2	0.229	33.8	0.168	0.2
03/20/24	11:00	46.3	0.225	33.9	0.168	0.2
03/20/24	12:00	45.8	0.223	33.8	0.168	0.2
03/20/24	13:00	45.1	0.225	33.1	0.168	0.2
03/20/24	14:00	44.0	0.219	33.3	0.169	0.2
03/20/24	15:00	43.1	0.215	33.5	0.170	0.2
03/20/24	16:00	42.1	0.209	33.7	0.171	0.2
03/20/24	17:00	41.6	0.207	33.9	0.172	0.2
03/20/24	18:00	41.1	0.204	33.9	0.172	0.2
03/20/24	19:00	40.4	0.201	34.0	0.172	0.2
03/20/24	20:00	39.8	0.198	34.0	0.173	0.2
03/20/24	21:00	39.2	0.195	34.0	0.173	0.2
03/20/24	22:00	38.5	0.192	34.0	0.173	0.2
03/20/24	23:00	37.9	0.190	34.0	0.174	0.2
03/21/24	00:00	37.3	0.187	34.0	0.174	0.2
03/21/24	01:00	37.1	0.186	33.9	0.173	0.2
03/21/24	02:00	36.6	0.184	33.6	0.172	0.2
03/21/24	03:00	36.2	0.182	33.3	0.171	0.1
03/21/24	04:00	36.4	0.183	33.1	0.169	0.1
03/21/24	05:00	36.1	0.181	33.0	0.169	0.1
03/21/24	06:00	36.0	0.181	33.0	0.170	0.1
03/21/24	07:00	35.6	0.179	33.2	0.170	0.1
03/21/24	08:00	35.1	0.177	33.4	0.172	0.1
03/21/24	09:00	34.8	0.176	33.5	0.172	0.1
03/21/24	10:00	34.1	0.172	33.6	0.174	0.1
03/21/24	11:00	33.6	0.171	33.8	0.175	0.1
03/21/24	12:00	33.3	0.169	33.9	0.176	0.1
03/21/24	13:00	32.5	0.166	33.9	0.176	0.1
03/21/24	14:00	32.3	0.165	33.9	0.177	0.1
03/21/24	15:00	32.5	0.167	33.9	0.177	0.1
03/21/24	16:00	32.4	0.166	33.8	0.177	0.1
03/21/24	17:00	32.2	0.165	33.8	0.177	0.1
03/21/24	18:00	32.1	0.165	33.9	0.178	0.1
03/21/24	19:00	32.0	0.165	34.0	0.179	0.1
03/21/24	20:00	31.8	0.164	34.2	0.179	0.1
03/21/24	21:00	31.7	0.164	34.3	0.180	0.1
03/21/24	22:00	31.7	0.163	34.4	0.181	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/21/24	23:00	31.8	0.163	34.5	0.181	0.1
03/22/24	00:00	31.9	0.164	34.6	0.181	0.1
03/22/24	01:00	31.5	0.162	34.8	0.183	0.1
03/22/24	02:00	31.5	0.162	35.2	0.185	0.1
03/22/24	03:00	31.1	0.160	35.6	0.186	0.1
03/22/24	04:00	31.2	0.161	35.7	0.187	0.1
03/22/24	05:00	31.4	0.161	35.6	0.186	0.1
03/22/24	06:00	31.3	0.161	35.5	0.185	0.1
03/22/24	07:00	31.0	0.159	35.4	0.185	0.1
03/22/24	08:00	30.8	0.157	35.4	0.184	0.1
03/22/24	09:00	31.1	0.159	35.3	0.184	0.1
03/22/24	10:00	31.4	0.160	35.3	0.183	0.1
03/22/24	11:00	32.2	0.164	35.1	0.182	0.1
03/22/24	12:00	32.7	0.166	35.1	0.181	0.1
03/22/24	13:00	33.5	0.169	35.0	0.181	0.1
03/22/24	14:00	36.3	0.177	35.5	0.180	0.1
03/22/24	15:00	36.3	0.177	35.6	0.180	0.1
03/22/24	16:00	37.0	0.180	35.6	0.180	0.1
03/22/24	17:00	37.5	0.183	35.5	0.179	0.1
03/22/24	18:00	38.1	0.186	35.4	0.178	0.1
03/22/24	19:00	38.9	0.189	35.3	0.177	0.1
03/22/24	20:00	39.7	0.193	35.1	0.176	0.1
03/22/24	21:00	40.2	0.195	35.0	0.176	0.1
03/22/24	22:00	40.5	0.197	34.9	0.175	0.1
03/22/24	23:00	41.0	0.199	34.8	0.174	0.2
03/23/24	00:00	41.6	0.202	34.7	0.174	0.2
03/23/24	01:00	42.1	0.204	34.6	0.173	0.2
03/23/24	02:00	42.4	0.206	34.5	0.172	0.2
03/23/24	03:00	42.8	0.208	34.4	0.172	0.2
03/23/24	04:00	42.8	0.208	34.5	0.172	0.2
03/23/24	05:00	42.9	0.209	34.6	0.173	0.2
03/23/24	06:00	43.2	0.211	34.6	0.173	0.2
03/23/24	07:00	43.8	0.214	34.5	0.173	0.2
03/23/24	08:00	44.4	0.217	34.4	0.173	0.2
03/23/24	09:00	44.6	0.219	34.2	0.173	0.2
03/23/24	10:00	44.4	0.218	34.2	0.173	0.2
03/23/24	11:00	43.8	0.215	34.2	0.173	0.2
03/23/24	12:00	43.2	0.213	34.3	0.174	0.2
03/23/24	13:00	42.3	0.210	34.2	0.175	0.2
03/23/24	14:00	40.3	0.205	33.8	0.175	0.1
03/23/24	15:00	40.2	0.205	33.7	0.174	0.1
03/23/24	16:00	39.9	0.203	33.7	0.175	0.1
03/23/24	17:00	39.6	0.201	33.8	0.175	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/23/24	18:00	39.2	0.200	33.9	0.176	0.1
03/23/24	19:00	38.8	0.198	33.9	0.176	0.1
03/23/24	20:00	38.5	0.197	34.0	0.177	0.1
03/23/24	21:00	38.4	0.196	34.0	0.177	0.1
03/23/24	22:00	38.7	0.198	33.9	0.176	0.1
03/23/24	23:00	38.7	0.197	33.9	0.176	0.1
03/24/24	00:00	38.6	0.197	33.9	0.176	0.1
03/24/24	01:00	38.7	0.197	33.8	0.176	0.1
03/24/24	02:00	38.9	0.198	33.8	0.175	0.1
03/24/24	03:00	38.9	0.198	33.7	0.175	0.1
03/24/24	04:00	39.0	0.198	33.6	0.174	0.1
03/24/24	05:00	39.3	0.199	33.6	0.173	0.1
03/24/24	06:00	39.5	0.200	33.5	0.173	0.1
03/24/24	07:00	39.6	0.200	33.6	0.173	0.1
03/24/24	08:00	39.4	0.198	33.7	0.173	0.1
03/24/24	09:00	39.2	0.197	33.8	0.173	0.1
03/24/24	10:00	39.3	0.197	33.9	0.173	0.1
03/24/24	11:00	39.5	0.198	33.9	0.173	0.1
03/24/24	12:00	39.9	0.200	33.9	0.173	0.1
03/24/24	13:00	41.0	0.204	33.9	0.172	0.1
03/24/24	14:00	41.3	0.205	34.0	0.173	0.1
03/24/24	15:00	41.2	0.205	34.1	0.173	0.1
03/24/24	16:00	41.3	0.205	34.1	0.173	0.1
03/24/24	17:00	41.7	0.207	34.1	0.173	0.1
03/24/24	18:00	41.8	0.207	34.1	0.172	0.1
03/24/24	19:00	41.9	0.207	34.1	0.172	0.1
03/24/24	20:00	42.1	0.208	34.1	0.172	0.1
03/24/24	21:00	42.1	0.208	34.1	0.172	0.1
03/24/24	22:00	41.7	0.206	34.2	0.172	0.1
03/24/24	23:00	41.3	0.204	34.3	0.173	0.1
03/25/24	00:00	41.1	0.203	34.4	0.174	0.1
03/25/24	01:00	40.7	0.201	34.6	0.174	0.1
03/25/24	02:00	40.0	0.198	34.8	0.175	0.1
03/25/24	03:00	39.7	0.197	34.9	0.176	0.1
03/25/24	04:00	39.9	0.198	35.0	0.177	0.1
03/25/24	05:00	39.8	0.197	35.2	0.178	0.1
03/25/24	06:00	39.9	0.198	35.3	0.179	0.1
03/25/24	07:00	39.2	0.195	35.6	0.180	0.1
03/25/24	08:00	38.8	0.193	35.7	0.181	0.1
03/25/24	09:00	38.9	0.194	35.8	0.181	0.1
03/25/24	10:00	39.1	0.194	35.8	0.182	0.1
03/25/24	11:00	38.8	0.193	35.8	0.182	0.1
03/25/24	12:00	39.1	0.195	35.8	0.182	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/25/24	13:00	38.0	0.190	35.9	0.183	0.1
03/25/24	14:00	37.6	0.188	35.7	0.182	0.1
03/25/24	15:00	37.6	0.188	35.6	0.182	0.1
03/25/24	16:00	37.6	0.189	35.5	0.182	0.1
03/25/24	17:00	37.4	0.188	35.5	0.182	0.1
03/25/24	18:00	37.0	0.187	35.5	0.182	0.1
03/25/24	19:00	36.7	0.185	35.5	0.182	0.1
03/25/24	20:00	37.1	0.188	35.4	0.182	0.1
03/25/24	21:00	37.4	0.189	35.3	0.182	0.1
03/25/24	22:00	37.3	0.189	35.3	0.182	0.1
03/25/24	23:00	37.4	0.190	35.3	0.182	0.1
03/26/24	00:00	37.9	0.192	35.2	0.181	0.1
03/26/24	01:00	38.4	0.194	35.1	0.181	0.1
03/26/24	02:00	38.9	0.197	35.1	0.181	0.1
03/26/24	03:00	39.0	0.198	35.1	0.181	0.1
03/26/24	04:00	38.7	0.196	35.1	0.181	0.1
03/26/24	05:00	38.5	0.196	35.1	0.182	0.1
03/26/24	06:00	38.3	0.195	35.2	0.182	0.1
03/26/24	07:00	38.3	0.195	35.2	0.182	0.1
03/26/24	08:00	38.7	0.197	34.5	0.179	0.1
03/26/24	09:00	39.0	0.199	33.9	0.176	0.1
03/26/24	10:00	39.4	0.201	33.3	0.173	0.1
03/26/24	11:00	39.5	0.201	33.2	0.172	0.1
03/26/24	12:00	39.9	0.203	33.1	0.172	0.1
03/26/24	13:00	40.7	0.206	33.1	0.171	0.1
03/26/24	14:00	40.7	0.206	33.1	0.171	0.1
03/26/24	15:00	40.8	0.207	33.1	0.172	0.1
03/26/24	16:00	41.0	0.208	33.2	0.171	0.1
03/26/24	17:00	41.0	0.208	33.2	0.172	0.1
03/26/24	18:00	40.9	0.207	33.2	0.172	0.1
03/26/24	19:00	41.4	0.209	33.2	0.171	0.1
03/26/24	20:00	41.6	0.210	33.1	0.171	0.1
03/26/24	21:00	41.0	0.207	33.1	0.171	0.1
03/26/24	22:00	40.6	0.205	33.1	0.171	0.1
03/26/24	23:00	40.9	0.206	33.1	0.170	0.1
03/27/24	00:00	40.9	0.206	33.0	0.170	0.1
03/27/24	01:00	40.4	0.204	33.0	0.170	0.1
03/27/24	02:00	41.0	0.206	33.0	0.169	0.1
03/27/24	03:00	40.4	0.204	32.8	0.169	0.1
03/27/24	04:00	40.5	0.204	32.6	0.168	0.1
03/27/24	05:00	40.6	0.204	32.5	0.166	0.1
03/27/24	06:00	41.1	0.206	32.2	0.165	0.1
03/27/24	07:00	41.1	0.206	32.2	0.165	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/27/24	08:00	41.2	0.206	32.2	0.164	0.1
03/27/24	09:00	41.0	0.205	32.6	0.166	0.1
03/27/24	10:00	41.0	0.205	32.6	0.166	0.1
03/27/24	11:00	41.0	0.205	32.6	0.166	0.1
03/27/24	12:00	41.0	0.204	33.1	0.168	0.2
03/27/24	13:00	41.5	0.206	33.7	0.171	0.2
03/27/24	14:00	41.5	0.206	33.8	0.171	0.2
03/27/24	15:00	41.3	0.205	33.8	0.171	0.2
03/27/24	16:00	39.8	0.198	33.7	0.171	0.2
03/27/24	17:00	39.8	0.198	33.7	0.171	0.2
03/27/24	18:00	39.3	0.195	33.8	0.171	0.2
03/27/24	19:00	38.9	0.193	33.8	0.171	0.2
03/27/24	20:00	38.8	0.192	33.8	0.171	0.2
03/27/24	21:00	38.6	0.191	34.0	0.171	0.2
03/27/24	22:00	38.1	0.188	34.2	0.172	0.2
03/27/24	23:00	38.0	0.188	34.2	0.172	0.2
03/28/24	00:00	38.1	0.188	34.3	0.172	0.2
03/28/24	01:00	38.2	0.188	34.3	0.172	0.2
03/28/24	02:00	39.1	0.192	34.5	0.173	0.2
03/28/24	03:00	39.1	0.192	34.5	0.173	0.2
03/28/24	04:00	39.1	0.192	34.5	0.173	0.2
03/28/24	05:00	38.4	0.189	34.5	0.173	0.2
03/28/24	06:00	38.4	0.189	34.5	0.173	0.2
03/28/24	07:00	38.7	0.190	34.6	0.173	0.2
03/28/24	08:00	38.6	0.189	34.7	0.173	0.2
03/28/24	09:00	38.2	0.187	34.8	0.174	0.2
03/28/24	10:00	38.3	0.188	34.7	0.174	0.2
03/28/24	11:00	38.7	0.190	34.7	0.174	0.2
03/28/24	12:00	38.5	0.189	34.6	0.174	0.1
03/28/24	13:00	38.6	0.190	34.5	0.173	0.1
03/28/24	14:00	38.4	0.189	34.5	0.173	0.1
03/28/24	15:00	38.3	0.188	34.5	0.173	0.1
03/28/24	16:00	38.5	0.190	34.4	0.173	0.1
03/28/24	17:00	38.5	0.190	34.2	0.172	0.1
03/28/24	18:00	38.5	0.190	34.1	0.172	0.1
03/28/24	19:00	38.8	0.192	34.0	0.172	0.1
03/28/24	20:00	39.3	0.194	33.7	0.170	0.1
03/28/24	21:00	40.1	0.198	33.4	0.169	0.1
03/28/24	22:00	40.9	0.202	33.1	0.167	0.1
03/28/24	23:00	41.8	0.207	33.0	0.167	0.1
03/29/24	00:00	42.2	0.209	32.9	0.166	0.1
03/29/24	01:00	42.4	0.209	32.8	0.165	0.1
03/29/24	02:00	42.2	0.209	32.6	0.165	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/29/24	03:00	42.4	0.210	32.4	0.164	0.1
03/29/24	04:00	42.6	0.211	32.4	0.164	0.1
03/29/24	05:00	42.5	0.211	32.3	0.164	0.1
03/29/24	06:00	42.4	0.211	32.3	0.164	0.1
03/29/24	07:00	42.2	0.210	32.3	0.164	0.1
03/29/24	08:00	42.5	0.211	32.2	0.163	0.1
03/29/24	09:00	42.6	0.212	32.1	0.163	0.1
03/29/24	10:00	42.4	0.211	32.1	0.163	0.1
03/29/24	11:00	42.4	0.211	32.0	0.163	0.1
03/29/24	12:00	43.7	0.216	32.2	0.162	0.1
03/29/24	13:00	44.1	0.214	32.4	0.161	0.1
03/29/24	14:00	44.2	0.215	32.3	0.161	0.1
03/29/24	15:00	44.5	0.217	32.2	0.161	0.1
03/29/24	16:00	44.9	0.218	32.1	0.160	0.1
03/29/24	17:00	45.3	0.220	32.1	0.160	0.1
03/29/24	18:00	45.7	0.222	32.1	0.159	0.1
03/29/24	19:00	45.9	0.223	32.0	0.159	0.1
03/29/24	20:00	45.6	0.222	32.0	0.159	0.1
03/29/24	21:00	45.3	0.221	32.1	0.160	0.1
03/29/24	22:00	45.0	0.219	32.2	0.161	0.1
03/29/24	23:00	44.1	0.215	32.3	0.161	0.1
03/30/24	00:00	43.7	0.213	32.4	0.162	0.1
03/30/24	01:00	43.6	0.212	32.5	0.162	0.1
03/30/24	02:00	43.7	0.212	32.5	0.162	0.1
03/30/24	03:00	43.3	0.210	32.5	0.162	0.1
03/30/24	04:00	43.4	0.211	32.4	0.162	0.2
03/30/24	05:00	43.2	0.210	32.5	0.162	0.2
03/30/24	06:00	43.5	0.211	32.5	0.162	0.2
03/30/24	07:00	43.9	0.213	32.4	0.161	0.2
03/30/24	08:00	44.0	0.213	32.5	0.162	0.2
03/30/24	09:00	44.0	0.213	32.6	0.162	0.2
03/30/24	10:00	44.2	0.214	32.7	0.162	0.2
03/30/24	11:00	44.2	0.214	32.7	0.163	0.2
03/30/24	12:00	43.2	0.211	32.5	0.163	0.2
03/30/24	13:00	42.3	0.211	32.2	0.164	0.1
03/30/24	14:00	43.9	0.217	32.4	0.164	0.1
03/30/24	15:00	44.2	0.219	32.4	0.164	0.1
03/30/24	16:00	44.4	0.220	32.4	0.164	0.1
03/30/24	17:00	44.6	0.221	32.4	0.164	0.1
03/30/24	18:00	44.6	0.221	32.4	0.164	0.1
03/30/24	19:00	44.9	0.222	32.4	0.164	0.1
03/30/24	20:00	45.1	0.223	32.4	0.164	0.1
03/30/24	21:00	45.2	0.224	32.4	0.164	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/30/24	22:00	45.2	0.224	32.4	0.164	0.1
03/30/24	23:00	45.9	0.227	32.4	0.163	0.1
03/31/24	00:00	46.2	0.229	32.3	0.163	0.1
03/31/24	01:00	47.4	0.234	32.3	0.163	0.1
03/31/24	02:00	46.7	0.232	32.4	0.164	0.1
03/31/24	03:00	47.1	0.234	32.4	0.164	0.1
03/31/24	04:00	47.0	0.233	32.5	0.165	0.1
03/31/24	05:00	47.3	0.235	32.6	0.165	0.1
03/31/24	06:00	47.3	0.235	32.6	0.165	0.1
03/31/24	07:00	47.2	0.235	32.6	0.165	0.1
03/31/24	08:00	47.5	0.236	32.5	0.165	0.1
03/31/24	09:00	47.6	0.237	32.5	0.165	0.1
03/31/24	10:00	47.6	0.237	32.5	0.165	0.1
03/31/24	11:00	47.7	0.237	32.4	0.164	0.1
03/31/24	12:00	47.7	0.237	32.4	0.164	0.1
03/31/24	13:00	47.6	0.236	32.5	0.164	0.1
03/31/24	14:00	46.9	0.233	32.6	0.165	0.1
03/31/24	15:00	46.8	0.232	32.6	0.165	0.1
03/31/24	16:00	46.1	0.229	32.7	0.166	0.1
03/31/24	17:00	46.0	0.229	32.7	0.166	0.1
03/31/24	18:00	46.3	0.230	32.7	0.166	0.1
03/31/24	19:00	46.1	0.229	32.7	0.166	0.1
03/31/24	20:00	45.9	0.228	32.7	0.166	0.1
03/31/24	21:00	45.8	0.228	32.7	0.166	0.1
03/31/24	22:00	45.7	0.227	32.7	0.166	0.1
03/31/24	23:00	45.2	0.225	32.7	0.166	0.1

Average	49.9	0.218	37.7	0.175	0.8
Minimum	30.8	0.157	32.0	0.159	0.1
Maximum	125.8	0.319	61.3	0.191	10.0
Summation	71,906.4	314.434	54,264.6	251.593	1,090.2
Geometric Mean	48.1	0.217	37.3	0.175	0.3
Included Data Points	1440	1440	1440	1440	1440
Total number of Data Points	1440	1440	1440	1440	1440

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1					
		CO#/HR (LB/HR)	CO#/MM (LB/MMBTU)	NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)	OPACITY (PERCENT)	SO2#/H60 (LB/HR)
Parameter							
02/01/24	00:00	48.9	0.213	38.2	0.170	1.4	0.5
02/01/24	01:00	48.9	0.213	38.5	0.171	1.4	0.5
02/01/24	02:00	49.8	0.217	39.7	0.177	1.4	0.5
02/01/24	03:00	50.2	0.213	45.8	0.198	1.4	0.6
02/01/24	04:00	39.9	0.181	42.1	0.194	1.4	0.5
02/01/24	05:00	43.4	0.197	41.0	0.189	1.4	0.5
02/01/24	06:00	51.3	0.229	38.2	0.173	1.4	0.5
02/01/24	07:00	70.4	0.300	34.3	0.149	1.4	0.5
02/01/24	08:00	59.4	0.263	35.3	0.159	1.4	0.6
02/01/24	09:00	53.7	0.236	36.1	0.161	1.4	0.5
02/01/24	10:00	127.7	0.333	63.9	0.169	1.5	1.0
02/01/24	11:00	263.3	0.538	90.9	0.188	1.4	1.1
02/01/24	12:00	214.7	0.429	105.9	0.216	1.4	1.3
02/01/24	13:00	102.7	0.309	37.5	0.114	1.4	0.6
02/01/24	14:00	69.9	0.289	26.7	0.113	1.4	0.5
02/01/24	15:00	48.9	0.203	28.9	0.122	1.4	0.5
02/01/24	16:00	61.6	0.256	28.2	0.119	1.4	0.4
02/01/24	17:00	46.7	0.198	38.4	0.166	1.4	0.5
02/01/24	18:00	46.4	0.199	38.6	0.168	1.4	0.5
02/01/24	19:00	38.0	0.163	39.9	0.175	1.4	0.5
02/01/24	20:00	43.1	0.185	39.9	0.174	1.4	0.6
02/01/24	21:00	36.4	0.158	39.6	0.175	1.4	0.6
02/01/24	22:00	42.0	0.184	38.9	0.173	1.4	0.5
02/01/24	23:00	46.8	0.209	39.9	0.181	1.4	0.5
02/02/24	00:00	41.0	0.183	41.4	0.188	1.4	0.5
02/02/24	01:00	39.5	0.178	41.9	0.191	1.4	0.5
02/02/24	02:00	49.9	0.210	44.5	0.191	1.3	0.5
02/02/24	03:00	40.2	0.182	41.0	0.189	1.3	0.5
02/02/24	04:00	40.2	0.182	40.2	0.186	1.4	0.5
02/02/24	05:00	41.1	0.188	39.1	0.182	1.4	0.5
02/02/24	06:00	41.9	0.191	40.0	0.185	1.4	0.5
02/02/24	07:00	42.5	0.190	40.2	0.182	1.4	0.6
02/02/24	08:00	43.8	0.197	37.9	0.173	1.4	0.5
02/02/24	09:00	38.8	0.176	39.9	0.185	1.4	0.5
02/02/24	10:00	44.2	0.201	39.5	0.183	1.4	0.5
02/02/24	11:00	37.9	0.173	39.1	0.182	1.4	0.5
02/02/24	12:00	46.0	0.207	38.4	0.176	1.4	0.5
02/02/24	13:00	42.3	0.192	39.2	0.181	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/02/24	14:00	46.0	0.210	39.2	0.182	1.5	0.5
02/02/24	15:00	44.0	0.190	43.2	0.190	1.4	0.5
02/02/24	16:00	49.1	0.225	38.4	0.179	1.4	0.5
02/02/24	17:00	47.0	0.217	38.7	0.181	1.4	0.5
02/02/24	18:00	41.0	0.189	39.2	0.184	1.4	0.5
02/02/24	19:00	53.0	0.242	37.0	0.172	1.4	0.5
02/02/24	20:00	56.8	0.257	35.6	0.163	1.4	0.5
02/02/24	21:00	54.0	0.247	36.6	0.170	1.4	0.5
02/02/24	22:00	53.6	0.243	36.0	0.167	1.4	0.5
02/02/24	23:00	51.9	0.236	36.2	0.167	1.4	0.5
02/03/24	00:00	48.4	0.223	37.5	0.175	1.4	0.5
02/03/24	01:00	45.2	0.209	39.2	0.185	1.4	0.5
02/03/24	02:00	61.6	0.267	38.2	0.168	1.4	0.5
02/03/24	03:00	50.5	0.230	38.0	0.177	1.4	0.5
02/03/24	04:00	45.3	0.205	37.3	0.172	1.4	0.5
02/03/24	05:00	54.7	0.242	35.8	0.161	1.3	0.5
02/03/24	06:00	52.2	0.229	34.6	0.155	1.4	0.5
02/03/24	07:00	51.7	0.221	36.0	0.157	1.3	0.5
02/03/24	08:00	48.7	0.213	36.2	0.161	1.3	0.5
02/03/24	09:00	47.0	0.211	37.6	0.171	1.3	0.5
02/03/24	10:00	38.1	0.177	40.1	0.189	1.3	0.5
02/03/24	11:00	42.3	0.195	38.2	0.179	1.4	0.5
02/03/24	12:00	43.0	0.199	39.4	0.185	1.5	0.4
02/03/24	13:00	53.9	0.242	35.7	0.163	1.5	0.4
02/03/24	14:00	57.6	0.257	33.2	0.150	1.5	0.4
02/03/24	15:00	48.9	0.202	41.6	0.175	1.5	0.5
02/03/24	16:00	45.3	0.200	37.9	0.170	1.4	0.5
02/03/24	17:00	41.5	0.185	38.9	0.176	1.3	0.5
02/03/24	18:00	49.8	0.221	37.5	0.169	1.2	0.5
02/03/24	19:00	43.6	0.193	38.1	0.171	1.3	0.5
02/03/24	20:00	42.9	0.191	37.9	0.172	1.3	0.5
02/03/24	21:00	45.1	0.204	37.8	0.173	1.3	0.5
02/03/24	22:00	46.2	0.208	38.6	0.177	1.3	0.5
02/03/24	23:00	50.4	0.224	37.1	0.168	1.3	0.5
02/04/24	00:00	47.2	0.212	37.8	0.173	1.3	0.5
02/04/24	01:00	43.6	0.201	39.7	0.185	1.3	0.5
02/04/24	02:00	63.4	0.269	38.9	0.168	1.3	0.5
02/04/24	03:00	40.0	0.184	39.0	0.183	1.3	0.5
02/04/24	04:00	43.7	0.199	36.7	0.170	1.4	0.4
02/04/24	05:00	45.3	0.207	36.3	0.168	1.3	0.5
02/04/24	06:00	45.9	0.210	36.0	0.167	1.3	0.4
02/04/24	07:00	49.9	0.223	37.6	0.171	1.3	0.5
02/04/24	08:00	47.3	0.216	37.1	0.173	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/04/24	09:00	46.2	0.207	37.6	0.172	1.4	0.5
02/04/24	10:00	43.1	0.192	37.5	0.170	1.5	0.5
02/04/24	11:00	46.5	0.211	36.2	0.166	1.6	0.5
02/04/24	12:00	56.8	0.248	36.1	0.160	1.6	0.5
02/04/24	13:00	49.5	0.213	38.1	0.168	1.5	0.5
02/04/24	14:00	53.4	0.221	41.7	0.176	1.5	0.5
02/04/24	15:00	50.2	0.219	38.8	0.172	1.4	0.5
02/04/24	16:00	52.1	0.222	38.0	0.165	1.3	0.5
02/04/24	17:00	51.1	0.221	35.9	0.158	1.3	0.5
02/04/24	18:00	46.4	0.202	36.5	0.162	1.3	0.5
02/04/24	19:00	48.0	0.209	37.5	0.167	1.3	0.5
02/04/24	20:00	41.3	0.184	38.8	0.176	1.3	0.5
02/04/24	21:00	41.5	0.183	38.2	0.171	1.3	0.5
02/04/24	22:00	39.6	0.177	40.4	0.184	1.3	0.5
02/04/24	23:00	47.0	0.212	38.3	0.176	1.3	0.5
02/05/24	00:00	48.8	0.219	37.6	0.172	1.3	0.5
02/05/24	01:00	55.0	0.238	36.5	0.161	1.3	0.5
02/05/24	02:00	60.2	0.246	37.0	0.154	1.3	0.5
02/05/24	03:00	40.5	0.174	38.5	0.168	1.3	0.5
02/05/24	04:00	34.0	0.143	38.7	0.166	1.3	0.6
02/05/24	05:00	36.8	0.155	38.5	0.166	1.3	0.5
02/05/24	06:00	42.2	0.180	39.1	0.169	1.3	0.5
02/05/24	07:00	101.3	0.431	37.3	0.161	1.4	0.8
02/05/24	08:00	40.2	0.174	40.2	0.177	1.3	0.6
02/05/24	09:00	40.8	0.180	38.6	0.172	1.4	0.5
02/05/24	10:00	41.6	0.183	39.0	0.175	1.4	0.5
02/05/24	11:00	45.7	0.197	38.1	0.167	1.4	0.5
02/05/24	12:00	37.8	0.165	39.5	0.175	1.4	0.5
02/05/24	13:00	43.8	0.192	37.7	0.168	1.4	0.5
02/05/24	14:00	42.8	0.189	39.3	0.176	1.4	0.5
02/05/24	15:00	65.2	0.268	41.7	0.175	1.4	0.6
02/05/24	16:00	37.3	0.165	41.3	0.187	1.4	0.5
02/05/24	17:00	44.1	0.195	40.1	0.181	1.4	0.5
02/05/24	18:00	42.4	0.190	41.5	0.189	1.3	0.5
02/05/24	19:00	53.3	0.239	38.5	0.175	1.4	0.5
02/05/24	20:00	53.8	0.237	36.4	0.163	1.4	0.5
02/05/24	21:00	56.1	0.247	35.9	0.161	1.4	0.5
02/05/24	22:00	61.2	0.268	36.1	0.160	1.4	0.5
02/05/24	23:00	43.1	0.188	39.4	0.174	1.4	0.5
02/06/24	00:00	43.1	0.191	39.6	0.179	1.4	0.5
02/06/24	01:00	56.2	0.235	38.5	0.165	1.4	0.5
02/06/24	02:00	46.7	0.208	39.6	0.179	1.4	0.5
02/06/24	03:00	39.6	0.183	40.3	0.189	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/06/24	04:00	45.9	0.220	36.8	0.180	1.4	0.4
02/06/24	05:00	51.3	0.239	37.6	0.178	1.4	0.5
02/06/24	06:00	51.5	0.242	36.7	0.175	1.4	0.5
02/06/24	07:00	55.8	0.256	37.5	0.174	1.3	0.5
02/06/24	08:00	50.1	0.235	38.5	0.184	1.3	0.5
02/06/24	09:00	55.2	0.261	34.5	0.166	1.4	0.4
02/06/24	10:00	46.2	0.214	36.8	0.173	1.4	0.5
02/06/24	11:00	53.6	0.245	36.1	0.168	1.4	0.4
02/06/24	12:00	57.0	0.245	35.2	0.154	1.4	0.5
02/06/24	13:00	40.8	0.174	40.4	0.175	1.4	0.5
02/06/24	14:00	34.6	0.146	41.7	0.179	1.4	0.5
02/06/24	15:00	36.6	0.152	45.1	0.190	1.4	0.5
02/06/24	16:00	29.4	0.130	41.4	0.186	1.4	0.5
02/06/24	17:00	57.7	0.262	36.3	0.168	1.4	0.5
02/06/24	18:00	50.8	0.233	37.1	0.173	1.4	0.5
02/06/24	19:00	52.0	0.240	38.1	0.179	1.4	0.5
02/06/24	20:00	48.8	0.224	38.2	0.179	1.3	0.5
02/06/24	21:00	51.9	0.236	38.0	0.176	1.3	0.5
02/06/24	22:00	46.1	0.213	38.5	0.182	1.3	0.5
02/06/24	23:00	45.7	0.213	38.2	0.181	1.3	0.5
02/07/24	00:00	44.1	0.207	38.6	0.184	1.3	0.5
02/07/24	01:00	51.5	0.242	37.8	0.180	1.3	0.5
02/07/24	02:00	50.5	0.236	38.5	0.183	1.3	0.5
02/07/24	03:00	45.6	0.202	43.4	0.195	1.4	0.5
02/07/24	04:00	48.9	0.232	38.4	0.184	1.4	0.4
02/07/24	05:00	51.7	0.245	36.9	0.178	1.4	0.4
02/07/24	06:00	52.2	0.245	37.0	0.176	1.4	0.4
02/07/24	07:00	56.1	0.258	36.8	0.172	1.4	0.5
02/07/24	08:00	57.4	0.268	36.1	0.172	1.4	0.5
02/07/24	09:00	52.6	0.244	36.0	0.170	1.4	0.5
02/07/24	10:00	56.0	0.260	35.2	0.167	1.5	0.4
02/07/24	11:00	48.9	0.227	37.6	0.177	1.5	0.5
02/07/24	12:00	58.0	0.267	37.5	0.176	1.5	0.5
02/07/24	13:00	53.1	0.244	37.7	0.176	1.5	0.5
02/07/24	14:00	47.9	0.218	38.4	0.178	1.4	0.5
02/07/24	15:00	77.6	0.336	42.4	0.187	1.4	0.5
02/07/24	16:00	45.4	0.213	43.7	0.208	1.5	0.5
02/07/24	17:00	59.4	0.276	36.9	0.174	1.5	0.4
02/07/24	18:00	59.7	0.277	35.8	0.169	1.4	0.4
02/07/24	19:00	48.4	0.230	37.8	0.182	1.4	0.4
02/07/24	20:00	47.1	0.223	38.6	0.185	1.4	0.4
02/07/24	21:00	46.7	0.219	38.2	0.183	1.4	0.4
02/07/24	22:00	51.1	0.238	37.7	0.179	1.4	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/07/24	23:00	56.9	0.262	35.6	0.167	1.4	0.4
02/08/24	00:00	54.9	0.252	35.4	0.165	1.4	0.4
02/08/24	01:00	54.2	0.251	35.5	0.166	1.4	0.5
02/08/24	02:00	69.5	0.303	38.6	0.171	1.4	0.5
02/08/24	03:00	53.0	0.247	35.0	0.166	1.4	0.4
02/08/24	04:00	55.4	0.257	35.2	0.166	1.5	0.4
02/08/24	05:00	53.1	0.248	35.8	0.169	1.4	0.4
02/08/24	06:00	54.6	0.252	36.3	0.171	1.4	0.4
02/08/24	07:00	59.1	0.267	36.7	0.169	1.4	0.5
02/08/24	08:00	54.8	0.253	36.2	0.170	1.4	0.4
02/08/24	09:00	57.9	0.265	35.0	0.162	1.4	0.4
02/08/24	10:00	57.3	0.260	35.3	0.163	1.4	0.5
02/08/24	11:00	61.5	0.245	43.6	0.176	1.5	0.5
02/08/24	12:00	251.2	0.539	89.1	0.195	1.7	1.1
02/08/24	13:00	445.4	0.826	112.3	0.212	1.4	1.5
02/08/24	14:00	133.8	0.351	62.0	0.166	1.5	0.8
02/08/24	15:00	52.0	0.239	34.9	0.163	1.3	0.4
02/08/24	16:00	41.9	0.192	36.6	0.171	1.4	0.4
02/08/24	17:00	32.2	0.148	38.1	0.178	1.3	0.4
02/08/24	18:00	31.9	0.148	36.2	0.170	1.3	0.4
02/08/24	19:00	38.0	0.174	34.4	0.161	1.3	0.4
02/08/24	20:00	37.3	0.172	35.3	0.165	1.3	0.4
02/08/24	21:00	39.4	0.181	35.3	0.166	1.3	0.4
02/08/24	22:00	38.0	0.174	35.6	0.166	1.3	0.4
02/08/24	23:00	42.7	0.195	35.5	0.164	1.3	0.4
02/09/24	00:00	48.8	0.221	33.4	0.154	1.3	0.4
02/09/24	01:00	46.3	0.209	34.5	0.159	1.3	0.4
02/09/24	02:00	56.6	0.254	33.7	0.153	1.4	0.4
02/09/24	03:00	62.1	0.270	39.7	0.175	1.3	0.5
02/09/24	04:00	46.9	0.219	37.8	0.179	1.4	0.5
02/09/24	05:00	50.0	0.231	38.4	0.181	1.4	0.5
02/09/24	06:00	44.2	0.204	38.1	0.179	1.3	0.5
02/09/24	07:00	53.5	0.242	36.4	0.167	1.4	0.5
02/09/24	08:00	59.6	0.273	35.8	0.166	1.4	0.5
02/09/24	09:00	46.9	0.214	38.6	0.180	1.4	0.5
02/09/24	10:00	40.9	0.188	40.4	0.189	1.4	0.5
02/09/24	11:00	64.5	0.263	34.8	0.145	1.5	0.5
02/09/24	12:00	379.8	0.803	84.6	0.181	1.5	1.0
02/09/24	13:00	347.7	0.692	118.8	0.240	1.5	1.4
02/09/24	14:00	124.2	0.251	121.6	0.250	1.4	1.2
02/09/24	15:00	29.3	0.089	41.5	0.128	1.4	0.6
02/09/24	16:00	99.8	0.434	29.0	0.128	1.4	0.4
02/09/24	17:00	56.3	0.259	37.5	0.176	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/09/24	18:00	57.5	0.260	35.2	0.162	1.4	0.4
02/09/24	19:00	71.8	0.314	39.8	0.177	1.4	0.5
02/09/24	20:00	38.6	0.181	40.8	0.194	1.4	0.5
02/09/24	21:00	37.2	0.174	40.5	0.192	1.4	0.5
02/09/24	22:00	36.4	0.170	40.6	0.193	1.3	0.4
02/09/24	23:00	37.8	0.178	40.6	0.194	1.3	0.4
02/10/24	00:00	35.6	0.168	40.2	0.192	1.3	0.4
02/10/24	01:00	39.7	0.187	37.5	0.180	1.3	0.4
02/10/24	02:00	60.5	0.265	41.6	0.186	1.3	0.5
02/10/24	03:00	36.7	0.172	42.0	0.201	1.3	0.5
02/10/24	04:00	43.8	0.204	38.6	0.183	1.3	0.4
02/10/24	05:00	48.1	0.223	38.4	0.180	1.3	0.4
02/10/24	06:00	43.0	0.197	38.4	0.179	1.3	0.4
02/10/24	07:00	59.6	0.267	39.0	0.178	1.3	0.5
02/10/24	08:00	49.0	0.228	38.4	0.182	1.3	0.4
02/10/24	09:00	54.1	0.253	36.0	0.170	1.3	0.4
02/10/24	10:00	52.7	0.242	36.6	0.171	1.4	0.4
02/10/24	11:00	54.4	0.247	36.8	0.170	1.4	0.4
02/10/24	12:00	53.5	0.248	36.9	0.174	1.3	0.4
02/10/24	13:00	56.3	0.254	36.8	0.169	1.4	0.4
02/10/24	14:00	74.9	0.325	37.1	0.164	1.3	0.5
02/10/24	15:00	54.2	0.250	37.7	0.176	1.3	0.4
02/10/24	16:00	59.4	0.273	36.5	0.171	1.3	0.4
02/10/24	17:00	56.5	0.258	36.6	0.170	1.4	0.4
02/10/24	18:00	52.6	0.240	38.2	0.177	1.3	0.4
02/10/24	19:00	44.2	0.209	38.8	0.187	1.3	0.4
02/10/24	20:00	45.9	0.215	38.4	0.183	1.3	0.4
02/10/24	21:00	42.6	0.196	39.7	0.186	1.3	0.4
02/10/24	22:00	38.5	0.180	39.6	0.187	1.3	0.4
02/10/24	23:00	39.8	0.184	41.2	0.193	1.3	0.4
02/11/24	00:00	35.1	0.163	41.8	0.197	1.3	0.4
02/11/24	01:00	42.2	0.193	40.1	0.186	1.3	0.4
02/11/24	02:00	55.7	0.249	41.1	0.187	1.3	0.5
02/11/24	03:00	40.9	0.191	38.7	0.184	1.4	0.4
02/11/24	04:00	41.5	0.193	38.9	0.184	1.3	0.4
02/11/24	05:00	41.1	0.193	40.2	0.192	1.3	0.4
02/11/24	06:00	42.5	0.199	39.5	0.188	1.3	0.4
02/11/24	07:00	56.6	0.268	36.2	0.174	1.3	0.5
02/11/24	08:00	42.8	0.201	39.2	0.187	1.3	0.4
02/11/24	09:00	45.1	0.208	38.0	0.179	1.4	0.4
02/11/24	10:00	50.1	0.230	36.7	0.172	1.4	0.4
02/11/24	11:00	53.1	0.243	37.1	0.173	1.4	0.4
02/11/24	12:00	58.5	0.269	36.6	0.170	1.3	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/11/24	13:00	54.4	0.249	37.5	0.175	1.3	0.4
02/11/24	14:00	78.5	0.341	38.3	0.169	1.4	0.5
02/11/24	15:00	59.8	0.276	36.3	0.171	1.4	0.4
02/11/24	16:00	52.0	0.242	38.9	0.184	1.4	0.4
02/11/24	17:00	60.0	0.277	36.5	0.171	1.4	0.4
02/11/24	18:00	55.3	0.255	36.5	0.172	1.4	0.4
02/11/24	19:00	51.4	0.237	37.6	0.176	1.4	0.4
02/11/24	20:00	49.7	0.228	38.1	0.177	1.4	0.4
02/11/24	21:00	45.8	0.212	40.1	0.189	1.4	0.5
02/11/24	22:00	41.0	0.189	40.7	0.192	1.3	0.5
02/11/24	23:00	46.7	0.214	39.2	0.183	1.3	0.5
02/12/24	00:00	42.9	0.200	39.1	0.185	1.3	0.4
02/12/24	01:00	79.8	0.354	37.1	0.167	1.3	0.4
02/12/24	02:00	37.9	0.174	42.0	0.196	1.3	0.5
02/12/24	03:00	39.9	0.188	41.4	0.199	1.3	0.5
02/12/24	04:00	55.1	0.259	36.9	0.177	1.3	0.4
02/12/24	05:00	49.9	0.232	36.6	0.173	1.3	0.5
02/12/24	06:00	48.6	0.226	37.9	0.179	1.3	0.4
02/12/24	07:00	48.4	0.221	38.7	0.179	1.3	0.5
02/12/24	08:00	44.0	0.204	39.3	0.186	1.3	0.5
02/12/24	09:00	48.8	0.226	37.4	0.177	1.4	0.4
02/12/24	10:00	50.3	0.230	38.3	0.178	1.4	0.4
02/12/24	11:00	49.1	0.228	38.4	0.181	1.5	0.4
02/12/24	12:00	40.5	0.187	38.8	0.182	1.4	0.4
02/12/24	13:00	37.0	0.173	38.9	0.184	1.5	0.4
02/12/24	14:00	45.0	0.206	38.1	0.178	1.4	0.4
02/12/24	15:00	61.3	0.268	42.2	0.188	1.4	0.5
02/12/24	16:00	39.6	0.185	39.1	0.186	1.3	0.4
02/12/24	17:00	40.3	0.190	38.9	0.187	1.3	0.4
02/12/24	18:00	38.4	0.179	39.4	0.187	1.3	0.4
02/12/24	19:00	39.3	0.184	39.2	0.187	1.3	0.4
02/12/24	20:00	40.0	0.186	39.5	0.187	1.4	0.4
02/12/24	21:00	44.5	0.206	38.3	0.180	1.3	0.4
02/12/24	22:00	43.7	0.209	36.6	0.178	1.3	0.4
02/12/24	23:00	41.4	0.193	38.1	0.181	1.3	0.4
02/13/24	00:00	40.4	0.188	39.4	0.186	1.3	0.4
02/13/24	01:00	40.4	0.187	38.3	0.181	1.3	0.4
02/13/24	02:00	74.1	0.327	38.3	0.171	1.3	0.5
02/13/24	03:00	44.9	0.211	37.0	0.177	1.3	0.4
02/13/24	04:00	44.7	0.209	37.3	0.177	1.3	0.4
02/13/24	05:00	44.8	0.208	37.7	0.178	1.3	0.4
02/13/24	06:00	40.9	0.193	37.5	0.180	1.3	0.4
02/13/24	07:00	42.3	0.194	38.4	0.179	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/13/24	08:00	44.0	0.206	37.3	0.177	1.4	0.4
02/13/24	09:00	43.5	0.201	37.4	0.177	1.4	0.4
02/13/24	10:00	44.1	0.205	37.9	0.179	1.4	0.4
02/13/24	11:00	40.5	0.187	38.3	0.180	1.4	0.4
02/13/24	12:00	46.3	0.217	36.0	0.172	1.4	0.4
02/13/24	13:00	133.3	0.387	54.7	0.162	1.3	0.9
02/13/24	14:00	59.2	0.262	29.9	0.134	1.3	0.5
02/13/24	15:00	63.5	0.294	34.2	0.161	1.3	0.5
02/13/24	16:00	51.5	0.241	35.3	0.168	1.3	0.4
02/13/24	17:00	46.3	0.216	37.5	0.177	1.4	0.4
02/13/24	18:00	42.1	0.200	36.8	0.178	1.3	0.4
02/13/24	19:00	42.9	0.202	39.0	0.186	1.4	0.4
02/13/24	20:00	45.6	0.212	38.0	0.179	1.4	0.4
02/13/24	21:00	50.8	0.233	35.9	0.168	1.4	0.4
02/13/24	22:00	47.6	0.220	36.9	0.172	1.3	0.4
02/13/24	23:00	48.8	0.226	36.6	0.172	1.3	0.4
02/14/24	00:00	45.6	0.211	37.0	0.175	1.3	0.4
02/14/24	01:00	69.3	0.307	38.0	0.172	1.3	0.4
02/14/24	02:00	42.7	0.199	39.1	0.185	1.3	0.5
02/14/24	03:00	36.4	0.173	39.5	0.192	1.3	0.4
02/14/24	04:00	34.0	0.161	39.6	0.191	1.3	0.4
02/14/24	05:00	41.9	0.197	38.5	0.183	1.4	0.4
02/14/24	06:00	40.4	0.192	38.2	0.185	1.4	0.4
02/14/24	07:00	39.1	0.179	39.3	0.183	1.3	0.5
02/14/24	08:00	40.7	0.189	38.3	0.181	1.4	0.4
02/14/24	09:00	44.1	0.204	38.0	0.179	1.4	0.4
02/14/24	10:00	42.6	0.197	38.0	0.179	1.4	0.4
02/14/24	11:00	46.1	0.213	37.4	0.176	1.4	0.4
02/14/24	12:00	45.3	0.208	38.0	0.178	1.4	0.4
02/14/24	13:00	49.1	0.224	36.8	0.171	1.5	0.4
02/14/24	14:00	59.6	0.261	38.9	0.173	1.5	0.5
02/14/24	15:00	54.4	0.251	35.7	0.168	1.5	0.4
02/14/24	16:00	49.2	0.227	37.8	0.178	1.4	0.4
02/14/24	17:00	45.4	0.209	37.5	0.176	1.3	0.4
02/14/24	18:00	37.3	0.172	38.5	0.180	1.4	0.4
02/14/24	19:00	36.5	0.168	38.7	0.181	1.3	0.4
02/14/24	20:00	36.7	0.170	39.5	0.186	1.3	0.4
02/14/24	21:00	38.7	0.179	38.4	0.181	1.3	0.4
02/14/24	22:00	40.7	0.188	38.7	0.182	1.4	0.4
02/14/24	23:00	35.5	0.164	39.2	0.185	1.3	0.4
02/15/24	00:00	40.2	0.186	38.7	0.183	1.3	0.4
02/15/24	01:00	38.0	0.176	40.5	0.191	1.3	0.5
02/15/24	02:00	61.0	0.271	38.3	0.173	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/15/24	03:00	43.1	0.200	37.9	0.179	1.4	0.4
02/15/24	04:00	44.2	0.205	37.4	0.177	1.5	0.4
02/15/24	05:00	42.8	0.197	37.9	0.177	1.4	0.4
02/15/24	06:00	51.8	0.238	35.3	0.164	1.3	0.4
02/15/24	07:00	53.1	0.239	37.0	0.170	1.3	0.5
02/15/24	08:00	49.4	0.228	36.6	0.172	1.3	0.5
02/15/24	09:00	49.9	0.229	36.0	0.168	1.3	0.4
02/15/24	10:00	61.3	0.280	35.3	0.164	1.3	0.4
02/15/24	11:00	57.1	0.257	36.0	0.164	1.4	0.5
02/15/24	12:00	60.1	0.267	35.8	0.162	1.4	0.5
02/15/24	13:00	72.9	0.313	38.2	0.167	1.4	0.5
02/15/24	14:00	54.5	0.239	41.0	0.183	1.3	0.5
02/15/24	15:00	45.8	0.209	39.8	0.185	1.4	0.5
02/15/24	16:00	47.2	0.213	39.2	0.180	1.4	0.5
02/15/24	17:00	47.1	0.212	38.3	0.175	1.3	0.5
02/15/24	18:00	42.1	0.190	40.0	0.184	1.3	0.5
02/15/24	19:00	42.7	0.190	41.1	0.186	1.3	0.5
02/15/24	20:00	42.9	0.192	41.7	0.189	1.4	0.5
02/15/24	21:00	45.2	0.203	41.5	0.189	1.3	0.5
02/15/24	22:00	46.3	0.208	41.4	0.190	1.3	0.5
02/15/24	23:00	47.3	0.212	40.8	0.186	1.3	0.5
02/16/24	00:00	47.9	0.221	38.1	0.179	1.3	0.4
02/16/24	01:00	50.1	0.227	39.4	0.181	1.3	0.5
02/16/24	02:00	72.7	0.316	38.1	0.168	1.3	0.5
02/16/24	03:00	48.6	0.226	38.4	0.182	1.4	0.5
02/16/24	04:00	48.5	0.225	39.2	0.185	1.3	0.5
02/16/24	05:00	45.4	0.208	39.5	0.184	1.3	0.5
02/16/24	06:00	46.5	0.212	39.8	0.184	1.3	0.5
02/16/24	07:00	46.0	0.205	41.5	0.188	1.2	0.6
02/16/24	08:00	48.2	0.219	40.9	0.189	1.3	0.5
02/16/24	09:00	45.4	0.207	39.2	0.181	1.4	0.5
02/16/24	10:00	45.0	0.205	39.0	0.181	1.3	0.5
02/16/24	11:00	92.5	0.273	59.4	0.178	1.3	0.9
02/16/24	12:00	37.1	0.158	38.4	0.167	1.3	0.5
02/16/24	13:00	48.7	0.229	36.8	0.175	1.4	0.5
02/16/24	14:00	45.8	0.223	37.1	0.183	1.4	0.4
02/16/24	15:00	44.2	0.211	39.2	0.190	1.4	0.5
02/16/24	16:00	39.6	0.188	39.2	0.190	1.4	0.4
02/16/24	17:00	42.2	0.199	39.2	0.188	1.4	0.4
02/16/24	18:00	50.3	0.235	36.7	0.174	1.4	0.4
02/16/24	19:00	46.9	0.221	36.4	0.175	1.4	0.4
02/16/24	20:00	47.3	0.221	36.8	0.176	1.3	0.4
02/16/24	21:00	59.2	0.274	36.1	0.170	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/16/24	22:00	57.3	0.264	36.2	0.170	1.3	0.5
02/16/24	23:00	45.5	0.212	38.7	0.183	1.3	0.5
02/17/24	00:00	38.9	0.184	39.3	0.190	1.3	0.5
02/17/24	01:00	42.2	0.200	38.5	0.185	1.3	0.4
02/17/24	02:00	65.5	0.287	40.1	0.179	1.3	0.5
02/17/24	03:00	55.8	0.265	38.8	0.186	1.3	0.5
02/17/24	04:00	57.7	0.269	37.0	0.176	1.3	0.5
02/17/24	05:00	57.4	0.269	37.5	0.178	1.3	0.5
02/17/24	06:00	59.0	0.273	36.7	0.173	1.3	0.5
02/17/24	07:00	58.2	0.267	37.4	0.175	1.2	0.6
02/17/24	08:00	49.2	0.231	39.5	0.188	1.3	0.5
02/17/24	09:00	47.7	0.222	39.3	0.186	1.3	0.5
02/17/24	10:00	49.8	0.232	39.2	0.185	1.3	0.5
02/17/24	11:00	50.1	0.233	40.0	0.189	1.3	0.5
02/17/24	12:00	50.1	0.236	40.0	0.192	1.3	0.5
02/17/24	13:00	50.9	0.239	37.9	0.181	1.3	0.5
02/17/24	14:00	71.1	0.311	41.5	0.185	1.3	0.5
02/17/24	15:00	38.4	0.182	41.3	0.199	1.3	0.5
02/17/24	16:00	37.2	0.175	40.9	0.196	1.3	0.5
02/17/24	17:00	46.9	0.219	37.9	0.180	1.3	0.4
02/17/24	18:00	40.6	0.185	39.7	0.184	1.2	0.5
02/17/24	19:00	46.2	0.211	38.2	0.178	1.3	0.5
02/17/24	20:00	46.4	0.214	37.9	0.178	1.2	0.4
02/17/24	21:00	43.7	0.203	37.8	0.179	1.2	0.4
02/17/24	22:00	50.8	0.237	37.1	0.176	1.3	0.4
02/17/24	23:00	39.7	0.186	38.4	0.184	1.3	0.4
02/18/24	00:00	43.9	0.206	38.8	0.185	1.3	0.4
02/18/24	01:00	40.6	0.191	39.1	0.187	1.3	0.5
02/18/24	02:00	50.3	0.224	41.2	0.186	1.3	0.5
02/18/24	03:00	38.5	0.181	39.4	0.188	1.3	0.5
02/18/24	04:00	47.3	0.221	37.6	0.178	1.3	0.5
02/18/24	05:00	53.2	0.247	35.5	0.168	1.3	0.4
02/18/24	06:00	56.8	0.262	35.7	0.168	1.3	0.5
02/18/24	07:00	54.1	0.245	37.5	0.173	1.3	0.6
02/18/24	08:00	57.8	0.267	36.5	0.171	1.3	0.5
02/18/24	09:00	53.1	0.245	37.2	0.175	1.3	0.5
02/18/24	10:00	40.9	0.190	39.7	0.187	1.3	0.5
02/18/24	11:00	43.9	0.203	39.6	0.186	1.4	0.5
02/18/24	12:00	42.7	0.196	39.5	0.184	1.4	0.5
02/18/24	13:00	52.0	0.234	39.9	0.183	1.4	0.5
02/18/24	14:00	48.3	0.215	42.4	0.191	1.3	0.5
02/18/24	15:00	48.4	0.224	38.3	0.181	1.4	0.5
02/18/24	16:00	49.8	0.232	37.6	0.177	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/18/24	17:00	54.4	0.253	37.8	0.178	1.4	0.5
02/18/24	18:00	53.0	0.246	37.7	0.178	1.4	0.5
02/18/24	19:00	51.9	0.240	38.0	0.178	1.4	0.5
02/18/24	20:00	53.2	0.249	37.7	0.179	1.4	0.5
02/18/24	21:00	52.3	0.241	37.9	0.178	1.4	0.5
02/18/24	22:00	52.7	0.245	37.7	0.178	1.3	0.5
02/18/24	23:00	51.1	0.237	38.1	0.181	1.4	0.4
02/19/24	00:00	59.0	0.282	37.6	0.182	1.4	0.4
02/19/24	01:00	68.6	0.318	36.2	0.171	1.3	0.5
02/19/24	02:00	69.1	0.303	40.1	0.179	1.3	0.5
02/19/24	03:00	44.3	0.209	39.9	0.192	1.3	0.5
02/19/24	04:00	60.8	0.284	36.0	0.171	1.3	0.4
02/19/24	05:00	54.3	0.256	38.8	0.187	1.3	0.5
02/19/24	06:00	51.2	0.241	38.6	0.185	1.3	0.4
02/19/24	07:00	57.9	0.268	39.2	0.184	1.3	0.5
02/19/24	08:00	52.7	0.249	38.6	0.185	1.3	0.5
02/19/24	09:00	49.7	0.232	38.7	0.185	1.4	0.4
02/19/24	10:00	55.1	0.258	38.1	0.181	1.4	0.4
02/19/24	11:00	52.9	0.246	37.8	0.179	1.4	0.4
02/19/24	12:00	59.4	0.273	38.5	0.180	1.4	0.4
02/19/24	13:00	60.3	0.272	36.1	0.165	1.4	0.4
02/19/24	14:00	64.9	0.281	35.7	0.157	1.4	0.5
02/19/24	15:00	109.6	0.434	36.0	0.145	1.4	0.6
02/19/24	16:00	38.5	0.172	33.5	0.153	1.4	0.5
02/19/24	17:00	59.9	0.260	35.6	0.158	1.3	0.6
02/19/24	18:00	38.5	0.170	39.5	0.177	1.4	0.6
02/19/24	19:00	37.1	0.163	38.8	0.174	1.4	0.6
02/19/24	20:00	48.2	0.211	37.3	0.166	1.3	0.6
02/19/24	21:00	49.4	0.217	37.8	0.169	1.3	0.7
02/19/24	22:00	46.8	0.207	37.8	0.170	1.3	0.7
02/19/24	23:00	36.2	0.163	39.2	0.180	1.3	0.6
02/20/24	00:00	42.2	0.194	41.3	0.192	1.3	0.6
02/20/24	01:00	44.8	0.207	41.3	0.194	1.3	0.5
02/20/24	02:00	96.7	0.418	40.6	0.178	1.4	0.7
02/20/24	03:00	44.7	0.210	41.0	0.196	1.3	0.6
02/20/24	04:00	48.3	0.228	39.3	0.188	1.3	0.5
02/20/24	05:00	59.1	0.276	37.7	0.179	1.3	0.5
02/20/24	06:00	44.2	0.207	40.8	0.193	1.3	0.5
02/20/24	07:00	57.8	0.263	38.5	0.178	1.3	0.6
02/20/24	08:00	45.0	0.210	39.5	0.188	1.3	0.5
02/20/24	09:00	58.2	0.270	37.5	0.176	1.4	0.5
02/20/24	10:00	56.2	0.258	37.9	0.177	1.5	0.5
02/20/24	11:00	55.1	0.267	35.8	0.176	1.5	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/20/24	12:00	52.4	0.243	39.3	0.185	1.5	0.5
02/20/24	13:00	72.9	0.222	53.1	0.165	1.5	1.0
02/20/24	14:00	68.8	0.295	30.0	0.131	1.4	0.4
02/20/24	15:00	57.6	0.271	36.9	0.177	1.5	0.5
02/20/24	16:00	45.5	0.218	39.2	0.191	1.5	0.5
02/20/24	17:00	46.6	0.223	38.3	0.187	1.4	0.5
02/20/24	18:00	42.4	0.203	38.5	0.187	1.4	0.5
02/20/24	19:00	43.2	0.206	38.5	0.187	1.4	0.5
02/20/24	20:00	61.2	0.285	36.5	0.173	1.4	0.5
02/20/24	21:00	54.5	0.254	36.6	0.173	1.4	0.5
02/20/24	22:00	38.5	0.185	39.4	0.192	1.4	0.5
02/20/24	23:00	37.7	0.181	40.6	0.199	1.4	0.5
02/21/24	00:00	47.5	0.224	39.7	0.191	1.4	0.5
02/21/24	01:00	53.6	0.258	36.8	0.180	1.4	0.5
02/21/24	02:00	55.7	0.242	42.5	0.189	1.4	0.6
02/21/24	03:00	71.7	0.327	36.3	0.169	1.4	0.5
02/21/24	04:00	60.2	0.280	37.5	0.177	1.4	0.5
02/21/24	05:00	47.5	0.227	39.0	0.189	1.4	0.5
02/21/24	06:00	50.0	0.233	39.8	0.189	1.4	0.5
02/21/24	07:00	68.0	0.308	39.8	0.183	1.5	0.6
02/21/24	08:00	47.5	0.225	40.9	0.197	1.5	0.5
02/21/24	09:00	46.9	0.221	39.2	0.188	1.5	0.5
02/21/24	10:00	53.6	0.251	38.9	0.186	1.5	0.5
02/21/24	11:00	49.7	0.233	40.8	0.194	1.5	0.5
02/21/24	12:00	51.2	0.239	38.3	0.182	1.5	0.5
02/21/24	13:00	69.8	0.313	31.3	0.143	1.6	0.5
02/21/24	14:00	61.2	0.278	36.9	0.171	1.4	0.5
02/21/24	15:00	97.0	0.419	40.5	0.179	1.5	0.5
02/21/24	16:00	54.0	0.255	37.8	0.181	1.5	0.5
02/21/24	17:00	61.7	0.289	35.8	0.170	1.5	0.4
02/21/24	18:00	51.4	0.241	39.3	0.188	1.5	0.5
02/21/24	19:00	51.7	0.244	39.1	0.188	1.5	0.5
02/21/24	20:00	48.4	0.231	40.1	0.194	1.5	0.5
02/21/24	21:00	52.6	0.245	40.0	0.189	1.5	0.5
02/21/24	22:00	56.5	0.261	37.3	0.175	1.5	0.5
02/21/24	23:00	57.6	0.265	37.7	0.177	1.4	0.5
02/22/24	00:00	57.0	0.263	38.1	0.178	1.4	0.5
02/22/24	01:00	55.5	0.256	38.3	0.179	1.4	0.5
02/22/24	02:00	69.4	0.303	40.5	0.180	1.4	0.5
02/22/24	03:00	47.3	0.221	38.9	0.185	1.4	0.5
02/22/24	04:00	65.9	0.304	37.1	0.174	1.4	0.5
02/22/24	05:00	47.4	0.225	38.7	0.187	1.4	0.5
02/22/24	06:00	49.8	0.231	39.6	0.186	1.4	0.5

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/22/24	07:00	55.9	0.252	42.3	0.194	1.4	0.6
02/22/24	08:00	58.6	0.269	39.9	0.186	1.4	0.5
02/22/24	09:00	61.1	0.278	39.8	0.184	1.4	0.5
02/22/24	10:00	57.1	0.258	40.1	0.184	1.5	0.5
02/22/24	11:00	59.4	0.269	39.5	0.182	1.5	0.5
02/22/24	12:00	59.5	0.269	38.8	0.178	1.5	0.5
02/22/24	13:00	58.0	0.265	38.8	0.180	1.5	0.5
02/22/24	14:00	67.4	0.298	35.8	0.161	1.5	0.5
02/22/24	15:00	70.4	0.296	36.7	0.156	1.5	0.5
02/22/24	16:00	46.4	0.207	35.3	0.160	1.4	0.9
02/22/24	17:00	39.1	0.176	34.8	0.160	1.4	1.4
02/22/24	18:00	39.4	0.178	34.2	0.157	1.3	1.6
02/22/24	19:00	42.4	0.195	35.0	0.163	1.3	1.7
02/22/24	20:00	35.2	0.160	35.4	0.164	1.4	1.9
02/22/24	21:00	37.4	0.170	35.3	0.163	1.4	2.2
02/22/24	22:00	36.0	0.162	34.9	0.160	1.3	2.1
02/22/24	23:00	48.8	0.218	31.6	0.143	1.3	3.0
02/23/24	00:00	41.9	0.188	33.7	0.155	1.3	3.6
02/23/24	01:00	25.1	0.112	33.8	0.154	1.3	2.9
02/23/24	02:00	46.9	0.210	31.9	0.145	1.4	3.2
02/23/24	03:00	65.5	0.276	34.6	0.148	1.3	3.8
02/23/24	04:00	33.3	0.153	35.0	0.163	1.3	3.4
02/23/24	05:00	42.5	0.196	34.9	0.163	1.3	3.8
02/23/24	06:00	36.9	0.170	34.3	0.161	1.3	3.8
02/23/24	07:00	48.5	0.218	35.0	0.160	1.3	4.0
02/23/24	08:00	42.9	0.196	34.7	0.161	1.3	2.5
02/23/24	09:00	52.3	0.239	36.1	0.168	1.3	2.4
02/23/24	10:00	249.0	0.662	63.3	0.172	1.4	10.5
02/23/24	11:00	418.7	0.782	123.7	0.235	1.4	12.6
02/23/24	12:00	177.6	0.428	84.1	0.206	1.4	2.8
02/23/24	13:00	33.5	0.156	38.4	0.182	1.3	3.6
02/23/24	14:00	30.1	0.144	38.4	0.186	1.3	4.5
02/23/24	15:00	38.1	0.182	37.5	0.182	1.3	5.2
02/23/24	16:00	35.7	0.171	37.1	0.180	1.3	5.0
02/23/24	17:00	38.3	0.187	34.2	0.169	1.3	4.7
02/23/24	18:00	27.5	0.132	36.3	0.177	1.2	5.4
02/23/24	19:00	24.5	0.119	35.3	0.174	1.2	5.4
02/23/24	20:00	25.8	0.124	35.5	0.173	1.2	5.5
02/23/24	21:00	26.5	0.127	37.2	0.182	1.2	6.1
02/23/24	22:00	31.0	0.149	34.6	0.169	1.2	4.6
02/23/24	23:00	32.0	0.155	34.8	0.170	1.2	4.8
02/24/24	00:00	34.8	0.166	34.6	0.167	1.2	3.7
02/24/24	01:00	32.8	0.156	34.7	0.168	1.2	3.9

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/24/24	02:00	42.2	0.190	40.3	0.184	1.2	6.3
02/24/24	03:00	43.6	0.208	36.7	0.178	1.3	4.1
02/24/24	04:00	44.1	0.212	35.6	0.174	1.3	4.5
02/24/24	05:00	42.3	0.200	36.5	0.176	1.2	4.2
02/24/24	06:00	43.7	0.209	35.9	0.174	1.3	4.3
02/24/24	07:00	37.2	0.176	36.7	0.176	1.3	5.9
02/24/24	08:00	50.1	0.240	36.3	0.177	1.3	6.6
02/24/24	09:00	50.6	0.245	35.8	0.176	1.3	5.1
02/24/24	10:00	42.7	0.203	38.6	0.187	1.3	4.4
02/24/24	11:00	56.9	0.267	37.4	0.179	1.4	4.2
02/24/24	12:00	62.4	0.294	34.3	0.164	1.4	3.9
02/24/24	13:00	55.1	0.259	33.9	0.162	1.4	4.0
02/24/24	14:00	35.7	0.169	37.9	0.183	1.4	4.5
02/24/24	15:00	44.7	0.200	38.7	0.177	1.4	6.9
02/24/24	16:00	35.6	0.167	37.7	0.180	1.3	6.0
02/24/24	17:00	39.1	0.185	38.2	0.184	1.2	6.6
02/24/24	18:00	32.7	0.153	36.1	0.172	1.2	5.2
02/24/24	19:00	28.4	0.139	35.6	0.177	1.3	5.4
02/24/24	20:00	33.6	0.159	35.7	0.172	1.2	4.8
02/24/24	21:00	36.2	0.171	35.2	0.170	1.3	4.5
02/24/24	22:00	43.6	0.206	34.3	0.165	1.3	6.4
02/24/24	23:00	46.8	0.222	37.4	0.180	1.3	5.3
02/25/24	00:00	48.9	0.229	35.9	0.171	1.3	4.6
02/25/24	01:00	40.9	0.194	37.5	0.180	1.3	6.2
02/25/24	02:00	34.7	0.161	37.0	0.175	1.3	5.6
02/25/24	03:00	52.9	0.233	39.0	0.175	1.3	7.1
02/25/24	04:00	37.4	0.175	35.6	0.169	1.3	6.6
02/25/24	05:00	36.0	0.168	35.7	0.170	1.3	6.4
02/25/24	06:00	39.7	0.185	34.6	0.163	1.3	6.7
02/25/24	07:00	46.4	0.210	34.8	0.160	1.3	7.6
02/25/24	08:00	47.9	0.220	33.8	0.158	1.3	7.8
02/25/24	09:00	45.2	0.208	33.6	0.157	1.3	8.2
02/25/24	10:00	46.8	0.213	35.7	0.165	1.4	8.7
02/25/24	11:00	43.8	0.197	35.7	0.163	1.4	7.5
02/25/24	12:00	50.9	0.228	36.1	0.165	1.4	7.7
02/25/24	13:00	53.1	0.241	37.9	0.175	1.4	9.1
02/25/24	14:00	31.2	0.145	41.0	0.194	1.4	9.2
02/25/24	15:00	53.4	0.232	42.5	0.188	1.4	12.6
02/25/24	16:00	25.8	0.119	40.3	0.190	1.4	10.9
02/25/24	17:00	28.8	0.136	37.5	0.179	1.4	9.0
02/25/24	18:00	29.0	0.136	37.9	0.181	1.4	8.6
02/25/24	19:00	34.5	0.163	37.8	0.181	1.4	8.4
02/25/24	20:00	33.9	0.157	36.1	0.170	1.4	9.0

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/25/24	21:00	43.6	0.201	35.5	0.166	1.4	11.7
02/25/24	22:00	39.0	0.180	35.2	0.165	1.3	10.5
02/25/24	23:00	45.8	0.218	34.6	0.168	1.4	11.1
02/26/24	00:00	38.7	0.179	35.9	0.169	1.3	10.2
02/26/24	01:00	30.6	0.142	37.1	0.174	1.3	9.5
02/26/24	02:00	29.5	0.136	37.2	0.175	1.3	10.5
02/26/24	03:00	50.0	0.217	39.0	0.172	1.3	12.9
02/26/24	04:00	38.3	0.177	36.9	0.173	1.4	13.1
02/26/24	05:00	45.4	0.210	34.9	0.164	1.3	10.6
02/26/24	06:00	49.3	0.224	34.0	0.158	1.3	8.0
02/26/24	07:00	47.3	0.212	35.6	0.163	1.3	9.6
02/26/24	08:00	41.4	0.189	35.2	0.164	1.3	10.2
02/26/24	09:00	35.4	0.168	36.1	0.174	1.4	9.5
02/26/24	10:00	35.7	0.169	37.2	0.180	1.4	11.2
02/26/24	11:00	32.3	0.151	38.8	0.184	1.4	7.4
02/26/24	12:00	32.1	0.151	37.4	0.178	1.5	6.7
02/26/24	13:00	26.1	0.122	37.6	0.179	1.5	7.6
02/26/24	14:00	40.8	0.191	35.8	0.170	1.4	9.5
02/26/24	15:00	31.6	0.146	38.4	0.182	1.4	10.0
02/26/24	16:00	25.3	0.118	37.2	0.177	1.4	7.8
02/26/24	17:00	75.0	0.327	36.7	0.163	1.3	9.4
02/26/24	18:00	38.4	0.179	37.9	0.180	1.3	2.6
02/26/24	19:00	38.4	0.179	38.1	0.181	1.4	1.5
02/26/24	20:00	38.6	0.180	40.7	0.193	1.3	2.0
02/26/24	21:00	50.9	0.236	38.8	0.183	1.3	1.4
02/26/24	22:00	45.9	0.211	39.0	0.181	1.4	1.1
02/26/24	23:00	42.1	0.190	37.3	0.171	1.4	0.9
02/27/24	00:00	41.5	0.185	36.7	0.167	1.4	0.8
02/27/24	01:00	39.8	0.178	36.7	0.167	1.4	0.7
02/27/24	02:00	44.9	0.201	37.2	0.169	1.4	0.7
02/27/24	03:00	63.4	0.270	38.0	0.164	1.4	0.9
02/27/24	04:00	56.6	0.256	37.8	0.175	1.4	0.8
02/27/24	05:00	47.8	0.218	40.1	0.186	1.5	0.7
02/27/24	06:00	140.8	0.413	55.5	0.166	1.4	3.8
02/27/24	07:00	298.5	0.571	123.0	0.240	1.3	5.4
02/27/24	08:00	283.7	0.573	115.1	0.236	1.4	1.3
02/27/24	09:00	320.0	0.645	120.1	0.247	1.3	1.1
02/27/24	10:00	220.0	0.481	102.7	0.228	1.4	1.0
02/27/24	11:00	143.5	0.354	78.3	0.196	1.4	0.8
02/27/24	12:00	148.2	0.364	81.5	0.203	1.4	0.9
02/27/24	13:00	152.0	0.362	81.0	0.197	1.4	0.9
02/27/24	14:00	131.2	0.327	78.2	0.198	1.4	0.8
02/27/24	15:00	126.3	0.313	82.9	0.210	1.4	0.8

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/27/24	16:00	53.6	0.164	57.3	0.178	1.4	0.7
02/27/24	17:00	55.0	0.250	34.7	0.160	1.4	0.4
02/27/24	18:00	34.8	0.158	35.5	0.165	1.4	0.4
02/27/24	19:00	36.3	0.164	35.4	0.161	1.3	0.4
02/27/24	20:00	37.6	0.168	35.3	0.161	1.3	0.4
02/27/24	21:00	35.3	0.158	35.6	0.163	1.4	0.4
02/27/24	22:00	39.5	0.177	36.1	0.164	1.4	0.4
02/27/24	23:00	38.3	0.171	35.6	0.161	1.4	0.4
02/28/24	00:00	42.9	0.190	36.2	0.164	1.4	0.4
02/28/24	01:00	40.3	0.180	36.8	0.167	1.4	0.4
02/28/24	02:00	49.3	0.217	33.7	0.151	1.4	0.4
02/28/24	03:00	61.3	0.256	35.1	0.149	1.4	0.5
02/28/24	04:00	55.8	0.244	32.2	0.143	1.4	0.4
02/28/24	05:00	47.1	0.214	30.9	0.143	1.4	0.4
02/28/24	06:00	148.9	0.414	72.7	0.206	1.4	0.9
02/28/24	07:00	159.1	0.359	91.1	0.208	0.9	1.1
02/28/24	08:00	104.6	0.248	84.6	0.204	1.0	0.9
02/28/24	09:00	120.4	0.290	76.9	0.188	1.0	0.8
02/28/24	10:00	73.4	0.177	86.6	0.211	1.0	1.0
02/28/24	11:00	87.1	0.209	74.7	0.182	1.0	0.8
02/28/24	12:00	228.5	0.456	104.9	0.213	1.0	1.0
02/28/24	13:00	163.6	0.334	111.5	0.232	1.0	1.1
02/28/24	14:00	215.1	0.465	89.7	0.197	1.0	0.9
02/28/24	15:00	74.3	0.178	75.5	0.184	1.0	0.9
02/28/24	16:00	184.7	0.385	105.9	0.224	1.0	1.0
02/28/24	17:00	118.7	0.292	66.7	0.167	1.0	0.7
02/28/24	18:00	59.2	0.265	31.4	0.143	1.1	0.4
02/28/24	19:00	27.3	0.129	35.8	0.172	1.2	0.4
02/28/24	20:00	35.2	0.165	35.1	0.168	1.2	0.4
02/28/24	21:00	30.0	0.141	35.1	0.168	1.2	0.4
02/28/24	22:00	31.5	0.147	34.7	0.164	1.2	0.4
02/28/24	23:00	33.2	0.155	34.9	0.166	1.2	0.4
02/29/24	00:00	30.9	0.143	34.7	0.164	1.2	0.4
02/29/24	01:00	40.2	0.185	34.1	0.160	1.2	0.4
02/29/24	02:00	31.7	0.147	33.7	0.158	1.2	0.4
02/29/24	03:00	43.5	0.188	35.7	0.157	1.2	0.4
02/29/24	04:00	25.8	0.119	35.3	0.167	1.2	0.4
02/29/24	05:00	34.0	0.156	34.1	0.159	1.2	0.4
02/29/24	06:00	105.9	0.313	56.0	0.169	1.2	0.6
02/29/24	07:00	135.2	0.307	65.6	0.152	1.1	0.9
02/29/24	08:00	276.1	0.576	88.3	0.188	1.1	1.0
02/29/24	09:00	326.7	0.690	85.0	0.183	1.1	1.0
02/29/24	10:00	507.9	1.057	78.5	0.166	1.3	1.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

02/29/24	11:00	260.0	0.658	54.7	0.141	1.3	1.0
02/29/24	12:00	0.0	0.000	0.0	0.000	1.3	0.0
02/29/24	13:00	9.7	0.031	50.2	0.164	0.0	0.6
02/29/24	14:00	9.1	0.029	50.9	0.167	1.1	0.6
02/29/24	15:00	28.5	0.117	37.2	0.155	1.1	0.5
02/29/24	16:00	19.6	0.098	33.8	0.171	1.2	0.4
02/29/24	17:00	27.1	0.135	31.6	0.159	1.2	0.4
02/29/24	18:00	23.6	0.113	32.5	0.159	1.1	0.4
02/29/24	19:00	30.7	0.150	31.4	0.155	1.1	0.4
02/29/24	20:00	28.2	0.137	31.7	0.156	1.2	0.4
02/29/24	21:00	27.8	0.137	31.0	0.156	1.2	0.4
02/29/24	22:00	24.9	0.121	31.6	0.156	1.1	0.4
02/29/24	23:00	26.6	0.131	31.3	0.157	1.1	0.4
03/01/24	00:00	27.2	0.130	32.1	0.156	1.1	0.4
03/01/24	01:00	25.1	0.123	31.2	0.157	1.2	0.4
03/01/24	02:00	37.5	0.181	30.5	0.150	1.2	0.4
03/01/24	03:00	64.5	0.287	29.0	0.132	1.1	0.4
03/01/24	04:00	22.5	0.109	34.7	0.170	1.1	0.4
03/01/24	05:00	25.7	0.124	34.2	0.167	1.1	0.4
03/01/24	06:00	27.8	0.134	35.7	0.175	1.1	0.4
03/01/24	07:00	110.8	0.304	60.1	0.168	1.1	0.9
03/01/24	08:00	270.3	0.533	92.0	0.185	1.1	1.1
03/01/24	09:00	152.4	0.303	96.1	0.194	1.1	1.0
03/01/24	10:00	161.7	0.312	97.6	0.192	1.2	1.0
03/01/24	11:00	185.3	0.365	90.7	0.182	1.2	0.9
03/01/24	12:00	167.3	0.324	95.3	0.187	1.2	1.0
03/01/24	13:00	218.4	0.406	100.0	0.189	1.2	1.0
03/01/24	14:00	260.8	0.481	96.1	0.180	1.2	1.0
03/01/24	15:00	274.5	0.506	92.8	0.174	1.2	1.0
03/01/24	16:00	103.4	0.249	63.5	0.156	1.2	0.8
03/01/24	17:00	39.7	0.191	32.8	0.161	1.2	0.4
03/01/24	18:00	43.6	0.223	29.7	0.154	1.2	0.3
03/01/24	19:00	48.6	0.241	28.4	0.143	1.2	0.3
03/01/24	20:00	42.1	0.203	30.0	0.147	1.2	0.4
03/01/24	21:00	41.0	0.201	30.8	0.154	1.2	0.4
03/01/24	22:00	38.6	0.190	31.7	0.158	1.2	0.4
03/01/24	23:00	35.4	0.176	31.2	0.158	1.2	0.4
03/02/24	00:00	39.4	0.191	31.4	0.154	1.2	0.4
03/02/24	01:00	32.1	0.159	32.4	0.162	1.3	0.4
03/02/24	02:00	44.4	0.202	34.4	0.159	1.3	0.4
03/02/24	03:00	27.9	0.139	34.3	0.174	1.3	0.4
03/02/24	04:00	28.7	0.141	35.2	0.176	1.3	0.4
03/02/24	05:00	28.1	0.143	33.8	0.175	1.2	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/02/24	06:00	31.6	0.155	34.4	0.172	1.2	0.4
03/02/24	07:00	39.2	0.195	31.3	0.159	1.2	0.4
03/02/24	08:00	37.4	0.181	31.7	0.156	1.2	0.4
03/02/24	09:00	43.9	0.208	32.6	0.158	1.2	0.4
03/02/24	10:00	34.3	0.167	34.1	0.168	1.3	0.4
03/02/24	11:00	37.0	0.187	31.9	0.163	1.3	0.4
03/02/24	12:00	34.8	0.171	33.9	0.170	1.3	0.4
03/02/24	13:00	33.0	0.164	33.3	0.169	1.3	0.4
03/02/24	14:00	32.8	0.166	34.0	0.175	1.3	0.4
03/02/24	15:00	50.2	0.231	35.9	0.168	1.3	0.4
03/02/24	16:00	38.3	0.188	31.2	0.156	1.3	0.4
03/02/24	17:00	38.3	0.185	32.2	0.159	1.2	0.4
03/02/24	18:00	36.5	0.180	31.9	0.160	1.2	0.4
03/02/24	19:00	44.4	0.215	30.4	0.150	1.3	0.4
03/02/24	20:00	35.9	0.176	31.6	0.158	1.2	0.4
03/02/24	21:00	31.4	0.154	33.5	0.167	1.2	0.4
03/02/24	22:00	33.5	0.168	32.1	0.164	1.1	0.4
03/02/24	23:00	38.5	0.186	31.8	0.156	1.2	0.4
03/03/24	00:00	37.5	0.184	30.6	0.152	1.2	0.4
03/03/24	01:00	53.7	0.243	32.5	0.150	1.2	0.4
03/03/24	02:00	32.3	0.166	31.6	0.165	1.2	0.4
03/03/24	03:00	33.8	0.167	33.5	0.168	1.2	0.4
03/03/24	04:00	31.8	0.159	33.0	0.169	1.2	0.4
03/03/24	05:00	34.0	0.167	33.5	0.167	1.2	0.4
03/03/24	06:00	34.7	0.175	31.2	0.160	1.2	0.4
03/03/24	07:00	45.6	0.214	30.4	0.145	1.1	0.5
03/03/24	08:00	46.5	0.226	29.9	0.148	1.1	0.4
03/03/24	09:00	37.9	0.181	32.3	0.157	1.1	0.4
03/03/24	10:00	38.0	0.188	31.2	0.156	1.2	0.4
03/03/24	11:00	35.3	0.172	33.6	0.166	1.2	0.4
03/03/24	12:00	32.9	0.163	33.1	0.168	1.2	0.4
03/03/24	13:00	33.1	0.169	31.7	0.165	1.2	0.4
03/03/24	14:00	57.6	0.266	34.3	0.161	1.3	0.4
03/03/24	15:00	37.6	0.184	33.8	0.169	1.2	0.4
03/03/24	16:00	37.4	0.183	32.6	0.163	1.2	0.4
03/03/24	17:00	35.3	0.171	33.4	0.165	1.2	0.4
03/03/24	18:00	32.5	0.163	32.4	0.165	1.1	0.4
03/03/24	19:00	31.9	0.155	33.5	0.166	1.1	0.4
03/03/24	20:00	32.5	0.160	33.9	0.169	1.1	0.4
03/03/24	21:00	28.1	0.141	33.5	0.170	1.1	0.4
03/03/24	22:00	32.0	0.157	34.3	0.172	1.1	0.4
03/03/24	23:00	35.5	0.173	33.8	0.168	1.1	0.4
03/04/24	00:00	32.4	0.157	33.5	0.166	1.1	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/04/24	01:00	37.0	0.184	32.9	0.166	1.1	0.4
03/04/24	02:00	49.7	0.225	35.2	0.162	1.1	0.4
03/04/24	03:00	30.4	0.149	35.1	0.175	1.1	0.4
03/04/24	04:00	33.9	0.170	34.5	0.175	1.2	0.4
03/04/24	05:00	33.3	0.162	34.5	0.171	1.1	0.4
03/04/24	06:00	32.2	0.164	33.0	0.171	1.2	0.4
03/04/24	07:00	42.3 ST	0.193	37.5 ST	0.171	1.0	0.5 ST
03/04/24	08:00	38.4	0.194	33.3	0.171	1.1	0.4
03/04/24	09:00	39.6	0.201	32.8	0.170	1.1	0.4
03/04/24	10:00	46.2	0.235	32.3	0.167	1.1	0.4
03/04/24	11:00	35.2	0.183	32.6	0.172	1.2	0.4
03/04/24	12:00	35.7	0.182	32.6	0.170	1.2	0.4
03/04/24	13:00	35.7	0.187	32.1	0.171	1.0	0.4
03/04/24	14:00	49.8	0.246	34.1	0.172	1.1	0.4
03/04/24	15:00	35.8	0.191	32.9	0.178	1.2	0.4
03/04/24	16:00	35.1	0.183	34.6	0.183	1.1	0.4
03/04/24	17:00	40.7	0.217	33.3	0.181	1.1	0.4
03/04/24	18:00	42.6	0.232	31.6	0.175	1.1	0.4
03/04/24	19:00	40.1	0.213	32.9	0.177	1.1	0.4
03/04/24	20:00	38.4	0.204	32.2	0.174	1.1	0.4
03/04/24	21:00	31.2	0.169	32.0	0.176	1.0	0.4
03/04/24	22:00	33.9	0.181	31.5	0.172	1.0	0.4
03/04/24	23:00	32.8	0.171	33.7	0.179	1.1	0.4
03/05/24	00:00	33.0	0.170	33.7	0.178	1.1	0.4
03/05/24	01:00	33.9	0.172	35.4	0.182	1.1	0.4
03/05/24	02:00	40.4	0.206	33.0	0.172	1.1	0.4
03/05/24	03:00	29.3	0.153	34.8	0.185	1.1	0.4
03/05/24	04:00	28.5	0.149	35.1	0.187	1.1	0.4
03/05/24	05:00	39.9	0.205	32.0	0.168	1.1	0.4
03/05/24	06:00	33.8	0.181	31.7	0.172	1.1	0.4
03/05/24	07:00	33.8	0.172	35.1	0.182	0.8	0.5
03/05/24	08:00	33.4	0.177	34.5	0.185	0.8	0.4
03/05/24	09:00	41.2	0.218	32.4	0.174	1.0	0.4
03/05/24	10:00	44.9	0.235	30.9	0.165	1.0	0.4
03/05/24	11:00	45.1	0.240	31.3	0.168	0.9	0.4
03/05/24	12:00	40.2	0.213	31.1	0.167	1.0	0.4
03/05/24	13:00	42.6	0.224	31.0	0.165	0.9	0.4
03/05/24	14:00	90.8	0.313	48.4	0.170	1.0	0.7
03/05/24	15:00	41.3	0.213	36.8	0.194	0.9	0.5
03/05/24	16:00	35.9	0.183	35.0	0.181	0.9	0.4
03/05/24	17:00	42.2	0.213	33.9	0.175	0.9	0.4
03/05/24	18:00	39.0	0.201	34.1	0.179	0.9	0.4
03/05/24	19:00	41.5	0.216	32.4	0.172	0.9	0.4

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/05/24	20:00	42.0	0.220	32.5	0.173	0.9	0.4
03/05/24	21:00	42.7	0.217	33.9	0.175	0.9	0.4
03/05/24	22:00	46.9	0.232	33.7	0.170	0.9	0.4
03/05/24	23:00	46.2	0.228	34.3	0.172	0.9	0.4
03/06/24	00:00	46.3	0.235	33.1	0.171	0.9	0.4
03/06/24	01:00	44.0	0.220	34.3	0.175	0.9	0.4
03/06/24	02:00	62.1	0.296	35.9	0.174	0.9	0.4
03/06/24	03:00	43.3	0.220	32.1	0.166	0.9	0.4
03/06/24	04:00	41.7	0.213	33.9	0.176	0.9	0.4
03/06/24	05:00	35.6	0.186	33.5	0.178	0.9	0.4
03/06/24	06:00	42.7	0.218	34.0	0.176	0.9	0.4
03/06/24	07:00	49.9	0.242	35.1	0.173	0.8	0.5
03/06/24	08:00	51.8	0.265	33.9	0.176	0.9	0.4
03/06/24	09:00	44.1	0.227	33.3	0.175	0.9	0.4
03/06/24	10:00	0.0 I	0.000 I	0.0 I	0.000 I	0.9	0.0 I
03/06/24	11:00	0.0 I	0.000 I	0.0 I	0.000 I	0.9	0.0 I
03/06/24	12:00	0.0 I	0.000 I	0.0 I	0.000 I	0.9	0.0 I
03/06/24	13:00	0.0 I	0.000 I	0.0 I	0.000 I	0.9	0.0 I
03/06/24	14:00	0.0 I	0.000 I	0.0 I	0.000 I	1.0	0.0 I
03/06/24	15:00	0.0 I	0.000 I	0.0 I	0.000 I	1.0	0.0 I
03/06/24	16:00	53.2 ST	0.261 ST	35.0	0.175 ST	0.9	0.9
03/06/24	17:00	76.5	0.404	35.7	0.191	0.9	0.6
03/06/24	18:00	40.3	0.215	34.7	0.188	0.8	0.2
03/06/24	19:00	41.8	0.220	34.7	0.185	0.8	0.1
03/06/24	20:00	46.4	0.238	34.6	0.181	0.8	0.1
03/06/24	21:00	44.4	0.235	32.8	0.177	0.8	0.1
03/06/24	22:00	43.3	0.224	33.7	0.178	0.8	0.1
03/06/24	23:00	40.9	0.210	34.6	0.181	0.8	0.1
03/07/24	00:00	39.0	0.201	34.8	0.183	0.8	0.1
03/07/24	01:00	41.8	0.214	34.3	0.178	0.8	0.1
03/07/24	02:00	39.2	0.204	32.2	0.170	0.8	0.1
03/07/24	03:00	57.2	0.282	35.9	0.180	0.9	0.1
03/07/24	04:00	43.6	0.224	34.4	0.180	0.9	0.1
03/07/24	05:00	42.0	0.220	33.4	0.178	0.9	0.1
03/07/24	06:00	47.7	0.242	32.7	0.168	0.9	0.1
03/07/24	07:00	43.0	0.215	33.7	0.172	0.9	0.2
03/07/24	08:00	48.5	0.243	33.3	0.170	0.9	0.1
03/07/24	09:00	41.9	0.213	33.0	0.171	0.9	0.1
03/07/24	10:00	51.7	0.261	30.7	0.157	0.9	0.1
03/07/24	11:00	59.4	0.292	33.2	0.165	0.9	0.1
03/07/24	12:00	48.6	0.245	33.4	0.171	1.0	0.1
03/07/24	13:00	44.7	0.223	36.2	0.183	1.0	0.1
03/07/24	14:00	78.2	0.362	38.6	0.182	1.0	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/07/24	15:00	47.2	0.235	35.9	0.182	0.9	0.1
03/07/24	16:00	48.8	0.240	35.6	0.178	1.0	0.1
03/07/24	17:00	52.3	0.251	34.4	0.168	0.9	0.1
03/07/24	18:00	44.8	0.226	35.3	0.180	0.7	0.1
03/07/24	19:00	37.6	0.195	36.8	0.193	0.8	0.1
03/07/24	20:00	42.6	0.219	34.3	0.179	0.9	0.1
03/07/24	21:00	36.5	0.194	33.4	0.180	0.8	0.1
03/07/24	22:00	37.0	0.195	35.7	0.190	0.8	0.1
03/07/24	23:00	45.8	0.237	34.6	0.181	0.8	0.1
03/08/24	00:00	49.7	0.252	34.3	0.177	0.8	0.1
03/08/24	01:00	43.9	0.227	35.2	0.186	0.8	0.1
03/08/24	02:00	57.5	0.292	34.7	0.179	0.9	0.1
03/08/24	03:00	40.8	0.212	35.0	0.185	0.9	0.1
03/08/24	04:00	35.4	0.185	36.5	0.195	0.9	0.1
03/08/24	05:00	43.7	0.231	33.6	0.180	0.9	0.1
03/08/24	06:00	49.8	0.251	33.0	0.170	0.9	0.1
03/08/24	07:00	54.8	0.272	34.5	0.174	0.8	0.2
03/08/24	08:00	44.0	0.227	34.3	0.181	0.8	0.1
03/08/24	09:00	47.6	0.240	34.2	0.176	0.8	0.1
03/08/24	10:00	48.5	0.242	33.8	0.172	0.9	0.1
03/08/24	11:00	46.9	0.242	33.4	0.175	0.9	0.1
03/08/24	12:00	54.7	0.262	36.6	0.178	0.9	0.1
03/08/24	13:00	43.7	0.219	36.6	0.187	0.9	0.1
03/08/24	14:00	43.3	0.222	35.8	0.186	0.8	0.1
03/08/24	15:00	46.8	0.240	34.7	0.181	0.9	0.1
03/08/24	16:00	53.1	0.268	33.2	0.170	0.9	0.1
03/08/24	17:00	45.6	0.235	32.6	0.172	0.9	0.1
03/08/24	18:00	46.7	0.236	32.9	0.169	0.9	0.1
03/08/24	19:00	48.7	0.251	31.8	0.166	0.9	0.1
03/08/24	20:00	48.5	0.250	32.4	0.170	0.9	0.1
03/08/24	21:00	49.1	0.243	31.5	0.159	0.9	0.1
03/08/24	22:00	57.1	0.281	32.6	0.163	0.9	0.1
03/08/24	23:00	51.1	0.248	33.1	0.164	1.0	0.1
03/09/24	00:00	47.3	0.232	31.7	0.159	0.9	0.1
03/09/24	01:00	71.0	0.320	30.7	0.141	0.9	0.1
03/09/24	02:00	53.2	0.248	34.2	0.162	0.9	0.2
03/09/24	03:00	43.8	0.213	34.7	0.172	0.9	0.1
03/09/24	04:00	43.2	0.211	33.7	0.167	0.9	0.1
03/09/24	05:00	40.5	0.194	34.8	0.170	0.7	0.1
03/09/24	06:00	35.7	0.175	35.1	0.175	0.7	0.1
03/09/24	07:00	38.4	0.184	38.8	0.190	0.6	0.2
03/09/24	08:00	34.4	0.174	36.2	0.186	0.6	0.1
03/09/24	09:00	36.8	0.183	36.2	0.183	0.5	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/09/24	10:00	32.7	0.165	34.9	0.179	0.6	0.1
03/09/24	11:00	31.1	0.159	35.9	0.186	0.6	0.1
03/09/24	12:00	31.8	0.160	36.6	0.187	0.7	0.1
03/09/24	13:00	85.5	0.267	51.1	0.163	0.7	0.2
03/09/24	14:00	48.0	0.204	30.5	0.133	0.6	0.1
03/09/24	15:00	64.7	0.315	26.2	0.130	0.6	0.1
03/09/24	16:00	43.7	0.216	32.3	0.162	0.6	0.1
03/09/24	17:00	40.5	0.202	34.5	0.175	0.5	0.1
03/09/24	18:00	35.9	0.177	35.0	0.176	0.6	0.1
03/09/24	19:00	30.8	0.157	36.0	0.187	0.6	0.1
03/09/24	20:00	37.2	0.185	35.4	0.179	0.6	0.1
03/09/24	21:00	37.7	0.191	33.9	0.174	0.5	0.1
03/09/24	22:00	38.1	0.190	34.8	0.177	0.5	0.1
03/09/24	23:00	34.9	0.176	36.1	0.185	0.5	0.1
03/10/24	00:00	33.7	0.169	37.1	0.189	0.5	0.1
03/10/24	01:00	35.8	0.179	35.8	0.182	0.5	0.1
03/10/24	02:00	47.8	0.226	37.4	0.180	0.5	0.1
03/10/24	03:00	35.8	0.179	35.7	0.182	0.5	0.1
03/10/24	04:00	36.9	0.182	35.9	0.181	0.5	0.1
03/10/24	05:00	37.1	0.183	35.4	0.177	0.5	0.1
03/10/24	06:00	42.8	0.209	34.7	0.172	0.5	0.1
03/10/24	07:00	43.4	0.208	35.0	0.171	0.5	0.2
03/10/24	08:00	34.7	0.176	34.8	0.179	0.5	0.1
03/10/24	09:00	32.2	0.166	36.7	0.193	0.5	0.1
03/10/24	10:00	39.8	0.198	34.3	0.174	0.5	0.1
03/10/24	11:00	37.7	0.186	36.0	0.180	0.5	0.1
03/10/24	12:00	36.9	0.182	36.6	0.183	0.5	0.1
03/10/24	13:00	57.4	0.274	33.0	0.160	0.5	0.2
03/10/24	14:00	34.5	0.176	34.1	0.177	0.6	0.1
03/10/24	15:00	37.3	0.187	34.6	0.176	0.6	0.1
03/10/24	16:00	37.1	0.181	35.2	0.175	0.6	0.1
03/10/24	17:00	37.2	0.182	33.9	0.168	0.6	0.1
03/10/24	18:00	42.1	0.206	34.0	0.169	0.5	0.1
03/10/24	19:00	38.6	0.188	36.0	0.178	0.6	0.1
03/10/24	20:00	39.3	0.197	34.4	0.176	0.5	0.1
03/10/24	21:00	39.1	0.195	34.2	0.173	0.6	0.1
03/10/24	22:00	41.4	0.210	32.6	0.168	0.5	0.1
03/10/24	23:00	41.2	0.205	33.8	0.171	0.6	0.1
03/11/24	00:00	37.6	0.191	34.1	0.176	0.6	0.1
03/11/24	01:00	59.4	0.279	36.0	0.173	0.6	0.2
03/11/24	02:00	39.5	0.205	33.5	0.176	0.6	0.1
03/11/24	03:00	40.9	0.208	35.0	0.180	0.6	0.1
03/11/24	04:00	38.4	0.198	34.2	0.180	0.6	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/11/24	05:00	42.1	0.210	35.2	0.179	0.6	0.1
03/11/24	06:00	43.4	0.218	33.1	0.170	0.5	0.1
03/11/24	07:00	49.5	0.249	33.7	0.172	0.6	0.2
03/11/24	08:00	40.6	0.206	33.7	0.174	0.6	0.1
03/11/24	09:00	45.7	0.225	34.0	0.171	0.6	0.1
03/11/24	10:00	42.7	0.213	33.8	0.171	0.6	0.1
03/11/24	11:00	41.7	0.203	35.9	0.178	0.6	0.1
03/11/24	12:00	30.9	0.159	37.8	0.197	0.7	0.1
03/11/24	13:00	37.1	0.187	36.9	0.189	0.7	0.1
03/11/24	14:00	47.3	0.224	39.3	0.190	0.7	0.2
03/11/24	15:00	38.3	0.197	36.1	0.189	0.7	0.1
03/11/24	16:00	42.1	0.213	36.6	0.188	0.7	0.1
03/11/24	17:00	38.8	0.201	36.4	0.191	0.7	0.1
03/11/24	18:00	34.7	0.179	36.9	0.194	0.6	0.1
03/11/24	19:00	40.3	0.208	33.8	0.177	0.6	0.1
03/11/24	20:00	41.9	0.217	32.3	0.171	0.6	0.1
03/11/24	21:00	46.0	0.236	32.5	0.169	0.6	0.1
03/11/24	22:00	37.8	0.195	34.3	0.180	0.6	0.1
03/11/24	23:00	38.2	0.193	35.1	0.181	0.6	0.1
03/12/24	00:00	32.1	0.166	34.7	0.183	0.6	0.1
03/12/24	01:00	50.6	0.244	37.3	0.183	0.6	0.3
03/12/24	02:00	37.6	0.199	33.5	0.180	0.7	0.1
03/12/24	03:00	34.1	0.186	33.0	0.183	0.7	0.1
03/12/24	04:00	31.1	0.163	34.8	0.186	0.6	0.1
03/12/24	05:00	33.2	0.172	34.3	0.181	0.6	0.1
03/12/24	06:00	38.6	0.197	32.7	0.170	0.6	0.1
03/12/24	07:00	56.7	0.271	31.7	0.154	0.5	0.2
03/12/24	08:00	44.6	0.225	34.3	0.175	0.5	0.2
03/12/24	09:00	43.5	0.217	34.4	0.175	0.6	0.1
03/12/24	10:00	39.8	0.199	34.5	0.176	0.6	0.1
03/12/24	11:00	42.5	0.214	33.7	0.172	0.6	0.1
03/12/24	12:00	65.4	0.261	42.1	0.171	0.6	0.3
03/12/24	13:00	75.1	0.267	43.2	0.156	0.6	0.7
03/12/24	14:00	46.9	0.240	33.0	0.171	0.6	0.2
03/12/24	15:00	46.5	0.237	35.0	0.182	0.6	0.2
03/12/24	16:00	40.1	0.204	36.6	0.189	0.6	0.2
03/12/24	17:00	52.3	0.261	33.7	0.171	0.6	0.2
03/12/24	18:00	48.2	0.240	34.5	0.175	0.5	0.2
03/12/24	19:00	49.5	0.249	34.6	0.177	0.5	0.2
03/12/24	20:00	46.8	0.236	35.0	0.180	0.5	0.2
03/12/24	21:00	42.8	0.216	34.7	0.179	0.5	0.2
03/12/24	22:00	37.3	0.189	35.5	0.183	0.5	0.2
03/12/24	23:00	45.3	0.227	34.8	0.177	0.6	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/13/24	00:00	38.7	0.196	36.0	0.185	0.5	0.2
03/13/24	01:00	56.5	0.269	36.0	0.174	0.5	0.2
03/13/24	02:00	32.7	0.168	37.4	0.196	0.6	0.2
03/13/24	03:00	40.2	0.207	36.1	0.189	0.6	0.2
03/13/24	04:00	38.7	0.198	35.5	0.185	0.6	0.2
03/13/24	05:00	38.8	0.198	35.8	0.186	0.6	0.2
03/13/24	06:00	28.7	0.150	37.1	0.197	0.6	0.2
03/13/24	07:00	42.8	0.212	35.2	0.178	0.5	0.2
03/13/24	08:00	38.8	0.198	35.1	0.183	0.5	0.1
03/13/24	09:00	40.2	0.205	34.9	0.181	0.6	0.1
03/13/24	10:00	40.9	0.209	34.3	0.179	0.6	0.1
03/13/24	11:00	33.5	0.174	36.8	0.194	0.6	0.1
03/13/24	12:00	40.7	0.209	35.7	0.187	0.7	0.1
03/13/24	13:00	36.9	0.194	35.0	0.188	0.7	0.1
03/13/24	14:00	52.9	0.257	37.3	0.184	0.6	0.2
03/13/24	15:00	41.8	0.218	32.1	0.170	0.6	0.1
03/13/24	16:00	46.8	0.237	31.7	0.163	0.6	0.1
03/13/24	17:00	43.9	0.226	33.5	0.175	0.5	0.1
03/13/24	18:00	38.8	0.201	34.9	0.183	0.5	0.1
03/13/24	19:00	40.0	0.204	34.4	0.178	0.5	0.1
03/13/24	20:00	41.2	0.215	33.3	0.176	0.5	0.1
03/13/24	21:00	44.9	0.231	32.9	0.171	0.5	0.1
03/13/24	22:00	43.9	0.224	32.8	0.170	0.5	0.1
03/13/24	23:00	47.3	0.240	32.4	0.167	0.5	0.1
03/14/24	00:00	42.7	0.219	32.8	0.171	0.5	0.1
03/14/24	01:00	71.1	0.345	31.0	0.153	0.5	0.1
03/14/24	02:00	39.5	0.209	31.5	0.170	0.5	0.1
03/14/24	03:00	43.3	0.225	33.5	0.177	0.5	0.1
03/14/24	04:00	39.0	0.206	32.6	0.175	0.5	0.1
03/14/24	05:00	41.4	0.211	33.1	0.172	0.5	0.1
03/14/24	06:00	41.7	0.210	33.5	0.171	0.5	0.1
03/14/24	07:00	35.6	0.178	36.7	0.185	0.6	0.2
03/14/24	08:00	28.4	0.148	36.6	0.194	0.6	0.1
03/14/24	09:00	37.8	0.196	34.9	0.184	0.6	0.1
03/14/24	10:00	44.1	0.220	34.8	0.177	0.6	0.1
03/14/24	11:00	36.8	0.188	35.5	0.184	0.6	0.1
03/14/24	12:00	40.1	0.200	36.6	0.185	0.6	0.1
03/14/24	13:00	52.8	0.262	35.7	0.180	0.6	0.1
03/14/24	14:00	42.7	0.202	39.2	0.188	0.6	0.2
03/14/24	15:00	39.6	0.204	34.9	0.183	0.6	0.1
03/14/24	16:00	39.7	0.202	34.4	0.178	0.6	0.1
03/14/24	17:00	39.6	0.199	34.9	0.179	0.6	0.1
03/14/24	18:00	40.7	0.204	35.5	0.181	0.6	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/14/24	19:00	44.0	0.218	34.7	0.175	0.7	0.1
03/14/24	20:00	38.7	0.193	34.1	0.173	0.6	0.1
03/14/24	21:00	37.2	0.184	34.8	0.175	0.6	0.1
03/14/24	22:00	38.9	0.197	34.5	0.177	0.6	0.1
03/14/24	23:00	37.4	0.192	33.9	0.176	0.6	0.1
03/15/24	00:00	39.1	0.197	34.6	0.177	0.6	0.1
03/15/24	01:00	53.0	0.251	34.8	0.167	0.6	0.1
03/15/24	02:00	31.5	0.165	34.8	0.185	0.6	0.1
03/15/24	03:00	39.7	0.211	33.3	0.180	0.6	0.1
03/15/24	04:00	48.9	0.249	33.8	0.174	0.6	0.1
03/15/24	05:00	38.1	0.202	34.4	0.186	0.5	0.1
03/15/24	06:00	40.6	0.210	35.1	0.185	0.6	0.1
03/15/24	07:00	33.6	0.167	38.6	0.195	0.5	0.2
03/15/24	08:00	29.0	0.149	36.9	0.193	0.5	0.1
03/15/24	09:00	31.8	0.164	35.7	0.187	0.5	0.1
03/15/24	10:00	76.8	0.257	53.2	0.181	0.5	0.6
03/15/24	11:00	26.1	0.117	37.8	0.172	0.5	0.4
03/15/24	12:00	45.8	0.234	30.7	0.160	0.5	0.3
03/15/24	13:00	43.4	0.222	31.8	0.165	0.5	0.2
03/15/24	14:00	33.4	0.176	33.5	0.179	0.6	0.2
03/15/24	15:00	27.8	0.146	35.1	0.188	0.7	0.2
03/15/24	16:00	32.1	0.166	34.9	0.184	0.6	0.1
03/15/24	17:00	28.7	0.156	33.2	0.183	0.6	0.1
03/15/24	18:00	31.9	0.166	35.4	0.187	0.5	0.1
03/15/24	19:00	35.0	0.183	35.3	0.187	0.5	0.1
03/15/24	20:00	33.0	0.171	34.1	0.180	0.5	0.1
03/15/24	21:00	38.2	0.197	32.2	0.169	0.5	0.1
03/15/24	22:00	39.9	0.205	32.4	0.170	0.5	0.1
03/15/24	23:00	38.7	0.198	32.4	0.169	0.4	0.1
03/16/24	00:00	37.7	0.190	33.2	0.171	0.5	0.1
03/16/24	01:00	64.5	0.315	32.1	0.159	0.4	0.1
03/16/24	02:00	43.4	0.222	36.2	0.188	0.4	0.2
03/16/24	03:00	42.9	0.225	32.8	0.174	0.5	0.1
03/16/24	04:00	49.0	0.249	32.6	0.169	0.5	0.2
03/16/24	05:00	44.6	0.224	32.7	0.168	0.5	0.2
03/16/24	06:00	36.2	0.181	35.1	0.178	0.5	0.2
03/16/24	07:00	45.3	0.217	35.1	0.171	0.5	0.2
03/16/24	08:00	45.5	0.227	34.2	0.173	0.5	0.1
03/16/24	09:00	41.6	0.213	34.4	0.179	0.5	0.1
03/16/24	10:00	38.1	0.194	35.2	0.183	0.6	0.1
03/16/24	11:00	36.1	0.192	34.3	0.186	0.6	0.1
03/16/24	12:00	55.8	0.283	35.3	0.182	0.6	0.3
03/16/24	13:00	35.3	0.188	36.5	0.198	0.6	0.2

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/16/24	14:00	35.0	0.188	33.8	0.185	0.6	0.1
03/16/24	15:00	30.5	0.157	34.2	0.180	0.5	0.1
03/16/24	16:00	34.7	0.176	34.4	0.178	0.5	0.1
03/16/24	17:00	34.4	0.173	35.7	0.183	0.5	0.1
03/16/24	18:00	34.8	0.178	34.8	0.181	0.4	0.1
03/16/24	19:00	31.2	0.160	35.1	0.183	0.5	0.1
03/16/24	20:00	48.3	0.244	34.7	0.179	0.5	0.1
03/16/24	21:00	34.4	0.175	35.5	0.185	0.5	0.1
03/16/24	22:00	46.3	0.239	33.0	0.173	0.4	0.1
03/16/24	23:00	37.6	0.188	33.9	0.172	0.4	0.1
03/17/24	00:00	44.4	0.221	34.0	0.172	0.5	0.1
03/17/24	01:00	40.1	0.202	34.7	0.178	0.5	0.1
03/17/24	02:00	72.2	0.348	37.3	0.183	0.5	0.3
03/17/24	03:00	31.2	0.161	35.9	0.189	0.5	0.2
03/17/24	04:00	38.4	0.197	34.2	0.178	0.5	0.2
03/17/24	05:00	39.5	0.198	34.1	0.174	0.4	0.1
03/17/24	06:00	42.2	0.209	33.5	0.170	0.4	0.1
03/17/24	07:00	38.4	0.186	35.3	0.174	0.4	0.3
03/17/24	08:00	40.1	0.201	32.3	0.165	0.5	0.1
03/17/24	09:00	45.3	0.226	31.4	0.159	0.5	0.1
03/17/24	10:00	44.0	0.218	32.0	0.161	0.4	0.1
03/17/24	11:00	43.8	0.216	32.3	0.162	0.5	0.1
03/17/24	12:00	47.3	0.234	30.9	0.155	0.4	0.1
03/17/24	13:00	52.6	0.248	36.2	0.173	0.4	0.2
03/17/24	14:00	43.8	0.223	32.4	0.167	0.4	0.2
03/17/24	15:00	39.1	0.200	33.0	0.173	0.5	0.1
03/17/24	16:00	34.8	0.174	33.8	0.173	0.3	0.1
03/17/24	17:00	39.4	0.194	33.9	0.170	0.5	0.1
03/17/24	18:00	45.7	0.224	33.0	0.164	0.4	0.1
03/17/24	19:00	43.1	0.213	32.0	0.161	0.3	0.1
03/17/24	20:00	38.9	0.193	33.4	0.169	0.3	0.1
03/17/24	21:00	35.3	0.174	34.3	0.172	0.4	0.1
03/17/24	22:00	31.1	0.154	34.8	0.176	0.4	0.1
03/17/24	23:00	34.5	0.172	34.8	0.176	0.4	0.1
03/18/24	00:00	32.6	0.167	33.6	0.175	0.4	0.1
03/18/24	01:00	77.9	0.364	38.0	0.180	0.4	0.3
03/18/24	02:00	30.7	0.159	34.9	0.185	0.4	0.2
03/18/24	03:00	34.2	0.176	34.7	0.182	0.4	0.1
03/18/24	04:00	32.2	0.164	35.7	0.185	0.4	0.1
03/18/24	05:00	32.4	0.165	35.1	0.181	0.4	0.1
03/18/24	06:00	35.4	0.175	34.5	0.173	0.4	0.1
03/18/24	07:00	36.4	0.176	36.0	0.176	0.4	0.2
03/18/24	08:00	36.2	0.179	33.9	0.171	0.4	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/18/24	09:00	39.7	0.200	32.8	0.168	0.5	0.1
03/18/24	10:00	40.7	0.203	33.0	0.167	0.4	0.1
03/18/24	11:00	39.5	0.197	34.1	0.172	0.4	0.1
03/18/24	12:00	39.4	0.197	34.1	0.173	0.4	0.1
03/18/24	13:00	59.3	0.280	32.8	0.157	0.4	0.1
03/18/24	14:00	30.8	0.163	32.6	0.175	0.4	0.1
03/18/24	15:00	32.4	0.170	33.7	0.179	0.5	0.1
03/18/24	16:00	32.3	0.167	34.6	0.182	0.5	0.1
03/18/24	17:00	30.5	0.155	35.7	0.185	0.4	0.1
03/18/24	18:00	34.3	0.172	36.6	0.186	0.4	0.1
03/18/24	19:00	38.0	0.189	35.5	0.180	0.5	0.1
03/18/24	20:00	36.8	0.184	34.9	0.178	0.4	0.1
03/18/24	21:00	40.6	0.206	34.4	0.177	0.5	0.1
03/18/24	22:00	42.0	0.211	34.3	0.175	0.4	0.1
03/18/24	23:00	41.6	0.208	34.2	0.174	0.4	0.1
03/19/24	00:00	35.2	0.176	34.4	0.175	0.4	0.1
03/19/24	01:00	46.9	0.222	34.9	0.168	0.4	0.1
03/19/24	02:00	39.5	0.202	34.5	0.180	0.5	0.1
03/19/24	03:00	39.6	0.198	36.1	0.183	0.4	0.1
03/19/24	04:00	34.7	0.173	37.1	0.188	0.4	0.1
03/19/24	05:00	41.0	0.204	36.2	0.183	0.4	0.1
03/19/24	06:00	33.4	0.167	37.7	0.193	0.4	0.1
03/19/24	07:00	66.4	0.321	33.0	0.162	0.4	0.2
03/19/24	08:00	45.1	0.227	34.8	0.178	0.4	0.1
03/19/24	09:00	53.5	0.266	33.2	0.168	0.4	0.1
03/19/24	10:00	43.2	0.216	35.6	0.181	0.4	0.1
03/19/24	11:00	58.1	0.290	32.6	0.165	0.5	0.1
03/19/24	12:00	52.7	0.240	36.0	0.167	0.5	0.2
03/19/24	13:00	73.1	0.221	51.8	0.159	0.5	1.4
03/19/24	14:00	59.0	0.302	29.8	0.155	0.5	0.3
03/19/24	15:00	51.5	0.261	31.5	0.163	0.5	0.2
03/19/24	16:00	54.5	0.277	29.7	0.154	0.5	0.2
03/19/24	17:00	45.8	0.232	31.6	0.163	0.5	0.2
03/19/24	18:00	44.8	0.225	32.2	0.165	0.5	0.2
03/19/24	19:00	47.1	0.233	32.8	0.165	0.5	0.2
03/19/24	20:00	42.9	0.211	33.7	0.169	0.4	0.2
03/19/24	21:00	45.7	0.226	34.5	0.174	0.5	0.2
03/19/24	22:00	47.8	0.236	33.4	0.168	0.5	0.2
03/19/24	23:00	44.8	0.223	33.0	0.167	0.5	0.2
03/20/24	00:00	42.1	0.209	34.3	0.173	0.4	0.2
03/20/24	01:00	45.1	0.228	33.2	0.170	0.5	0.2
03/20/24	02:00	53.3	0.255	35.4	0.172	0.4	0.3
03/20/24	03:00	48.2	0.245	33.6	0.175	0.4	0.3

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/20/24	04:00	29.8	0.158	34.3	0.184	0.4	0.2
03/20/24	05:00	35.5	0.184	34.1	0.178	0.4	0.2
03/20/24	06:00	35.1	0.179	34.8	0.181	0.4	0.1
03/20/24	07:00	49.6	0.242	32.5	0.161	0.3	0.3
03/20/24	08:00	46.1	0.231	31.2	0.159	0.3	0.2
03/20/24	09:00	35.1	0.174	33.4	0.168	0.3	0.1
03/20/24	10:00	44.8	0.220	33.0	0.164	0.3	0.1
03/20/24	11:00	37.7	0.185	33.5	0.167	0.3	0.1
03/20/24	12:00	39.7	0.196	33.2	0.166	0.3	0.1
03/20/24	13:00	56.9	0.266	35.4	0.168	0.3	0.4
03/20/24	14:00	31.2	0.159	34.9	0.180	0.4	0.2
03/20/24	15:00	30.6	0.155	35.4	0.182	0.3	0.1
03/20/24	16:00	30.5	0.155	35.7	0.184	0.4	0.1
03/20/24	17:00	33.6	0.168	35.4	0.181	0.3	0.1
03/20/24	18:00	33.0	0.164	33.7	0.170	0.3	0.1
03/20/24	19:00	30.4	0.153	34.5	0.176	0.3	0.1
03/20/24	20:00	29.0	0.148	34.4	0.178	0.3	0.1
03/20/24	21:00	30.3	0.154	33.4	0.173	0.3	0.1
03/20/24	22:00	31.8	0.167	32.8	0.175	0.3	0.1
03/20/24	23:00	30.2	0.157	33.7	0.178	0.4	0.1
03/21/24	00:00	27.5	0.145	34.6	0.186	0.4	0.1
03/21/24	01:00	41.3	0.196	31.6	0.152	0.3	0.1
03/21/24	02:00	40.7	0.210	27.2	0.143	0.4	0.1
03/21/24	03:00	38.9	0.201	27.2	0.143	0.4	0.1
03/21/24	04:00	34.1	0.176	27.8	0.146	0.4	0.1
03/21/24	05:00	28.2	0.148	33.8	0.181	0.4	0.1
03/21/24	06:00	33.8	0.176	34.8	0.185	0.4	0.1
03/21/24	07:00	37.9	0.193	35.3	0.183	0.4	0.2
03/21/24	08:00	34.2	0.176	35.8	0.186	0.4	0.1
03/21/24	09:00	28.1	0.144	36.4	0.190	0.4	0.1
03/21/24	10:00	28.0	0.147	36.2	0.193	0.4	0.1
03/21/24	11:00	26.7	0.138	37.5	0.197	0.4	0.1
03/21/24	12:00	32.6	0.165	35.8	0.184	0.5	0.1
03/21/24	13:00	37.4	0.183	36.6	0.182	0.5	0.1
03/21/24	14:00	27.3	0.145	34.9	0.188	0.5	0.1
03/21/24	15:00	35.5	0.187	34.1	0.183	0.5	0.1
03/21/24	16:00	28.5	0.151	34.7	0.187	0.5	0.1
03/21/24	17:00	27.7	0.146	35.6	0.189	0.5	0.1
03/21/24	18:00	30.1	0.157	35.7	0.189	0.4	0.1
03/21/24	19:00	28.8	0.147	37.2	0.193	0.4	0.1
03/21/24	20:00	24.3	0.126	37.1	0.195	0.4	0.1
03/21/24	21:00	28.3	0.145	37.2	0.193	0.4	0.1
03/21/24	22:00	31.7	0.161	36.1	0.187	0.3	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/21/24	23:00	31.1	0.159	36.1	0.188	0.3	0.1
03/22/24	00:00	31.2	0.161	35.8	0.187	0.3	0.1
03/22/24	01:00	29.9	0.154	35.8	0.188	0.4	0.1
03/22/24	02:00	40.7	0.199	38.6	0.192	0.4	0.1
03/22/24	03:00	30.9	0.165	34.8	0.189	0.5	0.1
03/22/24	04:00	36.6	0.188	31.2	0.162	0.5	0.1
03/22/24	05:00	32.5	0.162	31.2	0.158	0.4	0.1
03/22/24	06:00	32.3	0.160	31.8	0.160	0.4	0.1
03/22/24	07:00	29.9	0.144	34.5	0.169	0.4	0.2
03/22/24	08:00	28.4	0.142	33.5	0.170	0.4	0.1
03/22/24	09:00	35.4	0.177	35.9	0.182	0.4	0.1
03/22/24	10:00	35.0	0.178	34.7	0.179	0.4	0.1
03/22/24	11:00	46.4	0.228	34.3	0.172	0.4	0.1
03/22/24	12:00	45.6	0.222	34.0	0.169	0.4	0.1
03/22/24	13:00	56.0	0.252	35.6	0.163	0.3	0.2
03/22/24	14:00	94.3	0.341	47.1	0.174	0.3	0.7
03/22/24	15:00	36.9	0.190	36.5	0.191	0.4	0.2
03/22/24	16:00	42.9	0.219	33.8	0.176	0.4	0.2
03/22/24	17:00	41.7	0.215	33.7	0.176	0.4	0.1
03/22/24	18:00	44.6	0.225	33.1	0.170	0.4	0.1
03/22/24	19:00	46.8	0.231	33.8	0.170	0.4	0.1
03/22/24	20:00	44.7	0.222	33.7	0.170	0.4	0.1
03/22/24	21:00	39.3	0.197	34.1	0.174	0.4	0.1
03/22/24	22:00	39.5	0.199	34.2	0.175	0.4	0.1
03/22/24	23:00	42.5	0.213	33.5	0.171	0.4	0.1
03/23/24	00:00	46.8	0.234	32.6	0.167	0.4	0.1
03/23/24	01:00	41.0	0.206	33.6	0.172	0.4	0.1
03/23/24	02:00	48.9	0.237	35.6	0.175	0.4	0.2
03/23/24	03:00	38.9	0.202	34.0	0.180	0.4	0.1
03/23/24	04:00	37.6	0.194	33.8	0.178	0.4	0.1
03/23/24	05:00	34.7	0.182	32.7	0.175	0.4	0.1
03/23/24	06:00	39.5	0.203	32.1	0.168	0.4	0.1
03/23/24	07:00	44.7	0.230	32.0	0.167	0.4	0.2
03/23/24	08:00	42.1	0.221	30.9	0.164	0.4	0.1
03/23/24	09:00	39.5	0.209	32.0	0.171	0.4	0.1
03/23/24	10:00	31.1	0.163	34.1	0.181	0.4	0.1
03/23/24	11:00	31.7	0.165	34.2	0.181	0.4	0.1
03/23/24	12:00	30.9	0.157	35.8	0.185	0.5	0.1
03/23/24	13:00	35.5	0.182	34.6	0.180	0.5	0.1
03/23/24	14:00	44.5	0.213	36.5	0.178	0.5	0.1
03/23/24	15:00	36.6	0.192	34.2	0.182	0.5	0.1
03/23/24	16:00	34.6	0.179	35.0	0.185	0.4	0.1
03/23/24	17:00	33.8	0.175	35.3	0.186	0.5	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/23/24	18:00	36.3	0.188	35.8	0.188	0.5	0.1
03/23/24	19:00	37.6	0.195	33.8	0.178	0.3	0.1
03/23/24	20:00	37.1	0.188	34.7	0.179	0.3	0.1
03/23/24	21:00	36.7	0.184	34.8	0.178	0.4	0.1
03/23/24	22:00	46.6	0.233	32.4	0.165	0.3	0.1
03/23/24	23:00	41.1	0.205	33.9	0.172	0.3	0.1
03/24/24	00:00	44.9	0.221	31.6	0.158	0.3	0.1
03/24/24	01:00	43.1	0.212	31.9	0.159	0.3	0.1
03/24/24	02:00	55.1	0.259	35.0	0.166	0.3	0.1
03/24/24	03:00	39.4	0.202	31.8	0.165	0.3	0.1
03/24/24	04:00	39.8	0.202	31.4	0.163	0.3	0.1
03/24/24	05:00	41.8	0.210	31.7	0.163	0.3	0.1
03/24/24	06:00	42.5	0.213	31.4	0.160	0.3	0.1
03/24/24	07:00	47.5	0.227	33.1	0.161	0.3	0.2
03/24/24	08:00	38.7	0.191	33.1	0.166	0.3	0.1
03/24/24	09:00	33.6	0.166	35.2	0.178	0.4	0.1
03/24/24	10:00	34.0	0.169	35.3	0.179	0.4	0.1
03/24/24	11:00	37.6	0.185	35.7	0.179	0.4	0.1
03/24/24	12:00	40.3	0.198	35.4	0.177	0.4	0.1
03/24/24	13:00	61.9	0.293	34.8	0.167	0.5	0.1
03/24/24	14:00	50.0	0.245	39.0	0.195	0.4	0.2
03/24/24	15:00	34.9	0.179	36.1	0.188	0.4	0.1
03/24/24	16:00	36.0	0.180	35.7	0.183	0.3	0.1
03/24/24	17:00	44.0	0.218	34.9	0.175	0.3	0.1
03/24/24	18:00	39.3	0.195	34.8	0.176	0.3	0.1
03/24/24	19:00	39.9	0.198	34.8	0.176	0.4	0.1
03/24/24	20:00	41.9	0.208	35.1	0.177	0.3	0.1
03/24/24	21:00	37.6	0.185	34.7	0.174	0.4	0.1
03/24/24	22:00	36.0	0.180	34.6	0.176	0.3	0.1
03/24/24	23:00	32.2	0.160	36.2	0.183	0.3	0.1
03/25/24	00:00	38.8	0.193	35.1	0.178	0.3	0.1
03/25/24	01:00	34.3	0.171	35.7	0.180	0.4	0.1
03/25/24	02:00	37.9	0.184	38.7	0.192	0.4	0.1
03/25/24	03:00	33.1	0.176	35.0	0.189	0.4	0.1
03/25/24	04:00	44.3	0.225	35.1	0.181	0.4	0.1
03/25/24	05:00	38.0	0.191	36.4	0.185	0.4	0.1
03/25/24	06:00	46.4	0.230	33.7	0.171	0.4	0.1
03/25/24	07:00	30.4	0.150	38.5	0.194	0.4	0.2
03/25/24	08:00	30.1	0.152	37.3	0.192	0.4	0.1
03/25/24	09:00	35.7	0.179	36.2	0.184	0.5	0.1
03/25/24	10:00	37.4	0.187	36.3	0.185	0.5	0.1
03/25/24	11:00	30.6	0.160	35.8	0.190	0.5	0.1
03/25/24	12:00	48.2	0.240	35.8	0.182	0.5	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/25/24	13:00	34.9	0.173	36.9	0.186	0.5	0.2
03/25/24	14:00	39.6	0.204	32.9	0.173	0.6	0.1
03/25/24	15:00	34.8	0.182	34.5	0.183	0.5	0.1
03/25/24	16:00	37.7	0.195	34.0	0.179	0.5	0.1
03/25/24	17:00	38.1	0.197	33.3	0.175	0.5	0.1
03/25/24	18:00	31.0	0.160	34.8	0.183	0.4	0.1
03/25/24	19:00	31.8	0.165	34.8	0.184	0.4	0.1
03/25/24	20:00	51.9	0.260	32.3	0.165	0.4	0.1
03/25/24	21:00	45.2	0.227	33.0	0.168	0.4	0.1
03/25/24	22:00	32.0	0.164	35.9	0.188	0.4	0.1
03/25/24	23:00	36.2	0.186	34.5	0.180	0.4	0.1
03/26/24	00:00	49.7	0.250	32.3	0.165	0.5	0.1
03/26/24	01:00	45.5	0.229	33.9	0.173	0.5	0.1
03/26/24	02:00	51.1	0.247	38.1	0.187	0.5	0.2
03/26/24	03:00	35.9	0.190	34.9	0.187	0.5	0.1
03/26/24	04:00	35.7	0.186	36.8	0.194	0.4	0.1
03/26/24	05:00	34.7	0.180	37.0	0.195	0.4	0.1
03/26/24	06:00	40.5	0.208	35.0	0.183	0.5	0.1
03/26/24	07:00	0.0 I	0.000 I	0.0 I	0.000 I	0.4	0.0 I
03/26/24	08:00	41.1	0.211	22.3	0.116	0.4	0.2
03/26/24	09:00	37.6	0.191	22.8	0.118	0.4	0.2
03/26/24	10:00	44.7	0.226	22.4	0.115	0.5	0.2
03/26/24	11:00	39.4	0.198	32.2	0.165	0.5	0.3
03/26/24	12:00	39.9	0.201	33.7	0.172	0.5	0.2
03/26/24	13:00	68.3	0.319	36.3	0.173	0.5	0.3
03/26/24	14:00	33.8	0.174	35.8	0.187	0.5	0.2
03/26/24	15:00	43.5	0.222	34.8	0.180	0.5	0.1
03/26/24	16:00	39.7	0.202	35.2	0.182	0.5	0.1
03/26/24	17:00	37.2	0.189	35.5	0.184	0.4	0.1
03/26/24	18:00	35.4	0.182	33.7	0.176	0.5	0.1
03/26/24	19:00	41.9	0.215	33.1	0.172	0.5	0.1
03/26/24	20:00	38.1	0.191	33.5	0.172	0.4	0.1
03/26/24	21:00	36.1	0.180	32.4	0.164	0.4	0.1
03/26/24	22:00	36.0	0.179	33.5	0.169	0.4	0.1
03/26/24	23:00	39.3	0.194	34.3	0.173	0.4	0.1
03/27/24	00:00	37.2	0.184	33.5	0.168	0.4	0.1
03/27/24	01:00	37.6	0.196	31.9	0.169	0.4	0.1
03/27/24	02:00	58.3	0.276	33.7	0.162	0.4	0.2
03/27/24	03:00	37.6	0.193	32.3	0.169	0.3	0.1
03/27/24	04:00	37.1	0.188	31.6	0.163	0.4	0.1
03/27/24	05:00	40.4	0.199	32.4	0.163	0.4	0.1
03/27/24	06:00	45.6	0.223	31.3	0.156	0.4	0.1
03/27/24	07:00	0.0 I	0.000 I	0.0 I	0.000 I	0.3	0.0 I

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/27/24	08:00	42.4	0.207	33.3	0.166	0.3	0.3
03/27/24	09:00	36.8	0.180	33.8	0.168	0.3	0.2
03/27/24	10:00	0.0 I	0.000 I	0.0 I	0.000 I	0.3	0.0 I
03/27/24	11:00	0.0 I	0.000 I	0.0 I	0.000 I	0.3	0.0 I
03/27/24	12:00	38.1	0.185	34.7	0.172	0.4	1.0
03/27/24	13:00	55.7	0.265	36.3	0.176	0.3	0.4
03/27/24	14:00	40.0	0.201	33.2	0.169	0.4	0.2
03/27/24	15:00	34.4	0.173	33.8	0.173	0.4	0.1
03/27/24	16:00	33.1	0.164	35.0	0.176	0.4	0.1
03/27/24	17:00	34.2	0.168	35.8	0.179	0.3	0.1
03/27/24	18:00	31.4	0.154	36.1	0.180	0.3	0.1
03/27/24	19:00	30.0	0.148	35.9	0.179	0.3	0.1
03/27/24	20:00	33.9	0.167	37.0	0.185	0.3	0.1
03/27/24	21:00	31.4	0.155	36.8	0.185	0.3	0.1
03/27/24	22:00	30.3	0.151	37.3	0.188	0.3	0.1
03/27/24	23:00	34.9	0.173	34.9	0.176	0.3	0.1
03/28/24	00:00	39.3	0.194	34.2	0.172	0.3	0.1
03/28/24	01:00	37.3	0.183	34.4	0.172	0.3	0.1
03/28/24	02:00	62.5	0.290	37.6	0.177	0.3	0.3
03/28/24	03:00	35.8	0.183	34.0	0.176	0.3	0.2
03/28/24	04:00	39.2	0.196	33.1	0.169	0.3	0.1
03/28/24	05:00	40.3	0.199	33.3	0.167	0.3	0.1
03/28/24	06:00	37.7	0.187	33.1	0.167	0.3	0.1
03/28/24	07:00	44.7	0.215	33.6	0.165	0.3	0.2
03/28/24	08:00	37.7	0.187	33.2	0.167	0.4	0.1
03/28/24	09:00	35.9	0.178	34.1	0.172	0.4	0.1
03/28/24	10:00	45.0	0.220	32.3	0.161	0.3	0.1
03/28/24	11:00	45.3	0.222	32.6	0.163	0.4	0.1
03/28/24	12:00	35.1	0.175	33.5	0.171	0.4	0.1
03/28/24	13:00	57.0	0.273	34.1	0.166	0.4	0.2
03/28/24	14:00	34.5	0.176	32.5	0.169	0.5	0.1
03/28/24	15:00	33.0	0.165	32.7	0.167	0.4	0.1
03/28/24	16:00	38.5	0.195	32.6	0.167	0.4	0.1
03/28/24	17:00	32.9	0.174	31.9	0.172	0.3	0.1
03/28/24	18:00	32.3	0.163	33.5	0.173	0.3	0.1
03/28/24	19:00	37.4	0.188	33.3	0.170	0.3	0.1
03/28/24	20:00	45.9	0.225	31.0	0.155	0.3	0.1
03/28/24	21:00	50.2	0.247	29.8	0.149	0.3	0.1
03/28/24	22:00	49.0	0.243	29.8	0.150	0.3	0.1
03/28/24	23:00	57.0	0.282	31.7	0.159	0.3	0.1
03/29/24	00:00	48.3	0.241	30.8	0.156	0.3	0.1
03/29/24	01:00	41.4	0.205	31.9	0.161	0.3	0.1
03/29/24	02:00	58.0	0.277	33.0	0.161	0.3	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/29/24	03:00	41.7	0.215	30.8	0.162	0.3	0.1
03/29/24	04:00	43.6	0.222	31.5	0.163	0.3	0.1
03/29/24	05:00	37.8	0.189	32.6	0.166	0.3	0.1
03/29/24	06:00	36.2	0.183	31.8	0.163	0.3	0.1
03/29/24	07:00	39.9	0.194	33.5	0.165	0.3	0.2
03/29/24	08:00	43.8	0.216	31.7	0.159	0.3	0.1
03/29/24	09:00	39.6	0.199	31.3	0.160	0.3	0.1
03/29/24	10:00	39.4	0.198	31.4	0.160	0.3	0.1
03/29/24	11:00	46.1	0.227	31.7	0.160	0.3	0.1
03/29/24	12:00	64.7	0.278	37.1	0.162	0.4	0.2
03/29/24	13:00	68.1	0.241	39.8	0.144	0.4	0.8
03/29/24	14:00	37.1	0.193	29.6	0.157	0.4	0.1
03/29/24	15:00	40.0	0.204	31.4	0.163	0.4	0.1
03/29/24	16:00	46.3	0.234	30.4	0.156	0.4	0.1
03/29/24	17:00	43.6	0.221	31.3	0.161	0.4	0.1
03/29/24	18:00	42.2	0.214	32.0	0.164	0.4	0.1
03/29/24	19:00	41.7	0.209	31.5	0.161	0.4	0.1
03/29/24	20:00	39.5	0.199	31.9	0.164	0.4	0.1
03/29/24	21:00	42.3	0.212	32.2	0.165	0.4	0.1
03/29/24	22:00	41.2	0.205	32.3	0.163	0.3	0.1
03/29/24	23:00	36.7	0.183	33.2	0.169	0.4	0.1
03/30/24	00:00	38.4	0.191	33.5	0.169	0.3	0.1
03/30/24	01:00	39.2	0.193	33.8	0.168	0.3	0.1
03/30/24	02:00	58.5	0.273	32.7	0.155	0.3	0.2
03/30/24	03:00	33.5	0.173	32.2	0.169	0.3	0.1
03/30/24	04:00	45.0	0.231	29.3	0.152	0.4	0.1
03/30/24	05:00	33.8	0.172	33.6	0.174	0.4	0.1
03/30/24	06:00	42.8	0.213	31.5	0.159	0.4	0.1
03/30/24	07:00	49.0	0.231	33.1	0.159	0.3	0.2
03/30/24	08:00	46.8	0.230	32.8	0.164	0.3	0.1
03/30/24	09:00	40.2	0.198	33.5	0.168	0.4	0.1
03/30/24	10:00	43.7	0.217	33.5	0.169	0.4	0.1
03/30/24	11:00	45.3	0.224	33.0	0.166	0.3	0.1
03/30/24	12:00	42.5	0.215	32.0	0.164	0.4	0.1
03/30/24	13:00	46.8	0.231	32.8	0.165	0.4	0.1
03/30/24	14:00	74.1	0.345	33.3	0.157	0.4	0.2
03/30/24	15:00	46.6	0.237	32.7	0.169	0.4	0.1
03/30/24	16:00	52.8	0.265	30.2	0.154	0.4	0.1
03/30/24	17:00	48.1	0.240	31.2	0.159	0.3	0.1
03/30/24	18:00	41.5	0.208	32.1	0.163	0.3	0.1
03/30/24	19:00	48.1	0.243	31.8	0.163	0.3	0.1
03/30/24	20:00	45.8	0.230	31.4	0.161	0.3	0.1
03/30/24	21:00	44.1	0.222	32.3	0.166	0.3	0.1

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Hourly Emissions

Plant: GENESEE POWER STATION LP

Interval: 1 Hour

Type: Roll with BAF Applied

Report Period: 02/01/2024 00:00 Through 03/31/2024 23:59

Time Online Criteria: 1 minute(s)

03/30/24	22:00	42.4	0.213	32.6	0.166	0.3	0.1
03/30/24	23:00	51.6	0.258	31.8	0.162	0.3	0.1
03/31/24	00:00	46.9	0.239	32.8	0.169	0.3	0.1
03/31/24	01:00	68.3	0.318	33.8	0.160	0.3	0.1
03/31/24	02:00	40.2	0.207	33.9	0.178	0.3	0.1
03/31/24	03:00	43.3	0.221	32.8	0.171	0.4	0.1
03/31/24	04:00	43.0	0.220	32.6	0.169	0.4	0.1
03/31/24	05:00	40.5	0.204	33.6	0.172	0.4	0.1
03/31/24	06:00	44.2	0.222	32.9	0.168	0.4	0.1
03/31/24	07:00	46.4	0.228	33.0	0.165	0.3	0.2
03/31/24	08:00	52.3	0.258	31.4	0.158	0.3	0.1
03/31/24	09:00	43.6	0.212	32.1	0.159	0.3	0.1
03/31/24	10:00	44.8	0.218	33.0	0.164	0.3	0.1
03/31/24	11:00	46.3	0.228	32.0	0.160	0.3	0.1
03/31/24	12:00	43.1	0.214	32.5	0.164	0.3	0.1
03/31/24	13:00	44.7	0.219	33.4	0.166	0.3	0.1
03/31/24	14:00	56.5	0.266	36.4	0.174	0.3	0.1
03/31/24	15:00	44.3	0.224	32.0	0.164	0.3	0.1
03/31/24	16:00	37.4	0.190	33.6	0.174	0.4	0.1
03/31/24	17:00	44.0	0.224	31.8	0.164	0.3	0.1
03/31/24	18:00	49.5	0.250	32.3	0.165	0.3	0.1
03/31/24	19:00	42.5	0.219	31.3	0.164	0.3	0.1
03/31/24	20:00	41.4	0.207	31.7	0.162	0.3	0.1
03/31/24	21:00	40.9	0.207	31.7	0.163	0.3	0.1
03/31/24	22:00	39.8	0.198	32.8	0.165	0.3	0.1
03/31/24	23:00	41.2	0.204	32.3	0.163	0.3	0.1

Average	49.9	0.219	37.6	0.175	1.0	0.8
Minimum	9.1	0.029	22.3	0.113	0.3	0.1
Maximum	507.9	1.057	123.7	0.250	1.7	13.1
Summation	71,356.6	312.241	53,792.6	249.529	1,385.1	1,078.9
Geometric Mean	45.3	0.211	36.8	0.174	0.8	0.3
Included Data Points	1429	1429	1429	1429	1439	1429
Total number of Data Points	1440	1440	1440	1440	1440	1440

F = Unit Offline

E = Exceedance

M = Maintenance

T = Out Of Control

Report Generated: 04/11/24 11:45

C = Calibration

S = Substituted

*** = Suspect**

Attachment 6.0

Data download reports of Hourly and 24-hour data for NO_x from April 11, 2022 to February 1, 2024 (also attached in email as excel files).

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter	Unit		
04/11/22	00:00	47.1	0.162
04/11/22	01:00	47.0	0.162
04/11/22	02:00	47.0	0.162
04/11/22	03:00	46.9	0.161
04/11/22	04:00	46.2	0.161
04/11/22	05:00	44.2	0.159
04/11/22	06:00	44.3	0.160
04/11/22	07:00	44.5	0.160
04/11/22	08:00	44.6	0.160
04/11/22	09:00	44.5	0.160
04/11/22	10:00	45.5	0.161
04/11/22	11:00	46.8	0.160
04/11/22	12:00	48.1	0.158
04/11/22	13:00	49.4	0.155
04/11/22	14:00	51.3	0.155
04/11/22	15:00	53.7	0.157
04/11/22	16:00	55.9	0.157
04/11/22	17:00	57.8	0.158
04/11/22	18:00	58.6	0.160
04/11/22	19:00	58.9	0.161
04/11/22	20:00	60.3	0.163
04/11/22	21:00	62.9	0.164
04/11/22	22:00	65.6	0.166
04/11/22	23:00	67.3	0.166
04/12/22	00:00	67.4	0.167
04/12/22	01:00	67.4	0.167
04/12/22	02:00	67.3	0.166
04/12/22	03:00	68.1	0.167
04/12/22	04:00	70.5	0.167
04/12/22	05:00	72.3	0.168
04/12/22	06:00	72.2	0.168
04/12/22	07:00	72.7	0.169
04/12/22	08:00	73.6	0.171
04/12/22	09:00	74.6	0.173
04/12/22	10:00	75.4	0.175
04/12/22	11:00	75.9	0.176
04/12/22	12:00	76.3	0.177
04/12/22	13:00	76.8	0.178
04/12/22	14:00	76.7	0.178
04/12/22	15:00	76.6	0.177
04/12/22	16:00	76.3	0.177
04/12/22	17:00	75.9	0.176
04/12/22	18:00	75.4	0.175
04/12/22	19:00	74.5	0.174
04/12/22	20:00	72.2	0.172
04/12/22	21:00	69.7	0.172
04/12/22	22:00	67.3	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/12/22	23:00	65.8	0.171
04/13/22	00:00	66.0	0.172
04/13/22	01:00	66.2	0.173
04/13/22	02:00	66.4	0.174
04/13/22	03:00	65.8	0.175
04/13/22	04:00	64.4	0.175
04/13/22	05:00	64.8	0.176
04/13/22	06:00	64.9	0.176
04/13/22	07:00	63.9	0.175
04/13/22	08:00	61.8	0.175
04/13/22	09:00	59.6	0.175
04/13/22	10:00	57.6	0.175
04/13/22	11:00	55.9	0.176
04/13/22	12:00	54.0	0.176
04/13/22	13:00	52.2	0.177
04/13/22	14:00	50.5	0.178
04/13/22	15:00	48.6	0.178
04/13/22	16:00	46.8	0.179
04/13/22	17:00	45.1	0.180
04/13/22	18:00	43.5	0.181
04/13/22	19:00	42.4	0.182
04/13/22	20:00	42.6	0.183
04/13/22	21:00	42.6	0.183
04/13/22	22:00	42.6	0.183
04/13/22	23:00	42.6	0.183
04/14/22	00:00	42.5	0.182
04/14/22	01:00	42.4	0.182
04/14/22	02:00	42.4	0.181
04/14/22	03:00	42.3	0.180
04/14/22	04:00	41.3	0.180
04/14/22	05:00	38.9	0.180
04/14/22	06:00	37.0	0.180
04/14/22	07:00	35.6	0.180
04/14/22	08:00	35.5	0.180
04/14/22	09:00	35.6	0.180
04/14/22	10:00	35.6	0.180
04/14/22	11:00	35.6	0.180
04/14/22	12:00	35.6	0.180
04/14/22	13:00	35.5	0.180
04/14/22	14:00	35.5	0.180
04/14/22	15:00	35.5	0.180
04/14/22	16:00	35.4	0.180
04/14/22	17:00	35.2	0.179
04/14/22	18:00	35.0	0.178
04/14/22	19:00	34.8	0.178
04/14/22	20:00	34.7	0.177
04/14/22	21:00	34.5	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/14/22	22:00	34.3	0.176
04/14/22	23:00	34.2	0.176
04/15/22	00:00	34.0	0.175
04/15/22	01:00	33.9	0.174
04/15/22	02:00	33.8	0.174
04/15/22	03:00	33.7	0.174
04/15/22	04:00	33.5	0.173
04/15/22	05:00	33.3	0.172
04/15/22	06:00	33.2	0.172
04/15/22	07:00	33.1	0.172
04/15/22	08:00	33.0	0.172
04/15/22	09:00	32.9	0.172
04/15/22	10:00	32.9	0.172
04/15/22	11:00	32.8	0.172
04/15/22	12:00	32.8	0.172
04/15/22	13:00	32.7	0.172
04/15/22	14:00	32.5	0.171
04/15/22	15:00	32.5	0.171
04/15/22	16:00	32.5	0.171
04/15/22	17:00	32.5	0.171
04/15/22	18:00	32.7	0.170
04/15/22	19:00	35.1	0.172
04/15/22	20:00	37.4	0.172
04/15/22	21:00	39.4	0.172
04/15/22	22:00	41.6	0.173
04/15/22	23:00	43.1	0.173
04/16/22	00:00	43.3	0.174
04/16/22	01:00	43.4	0.174
04/16/22	02:00	43.3	0.174
04/16/22	03:00	43.4	0.175
04/16/22	04:00	43.5	0.175
04/16/22	05:00	43.5	0.175
04/16/22	06:00	43.6	0.175
04/16/22	07:00	43.6	0.175
04/16/22	08:00	43.6	0.175
04/16/22	09:00	43.6	0.175
04/16/22	10:00	43.6	0.174
04/16/22	11:00	43.6	0.174
04/16/22	12:00	43.6	0.174
04/16/22	13:00	43.8	0.175
04/16/22	14:00	43.8	0.175
04/16/22	15:00	44.5	0.175
04/16/22	16:00	47.1	0.176
04/16/22	17:00	49.4	0.177
04/16/22	18:00	51.5	0.178
04/16/22	19:00	51.4	0.177
04/16/22	20:00	51.3	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/16/22	21:00	51.7	0.178
04/16/22	22:00	51.7	0.178
04/16/22	23:00	52.6	0.179
04/17/22	00:00	54.8	0.180
04/17/22	01:00	57.0	0.180
04/17/22	02:00	59.4	0.181
04/17/22	03:00	61.8	0.181
04/17/22	04:00	64.2	0.182
04/17/22	05:00	66.6	0.183
04/17/22	06:00	68.6	0.183
04/17/22	07:00	70.8	0.183
04/17/22	08:00	72.9	0.183
04/17/22	09:00	75.1	0.184
04/17/22	10:00	77.2	0.184
04/17/22	11:00	79.4	0.185
04/17/22	12:00	81.6	0.185
04/17/22	13:00	83.6	0.185
04/17/22	14:00	85.8	0.186
04/17/22	15:00	87.2	0.186
04/17/22	16:00	86.8	0.185
04/17/22	17:00	86.8	0.185
04/17/22	18:00	86.7	0.185
04/17/22	19:00	86.7	0.185
04/17/22	20:00	86.6	0.185
04/17/22	21:00	86.7	0.185
04/17/22	22:00	86.8	0.185
04/17/22	23:00	86.6	0.185
04/18/22	00:00	86.4	0.185
04/18/22	01:00	86.4	0.185
04/18/22	02:00	86.3	0.184
04/18/22	03:00	86.3	0.185
04/18/22	04:00	86.1	0.184
04/18/22	05:00	85.6	0.184
04/18/22	06:00	85.5	0.183
04/18/22	07:00	86.1	0.184
04/18/22	08:00	86.1	0.184
04/18/22	09:00	85.9	0.184
04/18/22	10:00	85.8	0.184
04/18/22	11:00	85.9	0.184
04/18/22	12:00	85.8	0.184
04/18/22	13:00	85.9	0.184
04/18/22	14:00	85.5	0.184
04/18/22	15:00	85.4	0.184
04/18/22	16:00	85.3	0.184
04/18/22	17:00	85.1	0.184
04/18/22	18:00	84.7	0.184
04/18/22	19:00	84.5	0.184

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/18/22	20:00	84.3	0.184
04/18/22	21:00	84.3	0.185
04/18/22	22:00	84.0	0.184
04/18/22	23:00	83.8	0.185
04/19/22	00:00	83.4	0.184
04/19/22	01:00	83.0	0.184
04/19/22	02:00	80.8	0.183
04/19/22	03:00	78.5	0.182
04/19/22	04:00	76.7	0.181
04/19/22	05:00	76.7	0.181
04/19/22	06:00	77.0	0.181
04/19/22	07:00	74.7	0.178
04/19/22	08:00	72.0	0.177
04/19/22	09:00	70.0	0.177
04/19/22	10:00	68.0	0.177
04/19/22	11:00	65.9	0.176
04/19/22	12:00	63.6	0.176
04/19/22	13:00	61.5	0.175
04/19/22	14:00	59.9	0.176
04/19/22	15:00	57.7	0.174
04/19/22	16:00	55.5	0.173
04/19/22	17:00	53.5	0.172
04/19/22	18:00	52.6	0.170
04/19/22	19:00	52.8	0.170
04/19/22	20:00	53.1	0.170
04/19/22	21:00	53.3	0.170
04/19/22	22:00	53.3	0.169
04/19/22	23:00	53.1	0.168
04/20/22	00:00	53.5	0.168
04/20/22	01:00	54.2	0.169
04/20/22	02:00	56.5	0.170
04/20/22	03:00	58.8	0.171
04/20/22	04:00	60.6	0.172
04/20/22	05:00	60.4	0.172
04/20/22	06:00	59.8	0.171
04/20/22	07:00	61.9	0.173
04/20/22	08:00	63.4	0.172
04/20/22	09:00	64.7	0.171
04/20/22	10:00	66.2	0.170
04/20/22	11:00	68.0	0.170
04/20/22	12:00	70.0	0.170
04/20/22	13:00	72.2	0.171
04/20/22	14:00	74.2	0.170
04/20/22	15:00	76.2	0.171
04/20/22	16:00	78.2	0.171
04/20/22	17:00	79.3	0.171
04/20/22	18:00	78.0	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/20/22	19:00	75.9	0.171
04/20/22	20:00	73.7	0.171
04/20/22	21:00	71.2	0.170
04/20/22	22:00	69.3	0.170
04/20/22	23:00	67.3	0.171
04/21/22	00:00	65.1	0.171
04/21/22	01:00	62.9	0.170
04/21/22	02:00	60.5	0.170
04/21/22	03:00	58.3	0.169
04/21/22	04:00	56.0	0.168
04/21/22	05:00	54.1	0.169
04/21/22	06:00	52.6	0.170
04/21/22	07:00	50.9	0.171
04/21/22	08:00	49.4	0.172
04/21/22	09:00	48.1	0.174
04/21/22	10:00	46.8	0.175
04/21/22	11:00	45.1	0.176
04/21/22	12:00	43.2	0.176
04/21/22	13:00	40.9	0.176
04/21/22	14:00	38.7	0.175
04/21/22	15:00	36.8	0.176
04/21/22	16:00	35.1	0.176
04/21/22	17:00	35.7	0.177
04/21/22	18:00	38.1	0.178
04/21/22	19:00	39.8	0.177
04/21/22	20:00	41.7	0.177
04/21/22	21:00	43.9	0.178
04/21/22	22:00	46.3	0.178
04/21/22	23:00	48.5	0.179
04/22/22	00:00	50.5	0.179
04/22/22	01:00	52.8	0.179
04/22/22	02:00	55.0	0.180
04/22/22	03:00	57.2	0.180
04/22/22	04:00	59.3	0.180
04/22/22	05:00	61.3	0.180
04/22/22	06:00	63.0	0.180
04/22/22	07:00	64.8	0.179
04/22/22	08:00	66.6	0.179
04/22/22	09:00	68.5	0.178
04/22/22	10:00	70.5	0.178
04/22/22	11:00	72.3	0.178
04/22/22	12:00	74.3	0.177
04/22/22	13:00	76.4	0.178
04/22/22	14:00	78.4	0.178
04/22/22	15:00	80.3	0.178
04/22/22	16:00	82.0	0.177
04/22/22	17:00	82.2	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/22/22	18:00	82.1	0.177
04/22/22	19:00	82.5	0.178
04/22/22	20:00	82.8	0.179
04/22/22	21:00	82.0	0.178
04/22/22	22:00	79.4	0.176
04/22/22	23:00	77.2	0.176
04/23/22	00:00	75.2	0.176
04/23/22	01:00	72.9	0.175
04/23/22	02:00	70.7	0.175
04/23/22	03:00	68.5	0.174
04/23/22	04:00	66.4	0.174
04/23/22	05:00	64.3	0.173
04/23/22	06:00	62.4	0.173
04/23/22	07:00	60.4	0.174
04/23/22	08:00	58.6	0.174
04/23/22	09:00	56.7	0.174
04/23/22	10:00	54.5	0.174
04/23/22	11:00	52.5	0.173
04/23/22	12:00	50.7	0.172
04/23/22	13:00	50.5	0.171
04/23/22	14:00	50.4	0.171
04/23/22	15:00	50.4	0.170
04/23/22	16:00	50.4	0.170
04/23/22	17:00	50.5	0.170
04/23/22	18:00	50.6	0.170
04/23/22	19:00	50.6	0.170
04/23/22	20:00	50.7	0.170
04/23/22	21:00	50.5	0.170
04/23/22	22:00	50.5	0.170
04/23/22	23:00	50.5	0.170
04/24/22	00:00	50.4	0.170
04/24/22	01:00	50.4	0.169
04/24/22	02:00	50.3	0.169
04/24/22	03:00	50.4	0.170
04/24/22	04:00	50.4	0.170
04/24/22	05:00	50.5	0.170
04/24/22	06:00	50.5	0.171
04/24/22	07:00	50.5	0.171
04/24/22	08:00	50.4	0.170
04/24/22	09:00	50.3	0.170
04/24/22	10:00	50.3	0.170
04/24/22	11:00	50.3	0.170
04/24/22	12:00	50.0	0.172
04/24/22	13:00	48.1	0.172
04/24/22	14:00	46.2	0.172
04/24/22	15:00	44.3	0.172
04/24/22	16:00	42.3	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/24/22	17:00	40.1	0.172
04/24/22	18:00	38.0	0.171
04/24/22	19:00	35.8	0.170
04/24/22	20:00	33.6	0.170
04/24/22	21:00	32.4	0.171
04/24/22	22:00	32.5	0.171
04/24/22	23:00	32.4	0.171
04/25/22	00:00	32.4	0.171
04/25/22	01:00	32.4	0.171
04/25/22	02:00	32.5	0.171
04/25/22	03:00	32.5	0.171
04/25/22	04:00	33.0	0.170
04/25/22	05:00	35.1	0.171
04/25/22	06:00	37.3	0.171
04/25/22	07:00	39.7	0.171
04/25/22	08:00	42.1	0.172
04/25/22	09:00	44.4	0.172
04/25/22	10:00	46.8	0.173
04/25/22	11:00	49.1	0.174
04/25/22	12:00	51.2	0.174
04/25/22	13:00	51.4	0.174
04/25/22	14:00	51.3	0.174
04/25/22	15:00	51.3	0.173
04/25/22	16:00	51.4	0.174
04/25/22	17:00	51.6	0.175
04/25/22	18:00	51.8	0.176
04/25/22	19:00	51.9	0.177
04/25/22	20:00	52.0	0.177
04/25/22	21:00	52.0	0.177
04/25/22	22:00	52.0	0.178
04/25/22	23:00	52.1	0.178
04/26/22	00:00	52.2	0.179
04/26/22	01:00	52.3	0.179
04/26/22	02:00	52.2	0.178
04/26/22	03:00	52.9	0.178
04/26/22	04:00	55.3	0.181
04/26/22	05:00	55.5	0.182
04/26/22	06:00	55.5	0.182
04/26/22	07:00	55.3	0.181
04/26/22	08:00	55.1	0.181
04/26/22	09:00	55.1	0.181
04/26/22	10:00	55.2	0.181
04/26/22	11:00	53.8	0.180
04/26/22	12:00	51.7	0.180
04/26/22	13:00	51.6	0.180
04/26/22	14:00	51.7	0.181
04/26/22	15:00	51.9	0.182

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/26/22	16:00	51.9	0.182
04/26/22	17:00	52.2	0.180
04/26/22	18:00	54.5	0.181
04/26/22	19:00	56.7	0.180
04/26/22	20:00	59.1	0.181
04/26/22	21:00	61.5	0.181
04/26/22	22:00	63.2	0.181
04/26/22	23:00	63.2	0.180
04/27/22	00:00	63.1	0.180
04/27/22	01:00	62.9	0.179
04/27/22	02:00	62.9	0.179
04/27/22	03:00	62.8	0.178
04/27/22	04:00	62.3	0.177
04/27/22	05:00	62.2	0.176
04/27/22	06:00	62.3	0.177
04/27/22	07:00	62.5	0.177
04/27/22	08:00	62.6	0.177
04/27/22	09:00	62.4	0.177
04/27/22	10:00	62.2	0.176
04/27/22	11:00	63.4	0.177
04/27/22	12:00	65.6	0.178
04/27/22	13:00	68.0	0.179
04/27/22	14:00	70.1	0.179
04/27/22	15:00	72.2	0.179
04/27/22	16:00	74.3	0.179
04/27/22	17:00	76.0	0.180
04/27/22	18:00	75.7	0.179
04/27/22	19:00	75.5	0.179
04/27/22	20:00	75.2	0.179
04/27/22	21:00	75.0	0.179
04/27/22	22:00	74.8	0.179
04/27/22	23:00	74.8	0.179
04/28/22	00:00	74.8	0.179
04/28/22	01:00	74.8	0.179
04/28/22	02:00	74.8	0.180
04/28/22	03:00	74.6	0.179
04/28/22	04:00	74.4	0.178
04/28/22	05:00	74.2	0.178
04/28/22	06:00	73.9	0.178
04/28/22	07:00	73.7	0.178
04/28/22	08:00	73.5	0.177
04/28/22	09:00	73.4	0.177
04/28/22	10:00	73.7	0.178
04/28/22	11:00	73.9	0.179
04/28/22	12:00	74.0	0.179
04/28/22	13:00	73.8	0.179
04/28/22	14:00	73.9	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/28/22	15:00	73.6	0.178
04/28/22	16:00	73.4	0.178
04/28/22	17:00	73.0	0.177
04/28/22	18:00	73.0	0.177
04/28/22	19:00	72.8	0.177
04/28/22	20:00	72.6	0.176
04/28/22	21:00	72.6	0.176
04/28/22	22:00	73.0	0.176
04/28/22	23:00	74.6	0.176
04/29/22	00:00	74.6	0.176
04/29/22	01:00	74.6	0.177
04/29/22	02:00	74.6	0.177
04/29/22	03:00	74.2	0.177
04/29/22	04:00	72.7	0.176
04/29/22	05:00	72.7	0.176
04/29/22	06:00	72.8	0.177
04/29/22	07:00	72.6	0.176
04/29/22	08:00	72.4	0.176
04/29/22	09:00	72.4	0.176
04/29/22	10:00	71.7	0.174
04/29/22	11:00	71.3	0.174
04/29/22	12:00	70.9	0.173
04/29/22	13:00	70.8	0.173
04/29/22	14:00	70.4	0.172
04/29/22	15:00	70.5	0.172
04/29/22	16:00	70.5	0.172
04/29/22	17:00	70.8	0.173
04/29/22	18:00	70.7	0.172
04/29/22	19:00	70.7	0.172
04/29/22	20:00	70.0	0.171
04/29/22	21:00	67.8	0.170
04/29/22	22:00	65.8	0.170
04/29/22	23:00	64.1	0.170
04/30/22	00:00	64.0	0.170
04/30/22	01:00	63.9	0.169
04/30/22	02:00	63.9	0.169
04/30/22	03:00	63.9	0.169
04/30/22	04:00	63.1	0.169
04/30/22	05:00	61.0	0.169
04/30/22	06:00	58.8	0.168
04/30/22	07:00	57.2	0.168
04/30/22	08:00	57.6	0.169
04/30/22	09:00	57.8	0.169
04/30/22	10:00	58.1	0.169
04/30/22	11:00	56.9	0.168
04/30/22	12:00	54.9	0.166
04/30/22	13:00	52.8	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
04/30/22	14:00	51.3	0.166
04/30/22	15:00	51.4	0.166
04/30/22	16:00	51.4	0.166
04/30/22	17:00	51.4	0.166
04/30/22	18:00	51.7	0.166
04/30/22	19:00	52.3	0.168
04/30/22	20:00	53.5	0.169
04/30/22	21:00	55.7	0.172
04/30/22	22:00	56.1	0.173
04/30/22	23:00	56.2	0.172
05/01/22	00:00	56.2	0.172
05/01/22	01:00	56.3	0.173
05/01/22	02:00	56.4	0.173
05/01/22	03:00	56.5	0.173
05/01/22	04:00	56.5	0.174
05/01/22	05:00	56.5	0.174
05/01/22	06:00	56.5	0.173
05/01/22	07:00	56.1	0.174
05/01/22	08:00	53.8	0.173
05/01/22	09:00	51.7	0.173
05/01/22	10:00	49.7	0.172
05/01/22	11:00	48.8	0.174
05/01/22	12:00	49.3	0.174
05/01/22	13:00	51.5	0.174
05/01/22	14:00	53.4	0.175
05/01/22	15:00	53.6	0.175
05/01/22	16:00	53.8	0.175
05/01/22	17:00	53.8	0.175
05/01/22	18:00	53.5	0.175
05/01/22	19:00	53.1	0.174
05/01/22	20:00	52.9	0.173
05/01/22	21:00	53.3	0.173
05/01/22	22:00	54.9	0.173
05/01/22	23:00	54.9	0.172
05/02/22	00:00	55.0	0.173
05/02/22	01:00	55.0	0.173
05/02/22	02:00	54.9	0.173
05/02/22	03:00	54.9	0.173
05/02/22	04:00	55.8	0.174
05/02/22	05:00	58.3	0.176
05/02/22	06:00	60.1	0.175
05/02/22	07:00	62.3	0.175
05/02/22	08:00	64.4	0.176
05/02/22	09:00	66.6	0.176
05/02/22	10:00	68.9	0.177
05/02/22	11:00	71.0	0.178
05/02/22	12:00	72.5	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/02/22	13:00	72.5	0.178
05/02/22	14:00	72.2	0.178
05/02/22	15:00	71.9	0.178
05/02/22	16:00	71.7	0.177
05/02/22	17:00	71.5	0.177
05/02/22	18:00	71.6	0.177
05/02/22	19:00	71.5	0.177
05/02/22	20:00	71.3	0.177
05/02/22	21:00	71.0	0.176
05/02/22	22:00	71.5	0.176
05/02/22	23:00	73.9	0.178
05/03/22	00:00	76.3	0.179
05/03/22	01:00	78.3	0.179
05/03/22	02:00	80.6	0.180
05/03/22	03:00	82.8	0.180
05/03/22	04:00	83.9	0.179
05/03/22	05:00	83.2	0.177
05/03/22	06:00	83.2	0.177
05/03/22	07:00	83.1	0.177
05/03/22	08:00	82.9	0.177
05/03/22	09:00	82.6	0.176
05/03/22	10:00	82.4	0.176
05/03/22	11:00	82.4	0.176
05/03/22	12:00	82.6	0.176
05/03/22	13:00	82.8	0.176
05/03/22	14:00	82.8	0.176
05/03/22	15:00	82.5	0.175
05/03/22	16:00	81.7	0.173
05/03/22	17:00	81.1	0.172
05/03/22	18:00	80.0	0.171
05/03/22	19:00	78.7	0.170
05/03/22	20:00	78.6	0.169
05/03/22	21:00	78.7	0.169
05/03/22	22:00	78.5	0.169
05/03/22	23:00	77.7	0.168
05/04/22	00:00	75.4	0.167
05/04/22	01:00	73.2	0.167
05/04/22	02:00	70.9	0.166
05/04/22	03:00	68.7	0.165
05/04/22	04:00	67.2	0.164
05/04/22	05:00	67.6	0.164
05/04/22	06:00	68.0	0.165
05/04/22	07:00	67.9	0.165
05/04/22	08:00	68.2	0.165
05/04/22	09:00	68.6	0.166
05/04/22	10:00	68.8	0.166
05/04/22	11:00	68.9	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/04/22	12:00	68.9	0.167
05/04/22	13:00	68.9	0.167
05/04/22	14:00	69.1	0.168
05/04/22	15:00	69.6	0.169
05/04/22	16:00	70.7	0.171
05/04/22	17:00	71.6	0.173
05/04/22	18:00	72.8	0.174
05/04/22	19:00	74.1	0.176
05/04/22	20:00	74.3	0.176
05/04/22	21:00	74.4	0.176
05/04/22	22:00	74.3	0.176
05/04/22	23:00	75.1	0.177
05/05/22	00:00	77.5	0.178
05/05/22	01:00	80.0	0.179
05/05/22	02:00	82.7	0.181
05/05/22	03:00	85.2	0.183
05/05/22	04:00	87.1	0.184
05/05/22	05:00	87.2	0.185
05/05/22	06:00	87.3	0.185
05/05/22	07:00	88.0	0.187
05/05/22	08:00	88.0	0.187
05/05/22	09:00	88.1	0.187
05/05/22	10:00	88.0	0.186
05/05/22	11:00	87.4	0.185
05/05/22	12:00	87.2	0.185
05/05/22	13:00	86.9	0.184
05/05/22	14:00	86.8	0.184
05/05/22	15:00	86.6	0.183
05/05/22	16:00	86.3	0.183
05/05/22	17:00	86.2	0.182
05/05/22	18:00	85.9	0.182
05/05/22	19:00	85.8	0.182
05/05/22	20:00	85.9	0.182
05/05/22	21:00	85.6	0.181
05/05/22	22:00	85.7	0.181
05/05/22	23:00	85.8	0.181
05/06/22	00:00	85.7	0.181
05/06/22	01:00	85.7	0.181
05/06/22	02:00	85.4	0.180
05/06/22	03:00	85.3	0.180
05/06/22	04:00	85.0	0.180
05/06/22	05:00	84.7	0.179
05/06/22	06:00	84.4	0.179
05/06/22	07:00	84.0	0.178
05/06/22	08:00	84.1	0.178
05/06/22	09:00	84.0	0.178
05/06/22	10:00	84.1	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/06/22	11:00	84.3	0.179
05/06/22	12:00	84.6	0.179
05/06/22	13:00	84.8	0.180
05/06/22	14:00	85.0	0.180
05/06/22	15:00	84.9	0.180
05/06/22	16:00	85.2	0.181
05/06/22	17:00	85.3	0.181
05/06/22	18:00	85.5	0.181
05/06/22	19:00	85.7	0.182
05/06/22	20:00	85.7	0.182
05/06/22	21:00	86.0	0.182
05/06/22	22:00	86.2	0.183
05/06/22	23:00	86.0	0.182
05/07/22	00:00	85.9	0.182
05/07/22	01:00	83.6	0.181
05/07/22	02:00	81.3	0.181
05/07/22	03:00	79.0	0.180
05/07/22	04:00	76.8	0.180
05/07/22	05:00	74.8	0.180
05/07/22	06:00	72.9	0.180
05/07/22	07:00	70.7	0.180
05/07/22	08:00	69.3	0.181
05/07/22	09:00	70.2	0.183
05/07/22	10:00	70.8	0.184
05/07/22	11:00	71.0	0.184
05/07/22	12:00	70.9	0.184
05/07/22	13:00	70.6	0.184
05/07/22	14:00	70.5	0.184
05/07/22	15:00	70.6	0.184
05/07/22	16:00	70.4	0.184
05/07/22	17:00	70.5	0.184
05/07/22	18:00	70.5	0.185
05/07/22	19:00	70.3	0.184
05/07/22	20:00	70.4	0.184
05/07/22	21:00	70.4	0.185
05/07/22	22:00	69.2	0.184
05/07/22	23:00	66.9	0.183
05/08/22	00:00	64.7	0.182
05/08/22	01:00	64.5	0.182
05/08/22	02:00	64.5	0.182
05/08/22	03:00	64.5	0.182
05/08/22	04:00	64.5	0.182
05/08/22	05:00	64.5	0.182
05/08/22	06:00	64.5	0.182
05/08/22	07:00	64.4	0.182
05/08/22	08:00	63.6	0.181
05/08/22	09:00	60.5	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/08/22	10:00	57.9	0.177
05/08/22	11:00	57.7	0.178
05/08/22	12:00	58.2	0.179
05/08/22	13:00	58.4	0.179
05/08/22	14:00	58.4	0.179
05/08/22	15:00	58.6	0.179
05/08/22	16:00	58.7	0.179
05/08/22	17:00	58.8	0.180
05/08/22	18:00	59.0	0.180
05/08/22	19:00	59.1	0.180
05/08/22	20:00	58.9	0.180
05/08/22	21:00	58.6	0.179
05/08/22	22:00	58.7	0.179
05/08/22	23:00	58.6	0.179
05/09/22	00:00	58.6	0.179
05/09/22	01:00	58.6	0.178
05/09/22	02:00	58.7	0.179
05/09/22	03:00	58.7	0.179
05/09/22	04:00	58.6	0.178
05/09/22	05:00	59.1	0.178
05/09/22	06:00	61.4	0.178
05/09/22	07:00	63.8	0.179
05/09/22	08:00	65.4	0.178
05/09/22	09:00	67.0	0.178
05/09/22	10:00	68.4	0.177
05/09/22	11:00	68.1	0.175
05/09/22	12:00	67.4	0.174
05/09/22	13:00	66.9	0.173
05/09/22	14:00	66.6	0.173
05/09/22	15:00	66.0	0.171
05/09/22	16:00	65.4	0.170
05/09/22	17:00	64.8	0.169
05/09/22	18:00	64.3	0.168
05/09/22	19:00	64.2	0.168
05/09/22	20:00	64.2	0.168
05/09/22	21:00	64.1	0.168
05/09/22	22:00	65.0	0.169
05/09/22	23:00	67.5	0.170
05/10/22	00:00	69.1	0.171
05/10/22	01:00	69.3	0.172
05/10/22	02:00	69.1	0.171
05/10/22	03:00	69.0	0.171
05/10/22	04:00	69.9	0.172
05/10/22	05:00	71.3	0.172
05/10/22	06:00	71.0	0.171
05/10/22	07:00	70.4	0.170
05/10/22	08:00	70.5	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/10/22	09:00	70.7	0.171
05/10/22	10:00	70.7	0.171
05/10/22	11:00	70.9	0.171
05/10/22	12:00	71.1	0.171
05/10/22	13:00	71.2	0.171
05/10/22	14:00	71.1	0.171
05/10/22	15:00	71.2	0.171
05/10/22	16:00	71.4	0.172
05/10/22	17:00	71.5	0.172
05/10/22	18:00	71.5	0.172
05/10/22	19:00	71.4	0.171
05/10/22	20:00	71.5	0.172
05/10/22	21:00	71.9	0.173
05/10/22	22:00	71.8	0.173
05/10/22	23:00	71.8	0.172
05/11/22	00:00	72.8	0.173
05/11/22	01:00	74.1	0.174
05/11/22	02:00	74.4	0.174
05/11/22	03:00	74.4	0.174
05/11/22	04:00	73.9	0.172
05/11/22	05:00	74.1	0.173
05/11/22	06:00	73.9	0.173
05/11/22	07:00	74.2	0.173
05/11/22	08:00	74.3	0.173
05/11/22	09:00	74.4	0.174
05/11/22	10:00	74.7	0.174
05/11/22	11:00	75.2	0.175
05/11/22	12:00	75.6	0.176
05/11/22	13:00	75.9	0.177
05/11/22	14:00	75.9	0.177
05/11/22	15:00	76.2	0.177
05/11/22	16:00	76.2	0.177
05/11/22	17:00	76.1	0.177
05/11/22	18:00	76.0	0.176
05/11/22	19:00	76.2	0.177
05/11/22	20:00	75.8	0.176
05/11/22	21:00	75.4	0.175
05/11/22	22:00	75.8	0.176
05/11/22	23:00	76.0	0.177
05/12/22	00:00	75.8	0.177
05/12/22	01:00	75.8	0.177
05/12/22	02:00	75.5	0.175
05/12/22	03:00	75.4	0.175
05/12/22	04:00	76.1	0.177
05/12/22	05:00	76.6	0.178
05/12/22	06:00	76.9	0.179
05/12/22	07:00	77.0	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/12/22	08:00	77.2	0.179
05/12/22	09:00	77.2	0.180
05/12/22	10:00	77.1	0.180
05/12/22	11:00	76.7	0.179
05/12/22	12:00	76.3	0.178
05/12/22	13:00	76.1	0.177
05/12/22	14:00	76.3	0.178
05/12/22	15:00	76.2	0.178
05/12/22	16:00	75.8	0.177
05/12/22	17:00	75.8	0.177
05/12/22	18:00	75.9	0.178
05/12/22	19:00	75.8	0.178
05/12/22	20:00	75.9	0.178
05/12/22	21:00	76.2	0.178
05/12/22	22:00	76.2	0.178
05/12/22	23:00	76.5	0.178
05/13/22	00:00	76.0	0.178
05/13/22	01:00	74.6	0.177
05/13/22	02:00	74.6	0.177
05/13/22	03:00	74.6	0.177
05/13/22	04:00	74.4	0.176
05/13/22	05:00	74.9	0.177
05/13/22	06:00	75.2	0.177
05/13/22	07:00	75.2	0.177
05/13/22	08:00	75.4	0.178
05/13/22	09:00	75.7	0.178
05/13/22	10:00	76.1	0.179
05/13/22	11:00	76.6	0.180
05/13/22	12:00	77.0	0.180
05/13/22	13:00	77.3	0.181
05/13/22	14:00	77.3	0.181
05/13/22	15:00	77.4	0.181
05/13/22	16:00	77.8	0.182
05/13/22	17:00	78.1	0.182
05/13/22	18:00	78.4	0.183
05/13/22	19:00	78.6	0.183
05/13/22	20:00	78.6	0.183
05/13/22	21:00	78.4	0.182
05/13/22	22:00	78.1	0.182
05/13/22	23:00	77.7	0.181
05/14/22	00:00	78.3	0.181
05/14/22	01:00	80.9	0.183
05/14/22	02:00	83.4	0.184
05/14/22	03:00	85.6	0.186
05/14/22	04:00	86.7	0.186
05/14/22	05:00	85.5	0.184
05/14/22	06:00	84.9	0.183

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/14/22	07:00	84.2	0.181
05/14/22	08:00	83.3	0.179
05/14/22	09:00	82.4	0.177
05/14/22	10:00	81.7	0.176
05/14/22	11:00	81.0	0.174
05/14/22	12:00	80.6	0.174
05/14/22	13:00	80.4	0.173
05/14/22	14:00	80.2	0.173
05/14/22	15:00	80.2	0.173
05/14/22	16:00	80.5	0.173
05/14/22	17:00	80.6	0.173
05/14/22	18:00	80.6	0.173
05/14/22	19:00	80.2	0.173
05/14/22	20:00	79.8	0.173
05/14/22	21:00	78.8	0.171
05/14/22	22:00	78.0	0.170
05/14/22	23:00	77.1	0.170
05/15/22	00:00	76.6	0.169
05/15/22	01:00	76.1	0.168
05/15/22	02:00	75.1	0.167
05/15/22	03:00	73.1	0.166
05/15/22	04:00	71.1	0.165
05/15/22	05:00	69.2	0.164
05/15/22	06:00	68.0	0.164
05/15/22	07:00	67.5	0.163
05/15/22	08:00	66.9	0.161
05/15/22	09:00	67.0	0.161
05/15/22	10:00	67.2	0.162
05/15/22	11:00	67.2	0.161
05/15/22	12:00	66.9	0.161
05/15/22	13:00	66.8	0.160
05/15/22	14:00	66.6	0.160
05/15/22	15:00	65.9	0.158
05/15/22	16:00	65.2	0.157
05/15/22	17:00	64.6	0.155
05/15/22	18:00	64.0	0.154
05/15/22	19:00	63.9	0.153
05/15/22	20:00	63.9	0.152
05/15/22	21:00	64.2	0.152
05/15/22	22:00	64.8	0.153
05/15/22	23:00	65.1	0.153
05/16/22	00:00	63.2	0.152
05/16/22	01:00	61.0	0.150
05/16/22	02:00	59.6	0.150
05/16/22	03:00	59.5	0.150
05/16/22	04:00	59.9	0.149
05/16/22	05:00	61.8	0.150

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
05/16/22	06:00		62.8	0.149
05/16/22	07:00		63.2	0.151
05/16/22	08:00		64.0	0.152
05/16/22	09:00		64.4	0.153
05/16/22	10:00		64.6	0.153
05/16/22	11:00		64.9	0.154
05/16/22	12:00		65.1	0.154
05/16/22	13:00		65.1	0.154
05/16/22	14:00		64.9	0.154
05/16/22	15:00		65.2	0.154
05/16/22	16:00		65.4	0.155
05/16/22	17:00		65.5	0.155
05/16/22	18:00		65.6	0.156
05/16/22	19:00		65.7	0.156
05/16/22	20:00		66.0	0.157
05/16/22	21:00		66.3	0.158
05/16/22	22:00		65.9	0.157
05/16/22	23:00		65.5	0.156
05/17/22	00:00		65.4	0.155
05/17/22	01:00		65.5	0.156
05/17/22	02:00		65.5	0.156
05/17/22	03:00		65.6	0.157
05/17/22	04:00		65.3	0.158
05/17/22	05:00		64.1	0.158
05/17/22	06:00		64.5	0.159
05/17/22	07:00		64.9	0.160
05/17/22	08:00		65.6	0.163
05/17/22	09:00		65.0	0.162
05/17/22	10:00		64.5	0.161
05/17/22	11:00		63.6	0.159
05/17/22	12:00		63.6	0.159
05/17/22	13:00		64.0	0.160
05/17/22	14:00		64.2	0.161
05/17/22	15:00		64.2	0.161
05/17/22	16:00		64.2	0.161
05/17/22	17:00		63.9	0.160
05/17/22	18:00		63.8	0.160
05/17/22	19:00		63.8	0.161
05/17/22	20:00		64.2	0.162
05/17/22	21:00		64.6	0.163
05/17/22	22:00		64.7	0.163
05/17/22	23:00		65.4	0.164
05/18/22	00:00		65.3	0.165
05/18/22	01:00		65.6	0.167
05/18/22	02:00		65.5	0.166
05/18/22	03:00		65.4	0.166
05/18/22	04:00		66.3	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/18/22	05:00	68.4	0.167
05/18/22	06:00	70.0	0.168
05/18/22	07:00	70.4	0.169
05/18/22	08:00	70.9	0.170
05/18/22	09:00	71.3	0.170
05/18/22	10:00	71.3	0.170
05/18/22	11:00	71.9	0.171
05/18/22	12:00	73.2	0.174
05/18/22	13:00	74.3	0.176
05/18/22	14:00	73.9	0.175
05/18/22	15:00	73.9	0.175
05/18/22	16:00	74.2	0.175
05/18/22	17:00	74.5	0.176
05/18/22	18:00	75.3	0.177
05/18/22	19:00	75.9	0.178
05/18/22	20:00	76.3	0.179
05/18/22	21:00	76.6	0.180
05/18/22	22:00	77.1	0.180
05/18/22	23:00	77.5	0.181
05/19/22	00:00	77.4	0.181
05/19/22	01:00	78.2	0.181
05/19/22	02:00	80.6	0.182
05/19/22	03:00	83.2	0.183
05/19/22	04:00	85.4	0.183
05/19/22	05:00	86.7	0.183
05/19/22	06:00	86.7	0.183
05/19/22	07:00	86.5	0.182
05/19/22	08:00	85.9	0.181
05/19/22	09:00	85.2	0.180
05/19/22	10:00	84.1	0.177
05/19/22	11:00	83.8	0.177
05/19/22	12:00	82.5	0.174
05/19/22	13:00	82.6	0.174
05/19/22	14:00	82.8	0.175
05/19/22	15:00	83.1	0.176
05/19/22	16:00	83.4	0.176
05/19/22	17:00	83.7	0.177
05/19/22	18:00	83.5	0.176
05/19/22	19:00	83.3	0.176
05/19/22	20:00	83.4	0.176
05/19/22	21:00	83.2	0.176
05/19/22	22:00	83.1	0.176
05/19/22	23:00	82.8	0.175
05/20/22	00:00	81.8	0.174
05/20/22	01:00	79.4	0.173
05/20/22	02:00	76.9	0.172
05/20/22	03:00	74.2	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/20/22	04:00	72.7	0.171
05/20/22	05:00	72.7	0.171
05/20/22	06:00	72.4	0.170
05/20/22	07:00	72.2	0.170
05/20/22	08:00	72.2	0.170
05/20/22	09:00	72.8	0.171
05/20/22	10:00	73.5	0.172
05/20/22	11:00	74.1	0.174
05/20/22	12:00	74.6	0.174
05/20/22	13:00	74.7	0.175
05/20/22	14:00	74.6	0.175
05/20/22	15:00	74.2	0.174
05/20/22	16:00	73.9	0.173
05/20/22	17:00	73.8	0.173
05/20/22	18:00	73.8	0.173
05/20/22	19:00	73.8	0.173
05/20/22	20:00	73.6	0.173
05/20/22	21:00	73.8	0.173
05/20/22	22:00	74.2	0.174
05/20/22	23:00	74.4	0.174
05/21/22	00:00	75.7	0.176
05/21/22	01:00	77.5	0.177
05/21/22	02:00	77.6	0.177
05/21/22	03:00	77.5	0.176
05/21/22	04:00	76.8	0.175
05/21/22	05:00	75.2	0.175
05/21/22	06:00	75.6	0.176
05/21/22	07:00	76.0	0.177
05/21/22	08:00	76.0	0.176
05/21/22	09:00	75.7	0.176
05/21/22	10:00	74.9	0.174
05/21/22	11:00	73.8	0.173
05/21/22	12:00	73.3	0.172
05/21/22	13:00	72.7	0.172
05/21/22	14:00	72.3	0.171
05/21/22	15:00	72.5	0.171
05/21/22	16:00	72.7	0.172
05/21/22	17:00	72.8	0.172
05/21/22	18:00	72.8	0.172
05/21/22	19:00	72.9	0.172
05/21/22	20:00	72.8	0.172
05/21/22	21:00	72.7	0.172
05/21/22	22:00	72.5	0.171
05/21/22	23:00	72.4	0.171
05/22/22	00:00	72.4	0.171
05/22/22	01:00	73.2	0.172
05/22/22	02:00	74.9	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/22/22	03:00	74.9	0.173
05/22/22	04:00	75.1	0.174
05/22/22	05:00	74.4	0.173
05/22/22	06:00	71.9	0.172
05/22/22	07:00	69.7	0.172
05/22/22	08:00	68.9	0.171
05/22/22	09:00	69.0	0.172
05/22/22	10:00	69.0	0.171
05/22/22	11:00	69.9	0.172
05/22/22	12:00	70.6	0.173
05/22/22	13:00	70.9	0.174
05/22/22	14:00	71.3	0.175
05/22/22	15:00	71.1	0.175
05/22/22	16:00	70.9	0.174
05/22/22	17:00	70.8	0.174
05/22/22	18:00	70.6	0.174
05/22/22	19:00	70.6	0.174
05/22/22	20:00	70.3	0.174
05/22/22	21:00	70.3	0.174
05/22/22	22:00	70.3	0.174
05/22/22	23:00	69.5	0.174
05/23/22	00:00	67.0	0.173
05/23/22	01:00	64.4	0.172
05/23/22	02:00	62.7	0.171
05/23/22	03:00	62.6	0.172
05/23/22	04:00	63.2	0.172
05/23/22	05:00	65.3	0.172
05/23/22	06:00	67.4	0.173
05/23/22	07:00	69.9	0.174
05/23/22	08:00	70.7	0.175
05/23/22	09:00	69.7	0.174
05/23/22	10:00	68.8	0.174
05/23/22	11:00	68.0	0.174
05/23/22	12:00	67.4	0.174
05/23/22	13:00	67.2	0.174
05/23/22	14:00	67.2	0.174
05/23/22	15:00	67.1	0.174
05/23/22	16:00	67.2	0.174
05/23/22	17:00	67.2	0.175
05/23/22	18:00	67.4	0.175
05/23/22	19:00	67.3	0.175
05/23/22	20:00	67.7	0.176
05/23/22	21:00	67.7	0.176
05/23/22	22:00	67.6	0.176
05/23/22	23:00	67.5	0.176
05/24/22	00:00	67.6	0.176
05/24/22	01:00	67.6	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/24/22	02:00	67.6	0.177
05/24/22	03:00	67.6	0.177
05/24/22	04:00	67.6	0.177
05/24/22	05:00	67.2	0.176
05/24/22	06:00	67.6	0.176
05/24/22	07:00	67.6	0.176
05/24/22	08:00	67.8	0.177
05/24/22	09:00	68.6	0.178
05/24/22	10:00	68.9	0.179
05/24/22	11:00	69.0	0.179
05/24/22	12:00	68.1	0.179
05/24/22	13:00	66.2	0.179
05/24/22	14:00	64.5	0.178
05/24/22	15:00	65.3	0.180
05/24/22	16:00	65.5	0.180
05/24/22	17:00	65.4	0.180
05/24/22	18:00	65.4	0.180
05/24/22	19:00	65.5	0.180
05/24/22	20:00	65.7	0.180
05/24/22	21:00	65.7	0.180
05/24/22	22:00	65.9	0.181
05/24/22	23:00	66.0	0.181
05/25/22	00:00	65.9	0.180
05/25/22	01:00	65.8	0.179
05/25/22	02:00	65.7	0.178
05/25/22	03:00	66.5	0.179
05/25/22	04:00	68.8	0.180
05/25/22	05:00	69.6	0.182
05/25/22	06:00	68.6	0.181
05/25/22	07:00	67.3	0.179
05/25/22	08:00	66.8	0.178
05/25/22	09:00	66.8	0.178
05/25/22	10:00	67.9	0.178
05/25/22	11:00	68.6	0.177
05/25/22	12:00	70.0	0.177
05/25/22	13:00	72.0	0.177
05/25/22	14:00	74.0	0.178
05/25/22	15:00	73.5	0.177
05/25/22	16:00	73.4	0.176
05/25/22	17:00	73.8	0.177
05/25/22	18:00	73.8	0.176
05/25/22	19:00	74.0	0.177
05/25/22	20:00	74.0	0.176
05/25/22	21:00	73.9	0.176
05/25/22	22:00	73.9	0.176
05/25/22	23:00	74.8	0.176
05/26/22	00:00	76.7	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/26/22	01:00	76.7	0.177
05/26/22	02:00	76.8	0.176
05/26/22	03:00	76.1	0.176
05/26/22	04:00	73.8	0.173
05/26/22	05:00	73.3	0.172
05/26/22	06:00	74.1	0.173
05/26/22	07:00	74.4	0.172
05/26/22	08:00	74.5	0.173
05/26/22	09:00	74.3	0.174
05/26/22	10:00	73.8	0.173
05/26/22	11:00	73.4	0.173
05/26/22	12:00	73.4	0.174
05/26/22	13:00	73.4	0.174
05/26/22	14:00	73.2	0.174
05/26/22	15:00	73.2	0.173
05/26/22	16:00	73.0	0.173
05/26/22	17:00	72.7	0.172
05/26/22	18:00	72.7	0.172
05/26/22	19:00	72.6	0.172
05/26/22	20:00	72.8	0.172
05/26/22	21:00	73.0	0.173
05/26/22	22:00	72.9	0.173
05/26/22	23:00	72.8	0.172
05/27/22	00:00	73.3	0.173
05/27/22	01:00	75.8	0.175
05/27/22	02:00	78.5	0.177
05/27/22	03:00	80.7	0.178
05/27/22	04:00	82.2	0.179
05/27/22	05:00	82.5	0.180
05/27/22	06:00	82.5	0.180
05/27/22	07:00	83.2	0.181
05/27/22	08:00	83.7	0.181
05/27/22	09:00	84.1	0.181
05/27/22	10:00	84.6	0.181
05/27/22	11:00	85.3	0.182
05/27/22	12:00	85.3	0.182
05/27/22	13:00	85.2	0.183
05/27/22	14:00	85.1	0.183
05/27/22	15:00	84.9	0.183
05/27/22	16:00	84.9	0.184
05/27/22	17:00	85.0	0.184
05/27/22	18:00	85.1	0.185
05/27/22	19:00	85.0	0.185
05/27/22	20:00	84.8	0.184
05/27/22	21:00	84.9	0.184
05/27/22	22:00	85.0	0.185
05/27/22	23:00	84.9	0.185

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
05/28/22	00:00		84.9	0.184
05/28/22	01:00		84.6	0.184
05/28/22	02:00		83.9	0.184
05/28/22	03:00		81.7	0.182
05/28/22	04:00		79.5	0.181
05/28/22	05:00		77.2	0.179
05/28/22	06:00		75.0	0.178
05/28/22	07:00		73.3	0.178
05/28/22	08:00		73.3	0.178
05/28/22	09:00		72.7	0.178
05/28/22	10:00		72.5	0.178
05/28/22	11:00		72.1	0.178
05/28/22	12:00		71.7	0.176
05/28/22	13:00		71.7	0.176
05/28/22	14:00		71.5	0.175
05/28/22	15:00		71.6	0.175
05/28/22	16:00		71.5	0.174
05/28/22	17:00		71.3	0.174
05/28/22	18:00		70.9	0.173
05/28/22	19:00		70.5	0.172
05/28/22	20:00		70.3	0.172
05/28/22	21:00		69.3	0.170
05/28/22	22:00		68.4	0.168
05/28/22	23:00		68.0	0.167
05/29/22	00:00		67.9	0.167
05/29/22	01:00		67.6	0.167
05/29/22	02:00		65.5	0.164
05/29/22	03:00		65.4	0.165
05/29/22	04:00		65.5	0.165
05/29/22	05:00		65.6	0.166
05/29/22	06:00		65.6	0.166
05/29/22	07:00		65.1	0.167
05/29/22	08:00		62.8	0.166
05/29/22	09:00		61.3	0.164
05/29/22	10:00		61.0	0.163
05/29/22	11:00		60.8	0.162
05/29/22	12:00		60.8	0.162
05/29/22	13:00		60.5	0.161
05/29/22	14:00		60.2	0.161
05/29/22	15:00		60.1	0.160
05/29/22	16:00		59.9	0.160
05/29/22	17:00		59.9	0.160
05/29/22	18:00		59.7	0.159
05/29/22	19:00		60.2	0.161
05/29/22	20:00		60.6	0.161
05/29/22	21:00		61.6	0.163
05/29/22	22:00		62.5	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/29/22	23:00	62.9	0.166
05/30/22	00:00	62.6	0.167
05/30/22	01:00	60.9	0.166
05/30/22	02:00	60.9	0.166
05/30/22	03:00	60.8	0.166
05/30/22	04:00	60.7	0.165
05/30/22	05:00	60.8	0.166
05/30/22	06:00	60.9	0.167
05/30/22	07:00	61.0	0.167
05/30/22	08:00	61.2	0.166
05/30/22	09:00	62.7	0.167
05/30/22	10:00	62.9	0.167
05/30/22	11:00	63.1	0.167
05/30/22	12:00	63.4	0.168
05/30/22	13:00	63.7	0.169
05/30/22	14:00	64.0	0.169
05/30/22	15:00	64.3	0.170
05/30/22	16:00	64.6	0.171
05/30/22	17:00	64.7	0.171
05/30/22	18:00	64.8	0.171
05/30/22	19:00	64.8	0.171
05/30/22	20:00	64.6	0.171
05/30/22	21:00	64.5	0.171
05/30/22	22:00	64.4	0.170
05/30/22	23:00	64.5	0.171
05/31/22	00:00	65.0	0.170
05/31/22	01:00	66.8	0.171
05/31/22	02:00	67.2	0.173
05/31/22	03:00	67.2	0.173
05/31/22	04:00	68.0	0.174
05/31/22	05:00	70.3	0.174
05/31/22	06:00	72.1	0.174
05/31/22	07:00	74.1	0.173
05/31/22	08:00	76.0	0.175
05/31/22	09:00	76.1	0.175
05/31/22	10:00	76.0	0.175
05/31/22	11:00	76.1	0.175
05/31/22	12:00	76.2	0.175
05/31/22	13:00	76.2	0.175
05/31/22	14:00	76.2	0.175
05/31/22	15:00	75.8	0.174
05/31/22	16:00	75.5	0.174
05/31/22	17:00	75.5	0.174
05/31/22	18:00	75.6	0.174
05/31/22	19:00	75.1	0.173
05/31/22	20:00	74.7	0.172
05/31/22	21:00	73.8	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
05/31/22	22:00	73.3	0.169
05/31/22	23:00	72.9	0.168
06/01/22	00:00	72.7	0.168
06/01/22	01:00	73.2	0.168
06/01/22	02:00	75.1	0.168
06/01/22	03:00	77.2	0.169
06/01/22	04:00	78.4	0.169
06/01/22	05:00	77.9	0.168
06/01/22	06:00	77.8	0.168
06/01/22	07:00	77.7	0.169
06/01/22	08:00	77.5	0.169
06/01/22	09:00	77.6	0.169
06/01/22	10:00	77.9	0.170
06/01/22	11:00	78.0	0.170
06/01/22	12:00	78.0	0.170
06/01/22	13:00	77.9	0.170
06/01/22	14:00	77.9	0.170
06/01/22	15:00	78.2	0.171
06/01/22	16:00	78.2	0.171
06/01/22	17:00	78.1	0.171
06/01/22	18:00	78.1	0.171
06/01/22	19:00	78.3	0.172
06/01/22	20:00	78.5	0.173
06/01/22	21:00	78.7	0.174
06/01/22	22:00	78.7	0.174
06/01/22	23:00	78.7	0.174
06/02/22	00:00	78.1	0.174
06/02/22	01:00	75.8	0.174
06/02/22	02:00	73.6	0.173
06/02/22	03:00	71.5	0.172
06/02/22	04:00	69.9	0.171
06/02/22	05:00	69.8	0.171
06/02/22	06:00	69.8	0.172
06/02/22	07:00	69.8	0.172
06/02/22	08:00	69.6	0.171
06/02/22	09:00	69.4	0.171
06/02/22	10:00	69.3	0.171
06/02/22	11:00	69.1	0.172
06/02/22	12:00	68.9	0.172
06/02/22	13:00	68.9	0.172
06/02/22	14:00	68.7	0.172
06/02/22	15:00	68.3	0.171
06/02/22	16:00	68.2	0.172
06/02/22	17:00	67.7	0.171
06/02/22	18:00	67.3	0.170
06/02/22	19:00	67.0	0.170
06/02/22	20:00	66.6	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/02/22	21:00	66.2	0.169
06/02/22	22:00	65.9	0.168
06/02/22	23:00	65.4	0.167
06/03/22	00:00	65.7	0.167
06/03/22	01:00	68.0	0.168
06/03/22	02:00	70.4	0.169
06/03/22	03:00	72.7	0.170
06/03/22	04:00	74.5	0.172
06/03/22	05:00	74.6	0.173
06/03/22	06:00	74.2	0.172
06/03/22	07:00	74.1	0.171
06/03/22	08:00	74.3	0.172
06/03/22	09:00	74.2	0.171
06/03/22	10:00	74.2	0.171
06/03/22	11:00	74.3	0.171
06/03/22	12:00	74.3	0.171
06/03/22	13:00	74.2	0.171
06/03/22	14:00	74.3	0.171
06/03/22	15:00	74.4	0.171
06/03/22	16:00	74.5	0.171
06/03/22	17:00	74.7	0.172
06/03/22	18:00	75.1	0.173
06/03/22	19:00	75.2	0.173
06/03/22	20:00	75.3	0.173
06/03/22	21:00	75.7	0.174
06/03/22	22:00	75.9	0.174
06/03/22	23:00	76.1	0.175
06/04/22	00:00	76.2	0.175
06/04/22	01:00	75.2	0.174
06/04/22	02:00	72.9	0.173
06/04/22	03:00	70.6	0.172
06/04/22	04:00	68.4	0.171
06/04/22	05:00	66.4	0.170
06/04/22	06:00	65.7	0.171
06/04/22	07:00	65.7	0.171
06/04/22	08:00	65.3	0.170
06/04/22	09:00	64.8	0.170
06/04/22	10:00	64.3	0.169
06/04/22	11:00	63.8	0.168
06/04/22	12:00	63.4	0.167
06/04/22	13:00	63.0	0.166
06/04/22	14:00	62.3	0.164
06/04/22	15:00	61.9	0.163
06/04/22	16:00	61.8	0.163
06/04/22	17:00	62.1	0.164
06/04/22	18:00	62.3	0.164
06/04/22	19:00	62.6	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/04/22	20:00	62.9	0.165
06/04/22	21:00	63.0	0.166
06/04/22	22:00	63.0	0.165
06/04/22	23:00	63.0	0.165
06/05/22	00:00	62.9	0.165
06/05/22	01:00	63.6	0.166
06/05/22	02:00	63.7	0.166
06/05/22	03:00	63.7	0.165
06/05/22	04:00	63.6	0.165
06/05/22	05:00	63.6	0.164
06/05/22	06:00	62.8	0.163
06/05/22	07:00	60.9	0.163
06/05/22	08:00	59.4	0.163
06/05/22	09:00	58.3	0.163
06/05/22	10:00	57.1	0.165
06/05/22	11:00	56.0	0.166
06/05/22	12:00	54.8	0.167
06/05/22	13:00	53.7	0.169
06/05/22	14:00	52.7	0.171
06/05/22	15:00	52.2	0.172
06/05/22	16:00	52.8	0.173
06/05/22	17:00	52.2	0.171
06/05/22	18:00	51.3	0.169
06/05/22	19:00	50.4	0.167
06/05/22	20:00	50.0	0.165
06/05/22	21:00	50.1	0.165
06/05/22	22:00	50.4	0.165
06/05/22	23:00	50.4	0.165
06/06/22	00:00	49.9	0.165
06/06/22	01:00	48.1	0.164
06/06/22	02:00	47.9	0.164
06/06/22	03:00	47.8	0.165
06/06/22	04:00	47.8	0.165
06/06/22	05:00	48.5	0.165
06/06/22	06:00	50.2	0.166
06/06/22	07:00	52.3	0.166
06/06/22	08:00	54.4	0.167
06/06/22	09:00	56.2	0.167
06/06/22	10:00	57.8	0.167
06/06/22	11:00	59.4	0.166
06/06/22	12:00	60.9	0.165
06/06/22	13:00	62.7	0.165
06/06/22	14:00	64.3	0.164
06/06/22	15:00	65.4	0.164
06/06/22	16:00	65.1	0.164
06/06/22	17:00	65.5	0.165
06/06/22	18:00	66.2	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/06/22	19:00	66.7	0.168
06/06/22	20:00	66.8	0.168
06/06/22	21:00	66.7	0.169
06/06/22	22:00	66.3	0.168
06/06/22	23:00	66.2	0.168
06/07/22	00:00	66.7	0.168
06/07/22	01:00	68.5	0.168
06/07/22	02:00	70.4	0.168
06/07/22	03:00	72.5	0.169
06/07/22	04:00	74.6	0.170
06/07/22	05:00	75.6	0.169
06/07/22	06:00	75.8	0.170
06/07/22	07:00	74.6	0.168
06/07/22	08:00	73.4	0.167
06/07/22	09:00	72.5	0.166
06/07/22	10:00	71.6	0.165
06/07/22	11:00	70.7	0.164
06/07/22	12:00	70.6	0.165
06/07/22	13:00	70.6	0.165
06/07/22	14:00	70.8	0.166
06/07/22	15:00	70.8	0.166
06/07/22	16:00	70.8	0.166
06/07/22	17:00	70.9	0.167
06/07/22	18:00	71.1	0.167
06/07/22	19:00	71.3	0.167
06/07/22	20:00	71.5	0.168
06/07/22	21:00	70.2	0.167
06/07/22	22:00	68.5	0.167
06/07/22	23:00	66.5	0.166
06/08/22	00:00	65.5	0.166
06/08/22	01:00	65.8	0.166
06/08/22	02:00	66.0	0.167
06/08/22	03:00	66.1	0.167
06/08/22	04:00	66.2	0.167
06/08/22	05:00	66.5	0.168
06/08/22	06:00	66.6	0.168
06/08/22	07:00	67.7	0.170
06/08/22	08:00	67.4	0.171
06/08/22	09:00	67.6	0.172
06/08/22	10:00	68.3	0.172
06/08/22	11:00	69.4	0.174
06/08/22	12:00	69.7	0.174
06/08/22	13:00	69.6	0.173
06/08/22	14:00	69.5	0.173
06/08/22	15:00	69.5	0.173
06/08/22	16:00	69.3	0.172
06/08/22	17:00	69.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/08/22	18:00	68.9	0.172
06/08/22	19:00	68.8	0.172
06/08/22	20:00	68.8	0.172
06/08/22	21:00	70.5	0.173
06/08/22	22:00	72.8	0.174
06/08/22	23:00	74.9	0.175
06/09/22	00:00	75.9	0.176
06/09/22	01:00	76.0	0.176
06/09/22	02:00	76.2	0.177
06/09/22	03:00	76.2	0.177
06/09/22	04:00	76.4	0.177
06/09/22	05:00	76.2	0.177
06/09/22	06:00	76.1	0.176
06/09/22	07:00	76.2	0.176
06/09/22	08:00	77.4	0.177
06/09/22	09:00	78.0	0.177
06/09/22	10:00	78.1	0.177
06/09/22	11:00	77.7	0.177
06/09/22	12:00	77.3	0.176
06/09/22	13:00	77.1	0.175
06/09/22	14:00	76.8	0.175
06/09/22	15:00	76.8	0.175
06/09/22	16:00	76.8	0.175
06/09/22	17:00	76.8	0.175
06/09/22	18:00	76.7	0.174
06/09/22	19:00	76.7	0.174
06/09/22	20:00	76.6	0.174
06/09/22	21:00	75.9	0.173
06/09/22	22:00	75.4	0.172
06/09/22	23:00	75.4	0.171
06/10/22	00:00	75.3	0.170
06/10/22	01:00	74.8	0.169
06/10/22	02:00	74.4	0.168
06/10/22	03:00	73.8	0.167
06/10/22	04:00	73.3	0.166
06/10/22	05:00	73.2	0.165
06/10/22	06:00	73.6	0.167
06/10/22	07:00	73.5	0.167
06/10/22	08:00	73.1	0.166
06/10/22	09:00	72.7	0.166
06/10/22	10:00	72.7	0.166
06/10/22	11:00	72.3	0.166
06/10/22	12:00	71.8	0.165
06/10/22	13:00	71.4	0.165
06/10/22	14:00	70.9	0.165
06/10/22	15:00	70.7	0.164
06/10/22	16:00	70.5	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/10/22	17:00	70.3	0.163
06/10/22	18:00	70.2	0.164
06/10/22	19:00	70.1	0.164
06/10/22	20:00	70.0	0.164
06/10/22	21:00	70.3	0.164
06/10/22	22:00	70.6	0.165
06/10/22	23:00	71.1	0.166
06/11/22	00:00	71.3	0.166
06/11/22	01:00	70.9	0.166
06/11/22	02:00	69.2	0.166
06/11/22	03:00	67.6	0.167
06/11/22	04:00	66.0	0.167
06/11/22	05:00	64.4	0.167
06/11/22	06:00	62.9	0.167
06/11/22	07:00	62.7	0.167
06/11/22	08:00	62.7	0.166
06/11/22	09:00	62.7	0.166
06/11/22	10:00	62.6	0.165
06/11/22	11:00	62.9	0.165
06/11/22	12:00	63.6	0.166
06/11/22	13:00	64.2	0.166
06/11/22	14:00	64.8	0.167
06/11/22	15:00	65.0	0.167
06/11/22	16:00	65.1	0.168
06/11/22	17:00	65.4	0.168
06/11/22	18:00	65.8	0.169
06/11/22	19:00	65.7	0.169
06/11/22	20:00	65.8	0.169
06/11/22	21:00	65.9	0.169
06/11/22	22:00	65.9	0.169
06/11/22	23:00	65.7	0.168
06/12/22	00:00	65.8	0.169
06/12/22	01:00	66.3	0.169
06/12/22	02:00	67.9	0.169
06/12/22	03:00	68.0	0.169
06/12/22	04:00	68.0	0.169
06/12/22	05:00	68.1	0.169
06/12/22	06:00	68.2	0.169
06/12/22	07:00	68.0	0.169
06/12/22	08:00	68.1	0.169
06/12/22	09:00	68.0	0.168
06/12/22	10:00	68.1	0.168
06/12/22	11:00	68.6	0.169
06/12/22	12:00	68.4	0.169
06/12/22	13:00	68.3	0.168
06/12/22	14:00	68.2	0.168
06/12/22	15:00	68.5	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/12/22	16:00	68.6	0.168
06/12/22	17:00	68.5	0.168
06/12/22	18:00	68.5	0.168
06/12/22	19:00	69.1	0.169
06/12/22	20:00	69.6	0.170
06/12/22	21:00	69.8	0.170
06/12/22	22:00	69.9	0.170
06/12/22	23:00	70.1	0.171
06/13/22	00:00	70.2	0.171
06/13/22	01:00	69.9	0.171
06/13/22	02:00	68.4	0.171
06/13/22	03:00	68.3	0.171
06/13/22	04:00	69.1	0.172
06/13/22	05:00	71.0	0.172
06/13/22	06:00	72.1	0.172
06/13/22	07:00	71.9	0.172
06/13/22	08:00	71.1	0.170
06/13/22	09:00	70.4	0.168
06/13/22	10:00	69.3	0.166
06/13/22	11:00	67.8	0.163
06/13/22	12:00	66.8	0.161
06/13/22	13:00	66.1	0.159
06/13/22	14:00	65.2	0.157
06/13/22	15:00	64.0	0.154
06/13/22	16:00	63.0	0.152
06/13/22	17:00	61.9	0.150
06/13/22	18:00	60.9	0.147
06/13/22	19:00	60.0	0.146
06/13/22	20:00	59.2	0.144
06/13/22	21:00	58.7	0.143
06/13/22	22:00	58.6	0.143
06/13/22	23:00	58.5	0.143
06/14/22	00:00	58.2	0.142
06/14/22	01:00	58.6	0.142
06/14/22	02:00	60.6	0.143
06/14/22	03:00	62.7	0.143
06/14/22	04:00	63.9	0.143
06/14/22	05:00	64.0	0.143
06/14/22	06:00	63.6	0.142
06/14/22	07:00	63.8	0.143
06/14/22	08:00	64.8	0.144
06/14/22	09:00	66.5	0.148
06/14/22	10:00	68.0	0.151
06/14/22	11:00	69.4	0.154
06/14/22	12:00	70.7	0.157
06/14/22	13:00	71.5	0.159
06/14/22	14:00	72.8	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/14/22	15:00	74.2	0.165
06/14/22	16:00	75.4	0.168
06/14/22	17:00	76.5	0.170
06/14/22	18:00	77.4	0.172
06/14/22	19:00	77.8	0.173
06/14/22	20:00	78.0	0.174
06/14/22	21:00	77.9	0.173
06/14/22	22:00	77.8	0.173
06/14/22	23:00	77.6	0.173
06/15/22	00:00	77.4	0.172
06/15/22	01:00	77.4	0.172
06/15/22	02:00	77.1	0.171
06/15/22	03:00	76.8	0.171
06/15/22	04:00	76.7	0.171
06/15/22	05:00	76.3	0.170
06/15/22	06:00	76.2	0.170
06/15/22	07:00	76.2	0.170
06/15/22	08:00	76.0	0.170
06/15/22	09:00	74.6	0.166
06/15/22	10:00	73.2	0.163
06/15/22	11:00	71.5	0.160
06/15/22	12:00	70.0	0.156
06/15/22	13:00	69.4	0.155
06/15/22	14:00	68.6	0.153
06/15/22	15:00	67.8	0.151
06/15/22	16:00	67.1	0.150
06/15/22	17:00	66.4	0.149
06/15/22	18:00	65.9	0.148
06/15/22	19:00	65.8	0.148
06/15/22	20:00	65.8	0.148
06/15/22	21:00	65.6	0.147
06/15/22	22:00	65.5	0.147
06/15/22	23:00	65.3	0.146
06/16/22	00:00	65.3	0.147
06/16/22	01:00	65.2	0.146
06/16/22	02:00	65.1	0.146
06/16/22	03:00	63.9	0.143
06/16/22	04:00	62.1	0.139
06/16/22	05:00	60.4	0.135
06/16/22	06:00	58.7	0.132
06/16/22	07:00	57.4	0.129
06/16/22	08:00	58.1	0.131
06/16/22	09:00	58.5	0.132
06/16/22	10:00	59.1	0.133
06/16/22	11:00	60.0	0.135
06/16/22	12:00	60.8	0.137
06/16/22	13:00	61.4	0.138

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/16/22	14:00	61.9	0.140
06/16/22	15:00	61.7	0.139
06/16/22	16:00	61.1	0.138
06/16/22	17:00	60.5	0.137
06/16/22	18:00	59.8	0.135
06/16/22	19:00	59.1	0.134
06/16/22	20:00	58.5	0.133
06/16/22	21:00	58.2	0.132
06/16/22	22:00	58.1	0.132
06/16/22	23:00	57.8	0.132
06/17/22	00:00	57.7	0.132
06/17/22	01:00	57.7	0.132
06/17/22	02:00	57.5	0.131
06/17/22	03:00	58.4	0.133
06/17/22	04:00	59.8	0.136
06/17/22	05:00	61.3	0.140
06/17/22	06:00	63.1	0.144
06/17/22	07:00	63.6	0.145
06/17/22	08:00	62.6	0.143
06/17/22	09:00	62.3	0.143
06/17/22	10:00	62.2	0.143
06/17/22	11:00	62.7	0.145
06/17/22	12:00	62.1	0.143
06/17/22	13:00	61.0	0.141
06/17/22	14:00	59.6	0.139
06/17/22	15:00	59.0	0.137
06/17/22	16:00	58.8	0.137
06/17/22	17:00	58.7	0.137
06/17/22	18:00	58.6	0.137
06/17/22	19:00	58.4	0.137
06/17/22	20:00	58.1	0.137
06/17/22	21:00	57.7	0.136
06/17/22	22:00	57.5	0.136
06/17/22	23:00	57.5	0.137
06/18/22	00:00	57.3	0.138
06/18/22	01:00	57.0	0.139
06/18/22	02:00	55.0	0.137
06/18/22	03:00	53.0	0.135
06/18/22	04:00	50.9	0.133
06/18/22	05:00	48.8	0.131
06/18/22	06:00	46.8	0.129
06/18/22	07:00	46.1	0.129
06/18/22	08:00	44.7	0.128
06/18/22	09:00	43.1	0.126
06/18/22	10:00	41.4	0.124
06/18/22	11:00	39.3	0.121
06/18/22	12:00	38.2	0.120

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/18/22	13:00	37.0	0.119
06/18/22	14:00	36.2	0.120
06/18/22	15:00	35.3	0.120
06/18/22	16:00	34.4	0.121
06/18/22	17:00	33.4	0.121
06/18/22	18:00	32.5	0.121
06/18/22	19:00	31.3	0.121
06/18/22	20:00	30.2	0.121
06/18/22	21:00	29.0	0.121
06/18/22	22:00	27.1	0.119
06/18/22	23:00	25.1	0.116
06/19/22	00:00	23.0	0.113
06/19/22	01:00	20.9	0.109
06/19/22	02:00	21.0	0.110
06/19/22	03:00	21.1	0.110
06/19/22	04:00	21.1	0.110
06/19/22	05:00	21.2	0.110
06/19/22	06:00	21.2	0.111
06/19/22	07:00	20.7	0.111
06/19/22	08:00	20.6	0.111
06/19/22	09:00	20.8	0.112
06/19/22	10:00	20.9	0.113
06/19/22	11:00	21.0	0.114
06/19/22	12:00	21.2	0.114
06/19/22	13:00	21.3	0.115
06/19/22	14:00	21.3	0.115
06/19/22	15:00	21.4	0.115
06/19/22	16:00	21.5	0.116
06/19/22	17:00	21.5	0.116
06/19/22	18:00	21.5	0.117
06/19/22	19:00	21.9	0.118
06/19/22	20:00	22.2	0.120
06/19/22	21:00	22.5	0.122
06/19/22	22:00	22.8	0.123
06/19/22	23:00	23.1	0.125
06/20/22	00:00	23.4	0.126
06/20/22	01:00	23.8	0.128
06/20/22	02:00	24.2	0.130
06/20/22	03:00	24.6	0.132
06/20/22	04:00	25.0	0.135
06/20/22	05:00	25.5	0.137
06/20/22	06:00	26.0	0.140
06/20/22	07:00	26.6	0.142
06/20/22	08:00	27.0	0.144
06/20/22	09:00	27.3	0.146
06/20/22	10:00	27.7	0.148
06/20/22	11:00	28.0	0.150

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/20/22	12:00	28.8	0.151
06/20/22	13:00	30.1	0.152
06/20/22	14:00	31.9	0.154
06/20/22	15:00	33.0	0.155
06/20/22	16:00	33.2	0.156
06/20/22	17:00	33.6	0.157
06/20/22	18:00	33.9	0.159
06/20/22	19:00	33.8	0.158
06/20/22	20:00	33.8	0.158
06/20/22	21:00	33.9	0.158
06/20/22	22:00	33.8	0.158
06/20/22	23:00	33.9	0.158
06/21/22	00:00	34.0	0.158
06/21/22	01:00	34.3	0.159
06/21/22	02:00	34.2	0.159
06/21/22	03:00	34.1	0.159
06/21/22	04:00	34.1	0.158
06/21/22	05:00	34.0	0.158
06/21/22	06:00	34.3	0.157
06/21/22	07:00	35.4	0.156
06/21/22	08:00	37.0	0.156
06/21/22	09:00	38.7	0.157
06/21/22	10:00	40.5	0.157
06/21/22	11:00	42.2	0.158
06/21/22	12:00	43.3	0.159
06/21/22	13:00	43.8	0.160
06/21/22	14:00	43.8	0.160
06/21/22	15:00	44.9	0.161
06/21/22	16:00	46.7	0.162
06/21/22	17:00	48.4	0.162
06/21/22	18:00	50.2	0.163
06/21/22	19:00	51.9	0.164
06/21/22	20:00	53.6	0.165
06/21/22	21:00	55.5	0.166
06/21/22	22:00	57.6	0.168
06/21/22	23:00	59.6	0.169
06/22/22	00:00	61.6	0.170
06/22/22	01:00	63.3	0.171
06/22/22	02:00	65.5	0.172
06/22/22	03:00	67.5	0.173
06/22/22	04:00	69.4	0.174
06/22/22	05:00	71.2	0.175
06/22/22	06:00	72.7	0.176
06/22/22	07:00	73.5	0.177
06/22/22	08:00	73.7	0.178
06/22/22	09:00	73.7	0.178
06/22/22	10:00	73.9	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/22/22	11:00	73.9	0.179
06/22/22	12:00	74.2	0.180
06/22/22	13:00	74.4	0.181
06/22/22	14:00	74.7	0.182
06/22/22	15:00	74.7	0.182
06/22/22	16:00	74.5	0.181
06/22/22	17:00	74.4	0.181
06/22/22	18:00	74.4	0.181
06/22/22	19:00	74.4	0.182
06/22/22	20:00	74.4	0.182
06/22/22	21:00	74.6	0.182
06/22/22	22:00	74.5	0.182
06/22/22	23:00	74.6	0.183
06/23/22	00:00	74.7	0.183
06/23/22	01:00	74.2	0.184
06/23/22	02:00	72.0	0.182
06/23/22	03:00	70.1	0.181
06/23/22	04:00	68.2	0.181
06/23/22	05:00	67.0	0.181
06/23/22	06:00	67.5	0.183
06/23/22	07:00	67.4	0.183
06/23/22	08:00	65.9	0.183
06/23/22	09:00	64.1	0.181
06/23/22	10:00	62.6	0.180
06/23/22	11:00	62.6	0.181
06/23/22	12:00	62.8	0.182
06/23/22	13:00	62.6	0.181
06/23/22	14:00	61.8	0.179
06/23/22	15:00	61.4	0.178
06/23/22	16:00	61.3	0.178
06/23/22	17:00	61.2	0.178
06/23/22	18:00	60.9	0.177
06/23/22	19:00	60.9	0.177
06/23/22	20:00	61.0	0.177
06/23/22	21:00	61.2	0.178
06/23/22	22:00	61.9	0.180
06/23/22	23:00	62.1	0.180
06/24/22	00:00	62.2	0.183
06/24/22	01:00	60.6	0.181
06/24/22	02:00	60.7	0.182
06/24/22	03:00	60.8	0.182
06/24/22	04:00	60.9	0.182
06/24/22	05:00	60.2	0.181
06/24/22	06:00	57.9	0.178
06/24/22	07:00	57.9	0.178
06/24/22	08:00	59.2	0.178
06/24/22	09:00	60.8	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/24/22	10:00	61.3	0.178
06/24/22	11:00	61.0	0.177
06/24/22	12:00	60.5	0.175
06/24/22	13:00	60.5	0.175
06/24/22	14:00	61.0	0.176
06/24/22	15:00	61.2	0.177
06/24/22	16:00	61.0	0.177
06/24/22	17:00	60.8	0.177
06/24/22	18:00	60.6	0.176
06/24/22	19:00	60.6	0.176
06/24/22	20:00	60.2	0.175
06/24/22	21:00	59.5	0.173
06/24/22	22:00	58.8	0.172
06/24/22	23:00	57.9	0.171
06/25/22	00:00	55.7	0.166
06/25/22	01:00	56.0	0.167
06/25/22	02:00	55.9	0.167
06/25/22	03:00	55.9	0.167
06/25/22	04:00	56.0	0.168
06/25/22	05:00	56.1	0.168
06/25/22	06:00	56.1	0.169
06/25/22	07:00	55.2	0.169
06/25/22	08:00	54.8	0.168
06/25/22	09:00	54.8	0.168
06/25/22	10:00	55.3	0.169
06/25/22	11:00	55.7	0.170
06/25/22	12:00	55.9	0.170
06/25/22	13:00	56.1	0.171
06/25/22	14:00	56.2	0.171
06/25/22	15:00	56.4	0.171
06/25/22	16:00	56.6	0.172
06/25/22	17:00	56.9	0.173
06/25/22	18:00	57.2	0.174
06/25/22	19:00	57.5	0.174
06/25/22	20:00	57.9	0.175
06/25/22	21:00	58.6	0.177
06/25/22	22:00	59.2	0.178
06/25/22	23:00	60.1	0.179
06/26/22	00:00	62.1	0.181
06/26/22	01:00	64.2	0.182
06/26/22	02:00	66.9	0.185
06/26/22	03:00	67.6	0.187
06/26/22	04:00	67.5	0.186
06/26/22	05:00	67.3	0.185
06/26/22	06:00	67.3	0.185
06/26/22	07:00	66.4	0.183
06/26/22	08:00	65.3	0.185

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/26/22	09:00	64.1	0.185
06/26/22	10:00	62.7	0.186
06/26/22	11:00	61.1	0.185
06/26/22	12:00	59.5	0.185
06/26/22	13:00	57.9	0.185
06/26/22	14:00	55.7	0.182
06/26/22	15:00	53.6	0.179
06/26/22	16:00	51.8	0.177
06/26/22	17:00	49.8	0.175
06/26/22	18:00	48.0	0.173
06/26/22	19:00	45.8	0.170
06/26/22	20:00	43.6	0.168
06/26/22	21:00	41.0	0.165
06/26/22	22:00	38.1	0.160
06/26/22	23:00	35.5	0.156
06/27/22	00:00	33.2	0.152
06/27/22	01:00	30.6	0.149
06/27/22	02:00	27.5	0.143
06/27/22	03:00	26.3	0.139
06/27/22	04:00	26.0	0.138
06/27/22	05:00	25.8	0.137
06/27/22	06:00	25.8	0.136
06/27/22	07:00	27.1	0.135
06/27/22	08:00	28.1	0.134
06/27/22	09:00	28.6	0.131
06/27/22	10:00	29.9	0.131
06/27/22	11:00	30.7	0.129
06/27/22	12:00	31.8	0.128
06/27/22	13:00	32.8	0.127
06/27/22	14:00	34.5	0.130
06/27/22	15:00	35.9	0.131
06/27/22	16:00	37.2	0.131
06/27/22	17:00	38.1	0.131
06/27/22	18:00	39.0	0.130
06/27/22	19:00	40.0	0.130
06/27/22	20:00	41.1	0.130
06/27/22	21:00	42.9	0.132
06/27/22	22:00	45.1	0.135
06/27/22	23:00	47.0	0.137
06/28/22	00:00	48.0	0.139
06/28/22	01:00	48.1	0.140
06/28/22	02:00	48.3	0.141
06/28/22	03:00	48.4	0.142
06/28/22	04:00	48.3	0.141
06/28/22	05:00	48.3	0.141
06/28/22	06:00	48.0	0.140
06/28/22	07:00	48.5	0.142

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/28/22	08:00	48.8	0.142
06/28/22	09:00	49.2	0.143
06/28/22	10:00	48.7	0.142
06/28/22	11:00	48.5	0.142
06/28/22	12:00	48.3	0.141
06/28/22	13:00	48.1	0.141
06/28/22	14:00	48.2	0.141
06/28/22	15:00	47.8	0.140
06/28/22	16:00	47.6	0.140
06/28/22	17:00	47.6	0.140
06/28/22	18:00	47.7	0.140
06/28/22	19:00	47.8	0.140
06/28/22	20:00	47.8	0.140
06/28/22	21:00	47.8	0.140
06/28/22	22:00	47.7	0.140
06/28/22	23:00	47.7	0.140
06/29/22	00:00	46.8	0.138
06/29/22	01:00	46.5	0.136
06/29/22	02:00	46.3	0.135
06/29/22	03:00	46.0	0.134
06/29/22	04:00	45.7	0.132
06/29/22	05:00	46.1	0.132
06/29/22	06:00	47.8	0.134
06/29/22	07:00	47.2	0.132
06/29/22	08:00	47.2	0.132
06/29/22	09:00	47.6	0.133
06/29/22	10:00	48.3	0.134
06/29/22	11:00	48.9	0.136
06/29/22	12:00	49.3	0.137
06/29/22	13:00	49.7	0.137
06/29/22	14:00	49.5	0.136
06/29/22	15:00	49.6	0.136
06/29/22	16:00	50.5	0.139
06/29/22	17:00	50.9	0.139
06/29/22	18:00	51.1	0.140
06/29/22	19:00	51.6	0.141
06/29/22	20:00	51.9	0.141
06/29/22	21:00	52.2	0.142
06/29/22	22:00	52.3	0.142
06/29/22	23:00	52.3	0.142
06/30/22	00:00	52.3	0.142
06/30/22	01:00	52.3	0.142
06/30/22	02:00	52.3	0.142
06/30/22	03:00	52.4	0.142
06/30/22	04:00	52.5	0.143
06/30/22	05:00	52.0	0.142
06/30/22	06:00	50.4	0.140

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
06/30/22	07:00	50.3	0.140
06/30/22	08:00	50.0	0.140
06/30/22	09:00	49.3	0.138
06/30/22	10:00	48.8	0.137
06/30/22	11:00	48.5	0.136
06/30/22	12:00	48.4	0.136
06/30/22	13:00	48.4	0.137
06/30/22	14:00	48.9	0.138
06/30/22	15:00	49.1	0.139
06/30/22	16:00	49.0	0.138
06/30/22	17:00	48.4	0.137
06/30/22	18:00	47.9	0.136
06/30/22	19:00	47.3	0.135
06/30/22	20:00	46.6	0.133
06/30/22	21:00	45.7	0.131
06/30/22	22:00	45.4	0.130
06/30/22	23:00	45.6	0.131
07/01/22	00:00	46.9	0.132
07/01/22	01:00	47.0	0.132
07/01/22	02:00	47.0	0.133
07/01/22	03:00	47.0	0.133
07/01/22	04:00	47.1	0.133
07/01/22	05:00	47.3	0.133
07/01/22	06:00	47.8	0.132
07/01/22	07:00	48.3	0.133
07/01/22	08:00	48.4	0.134
07/01/22	09:00	49.4	0.136
07/01/22	10:00	49.5	0.136
07/01/22	11:00	49.9	0.137
07/01/22	12:00	50.0	0.136
07/01/22	13:00	49.5	0.135
07/01/22	14:00	48.6	0.133
07/01/22	15:00	48.3	0.132
07/01/22	16:00	48.2	0.131
07/01/22	17:00	49.0	0.133
07/01/22	18:00	49.7	0.134
07/01/22	19:00	50.6	0.136
07/01/22	20:00	51.3	0.137
07/01/22	21:00	52.3	0.139
07/01/22	22:00	52.5	0.139
07/01/22	23:00	52.9	0.140
07/02/22	00:00	53.9	0.141
07/02/22	01:00	55.8	0.145
07/02/22	02:00	55.6	0.144
07/02/22	03:00	55.5	0.143
07/02/22	04:00	55.3	0.142
07/02/22	05:00	55.1	0.142

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/02/22	06:00	54.0	0.141
07/02/22	07:00	52.5	0.139
07/02/22	08:00	53.4	0.142
07/02/22	09:00	53.4	0.142
07/02/22	10:00	53.4	0.142
07/02/22	11:00	52.9	0.141
07/02/22	12:00	51.8	0.139
07/02/22	13:00	51.6	0.138
07/02/22	14:00	52.0	0.139
07/02/22	15:00	52.5	0.140
07/02/22	16:00	52.4	0.140
07/02/22	17:00	52.3	0.140
07/02/22	18:00	52.0	0.140
07/02/22	19:00	52.2	0.141
07/02/22	20:00	52.6	0.142
07/02/22	21:00	52.8	0.143
07/02/22	22:00	52.9	0.144
07/02/22	23:00	52.2	0.143
07/03/22	00:00	49.7	0.138
07/03/22	01:00	47.8	0.135
07/03/22	02:00	48.0	0.137
07/03/22	03:00	48.2	0.138
07/03/22	04:00	48.3	0.138
07/03/22	05:00	48.4	0.139
07/03/22	06:00	48.6	0.140
07/03/22	07:00	48.4	0.141
07/03/22	08:00	45.9	0.138
07/03/22	09:00	44.2	0.135
07/03/22	10:00	44.3	0.135
07/03/22	11:00	44.2	0.134
07/03/22	12:00	45.1	0.136
07/03/22	13:00	45.6	0.137
07/03/22	14:00	45.7	0.137
07/03/22	15:00	45.7	0.137
07/03/22	16:00	45.8	0.137
07/03/22	17:00	46.3	0.139
07/03/22	18:00	46.7	0.140
07/03/22	19:00	46.8	0.140
07/03/22	20:00	47.1	0.140
07/03/22	21:00	47.2	0.141
07/03/22	22:00	47.3	0.141
07/03/22	23:00	47.8	0.141
07/04/22	00:00	49.8	0.145
07/04/22	01:00	49.5	0.144
07/04/22	02:00	49.3	0.142
07/04/22	03:00	49.0	0.141
07/04/22	04:00	48.9	0.140

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/04/22	05:00	48.6	0.139
07/04/22	06:00	48.5	0.138
07/04/22	07:00	48.0	0.135
07/04/22	08:00	48.1	0.134
07/04/22	09:00	49.2	0.136
07/04/22	10:00	48.5	0.134
07/04/22	11:00	48.2	0.133
07/04/22	12:00	47.8	0.133
07/04/22	13:00	47.5	0.132
07/04/22	14:00	47.5	0.132
07/04/22	15:00	47.3	0.132
07/04/22	16:00	47.2	0.131
07/04/22	17:00	46.9	0.130
07/04/22	18:00	47.0	0.130
07/04/22	19:00	47.0	0.130
07/04/22	20:00	46.7	0.129
07/04/22	21:00	46.5	0.129
07/04/22	22:00	46.5	0.129
07/04/22	23:00	46.4	0.129
07/05/22	00:00	46.3	0.129
07/05/22	01:00	46.5	0.129
07/05/22	02:00	46.6	0.130
07/05/22	03:00	46.7	0.130
07/05/22	04:00	46.8	0.130
07/05/22	05:00	46.9	0.131
07/05/22	06:00	47.1	0.131
07/05/22	07:00	48.9	0.134
07/05/22	08:00	50.7	0.137
07/05/22	09:00	49.3	0.134
07/05/22	10:00	48.3	0.131
07/05/22	11:00	47.6	0.130
07/05/22	12:00	47.2	0.129
07/05/22	13:00	46.6	0.127
07/05/22	14:00	45.8	0.125
07/05/22	15:00	45.1	0.123
07/05/22	16:00	44.3	0.121
07/05/22	17:00	43.5	0.119
07/05/22	18:00	42.4	0.117
07/05/22	19:00	41.3	0.114
07/05/22	20:00	40.6	0.112
07/05/22	21:00	40.1	0.110
07/05/22	22:00	40.2	0.110
07/05/22	23:00	40.9	0.112
07/06/22	00:00	41.8	0.113
07/06/22	01:00	43.2	0.116
07/06/22	02:00	43.6	0.117
07/06/22	03:00	43.9	0.119

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/06/22	04:00	44.4	0.121
07/06/22	05:00	45.4	0.123
07/06/22	06:00	47.7	0.128
07/06/22	07:00	47.8	0.127
07/06/22	08:00	47.7	0.126
07/06/22	09:00	49.2	0.130
07/06/22	10:00	50.2	0.132
07/06/22	11:00	51.3	0.135
07/06/22	12:00	51.7	0.136
07/06/22	13:00	52.6	0.138
07/06/22	14:00	53.3	0.139
07/06/22	15:00	53.6	0.140
07/06/22	16:00	54.3	0.142
07/06/22	17:00	54.1	0.142
07/06/22	18:00	53.9	0.141
07/06/22	19:00	54.0	0.142
07/06/22	20:00	53.8	0.141
07/06/22	21:00	53.6	0.141
07/06/22	22:00	53.5	0.141
07/06/22	23:00	52.8	0.139
07/07/22	00:00	52.5	0.139
07/07/22	01:00	53.1	0.139
07/07/22	02:00	53.0	0.139
07/07/22	03:00	52.8	0.138
07/07/22	04:00	52.6	0.138
07/07/22	05:00	52.2	0.136
07/07/22	06:00	52.0	0.136
07/07/22	07:00	52.1	0.136
07/07/22	08:00	52.4	0.137
07/07/22	09:00	52.3	0.137
07/07/22	10:00	51.9	0.136
07/07/22	11:00	52.1	0.137
07/07/22	12:00	52.3	0.138
07/07/22	13:00	52.1	0.137
07/07/22	14:00	52.2	0.138
07/07/22	15:00	52.6	0.138
07/07/22	16:00	52.5	0.138
07/07/22	17:00	53.2	0.140
07/07/22	18:00	54.0	0.142
07/07/22	19:00	54.9	0.144
07/07/22	20:00	55.7	0.146
07/07/22	21:00	56.1	0.147
07/07/22	22:00	56.0	0.147
07/07/22	23:00	55.8	0.146
07/08/22	00:00	55.7	0.146
07/08/22	01:00	56.3	0.148
07/08/22	02:00	56.4	0.148

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/08/22	03:00	56.3	0.148
07/08/22	04:00	56.4	0.148
07/08/22	05:00	56.4	0.148
07/08/22	06:00	56.6	0.149
07/08/22	07:00	56.5	0.149
07/08/22	08:00	56.1	0.148
07/08/22	09:00	56.4	0.148
07/08/22	10:00	57.0	0.149
07/08/22	11:00	57.1	0.149
07/08/22	12:00	57.2	0.149
07/08/22	13:00	57.3	0.150
07/08/22	14:00	57.8	0.151
07/08/22	15:00	58.0	0.151
07/08/22	16:00	58.1	0.152
07/08/22	17:00	58.1	0.152
07/08/22	18:00	58.0	0.152
07/08/22	19:00	57.6	0.151
07/08/22	20:00	57.1	0.150
07/08/22	21:00	56.9	0.149
07/08/22	22:00	56.8	0.149
07/08/22	23:00	56.7	0.149
07/09/22	00:00	54.7	0.147
07/09/22	01:00	52.3	0.142
07/09/22	02:00	52.0	0.142
07/09/22	03:00	52.0	0.142
07/09/22	04:00	52.1	0.142
07/09/22	05:00	51.7	0.142
07/09/22	06:00	49.4	0.139
07/09/22	07:00	47.6	0.138
07/09/22	08:00	46.2	0.137
07/09/22	09:00	44.7	0.135
07/09/22	10:00	45.2	0.137
07/09/22	11:00	45.6	0.138
07/09/22	12:00	45.7	0.138
07/09/22	13:00	45.8	0.139
07/09/22	14:00	45.8	0.138
07/09/22	15:00	45.9	0.139
07/09/22	16:00	46.2	0.140
07/09/22	17:00	46.8	0.141
07/09/22	18:00	46.9	0.142
07/09/22	19:00	47.2	0.142
07/09/22	20:00	47.6	0.144
07/09/22	21:00	47.2	0.143
07/09/22	22:00	45.1	0.140
07/09/22	23:00	43.0	0.138
07/10/22	00:00	42.6	0.137
07/10/22	01:00	42.5	0.136

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/10/22	02:00	42.5	0.136
07/10/22	03:00	42.5	0.136
07/10/22	04:00	42.4	0.136
07/10/22	05:00	42.3	0.135
07/10/22	06:00	42.3	0.135
07/10/22	07:00	42.2	0.134
07/10/22	08:00	42.0	0.133
07/10/22	09:00	41.5	0.131
07/10/22	10:00	40.4	0.128
07/10/22	11:00	39.4	0.126
07/10/22	12:00	39.4	0.126
07/10/22	13:00	39.0	0.125
07/10/22	14:00	38.2	0.123
07/10/22	15:00	36.9	0.121
07/10/22	16:00	35.0	0.118
07/10/22	17:00	33.1	0.116
07/10/22	18:00	32.5	0.115
07/10/22	19:00	32.5	0.115
07/10/22	20:00	32.5	0.115
07/10/22	21:00	32.5	0.115
07/10/22	22:00	32.5	0.115
07/10/22	23:00	32.5	0.115
07/11/22	00:00	32.5	0.115
07/11/22	01:00	32.5	0.115
07/11/22	02:00	32.5	0.115
07/11/22	03:00	32.5	0.115
07/11/22	04:00	32.5	0.115
07/11/22	05:00	32.5	0.115
07/11/22	06:00	32.5	0.115
07/11/22	07:00	32.5	0.115
07/11/22	08:00	32.5	0.115
07/11/22	09:00	32.5	0.115
07/11/22	10:00	32.5	0.115
07/11/22	11:00	32.5	0.115
07/11/22	12:00	32.5	0.115
07/11/22	13:00	32.5	0.115
07/11/22	14:00	32.5	0.115
07/11/22	15:00	32.5	0.115
07/11/22	16:00	32.5	0.115
07/11/22	17:00	32.5	0.115
07/11/22	18:00	32.5	0.115
07/11/22	19:00	32.5	0.115
07/11/22	20:00	32.5	0.115
07/11/22	21:00	32.5	0.115
07/11/22	22:00	32.5	0.115
07/11/22	23:00	32.5	0.115
07/12/22	00:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter			
Unit			
07/12/22	01:00	32.5	0.115
07/12/22	02:00	32.5	0.115
07/12/22	03:00	32.5	0.115
07/12/22	04:00	32.5	0.115
07/12/22	05:00	32.5	0.115
07/12/22	06:00	32.5	0.115
07/12/22	07:00	32.5	0.115
07/12/22	08:00	32.5	0.115
07/12/22	09:00	32.5	0.115
07/12/22	10:00	32.5	0.115
07/12/22	11:00	32.5	0.115
07/12/22	12:00	32.5	0.115
07/12/22	13:00	32.5	0.115
07/12/22	14:00	32.5	0.115
07/12/22	15:00	32.5	0.115
07/12/22	16:00	32.5	0.115
07/12/22	17:00	32.5	0.115
07/12/22	18:00	32.5	0.115
07/12/22	19:00	32.5	0.115
07/12/22	20:00	32.5	0.115
07/12/22	21:00	32.5	0.115
07/12/22	22:00	32.5	0.115
07/12/22	23:00	32.5	0.115
07/13/22	00:00	32.5	0.115
07/13/22	01:00	32.5	0.115
07/13/22	02:00	32.5	0.115
07/13/22	03:00	32.5	0.115
07/13/22	04:00	32.5	0.115
07/13/22	05:00	32.5	0.115
07/13/22	06:00	32.5	0.115
07/13/22	07:00	32.5	0.115
07/13/22	08:00	32.5	0.115
07/13/22	09:00	32.5	0.115
07/13/22	10:00	32.5	0.115
07/13/22	11:00	32.5	0.115
07/13/22	12:00	32.5	0.115
07/13/22	13:00	32.5	0.115
07/13/22	14:00	32.5	0.115
07/13/22	15:00	32.5	0.115
07/13/22	16:00	32.5	0.115
07/13/22	17:00	32.5	0.115
07/13/22	18:00	32.5	0.115
07/13/22	19:00	32.5	0.115
07/13/22	20:00	32.5	0.115
07/13/22	21:00	32.5	0.115
07/13/22	22:00	32.5	0.115
07/13/22	23:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/14/22	00:00	32.5	0.115
07/14/22	01:00	32.5	0.115
07/14/22	02:00	32.5	0.115
07/14/22	03:00	32.5	0.115
07/14/22	04:00	32.5	0.115
07/14/22	05:00	32.5	0.115
07/14/22	06:00	32.5	0.115
07/14/22	07:00	32.5	0.115
07/14/22	08:00	32.5	0.115
07/14/22	09:00	32.5	0.115
07/14/22	10:00	32.5	0.115
07/14/22	11:00	32.5	0.115
07/14/22	12:00	32.5	0.115
07/14/22	13:00	32.5	0.115
07/14/22	14:00	32.5	0.115
07/14/22	15:00	32.5	0.115
07/14/22	16:00	32.5	0.115
07/14/22	17:00	32.5	0.115
07/14/22	18:00	32.5	0.115
07/14/22	19:00	32.5	0.115
07/14/22	20:00	32.5	0.115
07/14/22	21:00	32.5	0.115
07/14/22	22:00	32.5	0.115
07/14/22	23:00	32.5	0.115
07/15/22	00:00	32.5	0.115
07/15/22	01:00	32.5	0.115
07/15/22	02:00	32.5	0.115
07/15/22	03:00	32.5	0.115
07/15/22	04:00	32.5	0.115
07/15/22	05:00	32.5	0.115
07/15/22	06:00	32.5	0.115
07/15/22	07:00	32.5	0.115
07/15/22	08:00	32.5	0.115
07/15/22	09:00	32.5	0.115
07/15/22	10:00	32.5	0.115
07/15/22	11:00	32.5	0.115
07/15/22	12:00	32.5	0.115
07/15/22	13:00	32.5	0.115
07/15/22	14:00	32.5	0.115
07/15/22	15:00	32.5	0.115
07/15/22	16:00	32.5	0.115
07/15/22	17:00	32.5	0.115
07/15/22	18:00	32.5	0.115
07/15/22	19:00	32.5	0.115
07/15/22	20:00	32.5	0.115
07/15/22	21:00	32.5	0.115
07/15/22	22:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/15/22	23:00	32.5	0.115
07/16/22	00:00	32.5	0.115
07/16/22	01:00	32.5	0.115
07/16/22	02:00	32.5	0.115
07/16/22	03:00	32.5	0.115
07/16/22	04:00	32.5	0.115
07/16/22	05:00	32.5	0.115
07/16/22	06:00	32.5	0.115
07/16/22	07:00	32.5	0.115
07/16/22	08:00	32.5	0.115
07/16/22	09:00	32.5	0.115
07/16/22	10:00	32.5	0.115
07/16/22	11:00	32.5	0.115
07/16/22	12:00	32.5	0.115
07/16/22	13:00	32.5	0.115
07/16/22	14:00	32.5	0.115
07/16/22	15:00	32.5	0.115
07/16/22	16:00	32.5	0.115
07/16/22	17:00	32.5	0.115
07/16/22	18:00	32.5	0.115
07/16/22	19:00	32.5	0.115
07/16/22	20:00	32.5	0.115
07/16/22	21:00	32.5	0.115
07/16/22	22:00	32.5	0.115
07/16/22	23:00	32.5	0.115
07/17/22	00:00	32.5	0.115
07/17/22	01:00	32.5	0.115
07/17/22	02:00	32.5	0.115
07/17/22	03:00	32.5	0.115
07/17/22	04:00	32.5	0.115
07/17/22	05:00	32.5	0.115
07/17/22	06:00	32.5	0.115
07/17/22	07:00	32.5	0.115
07/17/22	08:00	32.5	0.115
07/17/22	09:00	32.5	0.115
07/17/22	10:00	32.5	0.115
07/17/22	11:00	32.5	0.115
07/17/22	12:00	32.5	0.115
07/17/22	13:00	32.5	0.115
07/17/22	14:00	32.5	0.115
07/17/22	15:00	32.5	0.115
07/17/22	16:00	32.5	0.115
07/17/22	17:00	32.5	0.115
07/17/22	18:00	32.5	0.115
07/17/22	19:00	32.5	0.115
07/17/22	20:00	32.5	0.115
07/17/22	21:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
07/17/22	22:00		32.5	0.115
07/17/22	23:00		32.5	0.115
07/18/22	00:00		32.5	0.115
07/18/22	01:00		32.5	0.115
07/18/22	02:00		32.5	0.115
07/18/22	03:00		32.5	0.115
07/18/22	04:00		32.5	0.115
07/18/22	05:00		32.5	0.115
07/18/22	06:00		32.5	0.115
07/18/22	07:00		32.5	0.115
07/18/22	08:00		32.5	0.115
07/18/22	09:00		32.5	0.115
07/18/22	10:00		32.5	0.115
07/18/22	11:00		32.5	0.115
07/18/22	12:00		32.5	0.115
07/18/22	13:00		32.5	0.115
07/18/22	14:00		32.5	0.115
07/18/22	15:00		32.5	0.115
07/18/22	16:00		32.5	0.115
07/18/22	17:00		32.5	0.115
07/18/22	18:00		32.5	0.115
07/18/22	19:00		32.5	0.115
07/18/22	20:00		32.5	0.115
07/18/22	21:00		32.5	0.115
07/18/22	22:00		32.5	0.115
07/18/22	23:00		32.5	0.115
07/19/22	00:00		32.5	0.115
07/19/22	01:00		32.5	0.115
07/19/22	02:00		32.5	0.115
07/19/22	03:00		32.5	0.115
07/19/22	04:00		32.5	0.115
07/19/22	05:00		32.5	0.115
07/19/22	06:00		32.5	0.115
07/19/22	07:00		32.5	0.115
07/19/22	08:00		32.5	0.115
07/19/22	09:00		32.5	0.115
07/19/22	10:00		32.5	0.115
07/19/22	11:00		32.5	0.115
07/19/22	12:00		32.5	0.115
07/19/22	13:00		32.5	0.115
07/19/22	14:00		32.5	0.115
07/19/22	15:00		32.5	0.115
07/19/22	16:00		32.5	0.115
07/19/22	17:00		32.5	0.115
07/19/22	18:00		32.5	0.115
07/19/22	19:00		32.5	0.115
07/19/22	20:00		32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter			
Unit			
07/19/22	21:00	32.5	0.115
07/19/22	22:00	32.5	0.115
07/19/22	23:00	32.5	0.115
07/20/22	00:00	32.5	0.115
07/20/22	01:00	32.5	0.115
07/20/22	02:00	32.5	0.115
07/20/22	03:00	32.5	0.115
07/20/22	04:00	32.5	0.115
07/20/22	05:00	32.5	0.115
07/20/22	06:00	32.5	0.115
07/20/22	07:00	32.5	0.115
07/20/22	08:00	32.5	0.115
07/20/22	09:00	32.5	0.115
07/20/22	10:00	32.5	0.115
07/20/22	11:00	32.5	0.115
07/20/22	12:00	32.5	0.115
07/20/22	13:00	32.5	0.115
07/20/22	14:00	32.5	0.115
07/20/22	15:00	32.5	0.115
07/20/22	16:00	32.5	0.115
07/20/22	17:00	32.5	0.115
07/20/22	18:00	32.5	0.115
07/20/22	19:00	32.5	0.115
07/20/22	20:00	32.5	0.115
07/20/22	21:00	32.5	0.115
07/20/22	22:00	32.5	0.115
07/20/22	23:00	32.5	0.115
07/21/22	00:00	32.5	0.115
07/21/22	01:00	32.5	0.115
07/21/22	02:00	32.5	0.115
07/21/22	03:00	32.5	0.115
07/21/22	04:00	32.5	0.115
07/21/22	05:00	32.5	0.115
07/21/22	06:00	32.5	0.115
07/21/22	07:00	32.5	0.115
07/21/22	08:00	32.5	0.115
07/21/22	09:00	32.5	0.115
07/21/22	10:00	32.5	0.115
07/21/22	11:00	32.5	0.115
07/21/22	12:00	32.5	0.115
07/21/22	13:00	32.5	0.115
07/21/22	14:00	32.5	0.115
07/21/22	15:00	32.5	0.115
07/21/22	16:00	32.5	0.115
07/21/22	17:00	32.5	0.115
07/21/22	18:00	32.5	0.115
07/21/22	19:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/21/22	20:00	32.5	0.115
07/21/22	21:00	32.5	0.115
07/21/22	22:00	32.5	0.115
07/21/22	23:00	32.5	0.115
07/22/22	00:00	32.5	0.115
07/22/22	01:00	32.5	0.115
07/22/22	02:00	32.5	0.115
07/22/22	03:00	32.5	0.115
07/22/22	04:00	32.5	0.115
07/22/22	05:00	32.5	0.115
07/22/22	06:00	32.5	0.115
07/22/22	07:00	32.5	0.115
07/22/22	08:00	32.5	0.115
07/22/22	09:00	32.5	0.115
07/22/22	10:00	32.5	0.115
07/22/22	11:00	32.5	0.115
07/22/22	12:00	32.5	0.115
07/22/22	13:00	32.5	0.115
07/22/22	14:00	32.5	0.115
07/22/22	15:00	32.5	0.115
07/22/22	16:00	32.5	0.115
07/22/22	17:00	32.5	0.115
07/22/22	18:00	32.5	0.115
07/22/22	19:00	32.5	0.115
07/22/22	20:00	32.5	0.115
07/22/22	21:00	32.5	0.115
07/22/22	22:00	32.5	0.115
07/22/22	23:00	32.5	0.115
07/23/22	00:00	32.5	0.115
07/23/22	01:00	32.5	0.115
07/23/22	02:00	32.5	0.115
07/23/22	03:00	32.5	0.115
07/23/22	04:00	32.5	0.115
07/23/22	05:00	32.5	0.115
07/23/22	06:00	32.5	0.115
07/23/22	07:00	32.5	0.115
07/23/22	08:00	32.5	0.115
07/23/22	09:00	32.5	0.115
07/23/22	10:00	32.5	0.115
07/23/22	11:00	32.5	0.115
07/23/22	12:00	32.5	0.115
07/23/22	13:00	32.5	0.115
07/23/22	14:00	32.5	0.115
07/23/22	15:00	32.5	0.115
07/23/22	16:00	32.5	0.115
07/23/22	17:00	32.5	0.115
07/23/22	18:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter			
Unit			
07/23/22	19:00	32.5	0.115
07/23/22	20:00	32.5	0.115
07/23/22	21:00	32.5	0.115
07/23/22	22:00	32.5	0.115
07/23/22	23:00	32.5	0.115
07/24/22	00:00	32.5	0.115
07/24/22	01:00	32.5	0.115
07/24/22	02:00	32.5	0.115
07/24/22	03:00	32.5	0.115
07/24/22	04:00	32.5	0.115
07/24/22	05:00	32.5	0.115
07/24/22	06:00	32.5	0.115
07/24/22	07:00	32.5	0.115
07/24/22	08:00	32.5	0.115
07/24/22	09:00	32.5	0.115
07/24/22	10:00	32.5	0.115
07/24/22	11:00	32.5	0.115
07/24/22	12:00	32.5	0.115
07/24/22	13:00	32.5	0.115
07/24/22	14:00	32.5	0.115
07/24/22	15:00	32.5	0.115
07/24/22	16:00	32.5	0.115
07/24/22	17:00	32.5	0.115
07/24/22	18:00	32.5	0.115
07/24/22	19:00	32.5	0.115
07/24/22	20:00	32.5	0.115
07/24/22	21:00	32.5	0.115
07/24/22	22:00	32.5	0.115
07/24/22	23:00	32.5	0.115
07/25/22	00:00	32.5	0.115
07/25/22	01:00	32.5	0.115
07/25/22	02:00	32.5	0.115
07/25/22	03:00	32.5	0.115
07/25/22	04:00	32.5	0.115
07/25/22	05:00	32.5	0.115
07/25/22	06:00	32.5	0.115
07/25/22	07:00	32.5	0.115
07/25/22	08:00	32.5	0.115
07/25/22	09:00	32.5	0.115
07/25/22	10:00	32.5	0.115
07/25/22	11:00	32.5	0.115
07/25/22	12:00	32.5	0.115
07/25/22	13:00	32.5	0.115
07/25/22	14:00	32.5	0.115
07/25/22	15:00	32.5	0.115
07/25/22	16:00	32.5	0.115
07/25/22	17:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/25/22	18:00	32.5	0.115
07/25/22	19:00	32.5	0.115
07/25/22	20:00	32.5	0.115
07/25/22	21:00	32.5	0.115
07/25/22	22:00	32.5	0.115
07/25/22	23:00	32.5	0.115
07/26/22	00:00	32.5	0.115
07/26/22	01:00	32.5	0.115
07/26/22	02:00	32.5	0.115
07/26/22	03:00	32.5	0.115
07/26/22	04:00	32.5	0.115
07/26/22	05:00	32.5	0.115
07/26/22	06:00	32.5	0.115
07/26/22	07:00	32.5	0.115
07/26/22	08:00	32.5	0.115
07/26/22	09:00	32.5	0.115
07/26/22	10:00	32.5	0.115
07/26/22	11:00	32.5	0.115
07/26/22	12:00	32.5	0.115
07/26/22	13:00	32.5	0.115
07/26/22	14:00	32.5	0.115
07/26/22	15:00	32.5	0.115
07/26/22	16:00	32.5	0.115
07/26/22	17:00	32.5	0.115
07/26/22	18:00	32.5	0.115
07/26/22	19:00	32.5	0.115
07/26/22	20:00	32.5	0.115
07/26/22	21:00	32.5	0.115
07/26/22	22:00	32.5	0.115
07/26/22	23:00	32.5	0.115
07/27/22	00:00	32.5	0.115
07/27/22	01:00	32.5	0.115
07/27/22	02:00	32.5	0.115
07/27/22	03:00	32.5	0.115
07/27/22	04:00	32.5	0.115
07/27/22	05:00	32.5	0.115
07/27/22	06:00	32.5	0.115
07/27/22	07:00	32.5	0.115
07/27/22	08:00	32.5	0.115
07/27/22	09:00	32.5	0.115
07/27/22	10:00	32.5	0.115
07/27/22	11:00	32.5	0.115
07/27/22	12:00	32.5	0.115
07/27/22	13:00	32.5	0.115
07/27/22	14:00	32.5	0.115
07/27/22	15:00	32.5	0.115
07/27/22	16:00	32.5	0.115

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/27/22	17:00	32.5	0.115
07/27/22	18:00	32.5	0.115
07/27/22	19:00	32.5	0.115
07/27/22	20:00	32.5	0.115
07/27/22	21:00	32.5	0.115
07/27/22	22:00	32.5	0.115
07/27/22	23:00	32.5	0.115
07/28/22	00:00	32.5	0.115
07/28/22	01:00	29.9	0.113
07/28/22	02:00	27.1	0.111
07/28/22	03:00	24.9	0.109
07/28/22	04:00	24.0	0.109
07/28/22	05:00	23.2	0.109
07/28/22	06:00	22.4	0.109I
07/28/22	07:00	21.6	0.110I
07/28/22	08:00	20.7	0.109I
07/28/22	09:00	19.8	0.109I
07/28/22	10:00	19.1	0.109I
07/28/22	11:00	18.6	0.109I
07/28/22	12:00	18.7	0.109I
07/28/22	13:00	18.7	0.110I
07/28/22	14:00	19.8	0.115I
07/28/22	15:00	23.1	0.126I
07/28/22	16:00	25.7	0.136I
07/28/22	17:00	27.3	0.142I
07/28/22	18:00	28.3	0.145I
07/28/22	19:00	29.7	0.150I
07/28/22	20:00	31.3	0.157I
07/28/22	21:00	33.4	0.165I
07/28/22	22:00	36.1	0.174I
07/28/22	23:00	38.5	0.180I
07/29/22	00:00	39.6	0.180I
07/29/22	01:00	40.8	0.176I
07/29/22	02:00	41.4	0.168I
07/29/22	03:00	41.9	0.168I
07/29/22	04:00	41.9	0.168I
07/29/22	05:00	41.9	0.168I
07/29/22	06:00	41.9	0.168I
07/29/22	07:00	41.9	0.168I
07/29/22	08:00	41.9	0.168I
07/29/22	09:00	41.9	0.168I
07/29/22	10:00	41.9	0.168I
07/29/22	11:00	41.9	0.168I
07/29/22	12:00	41.9	0.168I
07/29/22	13:00	41.9	0.168I
07/29/22	14:00	41.9	0.168I
07/29/22	15:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
07/29/22	16:00	41.9	0.168I
07/29/22	17:00	41.9	0.168I
07/29/22	18:00	41.9	0.168I
07/29/22	19:00	41.9	0.168I
07/29/22	20:00	41.9	0.168I
07/29/22	21:00	41.9	0.168I
07/29/22	22:00	41.9	0.168I
07/29/22	23:00	41.9	0.168I
07/30/22	00:00	41.9	0.168I
07/30/22	01:00	41.9	0.168I
07/30/22	02:00	41.9	0.168I
07/30/22	03:00	41.9	0.168I
07/30/22	04:00	41.9	0.168I
07/30/22	05:00	41.9	0.168I
07/30/22	06:00	41.9	0.168I
07/30/22	07:00	41.9	0.168I
07/30/22	08:00	41.9	0.168I
07/30/22	09:00	41.9	0.168I
07/30/22	10:00	41.9	0.168I
07/30/22	11:00	41.9	0.168I
07/30/22	12:00	41.9	0.168I
07/30/22	13:00	41.9	0.168I
07/30/22	14:00	41.9	0.168I
07/30/22	15:00	41.9	0.168I
07/30/22	16:00	41.9	0.168I
07/30/22	17:00	41.9	0.168I
07/30/22	18:00	41.9	0.168I
07/30/22	19:00	41.9	0.168I
07/30/22	20:00	41.9	0.168I
07/30/22	21:00	41.9	0.168I
07/30/22	22:00	41.9	0.168I
07/30/22	23:00	41.9	0.168I
07/31/22	00:00	41.9	0.168I
07/31/22	01:00	41.9	0.168I
07/31/22	02:00	41.9	0.168I
07/31/22	03:00	41.9	0.168I
07/31/22	04:00	41.9	0.168I
07/31/22	05:00	41.9	0.168I
07/31/22	06:00	41.9	0.168I
07/31/22	07:00	41.9	0.168I
07/31/22	08:00	41.9	0.168I
07/31/22	09:00	41.9	0.168I
07/31/22	10:00	41.9	0.168I
07/31/22	11:00	41.9	0.168I
07/31/22	12:00	41.9	0.168I
07/31/22	13:00	41.9	0.168I
07/31/22	14:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter			
Unit			
07/31/22	15:00	41.9	0.168I
07/31/22	16:00	41.9	0.168I
07/31/22	17:00	41.9	0.168I
07/31/22	18:00	41.9	0.168I
07/31/22	19:00	41.9	0.168I
07/31/22	20:00	41.9	0.168I
07/31/22	21:00	41.9	0.168I
07/31/22	22:00	41.9	0.168I
07/31/22	23:00	41.9	0.168I
08/01/22	00:00	41.9	0.168I
08/01/22	01:00	41.9	0.168I
08/01/22	02:00	41.9	0.168I
08/01/22	03:00	41.9	0.168I
08/01/22	04:00	41.9	0.168I
08/01/22	05:00	41.9	0.168I
08/01/22	06:00	41.9	0.168I
08/01/22	07:00	41.9	0.168I
08/01/22	08:00	41.9	0.168I
08/01/22	09:00	41.9	0.168I
08/01/22	10:00	41.9	0.168I
08/01/22	11:00	41.9	0.168I
08/01/22	12:00	41.9	0.168I
08/01/22	13:00	41.9	0.168I
08/01/22	14:00	41.9	0.168I
08/01/22	15:00	41.9	0.168I
08/01/22	16:00	41.9	0.168I
08/01/22	17:00	41.9	0.168I
08/01/22	18:00	41.9	0.168I
08/01/22	19:00	41.9	0.168I
08/01/22	20:00	41.9	0.168I
08/01/22	21:00	41.9	0.168I
08/01/22	22:00	41.9	0.168I
08/01/22	23:00	41.9	0.168I
08/02/22	00:00	41.9	0.168I
08/02/22	01:00	41.9	0.168I
08/02/22	02:00	41.9	0.168I
08/02/22	03:00	41.9	0.168I
08/02/22	04:00	41.9	0.168I
08/02/22	05:00	41.9	0.168I
08/02/22	06:00	41.9	0.168I
08/02/22	07:00	41.9	0.168I
08/02/22	08:00	41.9	0.168I
08/02/22	09:00	41.9	0.168I
08/02/22	10:00	41.9	0.168I
08/02/22	11:00	41.9	0.168I
08/02/22	12:00	41.9	0.168I
08/02/22	13:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Parameter			
Unit			
08/02/22	14:00	41.9	0.168I
08/02/22	15:00	41.9	0.168I
08/02/22	16:00	41.9	0.168I
08/02/22	17:00	41.9	0.168I
08/02/22	18:00	41.9	0.168I
08/02/22	19:00	41.9	0.168I
08/02/22	20:00	41.9	0.168I
08/02/22	21:00	41.9	0.168I
08/02/22	22:00	41.9	0.168I
08/02/22	23:00	41.9	0.168I
08/03/22	00:00	41.9	0.168I
08/03/22	01:00	41.9	0.168I
08/03/22	02:00	41.9	0.168I
08/03/22	03:00	41.9	0.168I
08/03/22	04:00	41.9	0.168I
08/03/22	05:00	41.9	0.168I
08/03/22	06:00	41.9	0.168I
08/03/22	07:00	41.9	0.168I
08/03/22	08:00	41.9	0.168I
08/03/22	09:00	41.9	0.168I
08/03/22	10:00	41.9	0.168I
08/03/22	11:00	41.9	0.168I
08/03/22	12:00	41.9	0.168I
08/03/22	13:00	41.9	0.168I
08/03/22	14:00	41.9	0.168I
08/03/22	15:00	41.9	0.168I
08/03/22	16:00	41.9	0.168I
08/03/22	17:00	41.9	0.168I
08/03/22	18:00	41.9	0.168I
08/03/22	19:00	41.9	0.168I
08/03/22	20:00	41.9	0.168I
08/03/22	21:00	41.9	0.168I
08/03/22	22:00	41.9	0.168I
08/03/22	23:00	41.9	0.168I
08/04/22	00:00	41.9	0.168I
08/04/22	01:00	41.9	0.168I
08/04/22	02:00	41.9	0.168I
08/04/22	03:00	41.9	0.168I
08/04/22	04:00	41.9	0.168I
08/04/22	05:00	41.9	0.168I
08/04/22	06:00	41.9	0.168I
08/04/22	07:00	41.9	0.168I
08/04/22	08:00	41.9	0.168I
08/04/22	09:00	41.9	0.168I
08/04/22	10:00	41.9	0.168I
08/04/22	11:00	41.9	0.168I
08/04/22	12:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/04/22	13:00	41.9	0.168I
08/04/22	14:00	41.9	0.168I
08/04/22	15:00	41.9	0.168I
08/04/22	16:00	41.9	0.168I
08/04/22	17:00	41.9	0.168I
08/04/22	18:00	41.9	0.168I
08/04/22	19:00	41.9	0.168I
08/04/22	20:00	41.9	0.168I
08/04/22	21:00	41.9	0.168I
08/04/22	22:00	41.9	0.168I
08/04/22	23:00	41.9	0.168I
08/05/22	00:00	41.9	0.168I
08/05/22	01:00	41.9	0.168I
08/05/22	02:00	41.9	0.168I
08/05/22	03:00	41.9	0.168I
08/05/22	04:00	41.9	0.168I
08/05/22	05:00	41.9	0.168I
08/05/22	06:00	41.9	0.168I
08/05/22	07:00	41.9	0.168I
08/05/22	08:00	41.9	0.168I
08/05/22	09:00	41.9	0.168I
08/05/22	10:00	41.9	0.168I
08/05/22	11:00	41.9	0.168I
08/05/22	12:00	41.9	0.168I
08/05/22	13:00	41.9	0.168I
08/05/22	14:00	41.9	0.168I
08/05/22	15:00	41.9	0.168I
08/05/22	16:00	41.9	0.168I
08/05/22	17:00	41.9	0.168I
08/05/22	18:00	41.9	0.168I
08/05/22	19:00	41.9	0.168I
08/05/22	20:00	41.9	0.168I
08/05/22	21:00	41.9	0.168I
08/05/22	22:00	41.9	0.168I
08/05/22	23:00	41.9	0.168I
08/06/22	00:00	41.9	0.168I
08/06/22	01:00	41.9	0.168I
08/06/22	02:00	41.9	0.168I
08/06/22	03:00	41.9	0.168I
08/06/22	04:00	41.9	0.168I
08/06/22	05:00	41.9	0.168I
08/06/22	06:00	41.9	0.168I
08/06/22	07:00	41.9	0.168I
08/06/22	08:00	41.9	0.168I
08/06/22	09:00	41.9	0.168I
08/06/22	10:00	41.9	0.168I
08/06/22	11:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/06/22	12:00	41.9	0.168I
08/06/22	13:00	41.9	0.168I
08/06/22	14:00	41.9	0.168I
08/06/22	15:00	41.9	0.168I
08/06/22	16:00	41.9	0.168I
08/06/22	17:00	41.9	0.168I
08/06/22	18:00	41.9	0.168I
08/06/22	19:00	41.9	0.168I
08/06/22	20:00	41.9	0.168I
08/06/22	21:00	41.9	0.168I
08/06/22	22:00	41.9	0.168I
08/06/22	23:00	41.9	0.168I
08/07/22	00:00	41.9	0.168I
08/07/22	01:00	41.9	0.168I
08/07/22	02:00	41.9	0.168I
08/07/22	03:00	41.9	0.168I
08/07/22	04:00	41.9	0.168I
08/07/22	05:00	41.9	0.168I
08/07/22	06:00	41.9	0.168I
08/07/22	07:00	41.9	0.168I
08/07/22	08:00	41.9	0.168I
08/07/22	09:00	41.9	0.168I
08/07/22	10:00	41.9	0.168I
08/07/22	11:00	41.9	0.168I
08/07/22	12:00	41.9	0.168I
08/07/22	13:00	41.9	0.168I
08/07/22	14:00	41.9	0.168I
08/07/22	15:00	41.9	0.168I
08/07/22	16:00	41.9	0.168I
08/07/22	17:00	41.9	0.168I
08/07/22	18:00	41.9	0.168I
08/07/22	19:00	41.9	0.168I
08/07/22	20:00	41.9	0.168I
08/07/22	21:00	41.9	0.168I
08/07/22	22:00	41.9	0.168I
08/07/22	23:00	41.9	0.168I
08/08/22	00:00	41.9	0.168I
08/08/22	01:00	41.9	0.168I
08/08/22	02:00	41.9	0.168I
08/08/22	03:00	41.9	0.168I
08/08/22	04:00	41.9	0.168I
08/08/22	05:00	41.9	0.168I
08/08/22	06:00	41.9	0.168I
08/08/22	07:00	41.9	0.168I
08/08/22	08:00	41.9	0.168I
08/08/22	09:00	41.9	0.168I
08/08/22	10:00	41.9	0.168I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/08/22	11:00	41.9	0.168I
08/08/22	12:00	41.9	0.168I
08/08/22	13:00	41.9	0.168I
08/08/22	14:00	41.9	0.168I
08/08/22	15:00	41.9	0.168I
08/08/22	16:00	41.9	0.168I
08/08/22	17:00	41.9	0.168I
08/08/22	18:00	41.9	0.168I
08/08/22	19:00	41.9	0.168I
08/08/22	20:00	41.9	0.168I
08/08/22	21:00	41.9	0.168I
08/08/22	22:00	41.9	0.168I
08/08/22	23:00	41.9	0.168I
08/09/22	00:00	41.9	0.168I
08/09/22	01:00	41.9	0.168I
08/09/22	02:00	41.7	0.168I
08/09/22	03:00	41.3	0.168I
08/09/22	04:00	40.4	0.168I
08/09/22	05:00	39.7	0.171I
08/09/22	06:00	38.0	0.172I
08/09/22	07:00	34.2	0.158I
08/09/22	08:00	30.8	0.149I
08/09/22	09:00	28.4	0.145I
08/09/22	10:00	26.1	0.140I
08/09/22	11:00	23.8	0.136I
08/09/22	12:00	21.3	0.131I
08/09/22	13:00	18.9	0.126I
08/09/22	14:00	16.4	0.121I
08/09/22	15:00	14.1	0.116I
08/09/22	16:00	12.5	0.112I
08/09/22	17:00	12.4	0.112I
08/09/22	18:00	12.9	0.117I
08/09/22	19:00	13.4	0.117I
08/09/22	20:00	15.2	0.118I
08/09/22	21:00	18.4	0.122I
08/09/22	22:00	21.3	0.125I
08/09/22	23:00	24.2	0.128I
08/10/22	00:00	26.7	0.130
08/10/22	01:00	29.6	0.132
08/10/22	02:00	32.6	0.134
08/10/22	03:00	36.2	0.136
08/10/22	04:00	39.5	0.137
08/10/22	05:00	42.7	0.138
08/10/22	06:00	45.6	0.139
08/10/22	07:00	48.2	0.145
08/10/22	08:00	50.0	0.148
08/10/22	09:00	50.8	0.148

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/10/22	10:00	51.8	0.147
08/10/22	11:00	52.6	0.147
08/10/22	12:00	53.2	0.148
08/10/22	13:00	54.5	0.150
08/10/22	14:00	55.8	0.150
08/10/22	15:00	59.2	0.153
08/10/22	16:00	62.5	0.157
08/10/22	17:00	65.9	0.160
08/10/22	18:00	68.9	0.163
08/10/22	19:00	71.3	0.166
08/10/22	20:00	72.9	0.168
08/10/22	21:00	73.3	0.168
08/10/22	22:00	74.1	0.168
08/10/22	23:00	74.8	0.168
08/11/22	00:00	75.7	0.169
08/11/22	01:00	75.7	0.169
08/11/22	02:00	75.7	0.169
08/11/22	03:00	73.7	0.166
08/11/22	04:00	72.1	0.165
08/11/22	05:00	72.1	0.165
08/11/22	06:00	72.7	0.167
08/11/22	07:00	73.7	0.168
08/11/22	08:00	75.4	0.171
08/11/22	09:00	76.6	0.173
08/11/22	10:00	77.8	0.174
08/11/22	11:00	79.6	0.176
08/11/22	12:00	81.4	0.179
08/11/22	13:00	83.4	0.180
08/11/22	14:00	86.0	0.183
08/11/22	15:00	87.9	0.184
08/11/22	16:00	89.6	0.186
08/11/22	17:00	89.1	0.186
08/11/22	18:00	88.6	0.185
08/11/22	19:00	87.8	0.184
08/11/22	20:00	87.7	0.183
08/11/22	21:00	88.2	0.183
08/11/22	22:00	88.5	0.184
08/11/22	23:00	88.7	0.184
08/12/22	00:00	88.0	0.184
08/12/22	01:00	85.4	0.181
08/12/22	02:00	82.6	0.178
08/12/22	03:00	82.4	0.176
08/12/22	04:00	81.8	0.175
08/12/22	05:00	79.3	0.172
08/12/22	06:00	78.9	0.172
08/12/22	07:00	77.4	0.169
08/12/22	08:00	75.0	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/12/22	09:00	72.6	0.158
08/12/22	10:00	70.7	0.154
08/12/22	11:00	68.5	0.150
08/12/22	12:00	66.5	0.146
08/12/22	13:00	64.8	0.143
08/12/22	14:00	62.6	0.138
08/12/22	15:00	60.4	0.134
08/12/22	16:00	58.5	0.130
08/12/22	17:00	56.4	0.126
08/12/22	18:00	54.4	0.122
08/12/22	19:00	52.9	0.119
08/12/22	20:00	50.9	0.115
08/12/22	21:00	49.2	0.111
08/12/22	22:00	47.9	0.108
08/12/22	23:00	46.9	0.106
08/13/22	00:00	47.0	0.105
08/13/22	01:00	47.0	0.105
08/13/22	02:00	47.1	0.105
08/13/22	03:00	47.4	0.107
08/13/22	04:00	47.4	0.107
08/13/22	05:00	47.3	0.107
08/13/22	06:00	44.6	0.104
08/13/22	07:00	42.3	0.101
08/13/22	08:00	42.5	0.102
08/13/22	09:00	43.4	0.103
08/13/22	10:00	44.7	0.106
08/13/22	11:00	46.0	0.108
08/13/22	12:00	47.3	0.111
08/13/22	13:00	48.3	0.112
08/13/22	14:00	49.0	0.114
08/13/22	15:00	50.0	0.116
08/13/22	16:00	51.0	0.118
08/13/22	17:00	51.9	0.119
08/13/22	18:00	53.0	0.121
08/13/22	19:00	53.8	0.123
08/13/22	20:00	54.9	0.125
08/13/22	21:00	56.3	0.128
08/13/22	22:00	57.5	0.130
08/13/22	23:00	58.5	0.132
08/14/22	00:00	59.2	0.133
08/14/22	01:00	59.5	0.134
08/14/22	02:00	59.5	0.134
08/14/22	03:00	59.6	0.134
08/14/22	04:00	59.7	0.135
08/14/22	05:00	59.7	0.135
08/14/22	06:00	59.7	0.135
08/14/22	07:00	60.4	0.136

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/14/22	08:00	61.1	0.137
08/14/22	09:00	61.3	0.138
08/14/22	10:00	60.8	0.136
08/14/22	11:00	60.2	0.135
08/14/22	12:00	59.7	0.134
08/14/22	13:00	59.8	0.135
08/14/22	14:00	60.7	0.136
08/14/22	15:00	61.3	0.137
08/14/22	16:00	61.7	0.138
08/14/22	17:00	62.0	0.138
08/14/22	18:00	62.5	0.139
08/14/22	19:00	63.2	0.140
08/14/22	20:00	63.7	0.141
08/14/22	21:00	64.1	0.142
08/14/22	22:00	64.3	0.142
08/14/22	23:00	64.7	0.143
08/15/22	00:00	64.3	0.142
08/15/22	01:00	63.9	0.141
08/15/22	02:00	63.9	0.140
08/15/22	03:00	63.8	0.140
08/15/22	04:00	63.7	0.139
08/15/22	05:00	63.9	0.138
08/15/22	06:00	67.0	0.141
08/15/22	07:00	69.5	0.144
08/15/22	08:00	68.6	0.143
08/15/22	09:00	68.4	0.142
08/15/22	10:00	68.4	0.142
08/15/22	11:00	68.7	0.143
08/15/22	12:00	69.0	0.144
08/15/22	13:00	68.9	0.144
08/15/22	14:00	68.1	0.143
08/15/22	15:00	67.6	0.142
08/15/22	16:00	67.1	0.141
08/15/22	17:00	67.0	0.141
08/15/22	18:00	66.7	0.140
08/15/22	19:00	66.4	0.139
08/15/22	20:00	65.9	0.138
08/15/22	21:00	65.3	0.137
08/15/22	22:00	65.0	0.137
08/15/22	23:00	64.5	0.136
08/16/22	00:00	65.1	0.136
08/16/22	01:00	67.8	0.140
08/16/22	02:00	67.9	0.140
08/16/22	03:00	67.8	0.140
08/16/22	04:00	68.0	0.139
08/16/22	05:00	69.8	0.140
08/16/22	06:00	69.0	0.139

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/16/22	07:00	68.7	0.138
08/16/22	08:00	69.2	0.139
08/16/22	09:00	69.7	0.140
08/16/22	10:00	70.1	0.141
08/16/22	11:00	70.3	0.141
08/16/22	12:00	70.5	0.141
08/16/22	13:00	70.7	0.141
08/16/22	14:00	70.9	0.142
08/16/22	15:00	70.9	0.142
08/16/22	16:00	70.7	0.141
08/16/22	17:00	70.5	0.141
08/16/22	18:00	70.4	0.141
08/16/22	19:00	70.1	0.140
08/16/22	20:00	69.8	0.140
08/16/22	21:00	69.6	0.139
08/16/22	22:00	69.6	0.140
08/16/22	23:00	69.7	0.140
08/17/22	00:00	69.3	0.139
08/17/22	01:00	68.6	0.138
08/17/22	02:00	68.2	0.136
08/17/22	03:00	68.2	0.136
08/17/22	04:00	67.9	0.136
08/17/22	05:00	67.9	0.136
08/17/22	06:00	67.5	0.135
08/17/22	07:00	66.8	0.134
08/17/22	08:00	66.3	0.133
08/17/22	09:00	65.4	0.131
08/17/22	10:00	64.2	0.129
08/17/22	11:00	63.5	0.128
08/17/22	12:00	62.4	0.126
08/17/22	13:00	61.2	0.124
08/17/22	14:00	60.1	0.121
08/17/22	15:00	59.3	0.120
08/17/22	16:00	58.4	0.118
08/17/22	17:00	57.5	0.116
08/17/22	18:00	56.4	0.114
08/17/22	19:00	55.4	0.112
08/17/22	20:00	54.7	0.111
08/17/22	21:00	54.0	0.110
08/17/22	22:00	53.3	0.108
08/17/22	23:00	52.4	0.107
08/18/22	00:00	51.6	0.105
08/18/22	01:00	51.0	0.103
08/18/22	02:00	52.6	0.104
08/18/22	03:00	54.0	0.104
08/18/22	04:00	55.3	0.105
08/18/22	05:00	54.6	0.103

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/18/22	06:00	53.8	0.102
08/18/22	07:00	53.3	0.101
08/18/22	08:00	52.8	0.100
08/18/22	09:00	52.7	0.100
08/18/22	10:00	52.6	0.100
08/18/22	11:00	52.2	0.099
08/18/22	12:00	52.0	0.099
08/18/22	13:00	52.0	0.100
08/18/22	14:00	52.3	0.102
08/18/22	15:00	52.6	0.104
08/18/22	16:00	52.6	0.104
08/18/22	17:00	52.6	0.104
08/18/22	18:00	52.8	0.104
08/18/22	19:00	53.0	0.104
08/18/22	20:00	53.0	0.104
08/18/22	21:00	52.6	0.104
08/18/22	22:00	51.9	0.102
08/18/22	23:00	51.5	0.102
08/19/22	00:00	51.7	0.102
08/19/22	01:00	52.4	0.104
08/19/22	02:00	51.0	0.104
08/19/22	03:00	49.9	0.103
08/19/22	04:00	50.6	0.105
08/19/22	05:00	50.8	0.105
08/19/22	06:00	51.4	0.106
08/19/22	07:00	52.3	0.108
08/19/22	08:00	53.3	0.110
08/19/22	09:00	54.2	0.111
08/19/22	10:00	54.7	0.112
08/19/22	11:00	55.2	0.113
08/19/22	12:00	55.5	0.113
08/19/22	13:00	55.5	0.112
08/19/22	14:00	55.3	0.110
08/19/22	15:00	54.8	0.109
08/19/22	16:00	54.6	0.108
08/19/22	17:00	54.7	0.108
08/19/22	18:00	54.6	0.108
08/19/22	19:00	54.7	0.109
08/19/22	20:00	54.9	0.109
08/19/22	21:00	55.7	0.110
08/19/22	22:00	56.5	0.112
08/19/22	23:00	57.5	0.114
08/20/22	00:00	58.1	0.115
08/20/22	01:00	58.6	0.116
08/20/22	02:00	58.6	0.116
08/20/22	03:00	58.5	0.117
08/20/22	04:00	56.6	0.116

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/20/22	05:00	55.1	0.116
08/20/22	06:00	53.1	0.113
08/20/22	07:00	52.9	0.113
08/20/22	08:00	52.5	0.112
08/20/22	09:00	52.0	0.111
08/20/22	10:00	52.1	0.111
08/20/22	11:00	52.1	0.111
08/20/22	12:00	52.6	0.112
08/20/22	13:00	52.6	0.112
08/20/22	14:00	52.8	0.113
08/20/22	15:00	53.5	0.114
08/20/22	16:00	54.8	0.116
08/20/22	17:00	56.0	0.119
08/20/22	18:00	56.8	0.120
08/20/22	19:00	57.5	0.122
08/20/22	20:00	57.9	0.122
08/20/22	21:00	57.7	0.122
08/20/22	22:00	57.3	0.121
08/20/22	23:00	57.1	0.121
08/21/22	00:00	56.8	0.121
08/21/22	01:00	56.1	0.119
08/21/22	02:00	56.1	0.119
08/21/22	03:00	56.1	0.119
08/21/22	04:00	56.2	0.120
08/21/22	05:00	56.2	0.120
08/21/22	06:00	56.6	0.123
08/21/22	07:00	54.5	0.120
08/21/22	08:00	54.5	0.120
08/21/22	09:00	54.9	0.121
08/21/22	10:00	54.7	0.121
08/21/22	11:00	54.6	0.121
08/21/22	12:00	54.4	0.120
08/21/22	13:00	54.7	0.120
08/21/22	14:00	54.5	0.120
08/21/22	15:00	53.9	0.119
08/21/22	16:00	53.0	0.117
08/21/22	17:00	52.0	0.115
08/21/22	18:00	51.7	0.115
08/21/22	19:00	51.8	0.115
08/21/22	20:00	52.0	0.115
08/21/22	21:00	52.9	0.117
08/21/22	22:00	53.8	0.118
08/21/22	23:00	54.1	0.119
08/22/22	00:00	54.4	0.119
08/22/22	01:00	55.1	0.121
08/22/22	02:00	54.9	0.120
08/22/22	03:00	54.7	0.119

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/22/22	04:00	54.8	0.118
08/22/22	05:00	57.2	0.120
08/22/22	06:00	58.8	0.120
08/22/22	07:00	60.8	0.122
08/22/22	08:00	60.5	0.122
08/22/22	09:00	59.8	0.121
08/22/22	10:00	59.3	0.120
08/22/22	11:00	59.6	0.120
08/22/22	12:00	59.8	0.121
08/22/22	13:00	60.1	0.121
08/22/22	14:00	60.5	0.122
08/22/22	15:00	61.1	0.124
08/22/22	16:00	61.4	0.124
08/22/22	17:00	61.8	0.125
08/22/22	18:00	61.9	0.125
08/22/22	19:00	61.4	0.125
08/22/22	20:00	61.3	0.124
08/22/22	21:00	61.1	0.124
08/22/22	22:00	61.2	0.125
08/22/22	23:00	61.4	0.125
08/23/22	00:00	61.8	0.126
08/23/22	01:00	62.1	0.127
08/23/22	02:00	62.1	0.127
08/23/22	03:00	62.0	0.126
08/23/22	04:00	61.9	0.126
08/23/22	05:00	62.6	0.127
08/23/22	06:00	63.9	0.130
08/23/22	07:00	64.8	0.131
08/23/22	08:00	65.8	0.133
08/23/22	09:00	67.5	0.136
08/23/22	10:00	69.0	0.139
08/23/22	11:00	69.8	0.141
08/23/22	12:00	70.5	0.142
08/23/22	13:00	71.3	0.143
08/23/22	14:00	72.1	0.145
08/23/22	15:00	73.0	0.147
08/23/22	16:00	73.8	0.148
08/23/22	17:00	74.6	0.150
08/23/22	18:00	75.2	0.151
08/23/22	19:00	75.9	0.152
08/23/22	20:00	76.5	0.153
08/23/22	21:00	76.5	0.153
08/23/22	22:00	76.2	0.152
08/23/22	23:00	75.9	0.151
08/24/22	00:00	75.7	0.151
08/24/22	01:00	75.9	0.150
08/24/22	02:00	78.5	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/24/22	03:00	81.5	0.157
08/24/22	04:00	84.0	0.160
08/24/22	05:00	83.2	0.159
08/24/22	06:00	82.7	0.158
08/24/22	07:00	83.5	0.159
08/24/22	08:00	83.7	0.160
08/24/22	09:00	83.3	0.159
08/24/22	10:00	83.6	0.160
08/24/22	11:00	83.5	0.159
08/24/22	12:00	83.4	0.159
08/24/22	13:00	83.4	0.159
08/24/22	14:00	83.1	0.158
08/24/22	15:00	82.8	0.158
08/24/22	16:00	82.5	0.157
08/24/22	17:00	82.1	0.156
08/24/22	18:00	82.1	0.156
08/24/22	19:00	82.1	0.156
08/24/22	20:00	82.0	0.156
08/24/22	21:00	82.0	0.156
08/24/22	22:00	81.6	0.156
08/24/22	23:00	81.6	0.156
08/25/22	00:00	81.5	0.156
08/25/22	01:00	81.6	0.156
08/25/22	02:00	82.0	0.156
08/25/22	03:00	81.9	0.156
08/25/22	04:00	81.8	0.156
08/25/22	05:00	81.8	0.156
08/25/22	06:00	81.5	0.155
08/25/22	07:00	80.9	0.154
08/25/22	08:00	80.7	0.154
08/25/22	09:00	80.4	0.153
08/25/22	10:00	79.9	0.152
08/25/22	11:00	79.9	0.152
08/25/22	12:00	80.0	0.153
08/25/22	13:00	80.0	0.153
08/25/22	14:00	80.3	0.154
08/25/22	15:00	80.7	0.155
08/25/22	16:00	80.9	0.155
08/25/22	17:00	81.4	0.156
08/25/22	18:00	80.8	0.155
08/25/22	19:00	80.2	0.154
08/25/22	20:00	79.9	0.154
08/25/22	21:00	79.8	0.154
08/25/22	22:00	80.2	0.154
08/25/22	23:00	80.4	0.155
08/26/22	00:00	80.6	0.155
08/26/22	01:00	80.4	0.155

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/26/22	02:00	80.3	0.155
08/26/22	03:00	80.1	0.155
08/26/22	04:00	80.0	0.155
08/26/22	05:00	80.1	0.155
08/26/22	06:00	80.2	0.155
08/26/22	07:00	80.3	0.156
08/26/22	08:00	80.4	0.156
08/26/22	09:00	81.0	0.157
08/26/22	10:00	81.0	0.157
08/26/22	11:00	80.5	0.156
08/26/22	12:00	79.5	0.154
08/26/22	13:00	78.4	0.152
08/26/22	14:00	77.3	0.150
08/26/22	15:00	75.0	0.147
08/26/22	16:00	73.6	0.144
08/26/22	17:00	72.2	0.141
08/26/22	18:00	71.6	0.140
08/26/22	19:00	71.1	0.139
08/26/22	20:00	70.3	0.137
08/26/22	21:00	69.3	0.135
08/26/22	22:00	68.0	0.133
08/26/22	23:00	66.5	0.130
08/27/22	00:00	65.0	0.127
08/27/22	01:00	63.8	0.125
08/27/22	02:00	62.6	0.122
08/27/22	03:00	61.6	0.121
08/27/22	04:00	60.7	0.119
08/27/22	05:00	59.6	0.117
08/27/22	06:00	58.6	0.115
08/27/22	07:00	57.1	0.113
08/27/22	08:00	55.8	0.110
08/27/22	09:00	53.7	0.106
08/27/22	10:00	52.0	0.103
08/27/22	11:00	50.7	0.100
08/27/22	12:00	50.0	0.099
08/27/22	13:00	49.2	0.097
08/27/22	14:00	48.2	0.095
08/27/22	15:00	48.3	0.095
08/27/22	16:00	47.8	0.093
08/27/22	17:00	47.6	0.093
08/27/22	18:00	47.9	0.094
08/27/22	19:00	48.0	0.094
08/27/22	20:00	48.3	0.095
08/27/22	21:00	48.7	0.096
08/27/22	22:00	49.2	0.097
08/27/22	23:00	49.7	0.098
08/28/22	00:00	50.0	0.099

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
08/28/22	01:00		50.1	0.100
08/28/22	02:00		48.3	0.098
08/28/22	03:00		46.5	0.097
08/28/22	04:00		44.8	0.096
08/28/22	05:00		43.3	0.096
08/28/22	06:00		41.7	0.094
08/28/22	07:00		42.8	0.096
08/28/22	08:00		42.7	0.096
08/28/22	09:00		43.5	0.097
08/28/22	10:00		44.4	0.099
08/28/22	11:00		45.4	0.101
08/28/22	12:00		46.2	0.103
08/28/22	13:00		46.7	0.104
08/28/22	14:00		47.3	0.105
08/28/22	15:00		48.0	0.107
08/28/22	16:00		48.6	0.108
08/28/22	17:00		48.4	0.107
08/28/22	18:00		48.1	0.107
08/28/22	19:00		47.7	0.106
08/28/22	20:00		47.3	0.105
08/28/22	21:00		46.6	0.104
08/28/22	22:00		45.9	0.102
08/28/22	23:00		45.2	0.101
08/29/22	00:00		44.6	0.099
08/29/22	01:00		44.4	0.098
08/29/22	02:00		45.9	0.100
08/29/22	03:00		47.6	0.101
08/29/22	04:00		48.9	0.101
08/29/22	05:00		50.3	0.101
08/29/22	06:00		51.8	0.102
08/29/22	07:00		50.5	0.100
08/29/22	08:00		50.2	0.099
08/29/22	09:00		49.8	0.098
08/29/22	10:00		49.2	0.097
08/29/22	11:00		48.3	0.095
08/29/22	12:00		47.8	0.094
08/29/22	13:00		47.9	0.095
08/29/22	14:00		47.7	0.094
08/29/22	15:00		47.7	0.094
08/29/22	16:00		48.0	0.095
08/29/22	17:00		48.0	0.094
08/29/22	18:00		47.8	0.094
08/29/22	19:00		48.0	0.094
08/29/22	20:00		48.2	0.094
08/29/22	21:00		48.5	0.095
08/29/22	22:00		48.9	0.096
08/29/22	23:00		49.4	0.097

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
08/30/22	00:00		49.7	0.097
08/30/22	01:00		50.4	0.098
08/30/22	02:00		51.0	0.099
08/30/22	03:00		50.8	0.099
08/30/22	04:00		52.0	0.101
08/30/22	05:00		52.5	0.102
08/30/22	06:00		53.0	0.103
08/30/22	07:00		53.5	0.104
08/30/22	08:00		53.9	0.105
08/30/22	09:00		54.0	0.105
08/30/22	10:00		54.2	0.105
08/30/22	11:00		54.5	0.106
08/30/22	12:00		54.6	0.106
08/30/22	13:00		54.4	0.106
08/30/22	14:00		54.5	0.106
08/30/22	15:00		54.5	0.106
08/30/22	16:00		54.3	0.105
08/30/22	17:00		54.5	0.106
08/30/22	18:00		54.6	0.106
08/30/22	19:00		54.6	0.106
08/30/22	20:00		54.6	0.106
08/30/22	21:00		55.1	0.107
08/30/22	22:00		56.1	0.110
08/30/22	23:00		57.6	0.112
08/31/22	00:00		57.8	0.113
08/31/22	01:00		57.5	0.112
08/31/22	02:00		56.7	0.111
08/31/22	03:00		57.8	0.113
08/31/22	04:00		58.3	0.114
08/31/22	05:00		58.8	0.115
08/31/22	06:00		59.4	0.116
08/31/22	07:00		59.7	0.117
08/31/22	08:00		60.9	0.119
08/31/22	09:00		62.1	0.122
08/31/22	10:00		63.3	0.124
08/31/22	11:00		64.6	0.127
08/31/22	12:00		66.2	0.130
08/31/22	13:00		67.8	0.133
08/31/22	14:00		69.7	0.137
08/31/22	15:00		71.1	0.140
08/31/22	16:00		72.3	0.142
08/31/22	17:00		73.3	0.144
08/31/22	18:00		74.0	0.145
08/31/22	19:00		74.6	0.147
08/31/22	20:00		75.1	0.148
08/31/22	21:00		75.3	0.148
08/31/22	22:00		75.6	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
08/31/22	23:00	75.8	0.149
09/01/22	00:00	76.7	0.151
09/01/22	01:00	78.1	0.154
09/01/22	02:00	79.9	0.157
09/01/22	03:00	80.5	0.159
09/01/22	04:00	80.6	0.159
09/01/22	05:00	80.9	0.160
09/01/22	06:00	81.1	0.160
09/01/22	07:00	82.1	0.162
09/01/22	08:00	82.8	0.163
09/01/22	09:00	83.6	0.165
09/01/22	10:00	84.1	0.166
09/01/22	11:00	84.2	0.166
09/01/22	12:00	84.2	0.167
09/01/22	13:00	84.3	0.167
09/01/22	14:00	84.1	0.166
09/01/22	15:00	84.3	0.167
09/01/22	16:00	84.2	0.167
09/01/22	17:00	84.3	0.167
09/01/22	18:00	84.3	0.167
09/01/22	19:00	84.7	0.168
09/01/22	20:00	85.0	0.168
09/01/22	21:00	85.6	0.169
09/01/22	22:00	85.6	0.169
09/01/22	23:00	85.5	0.169
09/02/22	00:00	85.5	0.169
09/02/22	01:00	85.5	0.169
09/02/22	02:00	85.6	0.169
09/02/22	03:00	85.1	0.168
09/02/22	04:00	83.6	0.165
09/02/22	05:00	84.1	0.166
09/02/22	06:00	83.9	0.166
09/02/22	07:00	82.8	0.164
09/02/22	08:00	82.2	0.162
09/02/22	09:00	81.4	0.161
09/02/22	10:00	80.8	0.160
09/02/22	11:00	80.3	0.159
09/02/22	12:00	79.3	0.157
09/02/22	13:00	78.2	0.155
09/02/22	14:00	77.0	0.152
09/02/22	15:00	76.0	0.150
09/02/22	16:00	75.3	0.149
09/02/22	17:00	74.8	0.148
09/02/22	18:00	74.5	0.148
09/02/22	19:00	74.3	0.148
09/02/22	20:00	74.1	0.148
09/02/22	21:00	73.4	0.146

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/02/22	22:00	72.6	0.145
09/02/22	23:00	71.6	0.143
09/03/22	00:00	70.6	0.141
09/03/22	01:00	69.5	0.139
09/03/22	02:00	68.3	0.136
09/03/22	03:00	67.7	0.135
09/03/22	04:00	68.0	0.136
09/03/22	05:00	66.3	0.133
09/03/22	06:00	65.9	0.132
09/03/22	07:00	66.2	0.133
09/03/22	08:00	66.2	0.133
09/03/22	09:00	66.5	0.133
09/03/22	10:00	66.7	0.134
09/03/22	11:00	67.1	0.134
09/03/22	12:00	67.5	0.135
09/03/22	13:00	68.0	0.136
09/03/22	14:00	68.6	0.137
09/03/22	15:00	69.4	0.139
09/03/22	16:00	70.0	0.141
09/03/22	17:00	70.1	0.141
09/03/22	18:00	70.7	0.142
09/03/22	19:00	71.3	0.143
09/03/22	20:00	71.7	0.144
09/03/22	21:00	72.4	0.146
09/03/22	22:00	73.0	0.147
09/03/22	23:00	73.4	0.148
09/04/22	00:00	73.9	0.149
09/04/22	01:00	74.1	0.149
09/04/22	02:00	74.3	0.150
09/04/22	03:00	74.7	0.150
09/04/22	04:00	75.0	0.151
09/04/22	05:00	75.8	0.153
09/04/22	06:00	76.3	0.154
09/04/22	07:00	76.5	0.154
09/04/22	08:00	76.6	0.155
09/04/22	09:00	75.9	0.154
09/04/22	10:00	75.9	0.154
09/04/22	11:00	75.6	0.153
09/04/22	12:00	75.7	0.153
09/04/22	13:00	75.9	0.154
09/04/22	14:00	76.1	0.155
09/04/22	15:00	76.2	0.155
09/04/22	16:00	76.2	0.155
09/04/22	17:00	76.9	0.157
09/04/22	18:00	77.1	0.157
09/04/22	19:00	76.8	0.156
09/04/22	20:00	76.7	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/04/22	21:00	76.9	0.157
09/04/22	22:00	76.7	0.156
09/04/22	23:00	76.9	0.157
09/05/22	00:00	77.2	0.157
09/05/22	01:00	77.5	0.159
09/05/22	02:00	75.1	0.156
09/05/22	03:00	72.6	0.153
09/05/22	04:00	70.6	0.151
09/05/22	05:00	71.1	0.152
09/05/22	06:00	71.6	0.153
09/05/22	07:00	71.8	0.153
09/05/22	08:00	71.6	0.153
09/05/22	09:00	71.4	0.152
09/05/22	10:00	70.8	0.151
09/05/22	11:00	70.5	0.150
09/05/22	12:00	69.9	0.149
09/05/22	13:00	69.2	0.147
09/05/22	14:00	68.6	0.146
09/05/22	15:00	68.2	0.145
09/05/22	16:00	67.8	0.144
09/05/22	17:00	67.2	0.143
09/05/22	18:00	66.8	0.142
09/05/22	19:00	66.7	0.142
09/05/22	20:00	66.5	0.141
09/05/22	21:00	66.5	0.141
09/05/22	22:00	66.6	0.141
09/05/22	23:00	66.6	0.141
09/06/22	00:00	66.1	0.140
09/06/22	01:00	63.4	0.136
09/06/22	02:00	63.1	0.135
09/06/22	03:00	63.5	0.135
09/06/22	04:00	65.9	0.138
09/06/22	05:00	65.5	0.137
09/06/22	06:00	64.7	0.136
09/06/22	07:00	63.9	0.134
09/06/22	08:00	63.2	0.133
09/06/22	09:00	63.2	0.133
09/06/22	10:00	63.2	0.133
09/06/22	11:00	62.6	0.132
09/06/22	12:00	62.3	0.131
09/06/22	13:00	61.9	0.131
09/06/22	14:00	61.6	0.130
09/06/22	15:00	61.4	0.130
09/06/22	16:00	60.9	0.129
09/06/22	17:00	60.2	0.127
09/06/22	18:00	59.9	0.127
09/06/22	19:00	59.1	0.125

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/06/22	20:00	58.3	0.124
09/06/22	21:00	57.8	0.123
09/06/22	22:00	57.9	0.123
09/06/22	23:00	57.4	0.123
09/07/22	00:00	57.3	0.123
09/07/22	01:00	57.3	0.123
09/07/22	02:00	57.9	0.123
09/07/22	03:00	60.2	0.126
09/07/22	04:00	62.2	0.129
09/07/22	05:00	63.5	0.130
09/07/22	06:00	62.2	0.127
09/07/22	07:00	61.1	0.125
09/07/22	08:00	61.0	0.125
09/07/22	09:00	60.7	0.125
09/07/22	10:00	60.6	0.125
09/07/22	11:00	60.9	0.125
09/07/22	12:00	61.1	0.126
09/07/22	13:00	61.3	0.126
09/07/22	14:00	61.6	0.127
09/07/22	15:00	61.8	0.128
09/07/22	16:00	62.3	0.129
09/07/22	17:00	62.7	0.129
09/07/22	18:00	62.9	0.130
09/07/22	19:00	63.5	0.131
09/07/22	20:00	63.8	0.132
09/07/22	21:00	63.8	0.132
09/07/22	22:00	63.8	0.132
09/07/22	23:00	64.0	0.132
09/08/22	00:00	63.8	0.132
09/08/22	01:00	63.2	0.132
09/08/22	02:00	60.4	0.128
09/08/22	03:00	58.6	0.126
09/08/22	04:00	59.5	0.129
09/08/22	05:00	59.9	0.129
09/08/22	06:00	60.5	0.131
09/08/22	07:00	61.0	0.132
09/08/22	08:00	60.9	0.132
09/08/22	09:00	60.8	0.131
09/08/22	10:00	60.6	0.131
09/08/22	11:00	60.8	0.131
09/08/22	12:00	60.8	0.132
09/08/22	13:00	60.9	0.132
09/08/22	14:00	60.7	0.131
09/08/22	15:00	60.5	0.131
09/08/22	16:00	60.1	0.130
09/08/22	17:00	59.9	0.130
09/08/22	18:00	59.6	0.129

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/08/22	19:00	59.5	0.129
09/08/22	20:00	59.6	0.129
09/08/22	21:00	60.4	0.130
09/08/22	22:00	61.0	0.131
09/08/22	23:00	61.7	0.133
09/09/22	00:00	62.1	0.134
09/09/22	01:00	62.3	0.134
09/09/22	02:00	62.4	0.134
09/09/22	03:00	61.9	0.134
09/09/22	04:00	59.5	0.130
09/09/22	05:00	60.0	0.132
09/09/22	06:00	61.1	0.134
09/09/22	07:00	62.8	0.137
09/09/22	08:00	63.9	0.140
09/09/22	09:00	64.4	0.141
09/09/22	10:00	64.9	0.142
09/09/22	11:00	65.0	0.142
09/09/22	12:00	65.4	0.143
09/09/22	13:00	65.5	0.143
09/09/22	14:00	65.8	0.143
09/09/22	15:00	66.2	0.144
09/09/22	16:00	66.6	0.145
09/09/22	17:00	67.0	0.146
09/09/22	18:00	67.5	0.147
09/09/22	19:00	68.2	0.148
09/09/22	20:00	68.6	0.149
09/09/22	21:00	68.8	0.150
09/09/22	22:00	68.7	0.149
09/09/22	23:00	68.4	0.149
09/10/22	00:00	68.4	0.149
09/10/22	01:00	68.9	0.149
09/10/22	02:00	69.3	0.149
09/10/22	03:00	69.3	0.149
09/10/22	04:00	69.0	0.148
09/10/22	05:00	69.5	0.149
09/10/22	06:00	69.1	0.148
09/10/22	07:00	67.7	0.145
09/10/22	08:00	67.1	0.144
09/10/22	09:00	67.3	0.144
09/10/22	10:00	67.2	0.144
09/10/22	11:00	67.2	0.144
09/10/22	12:00	67.1	0.143
09/10/22	13:00	67.7	0.144
09/10/22	14:00	68.2	0.146
09/10/22	15:00	68.8	0.147
09/10/22	16:00	69.3	0.148
09/10/22	17:00	69.7	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/10/22	18:00	70.3	0.150
09/10/22	19:00	70.5	0.150
09/10/22	20:00	70.4	0.150
09/10/22	21:00	70.4	0.150
09/10/22	22:00	70.7	0.151
09/10/22	23:00	70.8	0.151
09/11/22	00:00	70.8	0.151
09/11/22	01:00	71.2	0.151
09/11/22	02:00	73.6	0.154
09/11/22	03:00	76.7	0.158
09/11/22	04:00	79.9	0.163
09/11/22	05:00	79.9	0.163
09/11/22	06:00	80.1	0.164
09/11/22	07:00	80.3	0.164
09/11/22	08:00	79.9	0.163
09/11/22	09:00	80.1	0.163
09/11/22	10:00	80.3	0.164
09/11/22	11:00	80.6	0.165
09/11/22	12:00	80.8	0.165
09/11/22	13:00	80.8	0.165
09/11/22	14:00	80.7	0.165
09/11/22	15:00	80.5	0.164
09/11/22	16:00	80.2	0.164
09/11/22	17:00	79.9	0.163
09/11/22	18:00	79.2	0.161
09/11/22	19:00	78.7	0.160
09/11/22	20:00	78.7	0.160
09/11/22	21:00	78.6	0.160
09/11/22	22:00	78.9	0.160
09/11/22	23:00	78.9	0.160
09/12/22	00:00	79.1	0.160
09/12/22	01:00	79.2	0.160
09/12/22	02:00	79.3	0.160
09/12/22	03:00	79.0	0.159
09/12/22	04:00	78.5	0.158
09/12/22	05:00	77.6	0.156
09/12/22	06:00	76.7	0.154
09/12/22	07:00	76.3	0.153
09/12/22	08:00	76.0	0.152
09/12/22	09:00	74.0	0.150
09/12/22	10:00	72.1	0.149
09/12/22	11:00	69.9	0.148
09/12/22	12:00	67.9	0.147
09/12/22	13:00	65.9	0.147
09/12/22	14:00	63.8	0.146
09/12/22	15:00	61.5	0.143
09/12/22	16:00	60.3	0.141

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/12/22	17:00	60.4	0.141
09/12/22	18:00	60.5	0.141
09/12/22	19:00	61.2	0.143
09/12/22	20:00	61.8	0.144
09/12/22	21:00	62.2	0.145
09/12/22	22:00	62.3	0.145
09/12/22	23:00	62.6	0.145
09/13/22	00:00	62.6	0.145
09/13/22	01:00	62.6	0.145
09/13/22	02:00	62.9	0.146
09/13/22	03:00	63.3	0.147
09/13/22	04:00	63.9	0.149
09/13/22	05:00	64.6	0.150
09/13/22	06:00	64.8	0.150
09/13/22	07:00	65.5	0.152
09/13/22	08:00	66.4	0.154
09/13/22	09:00	68.6	0.156
09/13/22	10:00	70.9	0.158
09/13/22	11:00	73.2	0.159
09/13/22	12:00	75.1	0.160
09/13/22	13:00	76.9	0.160
09/13/22	14:00	79.1	0.161
09/13/22	15:00	81.3	0.164
09/13/22	16:00	82.4	0.166
09/13/22	17:00	82.3	0.166
09/13/22	18:00	82.1	0.165
09/13/22	19:00	81.0	0.163
09/13/22	20:00	80.1	0.162
09/13/22	21:00	79.3	0.160
09/13/22	22:00	78.9	0.159
09/13/22	23:00	78.5	0.159
09/14/22	00:00	78.3	0.158
09/14/22	01:00	77.5	0.157
09/14/22	02:00	74.4	0.154
09/14/22	03:00	71.3	0.150
09/14/22	04:00	70.9	0.149
09/14/22	05:00	70.3	0.148
09/14/22	06:00	70.1	0.148
09/14/22	07:00	69.7	0.147
09/14/22	08:00	68.9	0.146
09/14/22	09:00	68.1	0.144
09/14/22	10:00	67.3	0.142
09/14/22	11:00	66.8	0.141
09/14/22	12:00	66.6	0.141
09/14/22	13:00	66.3	0.141
09/14/22	14:00	65.7	0.139
09/14/22	15:00	65.4	0.139

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/14/22	16:00	65.3	0.139
09/14/22	17:00	65.2	0.138
09/14/22	18:00	65.1	0.138
09/14/22	19:00	65.2	0.139
09/14/22	20:00	65.5	0.139
09/14/22	21:00	65.9	0.140
09/14/22	22:00	66.1	0.141
09/14/22	23:00	66.1	0.141
09/15/22	00:00	66.2	0.141
09/15/22	01:00	66.3	0.142
09/15/22	02:00	66.4	0.142
09/15/22	03:00	66.7	0.143
09/15/22	04:00	66.8	0.144
09/15/22	05:00	67.4	0.145
09/15/22	06:00	67.9	0.146
09/15/22	07:00	68.8	0.148
09/15/22	08:00	70.0	0.150
09/15/22	09:00	70.9	0.152
09/15/22	10:00	71.5	0.154
09/15/22	11:00	71.4	0.154
09/15/22	12:00	71.6	0.154
09/15/22	13:00	71.8	0.154
09/15/22	14:00	72.0	0.155
09/15/22	15:00	72.5	0.156
09/15/22	16:00	72.8	0.156
09/15/22	17:00	73.3	0.157
09/15/22	18:00	73.8	0.158
09/15/22	19:00	74.7	0.160
09/15/22	20:00	75.2	0.161
09/15/22	21:00	75.1	0.161
09/15/22	22:00	75.3	0.161
09/15/22	23:00	75.4	0.162
09/16/22	00:00	75.0	0.161
09/16/22	01:00	74.5	0.160
09/16/22	02:00	74.4	0.159
09/16/22	03:00	74.0	0.159
09/16/22	04:00	71.3	0.156
09/16/22	05:00	68.7	0.154
09/16/22	06:00	67.3	0.151
09/16/22	07:00	66.5	0.150
09/16/22	08:00	65.9	0.148
09/16/22	09:00	65.4	0.147
09/16/22	10:00	65.3	0.147
09/16/22	11:00	65.8	0.148
09/16/22	12:00	66.1	0.148
09/16/22	13:00	66.4	0.149
09/16/22	14:00	66.7	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/16/22	15:00	66.7	0.149
09/16/22	16:00	66.9	0.150
09/16/22	17:00	66.6	0.149
09/16/22	18:00	66.7	0.149
09/16/22	19:00	66.5	0.149
09/16/22	20:00	65.8	0.147
09/16/22	21:00	65.2	0.146
09/16/22	22:00	64.7	0.145
09/16/22	23:00	64.3	0.144
09/17/22	00:00	64.5	0.144
09/17/22	01:00	65.5	0.146
09/17/22	02:00	68.4	0.149
09/17/22	03:00	71.0	0.151
09/17/22	04:00	73.3	0.153
09/17/22	05:00	75.9	0.156
09/17/22	06:00	77.5	0.158
09/17/22	07:00	77.6	0.159
09/17/22	08:00	77.5	0.158
09/17/22	09:00	77.6	0.159
09/17/22	10:00	77.5	0.158
09/17/22	11:00	77.9	0.159
09/17/22	12:00	78.1	0.160
09/17/22	13:00	78.5	0.160
09/17/22	14:00	79.1	0.162
09/17/22	15:00	79.4	0.162
09/17/22	16:00	79.7	0.163
09/17/22	17:00	80.1	0.164
09/17/22	18:00	80.6	0.165
09/17/22	19:00	80.9	0.166
09/17/22	20:00	81.4	0.167
09/17/22	21:00	82.3	0.169
09/17/22	22:00	82.6	0.169
09/17/22	23:00	83.0	0.170
09/18/22	00:00	82.7	0.171
09/18/22	01:00	79.9	0.168
09/18/22	02:00	76.8	0.164
09/18/22	03:00	74.4	0.162
09/18/22	04:00	71.9	0.159
09/18/22	05:00	69.1	0.156
09/18/22	06:00	66.4	0.152
09/18/22	07:00	63.8	0.148
09/18/22	08:00	64.2	0.149
09/18/22	09:00	64.4	0.150
09/18/22	10:00	64.8	0.150
09/18/22	11:00	64.6	0.150
09/18/22	12:00	64.6	0.150
09/18/22	13:00	64.3	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/18/22	14:00	64.1	0.148
09/18/22	15:00	64.0	0.148
09/18/22	16:00	63.6	0.147
09/18/22	17:00	63.6	0.147
09/18/22	18:00	62.9	0.146
09/18/22	19:00	62.9	0.146
09/18/22	20:00	63.3	0.147
09/18/22	21:00	63.4	0.148
09/18/22	22:00	63.9	0.148
09/18/22	23:00	64.2	0.149
09/19/22	00:00	64.8	0.149
09/19/22	01:00	67.4	0.152
09/19/22	02:00	70.5	0.156
09/19/22	03:00	73.2	0.159
09/19/22	04:00	75.8	0.162
09/19/22	05:00	77.8	0.165
09/19/22	06:00	79.4	0.167
09/19/22	07:00	81.7	0.172
09/19/22	08:00	80.9	0.171
09/19/22	09:00	79.8	0.169
09/19/22	10:00	78.4	0.167
09/19/22	11:00	76.2	0.164
09/19/22	12:00	73.6	0.162
09/19/22	13:00	71.8	0.160
09/19/22	14:00	71.0	0.158
09/19/22	15:00	69.9	0.156
09/19/22	16:00	68.9	0.154
09/19/22	17:00	67.8	0.152
09/19/22	18:00	67.2	0.150
09/19/22	19:00	66.0	0.148
09/19/22	20:00	64.5	0.144
09/19/22	21:00	63.2	0.142
09/19/22	22:00	62.3	0.140
09/19/22	23:00	61.8	0.139
09/20/22	00:00	61.4	0.138
09/20/22	01:00	61.6	0.138
09/20/22	02:00	58.4	0.133
09/20/22	03:00	55.3	0.128
09/20/22	04:00	52.5	0.123
09/20/22	05:00	51.6	0.121
09/20/22	06:00	51.9	0.120
09/20/22	07:00	51.5	0.118
09/20/22	08:00	51.5	0.118
09/20/22	09:00	51.5	0.118
09/20/22	10:00	51.5	0.118
09/20/22	11:00	51.5	0.118
09/20/22	12:00	51.5	0.118

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/20/22	13:00	52.3	0.119
09/20/22	14:00	53.5	0.121
09/20/22	15:00	55.1	0.124
09/20/22	16:00	57.4	0.126
09/20/22	17:00	59.8	0.128
09/20/22	18:00	61.7	0.131
09/20/22	19:00	62.3	0.132
09/20/22	20:00	63.3	0.134
09/20/22	21:00	64.7	0.137
09/20/22	22:00	66.1	0.140
09/20/22	23:00	67.7	0.143
09/21/22	00:00	69.4	0.146
09/21/22	01:00	70.7	0.149
09/21/22	02:00	69.1	0.148
09/21/22	03:00	66.9	0.147
09/21/22	04:00	64.2	0.144
09/21/22	05:00	63.1	0.142
09/21/22	06:00	62.8	0.141
09/21/22	07:00	65.2	0.144
09/21/22	08:00	68.2	0.148
09/21/22	09:00	71.1	0.152
09/21/22	10:00	72.8	0.155
09/21/22	11:00	73.7	0.156
09/21/22	12:00	74.7	0.158
09/21/22	13:00	74.9	0.158
09/21/22	14:00	74.8	0.157
09/21/22	15:00	74.7	0.157
09/21/22	16:00	73.4	0.155
09/21/22	17:00	71.1	0.153
09/21/22	18:00	68.7	0.151
09/21/22	19:00	66.7	0.149
09/21/22	20:00	67.3	0.150
09/21/22	21:00	66.8	0.149
09/21/22	22:00	66.3	0.148
09/21/22	23:00	65.7	0.146
09/22/22	00:00	64.3	0.144
09/22/22	01:00	61.7	0.141
09/22/22	02:00	61.6	0.142
09/22/22	03:00	61.6	0.142
09/22/22	04:00	61.8	0.144
09/22/22	05:00	60.3	0.143
09/22/22	06:00	57.7	0.142
09/22/22	07:00	55.5	0.140
09/22/22	08:00	52.9	0.138
09/22/22	09:00	50.4	0.137
09/22/22	10:00	50.4	0.137
09/22/22	11:00	47.9	0.135

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/22/22	12:00	45.5	0.134
09/22/22	13:00	42.9	0.133
09/22/22	14:00	40.5	0.132
09/22/22	15:00	38.2	0.132
09/22/22	16:00	35.8	0.131
09/22/22	17:00	35.3	0.130
09/22/22	18:00	35.2	0.129
09/22/22	19:00	37.6	0.131
09/22/22	20:00	40.0	0.134
09/22/22	21:00	40.0	0.135
09/22/22	22:00	40.4	0.136
09/22/22	23:00	38.4	0.135
09/23/22	00:00	36.0	0.134
09/23/22	01:00	34.5	0.134
09/23/22	02:00	34.7	0.135
09/23/22	03:00	34.6	0.135
09/23/22	04:00	34.6	0.135
09/23/22	05:00	34.6	0.135
09/23/22	06:00	34.8	0.136
09/23/22	07:00	35.0	0.137
09/23/22	08:00	35.1	0.139
09/23/22	09:00	35.4	0.140
09/23/22	10:00	35.5	0.141
09/23/22	11:00	35.7	0.142
09/23/22	12:00	35.8	0.143
09/23/22	13:00	35.9	0.143
09/23/22	14:00	35.9	0.143
09/23/22	15:00	35.8	0.143
09/23/22	16:00	35.8	0.143
09/23/22	17:00	35.3	0.144
09/23/22	18:00	35.4	0.146
09/23/22	19:00	34.9	0.145
09/23/22	20:00	34.5	0.144
09/23/22	21:00	33.3	0.142
09/23/22	22:00	30.8	0.140
09/23/22	23:00	30.6	0.140
09/24/22	00:00	30.7	0.140
09/24/22	01:00	30.7	0.140
09/24/22	02:00	30.7	0.140
09/24/22	03:00	30.8	0.141
09/24/22	04:00	30.7	0.141
09/24/22	05:00	30.6	0.140
09/24/22	06:00	30.5	0.140
09/24/22	07:00	30.4	0.139
09/24/22	08:00	30.3	0.138
09/24/22	09:00	30.2	0.138
09/24/22	10:00	30.0	0.137

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/24/22	11:00	29.8	0.136
09/24/22	12:00	29.9	0.134
09/24/22	13:00	31.9	0.135
09/24/22	14:00	33.8	0.135
09/24/22	15:00	35.8	0.136
09/24/22	16:00	38.1	0.136
09/24/22	17:00	40.4	0.137
09/24/22	18:00	42.5	0.139
09/24/22	19:00	42.9	0.139
09/24/22	20:00	43.1	0.140
09/24/22	21:00	43.3	0.140
09/24/22	22:00	43.5	0.142
09/24/22	23:00	43.5	0.141
09/25/22	00:00	43.4	0.141
09/25/22	01:00	43.4	0.141
09/25/22	02:00	43.5	0.141
09/25/22	03:00	43.5	0.141
09/25/22	04:00	43.5	0.141
09/25/22	05:00	43.6	0.141
09/25/22	06:00	43.6	0.141
09/25/22	07:00	43.6	0.141
09/25/22	08:00	43.6	0.140
09/25/22	09:00	43.5	0.140
09/25/22	10:00	43.5	0.139
09/25/22	11:00	43.5	0.139
09/25/22	12:00	43.1	0.139
09/25/22	13:00	41.0	0.137
09/25/22	14:00	39.0	0.136
09/25/22	15:00	37.3	0.135
09/25/22	16:00	37.3	0.135
09/25/22	17:00	37.2	0.134
09/25/22	18:00	37.4	0.135
09/25/22	19:00	36.3	0.135
09/25/22	20:00	33.9	0.134
09/25/22	21:00	32.1	0.134
09/25/22	22:00	31.8	0.133
09/25/22	23:00	31.8	0.132
09/26/22	00:00	31.7	0.132
09/26/22	01:00	31.6	0.131
09/26/22	02:00	31.6	0.130
09/26/22	03:00	31.7	0.131
09/26/22	04:00	31.7	0.131
09/26/22	05:00	31.7	0.131
09/26/22	06:00	31.8	0.132
09/26/22	07:00	31.8	0.132
09/26/22	08:00	31.9	0.132
09/26/22	09:00	31.9	0.133

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/26/22	10:00	32.1	0.133
09/26/22	11:00	32.2	0.134
09/26/22	12:00	32.3	0.134
09/26/22	13:00	32.4	0.135
09/26/22	14:00	32.6	0.135
09/26/22	15:00	32.2	0.136
09/26/22	16:00	29.9	0.134
09/26/22	17:00	27.9	0.132
09/26/22	18:00	27.6	0.131
09/26/22	19:00	28.9	0.130
09/26/22	20:00	31.2	0.131
09/26/22	21:00	33.0	0.131
09/26/22	22:00	33.2	0.131
09/26/22	23:00	33.3	0.132
09/27/22	00:00	33.5	0.133
09/27/22	01:00	33.6	0.133
09/27/22	02:00	33.6	0.134
09/27/22	03:00	33.5	0.133
09/27/22	04:00	33.5	0.133
09/27/22	05:00	33.5	0.133
09/27/22	06:00	33.5	0.133
09/27/22	07:00	33.6	0.133
09/27/22	08:00	33.6	0.133
09/27/22	09:00	33.5	0.134
09/27/22	10:00	33.5	0.133
09/27/22	11:00	33.4	0.133
09/27/22	12:00	33.3	0.133
09/27/22	13:00	33.3	0.133
09/27/22	14:00	33.3	0.133
09/27/22	15:00	33.3	0.134
09/27/22	16:00	33.4	0.135
09/27/22	17:00	33.3	0.137
09/27/22	18:00	31.3	0.137
09/27/22	19:00	29.0	0.136
09/27/22	20:00	26.7	0.136
09/27/22	21:00	25.0	0.136
09/27/22	22:00	25.0	0.137
09/27/22	23:00	25.1	0.137
09/28/22	00:00	25.2	0.138
09/28/22	01:00	25.3	0.138
09/28/22	02:00	25.4	0.139
09/28/22	03:00	25.3	0.139
09/28/22	04:00	25.4	0.140
09/28/22	05:00	25.5	0.140
09/28/22	06:00	25.6	0.141
09/28/22	07:00	25.5	0.141
09/28/22	08:00	25.6	0.141

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/28/22	09:00	25.6	0.141
09/28/22	10:00	25.7	0.142
09/28/22	11:00	25.9	0.144
09/28/22	12:00	26.0	0.145
09/28/22	13:00	26.1	0.145
09/28/22	14:00	26.2	0.146
09/28/22	15:00	26.2	0.146
09/28/22	16:00	26.1	0.145
09/28/22	17:00	26.1	0.145
09/28/22	18:00	26.0	0.145
09/28/22	19:00	25.9	0.144
09/28/22	20:00	25.8	0.144
09/28/22	21:00	25.7	0.144
09/28/22	22:00	25.7	0.143
09/28/22	23:00	25.6	0.143
09/29/22	00:00	25.6	0.143
09/29/22	01:00	25.5	0.142
09/29/22	02:00	25.5	0.142
09/29/22	03:00	25.7	0.144
09/29/22	04:00	25.7	0.143
09/29/22	05:00	25.6	0.143
09/29/22	06:00	25.6	0.143
09/29/22	07:00	25.6	0.143
09/29/22	08:00	25.7	0.143
09/29/22	09:00	25.8	0.143
09/29/22	10:00	27.6	0.145
09/29/22	11:00	29.9	0.146
09/29/22	12:00	32.1	0.147
09/29/22	13:00	34.2	0.147
09/29/22	14:00	36.3	0.148
09/29/22	15:00	38.6	0.149
09/29/22	16:00	40.8	0.150
09/29/22	17:00	43.1	0.151
09/29/22	18:00	45.3	0.152
09/29/22	19:00	47.8	0.153
09/29/22	20:00	50.2	0.156
09/29/22	21:00	50.3	0.155
09/29/22	22:00	50.2	0.155
09/29/22	23:00	50.1	0.155
09/30/22	00:00	50.0	0.154
09/30/22	01:00	49.7	0.152
09/30/22	02:00	49.5	0.151
09/30/22	03:00	49.3	0.149
09/30/22	04:00	49.5	0.149
09/30/22	05:00	52.1	0.151
09/30/22	06:00	55.1	0.153
09/30/22	07:00	57.8	0.154

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
09/30/22	08:00	60.6	0.156
09/30/22	09:00	62.7	0.158
09/30/22	10:00	61.1	0.156
09/30/22	11:00	58.7	0.155
09/30/22	12:00	56.5	0.155
09/30/22	13:00	54.4	0.154
09/30/22	14:00	52.2	0.153
09/30/22	15:00	49.9	0.152
09/30/22	16:00	47.7	0.151
09/30/22	17:00	45.4	0.150
09/30/22	18:00	43.2	0.149
09/30/22	19:00	40.6	0.147
09/30/22	20:00	38.2	0.145
09/30/22	21:00	38.2	0.145
09/30/22	22:00	38.1	0.145
09/30/22	23:00	38.1	0.144
10/01/22	00:00	38.2	0.145
10/01/22	01:00	38.3	0.146
10/01/22	02:00	38.5	0.147
10/01/22	03:00	38.6	0.147
10/01/22	04:00	38.2	0.147
10/01/22	05:00	35.4	0.144
10/01/22	06:00	32.4	0.142
10/01/22	07:00	29.6	0.140
10/01/22	08:00	26.8	0.138
10/01/22	09:00	24.5	0.136
10/01/22	10:00	24.2	0.135
10/01/22	11:00	24.1	0.134
10/01/22	12:00	24.0	0.134
10/01/22	13:00	23.9	0.133
10/01/22	14:00	23.9	0.133
10/01/22	15:00	23.9	0.133
10/01/22	16:00	23.9	0.133
10/01/22	17:00	24.0	0.133
10/01/22	18:00	24.0	0.133
10/01/22	19:00	24.1	0.134
10/01/22	20:00	24.1	0.134
10/01/22	21:00	24.2	0.134
10/01/22	22:00	24.2	0.135
10/01/22	23:00	24.3	0.136
10/02/22	00:00	24.4	0.136
10/02/22	01:00	24.5	0.136
10/02/22	02:00	24.5	0.137
10/02/22	03:00	24.6	0.137
10/02/22	04:00	24.7	0.138
10/02/22	05:00	24.6	0.137
10/02/22	06:00	24.6	0.137

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/02/22	07:00	24.6	0.137
10/02/22	08:00	24.7	0.138
10/02/22	09:00	24.7	0.138
10/02/22	10:00	24.8	0.139
10/02/22	11:00	24.9	0.140
10/02/22	12:00	24.9	0.140
10/02/22	13:00	25.0	0.140
10/02/22	14:00	25.0	0.140
10/02/22	15:00	25.0	0.140
10/02/22	16:00	25.2	0.140
10/02/22	17:00	27.6	0.141
10/02/22	18:00	30.4	0.143
10/02/22	19:00	32.8	0.145
10/02/22	20:00	32.8	0.144
10/02/22	21:00	32.8	0.144
10/02/22	22:00	32.7	0.143
10/02/22	23:00	32.6	0.143
10/03/22	00:00	32.5	0.142
10/03/22	01:00	32.5	0.142
10/03/22	02:00	32.3	0.141
10/03/22	03:00	32.2	0.141
10/03/22	04:00	32.4	0.140
10/03/22	05:00	35.2	0.143
10/03/22	06:00	37.9	0.145
10/03/22	07:00	40.5	0.146
10/03/22	08:00	43.0	0.148
10/03/22	09:00	45.6	0.149
10/03/22	10:00	48.1	0.151
10/03/22	11:00	50.8	0.153
10/03/22	12:00	53.5	0.154
10/03/22	13:00	56.1	0.156
10/03/22	14:00	58.7	0.158
10/03/22	15:00	61.1	0.159
10/03/22	16:00	63.1	0.161
10/03/22	17:00	62.9	0.160
10/03/22	18:00	62.1	0.158
10/03/22	19:00	61.4	0.157
10/03/22	20:00	61.3	0.156
10/03/22	21:00	61.2	0.156
10/03/22	22:00	61.2	0.156
10/03/22	23:00	61.2	0.156
10/04/22	00:00	61.1	0.155
10/04/22	01:00	61.2	0.155
10/04/22	02:00	61.1	0.154
10/04/22	03:00	61.1	0.154
10/04/22	04:00	60.9	0.154
10/04/22	05:00	60.9	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/04/22	06:00	60.9	0.153
10/04/22	07:00	60.3	0.152
10/04/22	08:00	59.7	0.151
10/04/22	09:00	59.5	0.150
10/04/22	10:00	59.3	0.150
10/04/22	11:00	59.1	0.149
10/04/22	12:00	59.0	0.149
10/04/22	13:00	58.6	0.148
10/04/22	14:00	58.2	0.147
10/04/22	15:00	57.8	0.146
10/04/22	16:00	57.4	0.145
10/04/22	17:00	57.2	0.145
10/04/22	18:00	57.2	0.145
10/04/22	19:00	57.9	0.146
10/04/22	20:00	60.3	0.148
10/04/22	21:00	62.4	0.149
10/04/22	22:00	62.3	0.148
10/04/22	23:00	62.3	0.148
10/05/22	00:00	62.2	0.148
10/05/22	01:00	61.9	0.147
10/05/22	02:00	61.8	0.146
10/05/22	03:00	61.7	0.146
10/05/22	04:00	61.6	0.145
10/05/22	05:00	60.4	0.143
10/05/22	06:00	59.9	0.142
10/05/22	07:00	60.3	0.142
10/05/22	08:00	60.6	0.143
10/05/22	09:00	60.8	0.143
10/05/22	10:00	61.0	0.144
10/05/22	11:00	61.1	0.144
10/05/22	12:00	60.9	0.144
10/05/22	13:00	60.7	0.143
10/05/22	14:00	60.6	0.143
10/05/22	15:00	60.5	0.143
10/05/22	16:00	60.5	0.143
10/05/22	17:00	60.4	0.143
10/05/22	18:00	60.2	0.142
10/05/22	19:00	60.0	0.142
10/05/22	20:00	60.0	0.142
10/05/22	21:00	59.9	0.142
10/05/22	22:00	59.9	0.142
10/05/22	23:00	60.1	0.143
10/06/22	00:00	60.3	0.144
10/06/22	01:00	60.4	0.144
10/06/22	02:00	60.5	0.145
10/06/22	03:00	60.6	0.146
10/06/22	04:00	60.7	0.146

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/06/22	05:00	61.6	0.148
10/06/22	06:00	61.6	0.148
10/06/22	07:00	61.4	0.148
10/06/22	08:00	61.6	0.148
10/06/22	09:00	61.7	0.149
10/06/22	10:00	61.9	0.149
10/06/22	11:00	62.1	0.150
10/06/22	12:00	61.6	0.151
10/06/22	13:00	62.1	0.152
10/06/22	14:00	62.6	0.153
10/06/22	15:00	63.4	0.155
10/06/22	16:00	64.0	0.156
10/06/22	17:00	64.6	0.157
10/06/22	18:00	65.2	0.158
10/06/22	19:00	65.7	0.160
10/06/22	20:00	65.2	0.160
10/06/22	21:00	63.3	0.157
10/06/22	22:00	63.2	0.158
10/06/22	23:00	63.2	0.158
10/07/22	00:00	63.3	0.158
10/07/22	01:00	63.4	0.159
10/07/22	02:00	63.5	0.159
10/07/22	03:00	63.6	0.159
10/07/22	04:00	63.7	0.160
10/07/22	05:00	63.9	0.161
10/07/22	06:00	64.3	0.162
10/07/22	07:00	64.7	0.163
10/07/22	08:00	64.6	0.162
10/07/22	09:00	64.5	0.162
10/07/22	10:00	64.2	0.162
10/07/22	11:00	64.1	0.161
10/07/22	12:00	64.8	0.161
10/07/22	13:00	64.6	0.161
10/07/22	14:00	64.5	0.161
10/07/22	15:00	64.4	0.161
10/07/22	16:00	64.6	0.162
10/07/22	17:00	64.6	0.162
10/07/22	18:00	64.7	0.162
10/07/22	19:00	64.8	0.162
10/07/22	20:00	65.8	0.163
10/07/22	21:00	68.9	0.167
10/07/22	22:00	72.1	0.171
10/07/22	23:00	74.9	0.173
10/08/22	00:00	77.4	0.175
10/08/22	01:00	79.9	0.177
10/08/22	02:00	80.2	0.178
10/08/22	03:00	80.1	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/08/22	04:00	80.0	0.178
10/08/22	05:00	77.6	0.177
10/08/22	06:00	74.9	0.174
10/08/22	07:00	72.3	0.172
10/08/22	08:00	69.8	0.170
10/08/22	09:00	67.1	0.168
10/08/22	10:00	64.6	0.166
10/08/22	11:00	62.0	0.165
10/08/22	12:00	59.4	0.163
10/08/22	13:00	57.0	0.161
10/08/22	14:00	54.5	0.159
10/08/22	15:00	51.8	0.156
10/08/22	16:00	49.3	0.155
10/08/22	17:00	48.6	0.154
10/08/22	18:00	48.8	0.155
10/08/22	19:00	48.9	0.155
10/08/22	20:00	48.3	0.155
10/08/22	21:00	45.5	0.153
10/08/22	22:00	42.3	0.150
10/08/22	23:00	39.5	0.147
10/09/22	00:00	36.8	0.145
10/09/22	01:00	34.3	0.143
10/09/22	02:00	34.0	0.142
10/09/22	03:00	34.1	0.143
10/09/22	04:00	34.0	0.143
10/09/22	05:00	33.9	0.142
10/09/22	06:00	34.0	0.143
10/09/22	07:00	33.9	0.143
10/09/22	08:00	34.0	0.143
10/09/22	09:00	35.3	0.144
10/09/22	10:00	38.3	0.147
10/09/22	11:00	40.4	0.148
10/09/22	12:00	42.7	0.149
10/09/22	13:00	45.0	0.150
10/09/22	14:00	47.7	0.152
10/09/22	15:00	50.6	0.155
10/09/22	16:00	52.9	0.157
10/09/22	17:00	53.6	0.157
10/09/22	18:00	53.3	0.156
10/09/22	19:00	53.1	0.155
10/09/22	20:00	53.5	0.155
10/09/22	21:00	56.1	0.156
10/09/22	22:00	58.7	0.159
10/09/22	23:00	59.1	0.160
10/10/22	00:00	59.1	0.160
10/10/22	01:00	59.1	0.160
10/10/22	02:00	59.0	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/10/22	03:00	58.9	0.159
10/10/22	04:00	59.1	0.158
10/10/22	05:00	61.5	0.161
10/10/22	06:00	64.3	0.163
10/10/22	07:00	67.0	0.165
10/10/22	08:00	69.5	0.166
10/10/22	09:00	70.8	0.167
10/10/22	10:00	70.7	0.167
10/10/22	11:00	71.3	0.168
10/10/22	12:00	71.7	0.169
10/10/22	13:00	72.3	0.170
10/10/22	14:00	72.0	0.170
10/10/22	15:00	71.8	0.169
10/10/22	16:00	71.8	0.169
10/10/22	17:00	71.8	0.169
10/10/22	18:00	72.0	0.170
10/10/22	19:00	72.2	0.170
10/10/22	20:00	72.4	0.170
10/10/22	21:00	71.9	0.170
10/10/22	22:00	69.6	0.168
10/10/22	23:00	69.1	0.168
10/11/22	00:00	69.0	0.167
10/11/22	01:00	69.0	0.167
10/11/22	02:00	69.2	0.168
10/11/22	03:00	69.2	0.167
10/11/22	04:00	68.9	0.168
10/11/22	05:00	66.6	0.165
10/11/22	06:00	65.7	0.164
10/11/22	07:00	65.9	0.164
10/11/22	08:00	65.8	0.164
10/11/22	09:00	65.6	0.164
10/11/22	10:00	64.9	0.162
10/11/22	11:00	64.6	0.162
10/11/22	12:00	64.4	0.161
10/11/22	13:00	64.1	0.161
10/11/22	14:00	64.0	0.160
10/11/22	15:00	63.7	0.160
10/11/22	16:00	63.3	0.159
10/11/22	17:00	62.9	0.158
10/11/22	18:00	62.2	0.157
10/11/22	19:00	61.4	0.155
10/11/22	20:00	60.4	0.154
10/11/22	21:00	58.1	0.152
10/11/22	22:00	57.9	0.152
10/11/22	23:00	58.0	0.152
10/12/22	00:00	58.0	0.153
10/12/22	01:00	58.1	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/12/22	02:00	57.9	0.152
10/12/22	03:00	58.0	0.153
10/12/22	04:00	58.1	0.153
10/12/22	05:00	58.0	0.154
10/12/22	06:00	56.0	0.152
10/12/22	07:00	53.1	0.149
10/12/22	08:00	50.5	0.147
10/12/22	09:00	47.9	0.145
10/12/22	10:00	45.6	0.143
10/12/22	11:00	43.0	0.140
10/12/22	12:00	42.0	0.140
10/12/22	13:00	42.7	0.141
10/12/22	14:00	43.2	0.141
10/12/22	15:00	42.7	0.140
10/12/22	16:00	42.8	0.140
10/12/22	17:00	43.1	0.140
10/12/22	18:00	43.4	0.141
10/12/22	19:00	43.7	0.141
10/12/22	20:00	44.3	0.141
10/12/22	21:00	46.4	0.142
10/12/22	22:00	46.6	0.142
10/12/22	23:00	46.6	0.142
10/13/22	00:00	46.7	0.142
10/13/22	01:00	46.8	0.142
10/13/22	02:00	46.9	0.142
10/13/22	03:00	47.0	0.143
10/13/22	04:00	47.7	0.144
10/13/22	05:00	50.7	0.146
10/13/22	06:00	53.7	0.149
10/13/22	07:00	57.1	0.152
10/13/22	08:00	59.6	0.154
10/13/22	09:00	62.2	0.156
10/13/22	10:00	64.9	0.158
10/13/22	11:00	67.7	0.161
10/13/22	12:00	68.9	0.161
10/13/22	13:00	68.2	0.160
10/13/22	14:00	68.1	0.160
10/13/22	15:00	68.9	0.162
10/13/22	16:00	68.8	0.161
10/13/22	17:00	68.8	0.161
10/13/22	18:00	68.7	0.161
10/13/22	19:00	68.6	0.161
10/13/22	20:00	69.0	0.162
10/13/22	21:00	69.8	0.163
10/13/22	22:00	72.8	0.165
10/13/22	23:00	75.9	0.167
10/14/22	00:00	78.5	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
10/14/22	01:00		78.7	0.171
10/14/22	02:00		78.7	0.171
10/14/22	03:00		78.8	0.172
10/14/22	04:00		78.7	0.171
10/14/22	05:00		78.5	0.171
10/14/22	06:00		77.5	0.169
10/14/22	07:00		76.4	0.167
10/14/22	08:00		76.1	0.167
10/14/22	09:00		75.6	0.166
10/14/22	10:00		75.1	0.165
10/14/22	11:00		74.0	0.163
10/14/22	12:00		71.2	0.161
10/14/22	13:00		68.6	0.159
10/14/22	14:00		65.8	0.157
10/14/22	15:00		63.5	0.155
10/14/22	16:00		63.6	0.155
10/14/22	17:00		63.4	0.155
10/14/22	18:00		63.1	0.155
10/14/22	19:00		63.0	0.155
10/14/22	20:00		62.2	0.153
10/14/22	21:00		61.1	0.152
10/14/22	22:00		58.1	0.149
10/14/22	23:00		54.9	0.146
10/15/22	00:00		52.5	0.145
10/15/22	01:00		52.5	0.146
10/15/22	02:00		52.5	0.145
10/15/22	03:00		52.5	0.146
10/15/22	04:00		51.9	0.145
10/15/22	05:00		49.2	0.143
10/15/22	06:00		47.1	0.142
10/15/22	07:00		45.0	0.142
10/15/22	08:00		42.8	0.141
10/15/22	09:00		40.9	0.140
10/15/22	10:00		38.9	0.140
10/15/22	11:00		37.3	0.139
10/15/22	12:00		37.4	0.140
10/15/22	13:00		37.4	0.140
10/15/22	14:00		37.5	0.140
10/15/22	15:00		37.3	0.141
10/15/22	16:00		34.9	0.138
10/15/22	17:00		34.3	0.137
10/15/22	18:00		34.3	0.137
10/15/22	19:00		34.2	0.137
10/15/22	20:00		33.7	0.137
10/15/22	21:00		31.5	0.133
10/15/22	22:00		31.5	0.134
10/15/22	23:00		31.5	0.134

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
10/16/22	00:00		31.2	0.132
10/16/22	01:00		30.9	0.130
10/16/22	02:00		30.6	0.128
10/16/22	03:00		30.4	0.127
10/16/22	04:00		30.3	0.127
10/16/22	05:00		30.3	0.126
10/16/22	06:00		30.2	0.125
10/16/22	07:00		30.1	0.123
10/16/22	08:00		31.7	0.124
10/16/22	09:00		33.7	0.124
10/16/22	10:00		34.9	0.124
10/16/22	11:00		34.8	0.122
10/16/22	12:00		34.8	0.122
10/16/22	13:00		34.7	0.122
10/16/22	14:00		34.6	0.122
10/16/22	15:00		34.6	0.120
10/16/22	16:00		36.3	0.122
10/16/22	17:00		36.8	0.123
10/16/22	18:00		36.9	0.123
10/16/22	19:00		36.9	0.123
10/16/22	20:00		37.3	0.124
10/16/22	21:00		37.9	0.127
10/16/22	22:00		38.1	0.128
10/16/22	23:00		38.4	0.129
10/17/22	00:00		38.7	0.130
10/17/22	01:00		39.0	0.131
10/17/22	02:00		39.4	0.133
10/17/22	03:00		39.5	0.133
10/17/22	04:00		39.8	0.134
10/17/22	05:00		40.1	0.134
10/17/22	06:00		42.1	0.136
10/17/22	07:00		45.1	0.140
10/17/22	08:00		46.4	0.142
10/17/22	09:00		47.4	0.144
10/17/22	10:00		48.8	0.146
10/17/22	11:00		51.6	0.149
10/17/22	12:00		54.0	0.151
10/17/22	13:00		54.2	0.151
10/17/22	14:00		54.5	0.153
10/17/22	15:00		54.9	0.156
10/17/22	16:00		53.8	0.157
10/17/22	17:00		55.1	0.159
10/17/22	18:00		56.1	0.161
10/17/22	19:00		56.9	0.162
10/17/22	20:00		57.8	0.162
10/17/22	21:00		59.7	0.163
10/17/22	22:00		59.4	0.161

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/17/22	23:00	59.1	0.159
10/18/22	00:00	58.8	0.158
10/18/22	01:00	58.6	0.157
10/18/22	02:00	58.3	0.157
10/18/22	03:00	58.1	0.156
10/18/22	04:00	58.4	0.156
10/18/22	05:00	61.2	0.159
10/18/22	06:00	61.9	0.159
10/18/22	07:00	61.5	0.158
10/18/22	08:00	61.2	0.157
10/18/22	09:00	60.7	0.156
10/18/22	10:00	60.1	0.155
10/18/22	11:00	57.6	0.153
10/18/22	12:00	55.5	0.152
10/18/22	13:00	55.7	0.154
10/18/22	14:00	55.6	0.153
10/18/22	15:00	55.5	0.152
10/18/22	16:00	55.4	0.152
10/18/22	17:00	54.2	0.151
10/18/22	18:00	50.9	0.146
10/18/22	19:00	48.5	0.143
10/18/22	20:00	46.6	0.142
10/18/22	21:00	44.2	0.140
10/18/22	22:00	44.1	0.140
10/18/22	23:00	44.1	0.140
10/19/22	00:00	44.2	0.140
10/19/22	01:00	44.4	0.141
10/19/22	02:00	44.4	0.141
10/19/22	03:00	44.4	0.141
10/19/22	04:00	44.2	0.140
10/19/22	05:00	43.9	0.139
10/19/22	06:00	44.0	0.139
10/19/22	07:00	44.7	0.140
10/19/22	08:00	45.3	0.142
10/19/22	09:00	45.8	0.142
10/19/22	10:00	46.5	0.143
10/19/22	11:00	49.2	0.146
10/19/22	12:00	51.4	0.146
10/19/22	13:00	51.4	0.146
10/19/22	14:00	51.4	0.145
10/19/22	15:00	51.5	0.146
10/19/22	16:00	51.5	0.146
10/19/22	17:00	52.5	0.146
10/19/22	18:00	55.2	0.150
10/19/22	19:00	57.3	0.152
10/19/22	20:00	59.2	0.154
10/19/22	21:00	62.3	0.157

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/19/22	22:00	65.3	0.160
10/19/22	23:00	65.7	0.161
10/20/22	00:00	65.7	0.161
10/20/22	01:00	65.5	0.160
10/20/22	02:00	65.5	0.160
10/20/22	03:00	65.9	0.161
10/20/22	04:00	68.7	0.164
10/20/22	05:00	69.0	0.164
10/20/22	06:00	68.6	0.164
10/20/22	07:00	68.1	0.163
10/20/22	08:00	67.3	0.162
10/20/22	09:00	67.0	0.161
10/20/22	10:00	66.7	0.161
10/20/22	11:00	66.4	0.160
10/20/22	12:00	66.5	0.160
10/20/22	13:00	68.7	0.160
10/20/22	14:00	70.8	0.161
10/20/22	15:00	72.7	0.161
10/20/22	16:00	74.2	0.161
10/20/22	17:00	73.4	0.160
10/20/22	18:00	73.0	0.159
10/20/22	19:00	72.9	0.159
10/20/22	20:00	73.0	0.159
10/20/22	21:00	73.2	0.159
10/20/22	22:00	73.0	0.159
10/20/22	23:00	73.0	0.159
10/21/22	00:00	73.1	0.160
10/21/22	01:00	73.1	0.160
10/21/22	02:00	73.1	0.160
10/21/22	03:00	72.8	0.160
10/21/22	04:00	70.2	0.157
10/21/22	05:00	69.9	0.157
10/21/22	06:00	70.4	0.158
10/21/22	07:00	70.9	0.158
10/21/22	08:00	71.0	0.159
10/21/22	09:00	68.5	0.157
10/21/22	10:00	65.9	0.155
10/21/22	11:00	63.3	0.153
10/21/22	12:00	60.6	0.151
10/21/22	13:00	58.1	0.150
10/21/22	14:00	55.8	0.149
10/21/22	15:00	53.9	0.149
10/21/22	16:00	51.8	0.149
10/21/22	17:00	49.6	0.148
10/21/22	18:00	47.6	0.148
10/21/22	19:00	45.2	0.147
10/21/22	20:00	42.5	0.145

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/21/22	21:00	39.3	0.143
10/21/22	22:00	36.7	0.142
10/21/22	23:00	36.4	0.142
10/22/22	00:00	36.6	0.143
10/22/22	01:00	36.7	0.143
10/22/22	02:00	36.8	0.144
10/22/22	03:00	37.0	0.145
10/22/22	04:00	36.8	0.146
10/22/22	05:00	34.3	0.145
10/22/22	06:00	31.5	0.144
10/22/22	07:00	28.4	0.142
10/22/22	08:00	25.9	0.140
10/22/22	09:00	25.9	0.140
10/22/22	10:00	25.9	0.141
10/22/22	11:00	25.9	0.141
10/22/22	12:00	26.0	0.141
10/22/22	13:00	25.9	0.141
10/22/22	14:00	25.9	0.140
10/22/22	15:00	25.9	0.140
10/22/22	16:00	25.9	0.140
10/22/22	17:00	25.9	0.140
10/22/22	18:00	26.0	0.140
10/22/22	19:00	26.0	0.140
10/22/22	20:00	25.9	0.140
10/22/22	21:00	25.8	0.139
10/22/22	22:00	25.7	0.138
10/22/22	23:00	25.7	0.138
10/23/22	00:00	25.7	0.138
10/23/22	01:00	25.7	0.138
10/23/22	02:00	25.5	0.137
10/23/22	03:00	25.5	0.137
10/23/22	04:00	25.4	0.136
10/23/22	05:00	25.3	0.136
10/23/22	06:00	25.2	0.136
10/23/22	07:00	25.3	0.136
10/23/22	08:00	25.3	0.136
10/23/22	09:00	25.3	0.136
10/23/22	10:00	25.3	0.137
10/23/22	11:00	25.4	0.137
10/23/22	12:00	25.5	0.137
10/23/22	13:00	25.5	0.138
10/23/22	14:00	25.5	0.138
10/23/22	15:00	25.4	0.137
10/23/22	16:00	25.4	0.137
10/23/22	17:00	25.3	0.136
10/23/22	18:00	25.2	0.136
10/23/22	19:00	25.1	0.135

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/23/22	20:00	25.0	0.135
10/23/22	21:00	25.0	0.135
10/23/22	22:00	25.0	0.135
10/23/22	23:00	25.0	0.135
10/24/22	00:00	25.0	0.135
10/24/22	01:00	24.9	0.135
10/24/22	02:00	24.9	0.134
10/24/22	03:00	24.8	0.134
10/24/22	04:00	24.8	0.134
10/24/22	05:00	24.7	0.134
10/24/22	06:00	24.7	0.134
10/24/22	07:00	24.6	0.133
10/24/22	08:00	24.6	0.133
10/24/22	09:00	24.7	0.133
10/24/22	10:00	24.7	0.134
10/24/22	11:00	24.8	0.134
10/24/22	12:00	24.9	0.134
10/24/22	13:00	25.0	0.135
10/24/22	14:00	25.0	0.133
10/24/22	15:00	27.2	0.134
10/24/22	16:00	29.5	0.135
10/24/22	17:00	31.7	0.136
10/24/22	18:00	34.1	0.138
10/24/22	19:00	36.0	0.139
10/24/22	20:00	36.3	0.141
10/24/22	21:00	36.4	0.141
10/24/22	22:00	36.4	0.141
10/24/22	23:00	36.3	0.141
10/25/22	00:00	36.3	0.141
10/25/22	01:00	36.4	0.142
10/25/22	02:00	36.5	0.143
10/25/22	03:00	36.5	0.143
10/25/22	04:00	36.6	0.143
10/25/22	05:00	36.7	0.144
10/25/22	06:00	36.7	0.144
10/25/22	07:00	36.7	0.144
10/25/22	08:00	36.8	0.143
10/25/22	09:00	39.0	0.144
10/25/22	10:00	41.6	0.145
10/25/22	11:00	43.3	0.146
10/25/22	12:00	43.2	0.145
10/25/22	13:00	43.2	0.145
10/25/22	14:00	43.2	0.147
10/25/22	15:00	41.0	0.146
10/25/22	16:00	38.7	0.144
10/25/22	17:00	38.0	0.142
10/25/22	18:00	37.9	0.142

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/25/22	19:00	37.7	0.141
10/25/22	20:00	37.5	0.139
10/25/22	21:00	37.6	0.140
10/25/22	22:00	37.6	0.139
10/25/22	23:00	37.6	0.139
10/26/22	00:00	37.6	0.139
10/26/22	01:00	37.6	0.138
10/26/22	02:00	37.5	0.137
10/26/22	03:00	37.5	0.136
10/26/22	04:00	37.4	0.135
10/26/22	05:00	37.9	0.135
10/26/22	06:00	40.4	0.136
10/26/22	07:00	43.0	0.137
10/26/22	08:00	45.8	0.140
10/26/22	09:00	46.3	0.141
10/26/22	10:00	46.3	0.141
10/26/22	11:00	47.5	0.142
10/26/22	12:00	50.1	0.144
10/26/22	13:00	50.1	0.143
10/26/22	14:00	50.0	0.142
10/26/22	15:00	50.1	0.142
10/26/22	16:00	50.3	0.144
10/26/22	17:00	48.9	0.145
10/26/22	18:00	46.8	0.145
10/26/22	19:00	45.2	0.145
10/26/22	20:00	45.3	0.146
10/26/22	21:00	45.3	0.146
10/26/22	22:00	45.4	0.147
10/26/22	23:00	45.5	0.148
10/27/22	00:00	45.6	0.149
10/27/22	01:00	45.8	0.150
10/27/22	02:00	46.0	0.151
10/27/22	03:00	46.2	0.153
10/27/22	04:00	47.1	0.154
10/27/22	05:00	47.0	0.155
10/27/22	06:00	44.8	0.155
10/27/22	07:00	43.7	0.153
10/27/22	08:00	43.3	0.153
10/27/22	09:00	42.8	0.152
10/27/22	10:00	42.5	0.151
10/27/22	11:00	41.8	0.150
10/27/22	12:00	41.5	0.149
10/27/22	13:00	43.7	0.151
10/27/22	14:00	45.8	0.152
10/27/22	15:00	47.8	0.152
10/27/22	16:00	49.8	0.152
10/27/22	17:00	52.0	0.152

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/27/22	18:00	54.1	0.153
10/27/22	19:00	56.3	0.153
10/27/22	20:00	58.4	0.154
10/27/22	21:00	60.4	0.154
10/27/22	22:00	61.9	0.153
10/27/22	23:00	62.0	0.153
10/28/22	00:00	62.1	0.153
10/28/22	01:00	61.9	0.152
10/28/22	02:00	61.6	0.150
10/28/22	03:00	61.5	0.149
10/28/22	04:00	61.3	0.149
10/28/22	05:00	63.7	0.150
10/28/22	06:00	65.2	0.149
10/28/22	07:00	65.7	0.150
10/28/22	08:00	65.9	0.150
10/28/22	09:00	65.8	0.150
10/28/22	10:00	65.6	0.149
10/28/22	11:00	65.6	0.150
10/28/22	12:00	65.2	0.149
10/28/22	13:00	62.9	0.147
10/28/22	14:00	60.8	0.147
10/28/22	15:00	58.6	0.146
10/28/22	16:00	56.6	0.145
10/28/22	17:00	57.2	0.147
10/28/22	18:00	56.8	0.147
10/28/22	19:00	54.9	0.147
10/28/22	20:00	52.6	0.146
10/28/22	21:00	50.3	0.145
10/28/22	22:00	48.6	0.144
10/28/22	23:00	48.2	0.143
10/29/22	00:00	47.9	0.141
10/29/22	01:00	47.8	0.141
10/29/22	02:00	47.8	0.141
10/29/22	03:00	47.8	0.141
10/29/22	04:00	47.3	0.141
10/29/22	05:00	44.5	0.139
10/29/22	06:00	42.5	0.139
10/29/22	07:00	40.6	0.139
10/29/22	08:00	38.1	0.138
10/29/22	09:00	36.0	0.138
10/29/22	10:00	33.9	0.137
10/29/22	11:00	31.6	0.136
10/29/22	12:00	29.8	0.136
10/29/22	13:00	29.9	0.138
10/29/22	14:00	30.1	0.139
10/29/22	15:00	30.2	0.140
10/29/22	16:00	30.1	0.139

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
10/29/22	17:00	29.4	0.138
10/29/22	18:00	30.1	0.138
10/29/22	19:00	31.9	0.138
10/29/22	20:00	32.3	0.140
10/29/22	21:00	32.6	0.142
10/29/22	22:00	32.9	0.143
10/29/22	23:00	33.2	0.145
10/30/22	00:00	33.4	0.146
10/30/22	01:00	33.6	0.147
10/30/22	02:00	33.9	0.148
10/30/22	03:00	33.8	0.148
10/30/22	04:00	33.7	0.148
10/30/22	05:00	33.6	0.148
10/30/22	06:00	33.6	0.147
10/30/22	07:00	33.5	0.147
10/30/22	08:00	33.5	0.147
10/30/22	09:00	33.4	0.147
10/30/22	10:00	33.4	0.146
10/30/22	11:00	33.5	0.147
10/30/22	12:00	33.5	0.147
10/30/22	13:00	33.5	0.147
10/30/22	14:00	33.5	0.146
10/30/22	15:00	33.5	0.146
10/30/22	16:00	33.7	0.146
10/30/22	17:00	33.8	0.146
10/30/22	18:00	33.2	0.145
10/30/22	19:00	33.1	0.144
10/30/22	20:00	34.3	0.143
10/30/22	21:00	34.2	0.141
10/30/22	22:00	34.1	0.140
10/30/22	23:00	34.0	0.139
10/31/22	00:00	33.9	0.139
10/31/22	01:00	33.8	0.138
10/31/22	02:00	33.7	0.138
10/31/22	03:00	33.7	0.138
10/31/22	04:00	33.7	0.137
10/31/22	05:00	34.2	0.138
10/31/22	06:00	37.0	0.140
10/31/22	07:00	40.3	0.142
10/31/22	08:00	43.0	0.144
10/31/22	09:00	45.3	0.145
10/31/22	10:00	47.8	0.147
10/31/22	11:00	50.0	0.148
10/31/22	12:00	52.2	0.148
10/31/22	13:00	54.8	0.150
10/31/22	14:00	57.3	0.150
10/31/22	15:00	59.8	0.151

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
10/31/22	16:00		61.8	0.153
10/31/22	17:00		62.0	0.153
10/31/22	18:00		62.7	0.155
10/31/22	19:00		62.9	0.155
10/31/22	20:00		62.9	0.155
10/31/22	21:00		63.1	0.156
10/31/22	22:00		63.3	0.157
10/31/22	23:00		63.3	0.157
11/01/22	00:00		63.3	0.157
11/01/22	01:00		63.3	0.158
11/01/22	02:00		63.3	0.158
11/01/22	03:00		63.3	0.158
11/01/22	04:00		63.3	0.158
11/01/22	05:00		63.3	0.158
11/01/22	06:00		63.3	0.158
11/01/22	07:00		63.3	0.158
11/01/22	08:00		63.3	0.158
11/01/22	09:00		63.3	0.158
11/01/22	10:00		63.3	0.158
11/01/22	11:00		63.3	0.158
11/01/22	12:00		63.3	0.158
11/01/22	13:00		63.3	0.158
11/01/22	14:00		63.3	0.158
11/01/22	15:00		63.3	0.158
11/01/22	16:00		63.3	0.158
11/01/22	17:00		63.3	0.158
11/01/22	18:00		63.3	0.158
11/01/22	19:00		62.1	0.159
11/01/22	20:00		61.1	0.159
11/01/22	21:00		60.1	0.161
11/01/22	22:00		58.6	0.162
11/01/22	23:00		54.9	0.161
11/02/22	00:00		50.6	0.159I
11/02/22	01:00		47.2	0.157I
11/02/22	02:00		44.2	0.157I
11/02/22	03:00		41.3	0.156I
11/02/22	04:00		39.1	0.154I
11/02/22	05:00		37.0	0.154I
11/02/22	06:00		34.5	0.152I
11/02/22	07:00		32.2	0.152I
11/02/22	08:00		29.8	0.152I
11/02/22	09:00		27.7	0.153I
11/02/22	10:00		25.3	0.152I
11/02/22	11:00		22.9	0.150I
11/02/22	12:00		20.8	0.150I
11/02/22	13:00		19.4	0.151I
11/02/22	14:00		19.0	0.149I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/02/22	15:00	18.6	0.146I
11/02/22	16:00	18.6	0.143I
11/02/22	17:00	20.3	0.142I
11/02/22	18:00	22.0	0.142I
11/02/22	19:00	24.5	0.141I
11/02/22	20:00	25.5	0.141I
11/02/22	21:00	26.6	0.141
11/02/22	22:00	27.6	0.141
11/02/22	23:00	28.6	0.141
11/03/22	00:00	29.4	0.141
11/03/22	01:00	30.1	0.140
11/03/22	02:00	30.7	0.140
11/03/22	03:00	31.2	0.140
11/03/22	04:00	31.2	0.140
11/03/22	05:00	31.2	0.140
11/03/22	06:00	31.1	0.140
11/03/22	07:00	30.9	0.138
11/03/22	08:00	30.7	0.137
11/03/22	09:00	30.6	0.136
11/03/22	10:00	30.4	0.135
11/03/22	11:00	30.3	0.134
11/03/22	12:00	30.1	0.133
11/03/22	13:00	30.0	0.132
11/03/22	14:00	30.0	0.132
11/03/22	15:00	30.2	0.133
11/03/22	16:00	30.2	0.135
11/03/22	17:00	28.3	0.134
11/03/22	18:00	26.6	0.134
11/03/22	19:00	25.1	0.134
11/03/22	20:00	25.1	0.135
11/03/22	21:00	25.1	0.134
11/03/22	22:00	25.1	0.135
11/03/22	23:00	25.1	0.135
11/04/22	00:00	25.2	0.135
11/04/22	01:00	25.2	0.135
11/04/22	02:00	25.2	0.135
11/04/22	03:00	25.3	0.135
11/04/22	04:00	25.2	0.135
11/04/22	05:00	25.2	0.135
11/04/22	06:00	25.2	0.135
11/04/22	07:00	25.3	0.135
11/04/22	08:00	25.3	0.135
11/04/22	09:00	25.4	0.136
11/04/22	10:00	25.6	0.137
11/04/22	11:00	25.6	0.138
11/04/22	12:00	25.8	0.138
11/04/22	13:00	25.9	0.139

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/04/22	14:00	26.1	0.140
11/04/22	15:00	26.2	0.141
11/04/22	16:00	26.3	0.141
11/04/22	17:00	26.4	0.142
11/04/22	18:00	26.5	0.142
11/04/22	19:00	26.4	0.142
11/04/22	20:00	26.3	0.141
11/04/22	21:00	26.2	0.141
11/04/22	22:00	26.2	0.141
11/04/22	23:00	26.2	0.141
11/05/22	00:00	26.3	0.141
11/05/22	01:00	26.2	0.141
11/05/22	02:00	26.4	0.142
11/05/22	03:00	26.5	0.142
11/05/22	04:00	26.6	0.143
11/05/22	05:00	26.5	0.143
11/05/22	06:00	26.5	0.143
11/05/22	07:00	26.5	0.143
11/05/22	08:00	26.5	0.143
11/05/22	09:00	26.5	0.143
11/05/22	10:00	26.4	0.143
11/05/22	11:00	26.4	0.143
11/05/22	12:00	26.4	0.143
11/05/22	13:00	26.3	0.142
11/05/22	14:00	26.3	0.142
11/05/22	15:00	26.2	0.142
11/05/22	16:00	26.2	0.142
11/05/22	17:00	26.3	0.142
11/05/22	18:00	26.2	0.142
11/05/22	19:00	26.4	0.143
11/05/22	20:00	26.5	0.144
11/05/22	21:00	26.6	0.144
11/05/22	22:00	26.7	0.145
11/05/22	23:00	26.7	0.145
11/06/22	00:00	26.7	0.145
11/06/22	01:00	26.9	0.146
11/06/22	02:00	26.9	0.146
11/06/22	03:00	27.0	0.146
11/06/22	04:00	27.1	0.146
11/06/22	05:00	27.3	0.147
11/06/22	06:00	27.4	0.148
11/06/22	07:00	27.5	0.148
11/06/22	08:00	27.6	0.148
11/06/22	09:00	27.6	0.149
11/06/22	10:00	27.7	0.149
11/06/22	11:00	27.7	0.149
11/06/22	12:00	27.7	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/06/22	13:00		27.8	0.149
11/06/22	14:00		27.9	0.150
11/06/22	15:00		28.0	0.150
11/06/22	16:00		28.0	0.150
11/06/22	17:00		28.0	0.150
11/06/22	18:00		28.2	0.151
11/06/22	19:00		28.3	0.151
11/06/22	20:00		28.4	0.152
11/06/22	21:00		28.4	0.152
11/06/22	22:00		28.4	0.152
11/06/22	23:00		28.4	0.152
11/07/22	00:00		28.4	0.151
11/07/22	01:00		28.5	0.152
11/07/22	02:00		28.4	0.151
11/07/22	03:00		28.3	0.151
11/07/22	04:00		28.3	0.151
11/07/22	05:00		28.3	0.151
11/07/22	06:00		28.3	0.151
11/07/22	07:00		28.3	0.151
11/07/22	08:00		28.3	0.151
11/07/22	09:00		28.3	0.151
11/07/22	10:00		28.4	0.151
11/07/22	11:00		28.4	0.152
11/07/22	12:00		28.5	0.152
11/07/22	13:00		28.6	0.152
11/07/22	14:00		28.7	0.152
11/07/22	15:00		28.7	0.153
11/07/22	16:00		28.7	0.152
11/07/22	17:00		28.9	0.152
11/07/22	18:00		31.0	0.153
11/07/22	19:00		33.1	0.153
11/07/22	20:00		33.1	0.152
11/07/22	21:00		33.0	0.152
11/07/22	22:00		32.9	0.152
11/07/22	23:00		32.7	0.151
11/08/22	00:00		32.7	0.151
11/08/22	01:00		32.6	0.151
11/08/22	02:00		32.6	0.151
11/08/22	03:00		32.4	0.150
11/08/22	04:00		32.3	0.149
11/08/22	05:00		32.3	0.149
11/08/22	06:00		32.2	0.149
11/08/22	07:00		32.1	0.148
11/08/22	08:00		32.0	0.148
11/08/22	09:00		31.9	0.147
11/08/22	10:00		31.8	0.147
11/08/22	11:00		31.7	0.146

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/08/22	12:00	31.5	0.145
11/08/22	13:00	31.4	0.145
11/08/22	14:00	31.3	0.145
11/08/22	15:00	31.2	0.143
11/08/22	16:00	31.3	0.142
11/08/22	17:00	32.9	0.143
11/08/22	18:00	33.2	0.143
11/08/22	19:00	33.1	0.142
11/08/22	20:00	33.3	0.143
11/08/22	21:00	33.4	0.144
11/08/22	22:00	33.4	0.144
11/08/22	23:00	33.4	0.145
11/09/22	00:00	33.4	0.145
11/09/22	01:00	33.4	0.145
11/09/22	02:00	33.4	0.145
11/09/22	03:00	33.4	0.145
11/09/22	04:00	33.3	0.145
11/09/22	05:00	33.3	0.144
11/09/22	06:00	33.2	0.144
11/09/22	07:00	33.1	0.144
11/09/22	08:00	33.0	0.143
11/09/22	09:00	33.0	0.143
11/09/22	10:00	33.0	0.143
11/09/22	11:00	32.9	0.143
11/09/22	12:00	32.8	0.143
11/09/22	13:00	32.8	0.143
11/09/22	14:00	32.9	0.143
11/09/22	15:00	32.9	0.144
11/09/22	16:00	32.7	0.145
11/09/22	17:00	30.7	0.144
11/09/22	18:00	28.2	0.143
11/09/22	19:00	26.1	0.142
11/09/22	20:00	25.8	0.141
11/09/22	21:00	25.7	0.141
11/09/22	22:00	25.7	0.140
11/09/22	23:00	25.7	0.140
11/10/22	00:00	25.7	0.140
11/10/22	01:00	25.7	0.140
11/10/22	02:00	25.8	0.140
11/10/22	03:00	25.8	0.140
11/10/22	04:00	25.9	0.140
11/10/22	05:00	26.0	0.141
11/10/22	06:00	26.1	0.141
11/10/22	07:00	26.1	0.142
11/10/22	08:00	26.2	0.142
11/10/22	09:00	26.3	0.143
11/10/22	10:00	26.4	0.143

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/10/22	11:00	26.5	0.144
11/10/22	12:00	26.7	0.145
11/10/22	13:00	26.8	0.146
11/10/22	14:00	26.7	0.146
11/10/22	15:00	26.7	0.146
11/10/22	16:00	26.8	0.146
11/10/22	17:00	26.9	0.147
11/10/22	18:00	27.0	0.147
11/10/22	19:00	27.1	0.147
11/10/22	20:00	27.2	0.148
11/10/22	21:00	27.3	0.149
11/10/22	22:00	27.4	0.149
11/10/22	23:00	27.4	0.148
11/11/22	00:00	27.4	0.148
11/11/22	01:00	27.3	0.148
11/11/22	02:00	27.4	0.148
11/11/22	03:00	27.4	0.148
11/11/22	04:00	27.5	0.149
11/11/22	05:00	27.6	0.149
11/11/22	06:00	27.7	0.149
11/11/22	07:00	27.7	0.150
11/11/22	08:00	27.8	0.150
11/11/22	09:00	27.8	0.150
11/11/22	10:00	27.7	0.149
11/11/22	11:00	27.6	0.148
11/11/22	12:00	27.6	0.148
11/11/22	13:00	27.6	0.148
11/11/22	14:00	27.6	0.148
11/11/22	15:00	27.7	0.148
11/11/22	16:00	27.8	0.148
11/11/22	17:00	27.7	0.148
11/11/22	18:00	27.8	0.148
11/11/22	19:00	27.9	0.148
11/11/22	20:00	27.9	0.148
11/11/22	21:00	28.0	0.149
11/11/22	22:00	28.4	0.151
11/11/22	23:00	28.5	0.151
11/12/22	00:00	28.6	0.152
11/12/22	01:00	28.7	0.153
11/12/22	02:00	28.7	0.153
11/12/22	03:00	28.5	0.152
11/12/22	04:00	28.2	0.150
11/12/22	05:00	28.2	0.150
11/12/22	06:00	28.1	0.149
11/12/22	07:00	27.9	0.147
11/12/22	08:00	27.7	0.146
11/12/22	09:00	27.6	0.145

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/12/22	10:00		27.5	0.145
11/12/22	11:00		27.5	0.144
11/12/22	12:00		27.4	0.143
11/12/22	13:00		27.3	0.143
11/12/22	14:00		27.4	0.143
11/12/22	15:00		27.3	0.143
11/12/22	16:00		27.3	0.141
11/12/22	17:00		29.6	0.142
11/12/22	18:00		32.1	0.144
11/12/22	19:00		34.7	0.145
11/12/22	20:00		37.3	0.146
11/12/22	21:00		39.8	0.147
11/12/22	22:00		42.2	0.146
11/12/22	23:00		44.5	0.148
11/13/22	00:00		44.4	0.146
11/13/22	01:00		44.4	0.147
11/13/22	02:00		44.5	0.147
11/13/22	03:00		44.6	0.148
11/13/22	04:00		45.0	0.151
11/13/22	05:00		45.0	0.151
11/13/22	06:00		45.6	0.152
11/13/22	07:00		48.8	0.155
11/13/22	08:00		51.7	0.158
11/13/22	09:00		54.5	0.160
11/13/22	10:00		57.4	0.163
11/13/22	11:00		60.1	0.165
11/13/22	12:00		62.0	0.166
11/13/22	13:00		62.1	0.165
11/13/22	14:00		62.1	0.167
11/13/22	15:00		62.2	0.167
11/13/22	16:00		62.3	0.168
11/13/22	17:00		60.2	0.165
11/13/22	18:00		57.8	0.162
11/13/22	19:00		55.3	0.159
11/13/22	20:00		52.8	0.156
11/13/22	21:00		50.2	0.152
11/13/22	22:00		47.5	0.149
11/13/22	23:00		45.0	0.147
11/14/22	00:00		45.1	0.148
11/14/22	01:00		45.0	0.148
11/14/22	02:00		45.0	0.148
11/14/22	03:00		45.0	0.149
11/14/22	04:00		45.3	0.148
11/14/22	05:00		47.7	0.149
11/14/22	06:00		49.6	0.150
11/14/22	07:00		49.1	0.149
11/14/22	08:00		48.9	0.149

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/14/22	09:00		48.6	0.148
11/14/22	10:00		48.5	0.148
11/14/22	11:00		48.6	0.148
11/14/22	12:00		49.5	0.149
11/14/22	13:00		52.1	0.151
11/14/22	14:00		54.7	0.152
11/14/22	15:00		57.2	0.152
11/14/22	16:00		59.6	0.154
11/14/22	17:00		61.8	0.157
11/14/22	18:00		64.2	0.160
11/14/22	19:00		66.6	0.163
11/14/22	20:00		69.0	0.166
11/14/22	21:00		71.4	0.170
11/14/22	22:00		74.0	0.172
11/14/22	23:00		77.0	0.175
11/15/22	00:00		80.0	0.177
11/15/22	01:00		82.7	0.178
11/15/22	02:00		85.4	0.179
11/15/22	03:00		87.9	0.179
11/15/22	04:00		90.6	0.182
11/15/22	05:00		90.7	0.182
11/15/22	06:00		90.6	0.182
11/15/22	07:00		90.5	0.181
11/15/22	08:00		90.4	0.181
11/15/22	09:00		90.4	0.181
11/15/22	10:00		90.1	0.181
11/15/22	11:00		89.9	0.180
11/15/22	12:00		89.5	0.179
11/15/22	13:00		89.1	0.179
11/15/22	14:00		88.6	0.177
11/15/22	15:00		88.1	0.176
11/15/22	16:00		87.7	0.175
11/15/22	17:00		87.8	0.175
11/15/22	18:00		87.6	0.175
11/15/22	19:00		87.5	0.174
11/15/22	20:00		87.5	0.174
11/15/22	21:00		87.7	0.174
11/15/22	22:00		87.7	0.174
11/15/22	23:00		87.6	0.173
11/16/22	00:00		87.3	0.173
11/16/22	01:00		86.4	0.172
11/16/22	02:00		83.7	0.170
11/16/22	03:00		81.1	0.169
11/16/22	04:00		78.0	0.165
11/16/22	05:00		77.9	0.165
11/16/22	06:00		78.0	0.165
11/16/22	07:00		78.1	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/16/22	08:00	78.1	0.164
11/16/22	09:00	78.3	0.164
11/16/22	10:00	78.3	0.164
11/16/22	11:00	78.2	0.164
11/16/22	12:00	78.1	0.163
11/16/22	13:00	78.2	0.163
11/16/22	14:00	78.3	0.163
11/16/22	15:00	78.5	0.164
11/16/22	16:00	78.9	0.165
11/16/22	17:00	78.8	0.165
11/16/22	18:00	78.9	0.165
11/16/22	19:00	79.0	0.166
11/16/22	20:00	78.9	0.166
11/16/22	21:00	78.5	0.165
11/16/22	22:00	78.2	0.164
11/16/22	23:00	77.9	0.164
11/17/22	00:00	77.9	0.164
11/17/22	01:00	78.6	0.164
11/17/22	02:00	80.9	0.165
11/17/22	03:00	83.3	0.166
11/17/22	04:00	85.8	0.169
11/17/22	05:00	85.9	0.169
11/17/22	06:00	85.7	0.169
11/17/22	07:00	85.6	0.169
11/17/22	08:00	85.6	0.169
11/17/22	09:00	85.5	0.169
11/17/22	10:00	85.2	0.168
11/17/22	11:00	85.2	0.168
11/17/22	12:00	85.2	0.168
11/17/22	13:00	85.1	0.168
11/17/22	14:00	85.1	0.169
11/17/22	15:00	85.1	0.169
11/17/22	16:00	84.9	0.168
11/17/22	17:00	84.8	0.168
11/17/22	18:00	84.7	0.168
11/17/22	19:00	84.6	0.168
11/17/22	20:00	84.7	0.168
11/17/22	21:00	85.0	0.169
11/17/22	22:00	85.5	0.169
11/17/22	23:00	85.9	0.170
11/18/22	00:00	86.3	0.171
11/18/22	01:00	86.1	0.171
11/18/22	02:00	83.7	0.169
11/18/22	03:00	81.2	0.168
11/18/22	04:00	78.8	0.166
11/18/22	05:00	78.9	0.166
11/18/22	06:00	79.2	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/18/22	07:00		79.5	0.167
11/18/22	08:00		79.7	0.167
11/18/22	09:00		79.8	0.167
11/18/22	10:00		78.1	0.165
11/18/22	11:00		75.7	0.162
11/18/22	12:00		73.4	0.159
11/18/22	13:00		71.2	0.156
11/18/22	14:00		68.9	0.153
11/18/22	15:00		66.6	0.150
11/18/22	16:00		64.5	0.147
11/18/22	17:00		64.5	0.148
11/18/22	18:00		64.8	0.148
11/18/22	19:00		65.1	0.148
11/18/22	20:00		64.9	0.148
11/18/22	21:00		64.6	0.148
11/18/22	22:00		64.5	0.148
11/18/22	23:00		64.5	0.148
11/19/22	00:00		64.4	0.147
11/19/22	01:00		64.7	0.147
11/19/22	02:00		67.5	0.150
11/19/22	03:00		70.2	0.152
11/19/22	04:00		72.7	0.154
11/19/22	05:00		72.6	0.154
11/19/22	06:00		72.4	0.154
11/19/22	07:00		72.3	0.154
11/19/22	08:00		72.0	0.153
11/19/22	09:00		71.5	0.152
11/19/22	10:00		73.0	0.154
11/19/22	11:00		73.0	0.154
11/19/22	12:00		72.9	0.156
11/19/22	13:00		72.9	0.159
11/19/22	14:00		73.0	0.161
11/19/22	15:00		72.9	0.163
11/19/22	16:00		72.8	0.164
11/19/22	17:00		72.2	0.162
11/19/22	18:00		71.7	0.161
11/19/22	19:00		71.2	0.160
11/19/22	20:00		71.1	0.160
11/19/22	21:00		70.9	0.160
11/19/22	22:00		70.4	0.159
11/19/22	23:00		70.0	0.158
11/20/22	00:00		69.3	0.157
11/20/22	01:00		66.7	0.155
11/20/22	02:00		64.0	0.154
11/20/22	03:00		61.5	0.153
11/20/22	04:00		58.9	0.153
11/20/22	05:00		56.4	0.152

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/20/22	06:00	53.9	0.151
11/20/22	07:00	51.3	0.150
11/20/22	08:00	49.1	0.149
11/20/22	09:00	47.1	0.149
11/20/22	10:00	45.3	0.150
11/20/22	11:00	45.4	0.153
11/20/22	12:00	45.5	0.153
11/20/22	13:00	45.5	0.153
11/20/22	14:00	45.4	0.152
11/20/22	15:00	45.4	0.153
11/20/22	16:00	45.6	0.153
11/20/22	17:00	45.8	0.154
11/20/22	18:00	45.8	0.154
11/20/22	19:00	45.9	0.154
11/20/22	20:00	46.1	0.155
11/20/22	21:00	44.2	0.155
11/20/22	22:00	42.0	0.155
11/20/22	23:00	39.6	0.154
11/21/22	00:00	37.5	0.154
11/21/22	01:00	37.5	0.155
11/21/22	02:00	37.5	0.155
11/21/22	03:00	37.5	0.154
11/21/22	04:00	37.4	0.154
11/21/22	05:00	37.8	0.154
11/21/22	06:00	40.1	0.154
11/21/22	07:00	42.6	0.155
11/21/22	08:00	45.1	0.156
11/21/22	09:00	47.4	0.157
11/21/22	10:00	49.6	0.157
11/21/22	11:00	51.8	0.158
11/21/22	12:00	54.2	0.158
11/21/22	13:00	56.5	0.159
11/21/22	14:00	59.0	0.160
11/21/22	15:00	61.4	0.160
11/21/22	16:00	63.6	0.162
11/21/22	17:00	64.0	0.163
11/21/22	18:00	64.3	0.163
11/21/22	19:00	64.5	0.163
11/21/22	20:00	64.8	0.163
11/21/22	21:00	67.0	0.164
11/21/22	22:00	69.3	0.164
11/21/22	23:00	72.1	0.166
11/22/22	00:00	75.0	0.167
11/22/22	01:00	77.7	0.168
11/22/22	02:00	80.4	0.170
11/22/22	03:00	83.2	0.170
11/22/22	04:00	86.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/22/22	05:00		88.5	0.174
11/22/22	06:00		88.7	0.174
11/22/22	07:00		88.6	0.173
11/22/22	08:00		88.5	0.173
11/22/22	09:00		88.8	0.173
11/22/22	10:00		89.0	0.174
11/22/22	11:00		88.9	0.173
11/22/22	12:00		88.7	0.173
11/22/22	13:00		88.5	0.173
11/22/22	14:00		88.4	0.172
11/22/22	15:00		88.3	0.172
11/22/22	16:00		88.2	0.172
11/22/22	17:00		88.2	0.172
11/22/22	18:00		88.3	0.172
11/22/22	19:00		88.1	0.172
11/22/22	20:00		87.8	0.171
11/22/22	21:00		87.6	0.171
11/22/22	22:00		87.6	0.171
11/22/22	23:00		87.3	0.170
11/23/22	00:00		87.0	0.170
11/23/22	01:00		87.1	0.170
11/23/22	02:00		86.9	0.170
11/23/22	03:00		83.7	0.166
11/23/22	04:00		80.5	0.161
11/23/22	05:00		80.2	0.160
11/23/22	06:00		80.4	0.161
11/23/22	07:00		80.6	0.161
11/23/22	08:00		80.6	0.161
11/23/22	09:00		80.1	0.161
11/23/22	10:00		80.1	0.161
11/23/22	11:00		80.5	0.161
11/23/22	12:00		80.6	0.162
11/23/22	13:00		80.8	0.162
11/23/22	14:00		80.9	0.163
11/23/22	15:00		81.0	0.163
11/23/22	16:00		80.9	0.163
11/23/22	17:00		80.8	0.163
11/23/22	18:00		80.7	0.162
11/23/22	19:00		80.7	0.162
11/23/22	20:00		80.7	0.163
11/23/22	21:00		78.6	0.160
11/23/22	22:00		75.9	0.157
11/23/22	23:00		73.4	0.157
11/24/22	00:00		70.8	0.156
11/24/22	01:00		68.0	0.154
11/24/22	02:00		65.5	0.153
11/24/22	03:00		65.9	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/24/22	04:00		66.1	0.158
11/24/22	05:00		63.7	0.158
11/24/22	06:00		61.0	0.156
11/24/22	07:00		58.4	0.155
11/24/22	08:00		56.0	0.154
11/24/22	09:00		53.7	0.154
11/24/22	10:00		51.3	0.153
11/24/22	11:00		48.9	0.152
11/24/22	12:00		46.5	0.151
11/24/22	13:00		44.2	0.151
11/24/22	14:00		41.9	0.150
11/24/22	15:00		39.5	0.149
11/24/22	16:00		37.2	0.149
11/24/22	17:00		34.8	0.148
11/24/22	18:00		32.5	0.148
11/24/22	19:00		30.2	0.147
11/24/22	20:00		27.9	0.147
11/24/22	21:00		27.7	0.149
11/24/22	22:00		28.0	0.151
11/24/22	23:00		28.0	0.150
11/25/22	00:00		28.0	0.150
11/25/22	01:00		27.9	0.150
11/25/22	02:00		27.9	0.150
11/25/22	03:00		27.8	0.149
11/25/22	04:00		27.8	0.150
11/25/22	05:00		27.8	0.150
11/25/22	06:00		27.8	0.150
11/25/22	07:00		27.8	0.150
11/25/22	08:00		27.9	0.151
11/25/22	09:00		28.0	0.151
11/25/22	10:00		28.0	0.152
11/25/22	11:00		28.0	0.152
11/25/22	12:00		28.1	0.153
11/25/22	13:00		28.1	0.153
11/25/22	14:00		28.0	0.153
11/25/22	15:00		28.1	0.153
11/25/22	16:00		28.6	0.153
11/25/22	17:00		31.3	0.155
11/25/22	18:00		34.0	0.156
11/25/22	19:00		36.1	0.156
11/25/22	20:00		37.7	0.156
11/25/22	21:00		38.1	0.156
11/25/22	22:00		38.1	0.156
11/25/22	23:00		38.2	0.157
11/26/22	00:00		38.2	0.157
11/26/22	01:00		38.2	0.157
11/26/22	02:00		38.3	0.157

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
11/26/22	03:00		38.4	0.158
11/26/22	04:00		38.5	0.158
11/26/22	05:00		38.5	0.158
11/26/22	06:00		38.5	0.158
11/26/22	07:00		38.5	0.158
11/26/22	08:00		38.6	0.158
11/26/22	09:00		38.6	0.159
11/26/22	10:00		38.7	0.159
11/26/22	11:00		38.8	0.160
11/26/22	12:00		38.9	0.160
11/26/22	13:00		39.0	0.160
11/26/22	14:00		39.1	0.161
11/26/22	15:00		39.1	0.161
11/26/22	16:00		39.1	0.161
11/26/22	17:00		38.9	0.161
11/26/22	18:00		38.9	0.161
11/26/22	19:00		38.6	0.161
11/26/22	20:00		37.0	0.160
11/26/22	21:00		36.6	0.160
11/26/22	22:00		36.6	0.160
11/26/22	23:00		36.5	0.160
11/27/22	00:00		36.5	0.160
11/27/22	01:00		36.4	0.160
11/27/22	02:00		36.5	0.160
11/27/22	03:00		36.5	0.160
11/27/22	04:00		36.4	0.160
11/27/22	05:00		36.4	0.160
11/27/22	06:00		36.4	0.160
11/27/22	07:00		36.4	0.160
11/27/22	08:00		36.3	0.160
11/27/22	09:00		36.2	0.159
11/27/22	10:00		36.0	0.158
11/27/22	11:00		35.8	0.157
11/27/22	12:00		35.7	0.156
11/27/22	13:00		35.5	0.155
11/27/22	14:00		35.3	0.153
11/27/22	15:00		35.1	0.152
11/27/22	16:00		35.1	0.152
11/27/22	17:00		35.3	0.152
11/27/22	18:00		34.7	0.151
11/27/22	19:00		34.8	0.150
11/27/22	20:00		36.7	0.150
11/27/22	21:00		39.0	0.150
11/27/22	22:00		41.8	0.151
11/27/22	23:00		44.6	0.152
11/28/22	00:00		47.4	0.154
11/28/22	01:00		49.2	0.154

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/28/22	02:00	49.2	0.153
11/28/22	03:00	49.3	0.153
11/28/22	04:00	49.6	0.152
11/28/22	05:00	52.1	0.153
11/28/22	06:00	54.4	0.154
11/28/22	07:00	56.8	0.154
11/28/22	08:00	59.0	0.154
11/28/22	09:00	61.2	0.154
11/28/22	10:00	63.4	0.154
11/28/22	11:00	66.2	0.156
11/28/22	12:00	69.2	0.158
11/28/22	13:00	72.0	0.159
11/28/22	14:00	75.0	0.162
11/28/22	15:00	75.2	0.161
11/28/22	16:00	76.7	0.163
11/28/22	17:00	77.1	0.163
11/28/22	18:00	77.9	0.165
11/28/22	19:00	78.7	0.167
11/28/22	20:00	79.1	0.168
11/28/22	21:00	79.4	0.169
11/28/22	22:00	78.5	0.168
11/28/22	23:00	75.6	0.166
11/29/22	00:00	72.9	0.164
11/29/22	01:00	71.0	0.164
11/29/22	02:00	70.9	0.165
11/29/22	03:00	71.0	0.165
11/29/22	04:00	70.7	0.166
11/29/22	05:00	68.5	0.164
11/29/22	06:00	68.5	0.165
11/29/22	07:00	68.5	0.165
11/29/22	08:00	68.7	0.165
11/29/22	09:00	69.1	0.166
11/29/22	10:00	69.8	0.167
11/29/22	11:00	69.8	0.167
11/29/22	12:00	67.6	0.165
11/29/22	13:00	64.9	0.165
11/29/22	14:00	62.1	0.164
11/29/22	15:00	62.0	0.166
11/29/22	16:00	60.3	0.164
11/29/22	17:00	58.7	0.162
11/29/22	18:00	58.5	0.161
11/29/22	19:00	58.0	0.161
11/29/22	20:00	55.7	0.160
11/29/22	21:00	53.2	0.160
11/29/22	22:00	51.4	0.160
11/29/22	23:00	51.5	0.161
11/30/22	00:00	51.5	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
11/30/22	01:00	51.6	0.162
11/30/22	02:00	51.7	0.163
11/30/22	03:00	51.6	0.162
11/30/22	04:00	51.6	0.163
11/30/22	05:00	51.5	0.164
11/30/22	06:00	49.4	0.162
11/30/22	07:00	50.1	0.164
11/30/22	08:00	50.3	0.165
11/30/22	09:00	50.3	0.165
11/30/22	10:00	50.3	0.165
11/30/22	11:00	50.3	0.165
11/30/22	12:00	50.3	0.165
11/30/22	13:00	50.3	0.165
11/30/22	14:00	47.9	0.165
11/30/22	15:00	45.3	0.163
11/30/22	16:00	45.6	0.164
11/30/22	17:00	47.9	0.166
11/30/22	18:00	50.6	0.167
11/30/22	19:00	53.2	0.168
11/30/22	20:00	55.7	0.168
11/30/22	21:00	58.1	0.169
11/30/22	22:00	59.1	0.171
11/30/22	23:00	59.3	0.171
12/01/22	00:00	59.9	0.172
12/01/22	01:00	62.1	0.174
12/01/22	02:00	62.3	0.174
12/01/22	03:00	62.4	0.174
12/01/22	04:00	62.7	0.173
12/01/22	05:00	65.5	0.174
12/01/22	06:00	68.0	0.175
12/01/22	07:00	70.6	0.175
12/01/22	08:00	72.8	0.176
12/01/22	09:00	74.4	0.175
12/01/22	10:00	76.5	0.175
12/01/22	11:00	78.4	0.176
12/01/22	12:00	77.7	0.175
12/01/22	13:00	77.4	0.174
12/01/22	14:00	79.5	0.174
12/01/22	15:00	81.5	0.175
12/01/22	16:00	80.7	0.174
12/01/22	17:00	80.0	0.172
12/01/22	18:00	79.4	0.171
12/01/22	19:00	79.0	0.171
12/01/22	20:00	78.7	0.170
12/01/22	21:00	78.6	0.170
12/01/22	22:00	77.3	0.168
12/01/22	23:00	74.2	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/02/22	00:00		71.3	0.162
12/02/22	01:00		68.9	0.160
12/02/22	02:00		68.7	0.160
12/02/22	03:00		68.5	0.159
12/02/22	04:00		68.0	0.159
12/02/22	05:00		65.3	0.156
12/02/22	06:00		64.8	0.155
12/02/22	07:00		65.1	0.155
12/02/22	08:00		65.5	0.156
12/02/22	09:00		66.3	0.157
12/02/22	10:00		64.1	0.156
12/02/22	11:00		61.9	0.155
12/02/22	12:00		59.5	0.155
12/02/22	13:00		57.1	0.154
12/02/22	14:00		54.9	0.154
12/02/22	15:00		52.5	0.153
12/02/22	16:00		50.2	0.152
12/02/22	17:00		47.9	0.152
12/02/22	18:00		45.5	0.151
12/02/22	19:00		43.2	0.150
12/02/22	20:00		40.9	0.150
12/02/22	21:00		38.4	0.149
12/02/22	22:00		37.1	0.149
12/02/22	23:00		37.3	0.151
12/03/22	00:00		37.3	0.151
12/03/22	01:00		37.3	0.152
12/03/22	02:00		37.2	0.152
12/03/22	03:00		37.4	0.152
12/03/22	04:00		37.3	0.153
12/03/22	05:00		37.3	0.154
12/03/22	06:00		35.1	0.154
12/03/22	07:00		32.2	0.152
12/03/22	08:00		29.4	0.150
12/03/22	09:00		27.1	0.149
12/03/22	10:00		27.0	0.150
12/03/22	11:00		27.1	0.150
12/03/22	12:00		27.2	0.150
12/03/22	13:00		27.6	0.150
12/03/22	14:00		28.7	0.150
12/03/22	15:00		29.7	0.150
12/03/22	16:00		30.5	0.149
12/03/22	17:00		31.7	0.149
12/03/22	18:00		34.1	0.151
12/03/22	19:00		37.1	0.152
12/03/22	20:00		40.0	0.154
12/03/22	21:00		42.3	0.155
12/03/22	22:00		42.4	0.155

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/03/22	23:00		42.5	0.156
12/04/22	00:00		42.5	0.156
12/04/22	01:00		42.6	0.156
12/04/22	02:00		42.6	0.156
12/04/22	03:00		42.5	0.156
12/04/22	04:00		42.5	0.156
12/04/22	05:00		42.5	0.155
12/04/22	06:00		42.4	0.155
12/04/22	07:00		42.4	0.154
12/04/22	08:00		42.3	0.154
12/04/22	09:00		42.2	0.154
12/04/22	10:00		42.0	0.153
12/04/22	11:00		41.8	0.152
12/04/22	12:00		41.6	0.151
12/04/22	13:00		41.1	0.150
12/04/22	14:00		40.1	0.150
12/04/22	15:00		39.2	0.151
12/04/22	16:00		38.7	0.151
12/04/22	17:00		40.2	0.152
12/04/22	18:00		40.3	0.152
12/04/22	19:00		39.0	0.150
12/04/22	20:00		35.9	0.147
12/04/22	21:00		33.6	0.145
12/04/22	22:00		33.5	0.145
12/04/22	23:00		33.4	0.144
12/05/22	00:00		33.3	0.144
12/05/22	01:00		33.3	0.144
12/05/22	02:00		33.2	0.144
12/05/22	03:00		33.2	0.143
12/05/22	04:00		33.2	0.143
12/05/22	05:00		33.3	0.142
12/05/22	06:00		35.9	0.143
12/05/22	07:00		38.7	0.145
12/05/22	08:00		41.6	0.147
12/05/22	09:00		44.4	0.148
12/05/22	10:00		47.1	0.150
12/05/22	11:00		49.5	0.151
12/05/22	12:00		52.1	0.153
12/05/22	13:00		54.5	0.154
12/05/22	14:00		54.7	0.154
12/05/22	15:00		54.7	0.154
12/05/22	16:00		54.8	0.154
12/05/22	17:00		55.0	0.154
12/05/22	18:00		55.2	0.154
12/05/22	19:00		56.3	0.156
12/05/22	20:00		59.2	0.159
12/05/22	21:00		62.2	0.161

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/05/22	22:00	65.1	0.162
12/05/22	23:00	68.2	0.165
12/06/22	00:00	70.6	0.166
12/06/22	01:00	70.7	0.165
12/06/22	02:00	70.7	0.166
12/06/22	03:00	70.8	0.166
12/06/22	04:00	70.8	0.166
12/06/22	05:00	70.8	0.168
12/06/22	06:00	68.3	0.166
12/06/22	07:00	67.9	0.166
12/06/22	08:00	68.2	0.167
12/06/22	09:00	68.4	0.167
12/06/22	10:00	68.6	0.167
12/06/22	11:00	69.1	0.169
12/06/22	12:00	68.8	0.169
12/06/22	13:00	66.5	0.167
12/06/22	14:00	66.5	0.167
12/06/22	15:00	69.1	0.168
12/06/22	16:00	71.3	0.169
12/06/22	17:00	71.5	0.170
12/06/22	18:00	71.4	0.169
12/06/22	19:00	71.3	0.169
12/06/22	20:00	71.2	0.169
12/06/22	21:00	70.9	0.168
12/06/22	22:00	70.7	0.168
12/06/22	23:00	70.5	0.167
12/07/22	00:00	70.1	0.167
12/07/22	01:00	70.1	0.167
12/07/22	02:00	70.1	0.167
12/07/22	03:00	70.0	0.167
12/07/22	04:00	70.0	0.167
12/07/22	05:00	69.9	0.167
12/07/22	06:00	70.1	0.166
12/07/22	07:00	70.8	0.167
12/07/22	08:00	70.7	0.167
12/07/22	09:00	70.7	0.166
12/07/22	10:00	70.4	0.166
12/07/22	11:00	70.1	0.166
12/07/22	12:00	70.6	0.166
12/07/22	13:00	72.6	0.168
12/07/22	14:00	72.4	0.167
12/07/22	15:00	70.3	0.166
12/07/22	16:00	70.2	0.166
12/07/22	17:00	70.1	0.166
12/07/22	18:00	70.1	0.166
12/07/22	19:00	69.4	0.165
12/07/22	20:00	66.8	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/07/22	21:00	64.2	0.162
12/07/22	22:00	61.5	0.161
12/07/22	23:00	58.6	0.159
12/08/22	00:00	56.6	0.158
12/08/22	01:00	56.4	0.158
12/08/22	02:00	56.4	0.158
12/08/22	03:00	56.5	0.158
12/08/22	04:00	56.5	0.159
12/08/22	05:00	56.6	0.159
12/08/22	06:00	56.5	0.160
12/08/22	07:00	56.4	0.160
12/08/22	08:00	56.2	0.159
12/08/22	09:00	55.8	0.159
12/08/22	10:00	55.8	0.159
12/08/22	11:00	55.9	0.159
12/08/22	12:00	56.1	0.159
12/08/22	13:00	56.2	0.160
12/08/22	14:00	56.8	0.160
12/08/22	15:00	59.4	0.162
12/08/22	16:00	61.6	0.163
12/08/22	17:00	61.5	0.163
12/08/22	18:00	61.2	0.163
12/08/22	19:00	59.9	0.161
12/08/22	20:00	57.9	0.161
12/08/22	21:00	57.7	0.161
12/08/22	22:00	57.7	0.161
12/08/22	23:00	57.8	0.161
12/09/22	00:00	57.8	0.161
12/09/22	01:00	58.0	0.161
12/09/22	02:00	58.0	0.162
12/09/22	03:00	58.1	0.162
12/09/22	04:00	58.1	0.162
12/09/22	05:00	58.1	0.162
12/09/22	06:00	58.7	0.161
12/09/22	07:00	61.5	0.163
12/09/22	08:00	61.3	0.163
12/09/22	09:00	61.3	0.163
12/09/22	10:00	61.4	0.164
12/09/22	11:00	61.4	0.164
12/09/22	12:00	61.3	0.163
12/09/22	13:00	59.2	0.161
12/09/22	14:00	56.4	0.159
12/09/22	15:00	53.7	0.158
12/09/22	16:00	51.2	0.154
12/09/22	17:00	51.2	0.154
12/09/22	18:00	51.2	0.154
12/09/22	19:00	50.7	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/09/22	20:00		50.6	0.153
12/09/22	21:00		50.6	0.153
12/09/22	22:00		50.6	0.153
12/09/22	23:00		50.6	0.152
12/10/22	00:00		50.5	0.152
12/10/22	01:00		50.4	0.152
12/10/22	02:00		50.3	0.151
12/10/22	03:00		50.3	0.151
12/10/22	04:00		50.5	0.152
12/10/22	05:00		50.5	0.152
12/10/22	06:00		49.9	0.153
12/10/22	07:00		47.0	0.151
12/10/22	08:00		44.4	0.150
12/10/22	09:00		41.7	0.149
12/10/22	10:00		39.1	0.148
12/10/22	11:00		36.6	0.147
12/10/22	12:00		34.0	0.146
12/10/22	13:00		33.5	0.148
12/10/22	14:00		33.8	0.149
12/10/22	15:00		33.9	0.149
12/10/22	16:00		34.2	0.150
12/10/22	17:00		34.6	0.151
12/10/22	18:00		34.8	0.151
12/10/22	19:00		37.0	0.154
12/10/22	20:00		38.5	0.155
12/10/22	21:00		38.4	0.154
12/10/22	22:00		38.5	0.155
12/10/22	23:00		38.7	0.155
12/11/22	00:00		38.8	0.156
12/11/22	01:00		39.0	0.157
12/11/22	02:00		39.2	0.158
12/11/22	03:00		39.2	0.159
12/11/22	04:00		39.0	0.158
12/11/22	05:00		39.0	0.157
12/11/22	06:00		39.1	0.158
12/11/22	07:00		39.1	0.158
12/11/22	08:00		39.0	0.157
12/11/22	09:00		39.0	0.157
12/11/22	10:00		39.0	0.156
12/11/22	11:00		39.0	0.156
12/11/22	12:00		38.9	0.156
12/11/22	13:00		38.9	0.155
12/11/22	14:00		38.7	0.155
12/11/22	15:00		38.6	0.154
12/11/22	16:00		38.6	0.154
12/11/22	17:00		38.4	0.153
12/11/22	18:00		38.3	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/11/22	19:00	38.2	0.153
12/11/22	20:00	37.5	0.152
12/11/22	21:00	37.6	0.153
12/11/22	22:00	37.5	0.152
12/11/22	23:00	37.5	0.152
12/12/22	00:00	37.4	0.151
12/12/22	01:00	37.3	0.151
12/12/22	02:00	37.2	0.151
12/12/22	03:00	37.3	0.151
12/12/22	04:00	37.3	0.151
12/12/22	05:00	38.0	0.151
12/12/22	06:00	41.0	0.152
12/12/22	07:00	43.8	0.154
12/12/22	08:00	46.5	0.155
12/12/22	09:00	49.1	0.156
12/12/22	10:00	51.9	0.158
12/12/22	11:00	54.5	0.159
12/12/22	12:00	57.2	0.161
12/12/22	13:00	59.9	0.162
12/12/22	14:00	62.5	0.163
12/12/22	15:00	65.1	0.164
12/12/22	16:00	67.4	0.168
12/12/22	17:00	67.4	0.167
12/12/22	18:00	67.2	0.167
12/12/22	19:00	67.1	0.167
12/12/22	20:00	69.0	0.169
12/12/22	21:00	71.8	0.171
12/12/22	22:00	73.1	0.171
12/12/22	23:00	73.1	0.172
12/13/22	00:00	73.1	0.172
12/13/22	01:00	73.1	0.171
12/13/22	02:00	73.1	0.171
12/13/22	03:00	73.0	0.170
12/13/22	04:00	73.1	0.170
12/13/22	05:00	73.2	0.170
12/13/22	06:00	72.9	0.169
12/13/22	07:00	72.8	0.169
12/13/22	08:00	72.9	0.170
12/13/22	09:00	73.0	0.170
12/13/22	10:00	73.2	0.170
12/13/22	11:00	71.7	0.169
12/13/22	12:00	69.0	0.168
12/13/22	13:00	66.4	0.167
12/13/22	14:00	63.6	0.165
12/13/22	15:00	60.8	0.163
12/13/22	16:00	58.0	0.160
12/13/22	17:00	57.3	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/13/22	18:00	57.5	0.160
12/13/22	19:00	57.6	0.160
12/13/22	20:00	57.8	0.160
12/13/22	21:00	57.8	0.160
12/13/22	22:00	59.5	0.162
12/13/22	23:00	62.4	0.164
12/14/22	00:00	65.5	0.166
12/14/22	01:00	66.7	0.166
12/14/22	02:00	66.6	0.166
12/14/22	03:00	66.6	0.167
12/14/22	04:00	66.5	0.166
12/14/22	05:00	66.2	0.166
12/14/22	06:00	66.5	0.166
12/14/22	07:00	66.7	0.166
12/14/22	08:00	66.7	0.166
12/14/22	09:00	66.7	0.166
12/14/22	10:00	66.7	0.166
12/14/22	11:00	68.3	0.167
12/14/22	12:00	71.1	0.168
12/14/22	13:00	74.1	0.170
12/14/22	14:00	76.9	0.172
12/14/22	15:00	79.8	0.174
12/14/22	16:00	82.7	0.177
12/14/22	17:00	83.5	0.178
12/14/22	18:00	83.3	0.177
12/14/22	19:00	83.2	0.177
12/14/22	20:00	83.3	0.177
12/14/22	21:00	83.4	0.177
12/14/22	22:00	83.6	0.177
12/14/22	23:00	83.6	0.177
12/15/22	00:00	81.9	0.175
12/15/22	01:00	80.8	0.175
12/15/22	02:00	80.8	0.175
12/15/22	03:00	80.8	0.175
12/15/22	04:00	80.8	0.175
12/15/22	05:00	81.0	0.176
12/15/22	06:00	80.9	0.175
12/15/22	07:00	80.8	0.175
12/15/22	08:00	81.2	0.175
12/15/22	09:00	81.3	0.175
12/15/22	10:00	81.5	0.176
12/15/22	11:00	81.7	0.176
12/15/22	12:00	81.7	0.176
12/15/22	13:00	81.8	0.176
12/15/22	14:00	82.1	0.177
12/15/22	15:00	82.2	0.177
12/15/22	16:00	82.3	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/15/22	17:00	82.3	0.177
12/15/22	18:00	82.4	0.177
12/15/22	19:00	82.6	0.177
12/15/22	20:00	82.6	0.178
12/15/22	21:00	82.7	0.178
12/15/22	22:00	82.6	0.177
12/15/22	23:00	82.6	0.178
12/16/22	00:00	82.4	0.177
12/16/22	01:00	82.4	0.178
12/16/22	02:00	82.4	0.178
12/16/22	03:00	82.4	0.178
12/16/22	04:00	82.9	0.177
12/16/22	05:00	85.3	0.180
12/16/22	06:00	85.4	0.180
12/16/22	07:00	85.4	0.181
12/16/22	08:00	85.2	0.180
12/16/22	09:00	85.0	0.180
12/16/22	10:00	84.8	0.180
12/16/22	11:00	84.8	0.180
12/16/22	12:00	84.8	0.180
12/16/22	13:00	84.5	0.180
12/16/22	14:00	84.1	0.179
12/16/22	15:00	83.8	0.178
12/16/22	16:00	83.8	0.178
12/16/22	17:00	83.8	0.178
12/16/22	18:00	83.8	0.178
12/16/22	19:00	83.9	0.178
12/16/22	20:00	83.9	0.178
12/16/22	21:00	83.6	0.178
12/16/22	22:00	83.6	0.178
12/16/22	23:00	83.6	0.178
12/17/22	00:00	85.6	0.180
12/17/22	01:00	88.6	0.181
12/17/22	02:00	91.6	0.183
12/17/22	03:00	92.3	0.182
12/17/22	04:00	91.6	0.182
12/17/22	05:00	89.2	0.179
12/17/22	06:00	89.2	0.179
12/17/22	07:00	89.5	0.179
12/17/22	08:00	89.8	0.180
12/17/22	09:00	89.9	0.180
12/17/22	10:00	90.1	0.180
12/17/22	11:00	89.9	0.180
12/17/22	12:00	89.8	0.180
12/17/22	13:00	90.1	0.180
12/17/22	14:00	90.3	0.181
12/17/22	15:00	90.3	0.181

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/17/22	16:00	90.6	0.182
12/17/22	17:00	90.4	0.182
12/17/22	18:00	90.3	0.181
12/17/22	19:00	89.8	0.181
12/17/22	20:00	89.5	0.180
12/17/22	21:00	89.4	0.180
12/17/22	22:00	89.1	0.179
12/17/22	23:00	88.6	0.178
12/18/22	00:00	88.2	0.178
12/18/22	01:00	87.9	0.177
12/18/22	02:00	87.5	0.177
12/18/22	03:00	89.1	0.179
12/18/22	04:00	91.9	0.181
12/18/22	05:00	93.9	0.183
12/18/22	06:00	93.6	0.183
12/18/22	07:00	92.9	0.182
12/18/22	08:00	92.2	0.180
12/18/22	09:00	91.5	0.179
12/18/22	10:00	90.9	0.178
12/18/22	11:00	90.6	0.177
12/18/22	12:00	90.2	0.177
12/18/22	13:00	89.8	0.176
12/18/22	14:00	89.4	0.175
12/18/22	15:00	89.4	0.175
12/18/22	16:00	88.8	0.174
12/18/22	17:00	88.9	0.174
12/18/22	18:00	88.9	0.174
12/18/22	19:00	89.0	0.174
12/18/22	20:00	89.0	0.174
12/18/22	21:00	88.9	0.174
12/18/22	22:00	88.9	0.174
12/18/22	23:00	89.1	0.175
12/19/22	00:00	89.2	0.175
12/19/22	01:00	89.3	0.175
12/19/22	02:00	89.5	0.176
12/19/22	03:00	89.6	0.176
12/19/22	04:00	89.5	0.175
12/19/22	05:00	89.5	0.176
12/19/22	06:00	88.9	0.175
12/19/22	07:00	88.7	0.175
12/19/22	08:00	88.5	0.174
12/19/22	09:00	88.4	0.174
12/19/22	10:00	88.3	0.174
12/19/22	11:00	88.1	0.174
12/19/22	12:00	87.8	0.173
12/19/22	13:00	87.7	0.173
12/19/22	14:00	87.5	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/19/22	15:00	87.4	0.173
12/19/22	16:00	87.2	0.173
12/19/22	17:00	86.8	0.172
12/19/22	18:00	86.4	0.171
12/19/22	19:00	86.0	0.171
12/19/22	20:00	86.0	0.171
12/19/22	21:00	86.0	0.171
12/19/22	22:00	86.1	0.171
12/19/22	23:00	86.1	0.171
12/20/22	00:00	86.2	0.171
12/20/22	01:00	86.2	0.171
12/20/22	02:00	86.2	0.171
12/20/22	03:00	86.4	0.172
12/20/22	04:00	86.6	0.172
12/20/22	05:00	86.5	0.172
12/20/22	06:00	87.0	0.173
12/20/22	07:00	87.3	0.173
12/20/22	08:00	87.5	0.174
12/20/22	09:00	87.8	0.174
12/20/22	10:00	87.9	0.175
12/20/22	11:00	87.9	0.175
12/20/22	12:00	88.0	0.175
12/20/22	13:00	88.0	0.175
12/20/22	14:00	87.9	0.174
12/20/22	15:00	87.7	0.174
12/20/22	16:00	87.6	0.174
12/20/22	17:00	87.5	0.174
12/20/22	18:00	87.5	0.174
12/20/22	19:00	87.4	0.173
12/20/22	20:00	87.2	0.173
12/20/22	21:00	87.1	0.173
12/20/22	22:00	87.0	0.172
12/20/22	23:00	86.9	0.172
12/21/22	00:00	87.1	0.173
12/21/22	01:00	86.9	0.172
12/21/22	02:00	86.8	0.172
12/21/22	03:00	87.1	0.172
12/21/22	04:00	87.1	0.173
12/21/22	05:00	87.1	0.173
12/21/22	06:00	87.1	0.173
12/21/22	07:00	87.3	0.173
12/21/22	08:00	87.5	0.174
12/21/22	09:00	87.6	0.174
12/21/22	10:00	87.8	0.174
12/21/22	11:00	88.0	0.175
12/21/22	12:00	88.3	0.176
12/21/22	13:00	88.6	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/21/22	14:00		88.9	0.177
12/21/22	15:00		89.3	0.178
12/21/22	16:00		89.5	0.178
12/21/22	17:00		89.8	0.179
12/21/22	18:00		90.1	0.179
12/21/22	19:00		90.4	0.180
12/21/22	20:00		90.6	0.180
12/21/22	21:00		90.8	0.181
12/21/22	22:00		90.8	0.181
12/21/22	23:00		90.7	0.181
12/22/22	00:00		90.5	0.180
12/22/22	01:00		90.6	0.181
12/22/22	02:00		88.6	0.178
12/22/22	03:00		86.0	0.178
12/22/22	04:00		83.4	0.177
12/22/22	05:00		81.5	0.175
12/22/22	06:00		80.7	0.173
12/22/22	07:00		80.4	0.172
12/22/22	08:00		80.2	0.171
12/22/22	09:00		79.9	0.171
12/22/22	10:00		79.8	0.170
12/22/22	11:00		79.7	0.170
12/22/22	12:00		79.4	0.169
12/22/22	13:00		79.3	0.169
12/22/22	14:00		79.2	0.169
12/22/22	15:00		79.1	0.168
12/22/22	16:00		78.9	0.168
12/22/22	17:00		78.8	0.168
12/22/22	18:00		78.7	0.167
12/22/22	19:00		78.5	0.167
12/22/22	20:00		78.1	0.166
12/22/22	21:00		77.7	0.166
12/22/22	22:00		77.4	0.166
12/22/22	23:00		77.1	0.165
12/23/22	00:00		77.0	0.165
12/23/22	01:00		76.8	0.165
12/23/22	02:00		78.8	0.167
12/23/22	03:00		80.1	0.166
12/23/22	04:00		80.7	0.164
12/23/22	05:00		80.5	0.163
12/23/22	06:00		79.6	0.163
12/23/22	07:00		78.6	0.163
12/23/22	08:00		78.0	0.163
12/23/22	09:00		77.0	0.163
12/23/22	10:00		75.7	0.162
12/23/22	11:00		74.7	0.162
12/23/22	12:00		74.5	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/23/22	13:00		74.4	0.163
12/23/22	14:00		74.1	0.164
12/23/22	15:00		73.4	0.164
12/23/22	16:00		72.9	0.164
12/23/22	17:00		72.5	0.165
12/23/22	18:00		72.3	0.166
12/23/22	19:00		70.5	0.165
12/23/22	20:00		70.3	0.166
12/23/22	21:00		70.7	0.167
12/23/22	22:00		70.8	0.167
12/23/22	23:00		69.7	0.166
12/24/22	00:00		69.1	0.167
12/24/22	01:00		69.3	0.167
12/24/22	02:00		69.1	0.167
12/24/22	03:00		69.3	0.168
12/24/22	04:00		69.1	0.170
12/24/22	05:00		69.0	0.171
12/24/22	06:00		69.7	0.173
12/24/22	07:00		69.9	0.174
12/24/22	08:00		70.2	0.174
12/24/22	09:00		70.5	0.174
12/24/22	10:00		69.4	0.172
12/24/22	11:00		67.8	0.169
12/24/22	12:00		66.5	0.168
12/24/22	13:00		66.1	0.167
12/24/22	14:00		65.9	0.167
12/24/22	15:00		66.7	0.168
12/24/22	16:00		67.3	0.168
12/24/22	17:00		67.8	0.167
12/24/22	18:00		68.3	0.167
12/24/22	19:00		70.6	0.169
12/24/22	20:00		71.2	0.169
12/24/22	21:00		69.1	0.166
12/24/22	22:00		66.8	0.165
12/24/22	23:00		65.5	0.165
12/25/22	00:00		63.4	0.164
12/25/22	01:00		61.1	0.162
12/25/22	02:00		58.7	0.158
12/25/22	03:00		57.3	0.155
12/25/22	04:00		57.2	0.154
12/25/22	05:00		57.2	0.155
12/25/22	06:00		55.8	0.153
12/25/22	07:00		54.3	0.151
12/25/22	08:00		52.7	0.150
12/25/22	09:00		51.5	0.149
12/25/22	10:00		51.9	0.150
12/25/22	11:00		52.3	0.152

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/25/22	12:00	51.6	0.152
12/25/22	13:00	49.8	0.150
12/25/22	14:00	48.6	0.149
12/25/22	15:00	46.6	0.148
12/25/22	16:00	44.5	0.147
12/25/22	17:00	42.6	0.147
12/25/22	18:00	40.3	0.146
12/25/22	19:00	37.9	0.144
12/25/22	20:00	35.8	0.143
12/25/22	21:00	36.1	0.144
12/25/22	22:00	36.5	0.144
12/25/22	23:00	36.8	0.143
12/26/22	00:00	37.0	0.142
12/26/22	01:00	36.9	0.142
12/26/22	02:00	37.0	0.143
12/26/22	03:00	37.1	0.144
12/26/22	04:00	37.0	0.143
12/26/22	05:00	37.1	0.144
12/26/22	06:00	37.4	0.145
12/26/22	07:00	37.5	0.145
12/26/22	08:00	37.3	0.144
12/26/22	09:00	37.0	0.143
12/26/22	10:00	36.8	0.141
12/26/22	11:00	36.6	0.140
12/26/22	12:00	36.9	0.140
12/26/22	13:00	36.7	0.139
12/26/22	14:00	36.0	0.136
12/26/22	15:00	35.6	0.134
12/26/22	16:00	35.3	0.131
12/26/22	17:00	34.9	0.129
12/26/22	18:00	34.9	0.128
12/26/22	19:00	34.8	0.126
12/26/22	20:00	34.6	0.125
12/26/22	21:00	34.3	0.123
12/26/22	22:00	34.2	0.122
12/26/22	23:00	34.2	0.122
12/27/22	00:00	34.3	0.121
12/27/22	01:00	34.7	0.122
12/27/22	02:00	34.8	0.123
12/27/22	03:00	34.7	0.122
12/27/22	04:00	34.8	0.121
12/27/22	05:00	34.7	0.120
12/27/22	06:00	34.4	0.119
12/27/22	07:00	34.2	0.118
12/27/22	08:00	34.0	0.116
12/27/22	09:00	34.0	0.116
12/27/22	10:00	34.0	0.116

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/27/22	11:00	33.9	0.116
12/27/22	12:00	33.3	0.114
12/27/22	13:00	33.4	0.114
12/27/22	14:00	33.4	0.114
12/27/22	15:00	33.4	0.114
12/27/22	16:00	33.5	0.115
12/27/22	17:00	33.4	0.115
12/27/22	18:00	33.2	0.114
12/27/22	19:00	33.3	0.115
12/27/22	20:00	33.5	0.116
12/27/22	21:00	33.8	0.117
12/27/22	22:00	34.4	0.120
12/27/22	23:00	34.9	0.122
12/28/22	00:00	35.4	0.124
12/28/22	01:00	35.7	0.125
12/28/22	02:00	36.5	0.128
12/28/22	03:00	37.1	0.130
12/28/22	04:00	37.5	0.132
12/28/22	05:00	38.0	0.134
12/28/22	06:00	38.2	0.135
12/28/22	07:00	38.5	0.136
12/28/22	08:00	38.9	0.138
12/28/22	09:00	39.3	0.139
12/28/22	10:00	39.6	0.141
12/28/22	11:00	40.1	0.143
12/28/22	12:00	40.6	0.144
12/28/22	13:00	40.7	0.146
12/28/22	14:00	40.7	0.149
12/28/22	15:00	40.8	0.151
12/28/22	16:00	41.7	0.155
12/28/22	17:00	43.3	0.158
12/28/22	18:00	46.2	0.161
12/28/22	19:00	48.2	0.162
12/28/22	20:00	50.2	0.164
12/28/22	21:00	50.6	0.163
12/28/22	22:00	49.7	0.163
12/28/22	23:00	48.8	0.162
12/29/22	00:00	47.9	0.160
12/29/22	01:00	46.9	0.159
12/29/22	02:00	45.6	0.157
12/29/22	03:00	44.7	0.155
12/29/22	04:00	43.7	0.154
12/29/22	05:00	42.8	0.153
12/29/22	06:00	42.3	0.153
12/29/22	07:00	41.7	0.153
12/29/22	08:00	41.1	0.154
12/29/22	09:00	40.6	0.154

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
12/29/22	10:00	40.0	0.154
12/29/22	11:00	39.4	0.154
12/29/22	12:00	38.9	0.154
12/29/22	13:00	38.7	0.154
12/29/22	14:00	38.6	0.154
12/29/22	15:00	38.5	0.154
12/29/22	16:00	37.6	0.152
12/29/22	17:00	35.7	0.151
12/29/22	18:00	32.6	0.149
12/29/22	19:00	30.1	0.149
12/29/22	20:00	27.7	0.148
12/29/22	21:00	26.6	0.148
12/29/22	22:00	26.6	0.148
12/29/22	23:00	26.6	0.148
12/30/22	00:00	26.6	0.148
12/30/22	01:00	26.6	0.148
12/30/22	02:00	26.7	0.148
12/30/22	03:00	26.7	0.148
12/30/22	04:00	26.8	0.149
12/30/22	05:00	26.8	0.149
12/30/22	06:00	26.8	0.149
12/30/22	07:00	26.9	0.149
12/30/22	08:00	26.9	0.149
12/30/22	09:00	26.9	0.150
12/30/22	10:00	27.0	0.150
12/30/22	11:00	27.1	0.151
12/30/22	12:00	27.2	0.151
12/30/22	13:00	27.2	0.152
12/30/22	14:00	27.1	0.150
12/30/22	15:00	26.9	0.149
12/30/22	16:00	26.9	0.149
12/30/22	17:00	27.1	0.150
12/30/22	18:00	27.2	0.151
12/30/22	19:00	27.3	0.151
12/30/22	20:00	27.4	0.151
12/30/22	21:00	27.4	0.152
12/30/22	22:00	27.4	0.151
12/30/22	23:00	27.5	0.152
12/31/22	00:00	27.5	0.152
12/31/22	01:00	27.6	0.152
12/31/22	02:00	27.6	0.152
12/31/22	03:00	27.7	0.152
12/31/22	04:00	27.8	0.152
12/31/22	05:00	27.8	0.152
12/31/22	06:00	27.9	0.153
12/31/22	07:00	27.9	0.153
12/31/22	08:00	27.9	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 04/11/2022 00:00 Through 12/31/2022 23:59

Time Online Criteria: 1 minute(s)

Source	Parameter	Unit	UNIT1	
			NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
12/31/22	09:00		27.9	0.153
12/31/22	10:00		27.9	0.153
12/31/22	11:00		27.9	0.153
12/31/22	12:00		27.9	0.153
12/31/22	13:00		27.9	0.153
12/31/22	14:00		28.0	0.153
12/31/22	15:00		28.1	0.154
12/31/22	16:00		28.2	0.154
12/31/22	17:00		28.3	0.154
12/31/22	18:00		28.3	0.154
12/31/22	19:00		28.3	0.154
12/31/22	20:00		28.3	0.153
12/31/22	21:00		28.3	0.153
12/31/22	22:00		28.4	0.153
12/31/22	23:00		28.5	0.153
Average			55.8	0.152
Minimum			12.4	0.093
Maximum			93.9	0.187
Summation			354,616.3	918.477
Geometric Mean			52.5	0.134
Included Data Points			6360	6033
Total number of Data Points			6360	6360

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/01/23	00:00	28.4	0.153
01/01/23	01:00	28.3	0.153
01/01/23	02:00	28.3	0.153
01/01/23	03:00	28.5	0.153
01/01/23	04:00	28.5	0.153
01/01/23	05:00	28.5	0.153
01/01/23	06:00	28.6	0.153
01/01/23	07:00	28.6	0.154
01/01/23	08:00	28.6	0.153
01/01/23	09:00	28.6	0.153
01/01/23	10:00	28.5	0.153
01/01/23	11:00	28.5	0.153
01/01/23	12:00	28.5	0.153
01/01/23	13:00	28.4	0.153
01/01/23	14:00	28.4	0.153
01/01/23	15:00	28.3	0.152
01/01/23	16:00	28.1	0.152
01/01/23	17:00	28.0	0.151
01/01/23	18:00	28.0	0.151
01/01/23	19:00	28.0	0.151
01/01/23	20:00	28.1	0.151
01/01/23	21:00	28.1	0.151
01/01/23	22:00	27.9	0.150
01/01/23	23:00	28.0	0.151
01/02/23	00:00	27.9	0.151
01/02/23	01:00	28.0	0.151
01/02/23	02:00	28.0	0.151
01/02/23	03:00	28.0	0.151
01/02/23	04:00	28.0	0.151
01/02/23	05:00	27.9	0.151
01/02/23	06:00	27.9	0.151
01/02/23	07:00	28.0	0.151
01/02/23	08:00	28.0	0.151
01/02/23	09:00	28.1	0.152
01/02/23	10:00	28.1	0.152
01/02/23	11:00	28.1	0.152
01/02/23	12:00	28.1	0.152
01/02/23	13:00	28.1	0.152
01/02/23	14:00	28.0	0.152
01/02/23	15:00	28.1	0.152
01/02/23	16:00	28.2	0.153
01/02/23	17:00	28.3	0.154
01/02/23	18:00	28.4	0.155
01/02/23	19:00	28.4	0.155
01/02/23	20:00	28.4	0.155
01/02/23	21:00	28.4	0.155
01/02/23	22:00	28.5	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/02/23	23:00	28.6	0.156
01/03/23	00:00	28.6	0.157
01/03/23	01:00	28.6	0.157
01/03/23	02:00	28.5	0.157
01/03/23	03:00	28.5	0.157
01/03/23	04:00	28.5	0.157
01/03/23	05:00	28.5	0.157
01/03/23	06:00	28.5	0.157
01/03/23	07:00	28.5	0.157
01/03/23	08:00	28.4	0.157
01/03/23	09:00	28.4	0.157
01/03/23	10:00	28.5	0.157
01/03/23	11:00	28.5	0.157
01/03/23	12:00	28.4	0.156
01/03/23	13:00	28.4	0.156
01/03/23	14:00	28.5	0.157
01/03/23	15:00	28.5	0.157
01/03/23	16:00	28.5	0.156
01/03/23	17:00	28.4	0.156
01/03/23	18:00	28.4	0.155
01/03/23	19:00	28.4	0.155
01/03/23	20:00	28.4	0.155
01/03/23	21:00	28.4	0.155
01/03/23	22:00	28.4	0.154
01/03/23	23:00	28.1	0.153
01/04/23	00:00	28.0	0.152
01/04/23	01:00	28.0	0.152
01/04/23	02:00	28.0	0.152
01/04/23	03:00	28.0	0.152
01/04/23	04:00	28.0	0.151
01/04/23	05:00	28.0	0.152
01/04/23	06:00	28.0	0.151
01/04/23	07:00	27.9	0.151
01/04/23	08:00	27.9	0.151
01/04/23	09:00	27.8	0.150
01/04/23	10:00	27.7	0.150
01/04/23	11:00	27.7	0.149
01/04/23	12:00	27.7	0.149
01/04/23	13:00	27.8	0.150
01/04/23	14:00	27.7	0.149
01/04/23	15:00	27.7	0.149
01/04/23	16:00	27.8	0.149
01/04/23	17:00	27.8	0.150
01/04/23	18:00	28.0	0.150
01/04/23	19:00	28.0	0.150
01/04/23	20:00	28.0	0.150
01/04/23	21:00	28.2	0.151

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/04/23	22:00	28.2	0.151
01/04/23	23:00	28.3	0.151
01/05/23	00:00	28.4	0.151
01/05/23	01:00	28.4	0.151
01/05/23	02:00	28.5	0.151
01/05/23	03:00	28.4	0.151
01/05/23	04:00	28.5	0.151
01/05/23	05:00	28.6	0.151
01/05/23	06:00	28.7	0.151
01/05/23	07:00	28.8	0.152
01/05/23	08:00	28.9	0.152
01/05/23	09:00	29.0	0.152
01/05/23	10:00	29.2	0.153
01/05/23	11:00	29.3	0.153
01/05/23	12:00	29.5	0.154
01/05/23	13:00	29.7	0.155
01/05/23	14:00	29.9	0.157
01/05/23	15:00	30.1	0.158
01/05/23	16:00	30.3	0.159
01/05/23	17:00	30.4	0.159
01/05/23	18:00	30.3	0.159
01/05/23	19:00	30.3	0.159
01/05/23	20:00	30.3	0.159
01/05/23	21:00	30.3	0.159
01/05/23	22:00	30.5	0.159
01/05/23	23:00	30.5	0.159
01/06/23	00:00	30.6	0.160
01/06/23	01:00	30.7	0.160
01/06/23	02:00	30.6	0.160
01/06/23	03:00	30.6	0.160
01/06/23	04:00	30.5	0.160
01/06/23	05:00	30.5	0.160
01/06/23	06:00	31.2	0.160
01/06/23	07:00	33.5	0.160
01/06/23	08:00	36.1	0.161
01/06/23	09:00	37.3	0.160
01/06/23	10:00	37.1	0.159
01/06/23	11:00	37.1	0.160
01/06/23	12:00	37.0	0.159
01/06/23	13:00	36.9	0.159
01/06/23	14:00	36.8	0.159
01/06/23	15:00	36.6	0.158
01/06/23	16:00	36.4	0.157
01/06/23	17:00	36.2	0.156
01/06/23	18:00	36.2	0.156
01/06/23	19:00	36.1	0.156
01/06/23	20:00	36.0	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/06/23	21:00	36.0	0.156
01/06/23	22:00	35.9	0.156
01/06/23	23:00	35.9	0.157
01/07/23	00:00	35.9	0.157
01/07/23	01:00	36.0	0.158
01/07/23	02:00	36.0	0.158
01/07/23	03:00	36.0	0.158
01/07/23	04:00	36.1	0.159
01/07/23	05:00	36.1	0.160
01/07/23	06:00	35.5	0.161
01/07/23	07:00	33.1	0.161
01/07/23	08:00	30.4	0.159
01/07/23	09:00	29.2	0.160
01/07/23	10:00	29.4	0.161
01/07/23	11:00	29.4	0.161
01/07/23	12:00	29.5	0.161
01/07/23	13:00	29.4	0.161
01/07/23	14:00	29.4	0.161
01/07/23	15:00	29.5	0.161
01/07/23	16:00	29.6	0.161
01/07/23	17:00	29.6	0.162
01/07/23	18:00	29.6	0.162
01/07/23	19:00	29.6	0.162
01/07/23	20:00	29.6	0.161
01/07/23	21:00	29.5	0.161
01/07/23	22:00	29.5	0.161
01/07/23	23:00	29.4	0.160
01/08/23	00:00	29.3	0.160
01/08/23	01:00	29.3	0.159
01/08/23	02:00	29.2	0.159
01/08/23	03:00	29.1	0.158
01/08/23	04:00	29.2	0.158
01/08/23	05:00	29.2	0.158
01/08/23	06:00	29.1	0.158
01/08/23	07:00	29.2	0.158
01/08/23	08:00	29.2	0.159
01/08/23	09:00	29.3	0.159
01/08/23	10:00	29.3	0.159
01/08/23	11:00	29.3	0.158
01/08/23	12:00	29.2	0.158
01/08/23	13:00	29.1	0.158
01/08/23	14:00	29.0	0.157
01/08/23	15:00	28.9	0.157
01/08/23	16:00	28.9	0.157
01/08/23	17:00	28.8	0.156
01/08/23	18:00	28.8	0.156
01/08/23	19:00	28.8	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/08/23	20:00	28.7	0.155
01/08/23	21:00	28.6	0.155
01/08/23	22:00	28.7	0.155
01/08/23	23:00	28.9	0.156
01/09/23	00:00	29.2	0.158
01/09/23	01:00	29.3	0.158
01/09/23	02:00	29.6	0.160
01/09/23	03:00	29.7	0.160
01/09/23	04:00	29.8	0.160
01/09/23	05:00	29.7	0.160
01/09/23	06:00	29.6	0.159
01/09/23	07:00	29.4	0.158
01/09/23	08:00	29.4	0.158
01/09/23	09:00	29.3	0.157
01/09/23	10:00	29.2	0.157
01/09/23	11:00	29.3	0.157
01/09/23	12:00	29.3	0.157
01/09/23	13:00	29.3	0.157
01/09/23	14:00	29.5	0.158
01/09/23	15:00	29.4	0.158
01/09/23	16:00	29.4	0.157
01/09/23	17:00	29.3	0.157
01/09/23	18:00	29.4	0.158
01/09/23	19:00	29.5	0.158
01/09/23	20:00	29.5	0.159
01/09/23	21:00	29.6	0.159
01/09/23	22:00	29.5	0.159
01/09/23	23:00	29.4	0.158
01/10/23	00:00	29.0	0.156
01/10/23	01:00	28.9	0.156
01/10/23	02:00	28.8	0.155
01/10/23	03:00	28.8	0.156
01/10/23	04:00	29.0	0.157
01/10/23	05:00	29.3	0.158
01/10/23	06:00	29.5	0.159
01/10/23	07:00	29.9	0.161
01/10/23	08:00	30.0	0.162
01/10/23	09:00	30.2	0.163
01/10/23	10:00	30.5	0.164
01/10/23	11:00	30.6	0.165
01/10/23	12:00	30.6	0.165
01/10/23	13:00	30.6	0.165
01/10/23	14:00	30.5	0.165
01/10/23	15:00	30.5	0.164
01/10/23	16:00	30.7	0.165
01/10/23	17:00	30.8	0.166
01/10/23	18:00	30.9	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/10/23	19:00	30.9	0.166
01/10/23	20:00	31.0	0.167
01/10/23	21:00	31.2	0.167
01/10/23	22:00	31.2	0.168
01/10/23	23:00	31.3	0.168
01/11/23	00:00	31.4	0.168
01/11/23	01:00	31.3	0.168
01/11/23	02:00	31.2	0.167
01/11/23	03:00	31.2	0.167
01/11/23	04:00	30.9	0.166
01/11/23	05:00	30.7	0.165
01/11/23	06:00	30.5	0.164
01/11/23	07:00	30.2	0.162
01/11/23	08:00	30.1	0.162
01/11/23	09:00	30.0	0.161
01/11/23	10:00	29.9	0.161
01/11/23	11:00	29.9	0.161
01/11/23	12:00	29.9	0.161
01/11/23	13:00	30.0	0.161
01/11/23	14:00	30.3	0.162
01/11/23	15:00	30.3	0.164
01/11/23	16:00	30.3	0.164
01/11/23	17:00	30.3	0.164
01/11/23	18:00	30.3	0.164
01/11/23	19:00	30.2	0.163
01/11/23	20:00	30.1	0.163
01/11/23	21:00	30.0	0.163
01/11/23	22:00	30.0	0.163
01/11/23	23:00	29.9	0.162
01/12/23	00:00	29.9	0.163
01/12/23	01:00	30.0	0.163
01/12/23	02:00	29.9	0.163
01/12/23	03:00	29.9	0.163
01/12/23	04:00	29.8	0.162
01/12/23	05:00	29.8	0.162
01/12/23	06:00	29.8	0.162
01/12/23	07:00	29.7	0.162
01/12/23	08:00	29.7	0.162
01/12/23	09:00	29.7	0.162
01/12/23	10:00	29.6	0.162
01/12/23	11:00	29.5	0.162
01/12/23	12:00	29.5	0.162
01/12/23	13:00	29.5	0.162
01/12/23	14:00	29.3	0.161
01/12/23	15:00	29.1	0.160
01/12/23	16:00	29.1	0.160
01/12/23	17:00	29.1	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/12/23	18:00	29.1	0.159
01/12/23	19:00	29.0	0.159
01/12/23	20:00	29.1	0.159
01/12/23	21:00	29.1	0.159
01/12/23	22:00	29.1	0.159
01/12/23	23:00	29.1	0.159
01/13/23	00:00	29.0	0.158
01/13/23	01:00	29.1	0.158
01/13/23	02:00	29.1	0.158
01/13/23	03:00	29.1	0.157
01/13/23	04:00	29.1	0.157
01/13/23	05:00	29.1	0.156
01/13/23	06:00	29.1	0.156
01/13/23	07:00	29.2	0.157
01/13/23	08:00	29.2	0.157
01/13/23	09:00	29.2	0.157
01/13/23	10:00	29.2	0.156
01/13/23	11:00	29.2	0.156
01/13/23	12:00	29.2	0.156
01/13/23	13:00	29.2	0.156
01/13/23	14:00	29.1	0.156
01/13/23	15:00	29.2	0.156
01/13/23	16:00	29.3	0.156
01/13/23	17:00	29.3	0.156
01/13/23	18:00	29.4	0.156
01/13/23	19:00	29.6	0.158
01/13/23	20:00	29.7	0.158
01/13/23	21:00	29.7	0.159
01/13/23	22:00	29.8	0.159
01/13/23	23:00	29.9	0.160
01/14/23	00:00	30.1	0.161
01/14/23	01:00	30.2	0.161
01/14/23	02:00	30.3	0.162
01/14/23	03:00	30.3	0.162
01/14/23	04:00	30.4	0.163
01/14/23	05:00	30.6	0.163
01/14/23	06:00	30.7	0.164
01/14/23	07:00	30.7	0.164
01/14/23	08:00	30.7	0.164
01/14/23	09:00	30.8	0.164
01/14/23	10:00	30.8	0.164
01/14/23	11:00	30.7	0.163
01/14/23	12:00	30.5	0.162
01/14/23	13:00	30.4	0.161
01/14/23	14:00	30.5	0.162
01/14/23	15:00	30.6	0.163
01/14/23	16:00	30.8	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/14/23	17:00	30.9	0.164
01/14/23	18:00	30.9	0.164
01/14/23	19:00	31.0	0.165
01/14/23	20:00	31.0	0.165
01/14/23	21:00	31.1	0.165
01/14/23	22:00	31.1	0.165
01/14/23	23:00	31.1	0.166
01/15/23	00:00	31.1	0.166
01/15/23	01:00	31.0	0.166
01/15/23	02:00	31.0	0.166
01/15/23	03:00	31.0	0.166
01/15/23	04:00	30.9	0.166
01/15/23	05:00	30.9	0.166
01/15/23	06:00	30.8	0.166
01/15/23	07:00	30.8	0.167
01/15/23	08:00	30.8	0.167
01/15/23	09:00	30.8	0.167
01/15/23	10:00	30.8	0.167
01/15/23	11:00	30.9	0.168
01/15/23	12:00	31.1	0.169
01/15/23	13:00	31.3	0.170
01/15/23	14:00	31.1	0.170
01/15/23	15:00	31.0	0.169
01/15/23	16:00	31.2	0.171
01/15/23	17:00	31.1	0.170
01/15/23	18:00	30.9	0.169
01/15/23	19:00	30.7	0.168
01/15/23	20:00	30.6	0.167
01/15/23	21:00	30.6	0.168
01/15/23	22:00	30.7	0.168
01/15/23	23:00	30.7	0.168
01/16/23	00:00	30.7	0.168
01/16/23	01:00	30.8	0.168
01/16/23	02:00	30.8	0.168
01/16/23	03:00	31.0	0.169
01/16/23	04:00	31.0	0.169
01/16/23	05:00	31.0	0.169
01/16/23	06:00	31.0	0.169
01/16/23	07:00	31.1	0.170
01/16/23	08:00	31.0	0.169
01/16/23	09:00	30.9	0.169
01/16/23	10:00	30.9	0.169
01/16/23	11:00	30.9	0.169
01/16/23	12:00	30.9	0.169
01/16/23	13:00	30.8	0.168
01/16/23	14:00	30.7	0.168
01/16/23	15:00	30.8	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/16/23	16:00	30.5	0.167
01/16/23	17:00	30.6	0.168
01/16/23	18:00	30.7	0.169
01/16/23	19:00	30.8	0.169
01/16/23	20:00	30.7	0.169
01/16/23	21:00	30.7	0.169
01/16/23	22:00	30.5	0.169
01/16/23	23:00	30.3	0.168
01/17/23	00:00	30.2	0.167
01/17/23	01:00	30.1	0.166
01/17/23	02:00	29.9	0.165
01/17/23	03:00	29.7	0.164
01/17/23	04:00	29.6	0.163
01/17/23	05:00	29.4	0.162
01/17/23	06:00	29.2	0.161
01/17/23	07:00	29.0	0.159
01/17/23	08:00	29.1	0.160
01/17/23	09:00	29.0	0.159
01/17/23	10:00	29.0	0.158
01/17/23	11:00	29.1	0.159
01/17/23	12:00	29.1	0.158
01/17/23	13:00	29.2	0.159
01/17/23	14:00	29.3	0.159
01/17/23	15:00	29.2	0.158
01/17/23	16:00	29.2	0.157
01/17/23	17:00	29.2	0.157
01/17/23	18:00	29.3	0.157
01/17/23	19:00	29.3	0.157
01/17/23	20:00	29.3	0.157
01/17/23	21:00	29.3	0.157
01/17/23	22:00	29.4	0.157
01/17/23	23:00	29.6	0.158
01/18/23	00:00	29.7	0.158
01/18/23	01:00	29.7	0.158
01/18/23	02:00	29.6	0.158
01/18/23	03:00	29.9	0.159
01/18/23	04:00	30.0	0.160
01/18/23	05:00	30.2	0.161
01/18/23	06:00	31.0	0.161
01/18/23	07:00	33.8	0.162
01/18/23	08:00	34.7	0.161
01/18/23	09:00	34.9	0.162
01/18/23	10:00	35.1	0.164
01/18/23	11:00	35.0	0.164
01/18/23	12:00	35.0	0.164
01/18/23	13:00	34.9	0.164
01/18/23	14:00	34.7	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/18/23	15:00	34.8	0.164
01/18/23	16:00	34.7	0.164
01/18/23	17:00	34.7	0.164
01/18/23	18:00	34.7	0.164
01/18/23	19:00	34.8	0.165
01/18/23	20:00	34.9	0.166
01/18/23	21:00	35.0	0.167
01/18/23	22:00	35.0	0.168
01/18/23	23:00	35.1	0.169
01/19/23	00:00	35.2	0.170
01/19/23	01:00	35.4	0.171
01/19/23	02:00	35.6	0.173
01/19/23	03:00	35.5	0.173
01/19/23	04:00	35.6	0.173
01/19/23	05:00	35.5	0.173
01/19/23	06:00	34.9	0.174
01/19/23	07:00	32.2	0.173
01/19/23	08:00	31.4	0.175
01/19/23	09:00	31.4	0.175
01/19/23	10:00	31.2	0.174
01/19/23	11:00	31.2	0.174
01/19/23	12:00	31.1	0.173
01/19/23	13:00	31.4	0.175
01/19/23	14:00	31.6	0.176
01/19/23	15:00	31.6	0.175
01/19/23	16:00	31.5	0.175
01/19/23	17:00	31.5	0.174
01/19/23	18:00	31.5	0.174
01/19/23	19:00	31.5	0.174
01/19/23	20:00	31.5	0.174
01/19/23	21:00	31.4	0.173
01/19/23	22:00	31.4	0.173
01/19/23	23:00	31.3	0.172
01/20/23	00:00	31.2	0.171
01/20/23	01:00	31.1	0.170
01/20/23	02:00	31.0	0.169
01/20/23	03:00	31.0	0.168
01/20/23	04:00	31.1	0.168
01/20/23	05:00	31.2	0.169
01/20/23	06:00	31.1	0.168
01/20/23	07:00	31.3	0.169
01/20/23	08:00	31.3	0.169
01/20/23	09:00	31.4	0.170
01/20/23	10:00	31.5	0.171
01/20/23	11:00	31.6	0.171
01/20/23	12:00	31.8	0.172
01/20/23	13:00	31.8	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/20/23	14:00	31.9	0.172
01/20/23	15:00	31.9	0.172
01/20/23	16:00	32.1	0.173
01/20/23	17:00	32.2	0.174
01/20/23	18:00	32.2	0.173
01/20/23	19:00	32.2	0.173
01/20/23	20:00	32.2	0.173
01/20/23	21:00	32.2	0.173
01/20/23	22:00	32.2	0.173
01/20/23	23:00	32.3	0.173
01/21/23	00:00	32.4	0.174
01/21/23	01:00	32.6	0.174
01/21/23	02:00	32.7	0.175
01/21/23	03:00	32.8	0.176
01/21/23	04:00	32.7	0.176
01/21/23	05:00	32.7	0.176
01/21/23	06:00	32.8	0.176
01/21/23	07:00	32.8	0.176
01/21/23	08:00	32.8	0.176
01/21/23	09:00	32.8	0.175
01/21/23	10:00	32.6	0.175
01/21/23	11:00	32.7	0.175
01/21/23	12:00	32.7	0.175
01/21/23	13:00	32.6	0.174
01/21/23	14:00	32.5	0.174
01/21/23	15:00	32.3	0.173
01/21/23	16:00	32.2	0.172
01/21/23	17:00	32.3	0.173
01/21/23	18:00	32.3	0.173
01/21/23	19:00	32.3	0.173
01/21/23	20:00	32.3	0.173
01/21/23	21:00	32.2	0.173
01/21/23	22:00	32.1	0.172
01/21/23	23:00	32.0	0.171
01/22/23	00:00	31.9	0.171
01/22/23	01:00	31.9	0.171
01/22/23	02:00	31.8	0.170
01/22/23	03:00	31.9	0.170
01/22/23	04:00	31.8	0.170
01/22/23	05:00	31.8	0.170
01/22/23	06:00	31.8	0.170
01/22/23	07:00	31.8	0.170
01/22/23	08:00	31.7	0.169
01/22/23	09:00	31.6	0.169
01/22/23	10:00	31.8	0.169
01/22/23	11:00	31.8	0.169
01/22/23	12:00	31.8	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/22/23	13:00	31.9	0.169
01/22/23	14:00	31.9	0.169
01/22/23	15:00	32.1	0.170
01/22/23	16:00	32.2	0.170
01/22/23	17:00	32.1	0.170
01/22/23	18:00	32.0	0.169
01/22/23	19:00	32.0	0.169
01/22/23	20:00	32.0	0.169
01/22/23	21:00	32.0	0.169
01/22/23	22:00	32.1	0.170
01/22/23	23:00	32.3	0.170
01/23/23	00:00	32.3	0.170
01/23/23	01:00	32.3	0.170
01/23/23	02:00	32.4	0.171
01/23/23	03:00	32.4	0.171
01/23/23	04:00	32.4	0.171
01/23/23	05:00	32.5	0.171
01/23/23	06:00	32.5	0.171
01/23/23	07:00	32.5	0.172
01/23/23	08:00	32.7	0.173
01/23/23	09:00	32.8	0.173
01/23/23	10:00	32.9	0.174
01/23/23	11:00	33.0	0.175
01/23/23	12:00	33.1	0.175
01/23/23	13:00	33.0	0.175
01/23/23	14:00	32.7	0.174
01/23/23	15:00	32.6	0.173
01/23/23	16:00	32.6	0.172
01/23/23	17:00	32.5	0.172
01/23/23	18:00	32.5	0.172
01/23/23	19:00	32.6	0.172
01/23/23	20:00	32.7	0.173
01/23/23	21:00	32.7	0.173
01/23/23	22:00	32.7	0.173
01/23/23	23:00	32.6	0.172
01/24/23	00:00	32.6	0.172
01/24/23	01:00	32.6	0.172
01/24/23	02:00	32.7	0.173
01/24/23	03:00	32.7	0.173
01/24/23	04:00	32.7	0.173
01/24/23	05:00	32.7	0.173
01/24/23	06:00	32.6	0.173
01/24/23	07:00	32.7	0.173
01/24/23	08:00	32.6	0.173
01/24/23	09:00	32.5	0.172
01/24/23	10:00	32.4	0.171
01/24/23	11:00	32.3	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/24/23	12:00	32.3	0.171
01/24/23	13:00	32.6	0.172
01/24/23	14:00	32.8	0.173
01/24/23	15:00	33.0	0.173
01/24/23	16:00	33.2	0.174
01/24/23	17:00	33.4	0.175
01/24/23	18:00	33.3	0.175
01/24/23	19:00	33.2	0.175
01/24/23	20:00	33.1	0.175
01/24/23	21:00	33.2	0.175
01/24/23	22:00	33.3	0.175
01/24/23	23:00	33.3	0.176
01/25/23	00:00	33.4	0.176
01/25/23	01:00	33.4	0.176
01/25/23	02:00	33.3	0.176
01/25/23	03:00	33.3	0.176
01/25/23	04:00	33.3	0.176
01/25/23	05:00	33.1	0.175
01/25/23	06:00	33.0	0.175
01/25/23	07:00	32.8	0.173
01/25/23	08:00	32.6	0.172
01/25/23	09:00	32.3	0.171
01/25/23	10:00	32.4	0.172
01/25/23	11:00	32.5	0.172
01/25/23	12:00	32.4	0.172
01/25/23	13:00	32.3	0.171
01/25/23	14:00	32.2	0.170
01/25/23	15:00	32.1	0.170
01/25/23	16:00	32.0	0.170
01/25/23	17:00	32.1	0.170
01/25/23	18:00	32.0	0.169
01/25/23	19:00	32.2	0.170
01/25/23	20:00	32.3	0.170
01/25/23	21:00	32.3	0.170
01/25/23	22:00	32.4	0.170
01/25/23	23:00	32.5	0.170
01/26/23	00:00	32.7	0.171
01/26/23	01:00	32.7	0.171
01/26/23	02:00	32.8	0.171
01/26/23	03:00	32.9	0.171
01/26/23	04:00	33.0	0.171
01/26/23	05:00	33.2	0.172
01/26/23	06:00	33.4	0.173
01/26/23	07:00	33.7	0.175
01/26/23	08:00	34.0	0.176
01/26/23	09:00	34.3	0.178
01/26/23	10:00	34.4	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/26/23	11:00	34.4	0.179
01/26/23	12:00	34.9	0.179
01/26/23	13:00	36.0	0.181
01/26/23	14:00	36.1	0.182
01/26/23	15:00	36.3	0.183
01/26/23	16:00	36.2	0.183
01/26/23	17:00	36.1	0.184
01/26/23	18:00	36.3	0.185
01/26/23	19:00	36.3	0.185
01/26/23	20:00	36.3	0.184
01/26/23	21:00	36.3	0.185
01/26/23	22:00	36.2	0.185
01/26/23	23:00	36.1	0.185
01/27/23	00:00	36.0	0.184
01/27/23	01:00	36.0	0.184
01/27/23	02:00	36.0	0.185
01/27/23	03:00	36.0	0.185
01/27/23	04:00	36.1	0.186
01/27/23	05:00	35.9	0.185
01/27/23	06:00	35.8	0.184
01/27/23	07:00	35.8	0.184
01/27/23	08:00	35.7	0.184
01/27/23	09:00	35.5	0.183
01/27/23	10:00	35.3	0.181
01/27/23	11:00	35.1	0.180
01/27/23	12:00	34.4	0.179
01/27/23	13:00	33.6	0.177
01/27/23	14:00	33.5	0.174
01/27/23	15:00	33.1	0.172
01/27/23	16:00	32.8	0.169
01/27/23	17:00	32.7	0.169
01/27/23	18:00	32.6	0.169
01/27/23	19:00	32.4	0.168
01/27/23	20:00	32.4	0.168
01/27/23	21:00	32.3	0.168
01/27/23	22:00	32.1	0.167
01/27/23	23:00	32.1	0.166
01/28/23	00:00	32.0	0.166
01/28/23	01:00	31.9	0.166
01/28/23	02:00	31.7	0.165
01/28/23	03:00	31.7	0.165
01/28/23	04:00	31.6	0.165
01/28/23	05:00	31.6	0.165
01/28/23	06:00	31.7	0.165
01/28/23	07:00	31.6	0.165
01/28/23	08:00	31.4	0.164
01/28/23	09:00	31.3	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/28/23	10:00	31.2	0.162
01/28/23	11:00	31.1	0.162
01/28/23	12:00	31.0	0.161
01/28/23	13:00	30.5	0.161
01/28/23	14:00	30.5	0.162
01/28/23	15:00	30.6	0.163
01/28/23	16:00	30.8	0.164
01/28/23	17:00	30.7	0.163
01/28/23	18:00	30.8	0.164
01/28/23	19:00	30.8	0.164
01/28/23	20:00	30.8	0.164
01/28/23	21:00	30.8	0.164
01/28/23	22:00	30.9	0.165
01/28/23	23:00	30.8	0.164
01/29/23	00:00	30.8	0.164
01/29/23	01:00	30.7	0.164
01/29/23	02:00	30.7	0.164
01/29/23	03:00	30.7	0.163
01/29/23	04:00	30.7	0.163
01/29/23	05:00	30.8	0.163
01/29/23	06:00	30.6	0.162
01/29/23	07:00	30.5	0.161
01/29/23	08:00	30.6	0.162
01/29/23	09:00	30.8	0.163
01/29/23	10:00	30.9	0.163
01/29/23	11:00	31.0	0.164
01/29/23	12:00	31.1	0.164
01/29/23	13:00	31.2	0.165
01/29/23	14:00	31.3	0.165
01/29/23	15:00	31.4	0.166
01/29/23	16:00	31.5	0.166
01/29/23	17:00	31.6	0.167
01/29/23	18:00	31.5	0.166
01/29/23	19:00	31.7	0.167
01/29/23	20:00	31.6	0.167
01/29/23	21:00	31.4	0.166
01/29/23	22:00	31.5	0.166
01/29/23	23:00	31.6	0.167
01/30/23	00:00	31.6	0.167
01/30/23	01:00	31.6	0.167
01/30/23	02:00	31.6	0.168
01/30/23	03:00	31.7	0.168
01/30/23	04:00	31.8	0.169
01/30/23	05:00	31.8	0.169
01/30/23	06:00	32.0	0.171
01/30/23	07:00	32.1	0.172
01/30/23	08:00	32.1	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/30/23	09:00	32.1	0.173
01/30/23	10:00	32.3	0.174
01/30/23	11:00	32.4	0.175
01/30/23	12:00	32.5	0.176
01/30/23	13:00	32.6	0.177
01/30/23	14:00	32.5	0.177
01/30/23	15:00	32.6	0.177
01/30/23	16:00	32.9	0.178
01/30/23	17:00	34.0	0.178
01/30/23	18:00	34.2	0.179
01/30/23	19:00	34.1	0.178
01/30/23	20:00	34.3	0.179
01/30/23	21:00	34.4	0.180
01/30/23	22:00	34.2	0.179
01/30/23	23:00	34.3	0.179
01/31/23	00:00	34.3	0.180
01/31/23	01:00	34.2	0.179
01/31/23	02:00	34.2	0.179
01/31/23	03:00	34.2	0.179
01/31/23	04:00	34.3	0.179
01/31/23	05:00	34.3	0.179
01/31/23	06:00	35.4	0.178
01/31/23	07:00	38.6	0.179
01/31/23	08:00	40.0	0.179
01/31/23	09:00	40.0	0.179
01/31/23	10:00	40.1	0.179
01/31/23	11:00	40.0	0.179
01/31/23	12:00	40.1	0.180
01/31/23	13:00	40.2	0.180
01/31/23	14:00	40.4	0.182
01/31/23	15:00	40.5	0.183
01/31/23	16:00	40.3	0.183
01/31/23	17:00	39.2	0.183
01/31/23	18:00	39.1	0.183
01/31/23	19:00	39.2	0.183
01/31/23	20:00	39.1	0.183
01/31/23	21:00	39.1	0.183
01/31/23	22:00	39.3	0.184
01/31/23	23:00	39.2	0.183
02/01/23	00:00	39.1	0.183
02/01/23	01:00	39.1	0.183
02/01/23	02:00	39.2	0.182
02/01/23	03:00	38.9	0.181
02/01/23	04:00	38.7	0.180
02/01/23	05:00	38.7	0.180
02/01/23	06:00	37.6	0.181
02/01/23	07:00	34.3	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/01/23	08:00	33.0	0.179
02/01/23	09:00	33.2	0.180
02/01/23	10:00	33.2	0.180
02/01/23	11:00	33.2	0.180
02/01/23	12:00	33.1	0.179
02/01/23	13:00	33.2	0.179
02/01/23	14:00	33.0	0.179
02/01/23	15:00	32.9	0.178
02/01/23	16:00	32.9	0.177
02/01/23	17:00	32.9	0.178
02/01/23	18:00	32.9	0.178
02/01/23	19:00	33.0	0.178
02/01/23	20:00	33.0	0.178
02/01/23	21:00	33.0	0.178
02/01/23	22:00	33.0	0.178
02/01/23	23:00	33.1	0.178
02/02/23	00:00	33.3	0.179
02/02/23	01:00	33.2	0.179
02/02/23	02:00	33.1	0.178
02/02/23	03:00	33.1	0.178
02/02/23	04:00	33.0	0.178
02/02/23	05:00	33.0	0.177
02/02/23	06:00	33.0	0.177
02/02/23	07:00	33.1	0.178
02/02/23	08:00	33.1	0.178
02/02/23	09:00	33.0	0.177
02/02/23	10:00	32.9	0.177
02/02/23	11:00	32.9	0.177
02/02/23	12:00	33.0	0.177
02/02/23	13:00	32.8	0.176
02/02/23	14:00	32.7	0.176
02/02/23	15:00	32.8	0.176
02/02/23	16:00	32.8	0.176
02/02/23	17:00	32.8	0.176
02/02/23	18:00	32.8	0.176
02/02/23	19:00	32.8	0.176
02/02/23	20:00	32.8	0.176
02/02/23	21:00	32.8	0.176
02/02/23	22:00	32.9	0.177
02/02/23	23:00	32.9	0.177
02/03/23	00:00	32.9	0.177
02/03/23	01:00	33.0	0.178
02/03/23	02:00	33.2	0.180
02/03/23	03:00	33.4	0.181
02/03/23	04:00	33.5	0.182
02/03/23	05:00	33.6	0.182
02/03/23	06:00	34.6	0.183

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/03/23	07:00	38.0	0.185
02/03/23	08:00	40.9	0.185
02/03/23	09:00	44.5	0.187
02/03/23	10:00	46.2	0.188
02/03/23	11:00	46.1	0.187
02/03/23	12:00	46.1	0.187
02/03/23	13:00	46.0	0.187
02/03/23	14:00	45.8	0.187
02/03/23	15:00	45.7	0.187
02/03/23	16:00	46.9	0.187
02/03/23	17:00	50.2	0.189
02/03/23	18:00	53.3	0.190
02/03/23	19:00	56.6	0.192
02/03/23	20:00	58.3	0.192
02/03/23	21:00	57.9	0.188
02/03/23	22:00	57.6	0.187
02/03/23	23:00	57.4	0.185
02/04/23	00:00	57.1	0.183
02/04/23	01:00	57.0	0.182
02/04/23	02:00	56.6	0.180
02/04/23	03:00	56.2	0.178
02/04/23	04:00	56.1	0.178
02/04/23	05:00	55.9	0.177
02/04/23	06:00	54.8	0.176
02/04/23	07:00	51.3	0.174
02/04/23	08:00	48.0	0.172
02/04/23	09:00	44.3	0.169
02/04/23	10:00	42.5	0.168
02/04/23	11:00	42.5	0.169
02/04/23	12:00	42.2	0.167
02/04/23	13:00	42.0	0.166
02/04/23	14:00	42.1	0.166
02/04/23	15:00	42.3	0.166
02/04/23	16:00	41.0	0.165
02/04/23	17:00	37.5	0.163
02/04/23	18:00	34.3	0.161
02/04/23	19:00	30.9	0.158
02/04/23	20:00	29.0	0.158
02/04/23	21:00	29.3	0.160
02/04/23	22:00	29.3	0.160
02/04/23	23:00	29.3	0.160
02/05/23	00:00	29.4	0.161
02/05/23	01:00	29.3	0.160
02/05/23	02:00	29.4	0.161
02/05/23	03:00	29.7	0.162
02/05/23	04:00	29.6	0.161
02/05/23	05:00	29.6	0.161

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/05/23	06:00	29.5	0.161
02/05/23	07:00	29.4	0.160
02/05/23	08:00	29.4	0.160
02/05/23	09:00	29.2	0.159
02/05/23	10:00	29.2	0.159
02/05/23	11:00	29.2	0.159
02/05/23	12:00	29.3	0.160
02/05/23	13:00	29.5	0.161
02/05/23	14:00	29.6	0.161
02/05/23	15:00	29.4	0.160
02/05/23	16:00	29.4	0.160
02/05/23	17:00	29.4	0.160
02/05/23	18:00	29.5	0.160
02/05/23	19:00	29.8	0.160
02/05/23	20:00	29.8	0.160
02/05/23	21:00	29.8	0.160
02/05/23	22:00	29.8	0.160
02/05/23	23:00	29.8	0.160
02/06/23	00:00	29.8	0.160
02/06/23	01:00	29.8	0.160
02/06/23	02:00	29.8	0.160
02/06/23	03:00	29.8	0.160
02/06/23	04:00	29.8	0.160
02/06/23	05:00	29.8	0.160
02/06/23	06:00	29.8	0.160
02/06/23	07:00	29.8	0.160
02/06/23	08:00	29.8	0.160
02/06/23	09:00	29.8	0.160
02/06/23	10:00	29.8	0.160
02/06/23	11:00	29.8	0.160
02/06/23	12:00	29.8	0.160
02/06/23	13:00	29.8	0.160
02/06/23	14:00	29.8	0.160
02/06/23	15:00	29.8	0.160
02/06/23	16:00	29.8	0.160
02/06/23	17:00	29.8	0.160
02/06/23	18:00	29.8	0.160
02/06/23	19:00	29.8	0.160
02/06/23	20:00	29.8	0.160
02/06/23	21:00	29.8	0.160
02/06/23	22:00	29.8	0.160
02/06/23	23:00	29.8	0.160
02/07/23	00:00	29.8	0.160
02/07/23	01:00	29.8	0.160
02/07/23	02:00	29.8	0.160
02/07/23	03:00	29.8	0.160
02/07/23	04:00	29.8	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/07/23	05:00	29.8	0.160
02/07/23	06:00	29.8	0.160
02/07/23	07:00	29.8	0.160
02/07/23	08:00	29.8	0.160
02/07/23	09:00	29.8	0.160
02/07/23	10:00	29.8	0.160
02/07/23	11:00	29.8	0.160
02/07/23	12:00	29.8	0.160
02/07/23	13:00	29.8	0.160
02/07/23	14:00	29.8	0.160
02/07/23	15:00	29.8	0.160
02/07/23	16:00	29.8	0.160
02/07/23	17:00	29.8	0.160
02/07/23	18:00	29.8	0.160
02/07/23	19:00	29.8	0.160
02/07/23	20:00	29.8	0.160
02/07/23	21:00	29.8	0.160
02/07/23	22:00	29.8	0.160
02/07/23	23:00	29.8	0.160
02/08/23	00:00	29.8	0.160
02/08/23	01:00	29.8	0.160
02/08/23	02:00	29.8	0.160
02/08/23	03:00	29.8	0.160
02/08/23	04:00	29.8	0.160
02/08/23	05:00	29.8	0.160
02/08/23	06:00	29.8	0.160
02/08/23	07:00	29.8	0.160
02/08/23	08:00	29.8	0.160
02/08/23	09:00	29.8	0.160
02/08/23	10:00	29.8	0.160
02/08/23	11:00	29.8	0.160
02/08/23	12:00	29.8	0.160
02/08/23	13:00	29.8	0.160
02/08/23	14:00	29.8	0.160
02/08/23	15:00	28.5	0.160
02/08/23	16:00	27.3	0.160
02/08/23	17:00	26.1	0.160
02/08/23	18:00	25.0	0.160
02/08/23	19:00	23.8	0.160
02/08/23	20:00	22.7	0.161I
02/08/23	21:00	21.5	0.161I
02/08/23	22:00	20.3	0.162I
02/08/23	23:00	19.3	0.162I
02/09/23	00:00	18.1	0.163I
02/09/23	01:00	17.1	0.163I
02/09/23	02:00	16.0	0.163I
02/09/23	03:00	15.1	0.166I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/09/23	04:00	14.5	0.168I
02/09/23	05:00	14.0	0.168I
02/09/23	06:00	14.5	0.168I
02/09/23	07:00	14.9	0.162I
02/09/23	08:00	15.2	0.163I
02/09/23	09:00	15.6	0.169I
02/09/23	10:00	15.8	0.169I
02/09/23	11:00	16.3	0.171I
02/09/23	12:00	16.0	0.163I
02/09/23	13:00	15.8	0.153I
02/09/23	14:00	15.4	0.147I
02/09/23	15:00	17.4	0.147I
02/09/23	16:00	19.5	0.147I
02/09/23	17:00	21.4	0.145I
02/09/23	18:00	23.5	0.146I
02/09/23	19:00	25.9	0.147I
02/09/23	20:00	28.0	0.147I
02/09/23	21:00	29.9	0.147I
02/09/23	22:00	31.7	0.146I
02/09/23	23:00	33.5	0.146
02/10/23	00:00	35.7	0.147
02/10/23	01:00	37.0	0.147
02/10/23	02:00	38.5	0.147
02/10/23	03:00	38.9	0.147
02/10/23	04:00	38.7	0.147
02/10/23	05:00	38.7	0.147
02/10/23	06:00	38.7	0.147
02/10/23	07:00	38.7	0.147
02/10/23	08:00	38.7	0.147
02/10/23	09:00	38.7	0.147
02/10/23	10:00	39.3	0.147
02/10/23	11:00	38.8	0.146
02/10/23	12:00	38.0	0.147
02/10/23	13:00	38.0	0.147
02/10/23	14:00	36.7	0.145I
02/10/23	15:00	35.4	0.142I
02/10/23	16:00	34.3	0.140I
02/10/23	17:00	33.2	0.137I
02/10/23	18:00	32.9	0.139I
02/10/23	19:00	32.6	0.143I
02/10/23	20:00	32.7	0.147I
02/10/23	21:00	32.1	0.145I
02/10/23	22:00	31.5	0.143I
02/10/23	23:00	31.3	0.142I
02/11/23	00:00	31.0	0.140I
02/11/23	01:00	30.4	0.138I
02/11/23	02:00	29.9	0.136I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/11/23	03:00	29.8	0.135I
02/11/23	04:00	29.6	0.135I
02/11/23	05:00	29.4	0.134I
02/11/23	06:00	28.8	0.131I
02/11/23	07:00	29.2	0.128I
02/11/23	08:00	29.1	0.127I
02/11/23	09:00	30.1	0.126I
02/11/23	10:00	31.3	0.125I
02/11/23	11:00	31.3	0.125I
02/11/23	12:00	31.6	0.124I
02/11/23	13:00	32.3	0.123
02/11/23	14:00	33.6	0.123
02/11/23	15:00	34.7	0.122
02/11/23	16:00	35.9	0.122
02/11/23	17:00	37.0	0.122
02/11/23	18:00	38.0	0.123
02/11/23	19:00	38.9	0.123
02/11/23	20:00	39.6	0.123
02/11/23	21:00	40.1	0.124
02/11/23	22:00	40.4	0.125
02/11/23	23:00	41.0	0.128
02/12/23	00:00	41.3	0.129
02/12/23	01:00	41.4	0.129
02/12/23	02:00	41.6	0.130
02/12/23	03:00	41.7	0.131
02/12/23	04:00	41.9	0.131
02/12/23	05:00	42.0	0.132
02/12/23	06:00	42.3	0.133
02/12/23	07:00	42.5	0.135
02/12/23	08:00	42.8	0.136
02/12/23	09:00	43.1	0.137
02/12/23	10:00	43.3	0.138
02/12/23	11:00	43.6	0.139
02/12/23	12:00	44.0	0.140
02/12/23	13:00	44.3	0.141
02/12/23	14:00	44.5	0.142
02/12/23	15:00	45.2	0.144
02/12/23	16:00	45.9	0.147
02/12/23	17:00	46.5	0.149
02/12/23	18:00	47.1	0.151
02/12/23	19:00	47.4	0.152
02/12/23	20:00	47.6	0.153
02/12/23	21:00	47.8	0.154
02/12/23	22:00	48.1	0.155
02/12/23	23:00	47.9	0.154
02/13/23	00:00	48.1	0.155
02/13/23	01:00	48.3	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/13/23	02:00	48.7	0.157
02/13/23	03:00	49.0	0.158
02/13/23	04:00	49.4	0.159
02/13/23	05:00	49.8	0.161
02/13/23	06:00	50.1	0.162
02/13/23	07:00	50.4	0.163
02/13/23	08:00	50.6	0.163
02/13/23	09:00	50.8	0.164
02/13/23	10:00	51.0	0.165
02/13/23	11:00	51.4	0.166
02/13/23	12:00	51.5	0.166
02/13/23	13:00	51.9	0.168
02/13/23	14:00	52.3	0.169
02/13/23	15:00	52.1	0.168
02/13/23	16:00	51.8	0.167
02/13/23	17:00	51.6	0.166
02/13/23	18:00	51.5	0.166
02/13/23	19:00	51.5	0.166
02/13/23	20:00	51.4	0.165
02/13/23	21:00	51.4	0.165
02/13/23	22:00	51.3	0.164
02/13/23	23:00	51.2	0.164
02/14/23	00:00	51.2	0.164
02/14/23	01:00	51.3	0.164
02/14/23	02:00	51.5	0.164
02/14/23	03:00	51.4	0.163
02/14/23	04:00	51.3	0.163
02/14/23	05:00	50.9	0.161
02/14/23	06:00	50.8	0.160
02/14/23	07:00	50.8	0.160
02/14/23	08:00	50.9	0.160
02/14/23	09:00	51.0	0.161
02/14/23	10:00	51.1	0.161
02/14/23	11:00	51.0	0.160
02/14/23	12:00	50.9	0.160
02/14/23	13:00	50.8	0.160
02/14/23	14:00	50.7	0.159
02/14/23	15:00	50.7	0.159
02/14/23	16:00	50.7	0.160
02/14/23	17:00	50.8	0.160
02/14/23	18:00	50.8	0.160
02/14/23	19:00	50.9	0.161
02/14/23	20:00	51.0	0.161
02/14/23	21:00	51.0	0.161
02/14/23	22:00	51.1	0.162
02/14/23	23:00	51.2	0.162
02/15/23	00:00	51.3	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/15/23	01:00	51.2	0.162
02/15/23	02:00	50.9	0.162
02/15/23	03:00	50.8	0.162
02/15/23	04:00	50.9	0.162
02/15/23	05:00	51.1	0.163
02/15/23	06:00	51.1	0.163
02/15/23	07:00	51.1	0.163
02/15/23	08:00	51.1	0.163
02/15/23	09:00	51.0	0.163
02/15/23	10:00	51.1	0.163
02/15/23	11:00	51.2	0.163
02/15/23	12:00	51.4	0.164
02/15/23	13:00	51.5	0.164
02/15/23	14:00	51.8	0.165
02/15/23	15:00	51.9	0.165
02/15/23	16:00	52.1	0.166
02/15/23	17:00	52.2	0.166
02/15/23	18:00	52.2	0.166
02/15/23	19:00	52.2	0.167
02/15/23	20:00	52.3	0.167
02/15/23	21:00	52.2	0.167
02/15/23	22:00	52.2	0.166
02/15/23	23:00	52.1	0.166
02/16/23	00:00	52.0	0.166
02/16/23	01:00	51.9	0.165
02/16/23	02:00	52.1	0.165
02/16/23	03:00	52.2	0.166
02/16/23	04:00	52.2	0.166
02/16/23	05:00	52.2	0.166
02/16/23	06:00	52.2	0.166
02/16/23	07:00	52.3	0.166
02/16/23	08:00	52.2	0.166
02/16/23	09:00	52.2	0.166
02/16/23	10:00	52.2	0.166
02/16/23	11:00	52.3	0.167
02/16/23	12:00	52.3	0.167
02/16/23	13:00	52.3	0.167
02/16/23	14:00	52.2	0.167
02/16/23	15:00	52.2	0.167
02/16/23	16:00	52.1	0.166
02/16/23	17:00	52.0	0.166
02/16/23	18:00	52.0	0.166
02/16/23	19:00	51.8	0.165
02/16/23	20:00	51.6	0.164
02/16/23	21:00	51.9	0.165
02/16/23	22:00	52.1	0.165
02/16/23	23:00	52.1	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/17/23	00:00	52.0	0.165
02/17/23	01:00	52.3	0.165
02/17/23	02:00	52.2	0.165
02/17/23	03:00	52.3	0.165
02/17/23	04:00	52.6	0.165
02/17/23	05:00	52.8	0.166
02/17/23	06:00	52.9	0.166
02/17/23	07:00	52.9	0.166
02/17/23	08:00	52.9	0.166
02/17/23	09:00	53.1	0.166
02/17/23	10:00	53.1	0.166
02/17/23	11:00	53.0	0.165
02/17/23	12:00	53.1	0.165
02/17/23	13:00	53.1	0.165
02/17/23	14:00	53.1	0.165
02/17/23	15:00	53.4	0.166
02/17/23	16:00	53.5	0.166
02/17/23	17:00	53.6	0.166
02/17/23	18:00	53.7	0.166
02/17/23	19:00	54.0	0.168
02/17/23	20:00	54.2	0.169
02/17/23	21:00	54.2	0.169
02/17/23	22:00	54.0	0.168
02/17/23	23:00	53.9	0.168
02/18/23	00:00	53.8	0.168
02/18/23	01:00	53.4	0.167
02/18/23	02:00	53.3	0.167
02/18/23	03:00	53.0	0.166
02/18/23	04:00	52.6	0.165
02/18/23	05:00	52.4	0.165
02/18/23	06:00	52.3	0.165
02/18/23	07:00	52.2	0.165
02/18/23	08:00	52.3	0.165
02/18/23	09:00	52.1	0.165
02/18/23	10:00	52.2	0.165
02/18/23	11:00	52.3	0.165
02/18/23	12:00	52.2	0.165
02/18/23	13:00	52.2	0.165
02/18/23	14:00	52.2	0.165
02/18/23	15:00	52.2	0.166
02/18/23	16:00	52.2	0.166
02/18/23	17:00	52.2	0.166
02/18/23	18:00	52.1	0.166
02/18/23	19:00	52.0	0.166
02/18/23	20:00	51.9	0.166
02/18/23	21:00	51.9	0.166
02/18/23	22:00	51.9	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/18/23	23:00	52.1	0.166
02/19/23	00:00	52.1	0.167
02/19/23	01:00	52.2	0.167
02/19/23	02:00	52.3	0.167
02/19/23	03:00	52.4	0.168
02/19/23	04:00	52.4	0.168
02/19/23	05:00	52.4	0.168
02/19/23	06:00	52.4	0.168
02/19/23	07:00	52.4	0.168
02/19/23	08:00	52.3	0.168
02/19/23	09:00	52.4	0.168
02/19/23	10:00	52.5	0.168
02/19/23	11:00	52.5	0.169
02/19/23	12:00	52.7	0.169
02/19/23	13:00	52.8	0.169
02/19/23	14:00	52.9	0.170
02/19/23	15:00	52.9	0.170
02/19/23	16:00	52.9	0.170
02/19/23	17:00	52.9	0.170
02/19/23	18:00	53.0	0.170
02/19/23	19:00	53.1	0.170
02/19/23	20:00	53.2	0.171
02/19/23	21:00	53.2	0.171
02/19/23	22:00	53.3	0.171
02/19/23	23:00	53.5	0.172
02/20/23	00:00	53.7	0.172
02/20/23	01:00	53.9	0.173
02/20/23	02:00	54.1	0.174
02/20/23	03:00	54.3	0.174
02/20/23	04:00	54.3	0.174
02/20/23	05:00	54.4	0.174
02/20/23	06:00	54.4	0.175
02/20/23	07:00	54.3	0.174
02/20/23	08:00	54.4	0.175
02/20/23	09:00	54.3	0.174
02/20/23	10:00	54.2	0.174
02/20/23	11:00	54.0	0.173
02/20/23	12:00	53.8	0.173
02/20/23	13:00	53.5	0.172
02/20/23	14:00	53.3	0.171
02/20/23	15:00	53.2	0.171
02/20/23	16:00	53.2	0.171
02/20/23	17:00	53.2	0.171
02/20/23	18:00	53.3	0.171
02/20/23	19:00	53.2	0.171
02/20/23	20:00	53.0	0.170
02/20/23	21:00	53.0	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/20/23	22:00	52.9	0.170
02/20/23	23:00	52.8	0.170
02/21/23	00:00	52.9	0.170
02/21/23	01:00	52.8	0.170
02/21/23	02:00	52.7	0.170
02/21/23	03:00	52.6	0.169
02/21/23	04:00	52.6	0.169
02/21/23	05:00	52.7	0.170
02/21/23	06:00	52.9	0.170
02/21/23	07:00	53.1	0.171
02/21/23	08:00	53.3	0.172
02/21/23	09:00	53.5	0.172
02/21/23	10:00	53.5	0.172
02/21/23	11:00	53.5	0.172
02/21/23	12:00	53.7	0.172
02/21/23	13:00	53.8	0.173
02/21/23	14:00	53.9	0.173
02/21/23	15:00	53.6	0.171
02/21/23	16:00	53.5	0.171
02/21/23	17:00	53.3	0.170
02/21/23	18:00	53.1	0.169
02/21/23	19:00	53.2	0.169
02/21/23	20:00	53.2	0.169
02/21/23	21:00	53.3	0.169
02/21/23	22:00	53.4	0.170
02/21/23	23:00	53.5	0.170
02/22/23	00:00	53.5	0.170
02/22/23	01:00	53.6	0.170
02/22/23	02:00	53.6	0.170
02/22/23	03:00	53.7	0.170
02/22/23	04:00	53.8	0.171
02/22/23	05:00	53.8	0.171
02/22/23	06:00	53.8	0.171
02/22/23	07:00	53.7	0.170
02/22/23	08:00	53.6	0.170
02/22/23	09:00	53.5	0.170
02/22/23	10:00	53.6	0.170
02/22/23	11:00	53.6	0.170
02/22/23	12:00	53.5	0.170
02/22/23	13:00	53.4	0.170
02/22/23	14:00	53.4	0.170
02/22/23	15:00	53.5	0.170
02/22/23	16:00	53.6	0.170
02/22/23	17:00	53.5	0.169
02/22/23	18:00	53.7	0.170
02/22/23	19:00	53.8	0.170
02/22/23	20:00	53.9	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/22/23	21:00	53.7	0.168
02/22/23	22:00	53.6	0.167
02/22/23	23:00	53.4	0.166
02/23/23	00:00	53.4	0.166
02/23/23	01:00	53.2	0.165
02/23/23	02:00	53.1	0.164
02/23/23	03:00	53.0	0.164
02/23/23	04:00	53.0	0.164
02/23/23	05:00	52.9	0.163
02/23/23	06:00	52.8	0.163
02/23/23	07:00	52.7	0.163
02/23/23	08:00	52.7	0.163
02/23/23	09:00	52.7	0.162
02/23/23	10:00	52.7	0.162
02/23/23	11:00	52.7	0.162
02/23/23	12:00	52.8	0.162
02/23/23	13:00	52.8	0.161
02/23/23	14:00	52.7	0.161
02/23/23	15:00	52.5	0.160
02/23/23	16:00	52.1	0.159
02/23/23	17:00	52.1	0.159
02/23/23	18:00	51.5	0.157
02/23/23	19:00	51.2	0.157
02/23/23	20:00	50.9	0.156
02/23/23	21:00	50.9	0.156
02/23/23	22:00	50.9	0.157
02/23/23	23:00	50.9	0.157
02/24/23	00:00	50.9	0.157
02/24/23	01:00	51.0	0.158
02/24/23	02:00	51.1	0.158
02/24/23	03:00	51.1	0.158
02/24/23	04:00	51.1	0.158
02/24/23	05:00	51.1	0.158
02/24/23	06:00	51.1	0.158
02/24/23	07:00	51.0	0.158
02/24/23	08:00	51.0	0.159
02/24/23	09:00	51.0	0.159
02/24/23	10:00	50.9	0.159
02/24/23	11:00	50.8	0.159
02/24/23	12:00	50.9	0.160
02/24/23	13:00	51.1	0.161
02/24/23	14:00	51.3	0.162
02/24/23	15:00	51.7	0.164
02/24/23	16:00	52.1	0.166
02/24/23	17:00	52.4	0.167
02/24/23	18:00	52.8	0.169
02/24/23	19:00	53.1	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/24/23	20:00	53.2	0.171
02/24/23	21:00	53.3	0.171
02/24/23	22:00	53.2	0.171
02/24/23	23:00	53.2	0.171
02/25/23	00:00	53.2	0.172
02/25/23	01:00	53.2	0.172
02/25/23	02:00	53.2	0.172
02/25/23	03:00	53.2	0.172
02/25/23	04:00	53.2	0.173
02/25/23	05:00	53.1	0.173
02/25/23	06:00	53.1	0.172
02/25/23	07:00	53.0	0.172
02/25/23	08:00	53.0	0.172
02/25/23	09:00	53.0	0.172
02/25/23	10:00	53.0	0.172
02/25/23	11:00	53.1	0.172
02/25/23	12:00	53.1	0.172
02/25/23	13:00	53.1	0.172
02/25/23	14:00	53.1	0.171
02/25/23	15:00	53.1	0.171
02/25/23	16:00	53.0	0.171
02/25/23	17:00	52.9	0.170
02/25/23	18:00	53.0	0.170
02/25/23	19:00	53.0	0.170
02/25/23	20:00	53.1	0.171
02/25/23	21:00	53.2	0.171
02/25/23	22:00	53.3	0.171
02/25/23	23:00	53.5	0.172
02/26/23	00:00	53.6	0.172
02/26/23	01:00	53.7	0.172
02/26/23	02:00	53.8	0.173
02/26/23	03:00	53.7	0.172
02/26/23	04:00	53.8	0.173
02/26/23	05:00	53.9	0.173
02/26/23	06:00	54.1	0.174
02/26/23	07:00	54.3	0.174
02/26/23	08:00	54.4	0.175
02/26/23	09:00	54.6	0.175
02/26/23	10:00	54.8	0.176
02/26/23	11:00	54.9	0.176
02/26/23	12:00	54.9	0.176
02/26/23	13:00	54.9	0.177
02/26/23	14:00	55.0	0.177
02/26/23	15:00	55.2	0.177
02/26/23	16:00	55.3	0.178
02/26/23	17:00	55.5	0.178
02/26/23	18:00	55.5	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/26/23	19:00	55.5	0.178
02/26/23	20:00	55.4	0.178
02/26/23	21:00	55.4	0.178
02/26/23	22:00	55.4	0.178
02/26/23	23:00	55.3	0.178
02/27/23	00:00	55.3	0.177
02/27/23	01:00	55.2	0.177
02/27/23	02:00	55.2	0.177
02/27/23	03:00	55.2	0.177
02/27/23	04:00	55.2	0.177
02/27/23	05:00	55.1	0.176
02/27/23	06:00	55.0	0.176
02/27/23	07:00	55.0	0.176
02/27/23	08:00	55.0	0.176
02/27/23	09:00	54.9	0.176
02/27/23	10:00	54.9	0.176
02/27/23	11:00	54.9	0.176
02/27/23	12:00	54.9	0.176
02/27/23	13:00	55.0	0.175
02/27/23	14:00	55.0	0.175
02/27/23	15:00	55.0	0.174
02/27/23	16:00	55.0	0.172
02/27/23	17:00	54.8	0.171
02/27/23	18:00	54.6	0.171
02/27/23	19:00	54.6	0.170
02/27/23	20:00	54.7	0.170
02/27/23	21:00	54.7	0.169
02/27/23	22:00	54.8	0.169
02/27/23	23:00	54.8	0.169
02/28/23	00:00	54.8	0.169
02/28/23	01:00	54.9	0.169
02/28/23	02:00	54.8	0.168
02/28/23	03:00	54.8	0.168
02/28/23	04:00	54.9	0.168
02/28/23	05:00	54.9	0.168
02/28/23	06:00	55.0	0.168
02/28/23	07:00	55.0	0.167
02/28/23	08:00	55.1	0.167
02/28/23	09:00	55.2	0.167
02/28/23	10:00	55.1	0.167
02/28/23	11:00	55.2	0.167
02/28/23	12:00	55.2	0.167
02/28/23	13:00	55.1	0.168
02/28/23	14:00	55.0	0.169
02/28/23	15:00	55.1	0.170
02/28/23	16:00	55.1	0.171
02/28/23	17:00	55.4	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/28/23	18:00	55.5	0.173
02/28/23	19:00	55.5	0.174
02/28/23	20:00	55.5	0.174
02/28/23	21:00	55.5	0.174
02/28/23	22:00	55.4	0.174
02/28/23	23:00	55.4	0.175
03/01/23	00:00	55.4	0.175
03/01/23	01:00	55.3	0.175
03/01/23	02:00	55.3	0.175
03/01/23	03:00	55.1	0.175
03/01/23	04:00	55.1	0.175
03/01/23	05:00	55.2	0.175
03/01/23	06:00	55.1	0.175
03/01/23	07:00	55.1	0.175
03/01/23	08:00	55.1	0.175
03/01/23	09:00	55.1	0.176
03/01/23	10:00	55.1	0.176
03/01/23	11:00	55.1	0.177
03/01/23	12:00	55.1	0.177
03/01/23	13:00	55.1	0.177
03/01/23	14:00	55.0	0.176
03/01/23	15:00	54.9	0.176
03/01/23	16:00	54.9	0.176
03/01/23	17:00	54.9	0.176
03/01/23	18:00	55.0	0.176
03/01/23	19:00	54.9	0.176
03/01/23	20:00	54.9	0.176
03/01/23	21:00	54.9	0.176
03/01/23	22:00	54.9	0.176
03/01/23	23:00	54.9	0.175
03/02/23	00:00	54.9	0.176
03/02/23	01:00	54.9	0.176
03/02/23	02:00	55.0	0.176
03/02/23	03:00	55.1	0.177
03/02/23	04:00	55.2	0.177
03/02/23	05:00	55.1	0.177
03/02/23	06:00	55.0	0.177
03/02/23	07:00	54.9	0.176
03/02/23	08:00	54.8	0.176
03/02/23	09:00	54.7	0.175
03/02/23	10:00	54.7	0.175
03/02/23	11:00	54.5	0.175
03/02/23	12:00	54.5	0.174
03/02/23	13:00	54.6	0.175
03/02/23	14:00	54.7	0.175
03/02/23	15:00	54.9	0.176
03/02/23	16:00	54.9	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/02/23	17:00	54.9	0.176
03/02/23	18:00	54.7	0.175
03/02/23	19:00	54.7	0.175
03/02/23	20:00	54.8	0.175
03/02/23	21:00	54.8	0.175
03/02/23	22:00	54.7	0.175
03/02/23	23:00	54.6	0.175
03/03/23	00:00	54.5	0.175
03/03/23	01:00	54.5	0.174
03/03/23	02:00	54.4	0.174
03/03/23	03:00	54.3	0.174
03/03/23	04:00	54.2	0.173
03/03/23	05:00	54.1	0.173
03/03/23	06:00	54.1	0.173
03/03/23	07:00	54.1	0.173
03/03/23	08:00	54.1	0.173
03/03/23	09:00	54.1	0.172
03/03/23	10:00	54.0	0.171
03/03/23	11:00	54.0	0.171
03/03/23	12:00	54.1	0.170
03/03/23	13:00	54.0	0.170
03/03/23	14:00	53.9	0.169
03/03/23	15:00	54.0	0.168
03/03/23	16:00	53.9	0.168
03/03/23	17:00	53.8	0.168
03/03/23	18:00	53.7	0.167
03/03/23	19:00	53.6	0.167
03/03/23	20:00	53.5	0.166
03/03/23	21:00	53.5	0.166
03/03/23	22:00	53.4	0.165
03/03/23	23:00	53.2	0.164
03/04/23	00:00	53.2	0.164
03/04/23	01:00	53.5	0.164
03/04/23	02:00	53.8	0.165
03/04/23	03:00	54.2	0.165
03/04/23	04:00	54.5	0.166
03/04/23	05:00	54.7	0.167
03/04/23	06:00	54.8	0.167
03/04/23	07:00	55.0	0.167
03/04/23	08:00	55.1	0.168
03/04/23	09:00	55.2	0.168
03/04/23	10:00	55.2	0.168
03/04/23	11:00	55.2	0.168
03/04/23	12:00	55.2	0.168
03/04/23	13:00	55.1	0.168
03/04/23	14:00	55.1	0.168
03/04/23	15:00	54.9	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/04/23	16:00	54.9	0.167
03/04/23	17:00	54.7	0.167
03/04/23	18:00	54.6	0.167
03/04/23	19:00	54.6	0.167
03/04/23	20:00	54.6	0.167
03/04/23	21:00	54.5	0.167
03/04/23	22:00	54.6	0.168
03/04/23	23:00	54.8	0.169
03/05/23	00:00	54.7	0.169
03/05/23	01:00	54.4	0.168
03/05/23	02:00	54.0	0.168
03/05/23	03:00	53.6	0.167
03/05/23	04:00	53.3	0.166
03/05/23	05:00	53.0	0.165
03/05/23	06:00	52.8	0.165
03/05/23	07:00	52.8	0.165
03/05/23	08:00	52.7	0.165
03/05/23	09:00	52.7	0.165
03/05/23	10:00	52.7	0.165
03/05/23	11:00	52.7	0.165
03/05/23	12:00	52.6	0.165
03/05/23	13:00	52.6	0.165
03/05/23	14:00	52.6	0.165
03/05/23	15:00	52.7	0.166
03/05/23	16:00	52.7	0.166
03/05/23	17:00	52.7	0.166
03/05/23	18:00	52.8	0.166
03/05/23	19:00	52.8	0.167
03/05/23	20:00	52.9	0.167
03/05/23	21:00	53.0	0.168
03/05/23	22:00	53.0	0.168
03/05/23	23:00	53.0	0.168
03/06/23	00:00	53.1	0.169
03/06/23	01:00	53.1	0.168
03/06/23	02:00	53.2	0.169
03/06/23	03:00	53.2	0.169
03/06/23	04:00	53.2	0.169
03/06/23	05:00	53.3	0.169
03/06/23	06:00	53.3	0.169
03/06/23	07:00	53.4	0.169
03/06/23	08:00	53.3	0.169
03/06/23	09:00	53.4	0.169
03/06/23	10:00	53.4	0.169
03/06/23	11:00	53.5	0.170
03/06/23	12:00	53.5	0.170
03/06/23	13:00	53.6	0.169
03/06/23	14:00	53.7	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/06/23	15:00	53.6	0.170
03/06/23	16:00	53.7	0.170
03/06/23	17:00	53.6	0.169
03/06/23	18:00	53.7	0.169
03/06/23	19:00	53.7	0.169
03/06/23	20:00	53.6	0.169
03/06/23	21:00	53.7	0.169
03/06/23	22:00	53.8	0.169
03/06/23	23:00	53.9	0.169
03/07/23	00:00	53.9	0.169
03/07/23	01:00	54.0	0.170
03/07/23	02:00	54.0	0.170
03/07/23	03:00	54.1	0.170
03/07/23	04:00	54.2	0.170
03/07/23	05:00	54.3	0.171
03/07/23	06:00	54.5	0.171
03/07/23	07:00	54.6	0.172
03/07/23	08:00	54.7	0.172
03/07/23	09:00	54.8	0.173
03/07/23	10:00	53.5	0.173
03/07/23	11:00	53.6	0.173
03/07/23	12:00	53.7	0.173
03/07/23	13:00	53.6	0.173
03/07/23	14:00	53.7	0.173
03/07/23	15:00	53.6	0.173
03/07/23	16:00	53.6	0.173
03/07/23	17:00	53.6	0.173
03/07/23	18:00	53.5	0.172
03/07/23	19:00	53.5	0.172
03/07/23	20:00	53.4	0.172
03/07/23	21:00	53.3	0.173
03/07/23	22:00	53.4	0.173
03/07/23	23:00	53.4	0.173
03/08/23	00:00	53.3	0.173
03/08/23	01:00	53.3	0.173
03/08/23	02:00	53.3	0.173
03/08/23	03:00	53.5	0.173
03/08/23	04:00	53.4	0.173
03/08/23	05:00	53.3	0.173
03/08/23	06:00	53.3	0.173
03/08/23	07:00	53.2	0.173
03/08/23	08:00	53.1	0.173
03/08/23	09:00	53.1	0.173
03/08/23	10:00	53.1	0.173
03/08/23	11:00	53.1	0.173
03/08/23	12:00	53.1	0.173
03/08/23	13:00	54.5	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/08/23	14:00	54.4	0.171
03/08/23	15:00	54.2	0.170
03/08/23	16:00	54.1	0.170
03/08/23	17:00	53.9	0.170
03/08/23	18:00	54.1	0.170
03/08/23	19:00	54.2	0.170
03/08/23	20:00	54.2	0.170
03/08/23	21:00	54.3	0.171
03/08/23	22:00	54.5	0.171
03/08/23	23:00	54.5	0.171
03/09/23	00:00	54.6	0.172
03/09/23	01:00	54.5	0.172
03/09/23	02:00	54.6	0.171
03/09/23	03:00	54.8	0.172
03/09/23	04:00	54.9	0.172
03/09/23	05:00	54.9	0.172
03/09/23	06:00	54.8	0.172
03/09/23	07:00	55.0	0.172
03/09/23	08:00	54.9	0.172
03/09/23	09:00	54.8	0.172
03/09/23	10:00	54.6	0.171
03/09/23	11:00	54.5	0.171
03/09/23	12:00	54.4	0.171
03/09/23	13:00	54.2	0.171
03/09/23	14:00	54.3	0.171
03/09/23	15:00	54.5	0.171
03/09/23	16:00	54.7	0.172
03/09/23	17:00	54.7	0.172
03/09/23	18:00	54.5	0.171
03/09/23	19:00	54.5	0.171
03/09/23	20:00	54.6	0.172
03/09/23	21:00	54.6	0.172
03/09/23	22:00	54.6	0.171
03/09/23	23:00	54.5	0.171
03/10/23	00:00	54.3	0.170
03/10/23	01:00	54.3	0.170
03/10/23	02:00	54.1	0.169
03/10/23	03:00	54.1	0.169
03/10/23	04:00	54.0	0.168
03/10/23	05:00	53.9	0.168
03/10/23	06:00	53.9	0.168
03/10/23	07:00	53.9	0.168
03/10/23	08:00	53.9	0.167
03/10/23	09:00	54.0	0.167
03/10/23	10:00	53.9	0.167
03/10/23	11:00	54.0	0.167
03/10/23	12:00	54.1	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/10/23	13:00	54.2	0.168
03/10/23	14:00	54.2	0.168
03/10/23	15:00	54.2	0.168
03/10/23	16:00	54.2	0.168
03/10/23	17:00	54.3	0.168
03/10/23	18:00	54.3	0.168
03/10/23	19:00	54.3	0.168
03/10/23	20:00	54.3	0.168
03/10/23	21:00	54.3	0.168
03/10/23	22:00	54.2	0.167
03/10/23	23:00	54.2	0.167
03/11/23	00:00	54.3	0.168
03/11/23	01:00	54.4	0.168
03/11/23	02:00	54.5	0.168
03/11/23	03:00	54.4	0.168
03/11/23	04:00	54.5	0.169
03/11/23	05:00	54.5	0.169
03/11/23	06:00	54.6	0.170
03/11/23	07:00	54.7	0.170
03/11/23	08:00	54.4	0.170
03/11/23	09:00	54.4	0.170
03/11/23	10:00	54.5	0.171
03/11/23	11:00	54.5	0.171
03/11/23	12:00	54.4	0.171
03/11/23	13:00	54.3	0.171
03/11/23	14:00	54.3	0.171
03/11/23	15:00	54.2	0.170
03/11/23	16:00	54.1	0.171
03/11/23	17:00	54.1	0.171
03/11/23	18:00	54.1	0.171
03/11/23	19:00	54.1	0.171
03/11/23	20:00	54.0	0.171
03/11/23	21:00	54.1	0.171
03/11/23	22:00	54.1	0.172
03/11/23	23:00	54.1	0.172
03/12/23	00:00	54.1	0.173
03/12/23	01:00	54.2	0.173
03/12/23	02:00	54.2	0.173
03/12/23	03:00	54.2	0.173
03/12/23	04:00	54.1	0.173
03/12/23	05:00	54.1	0.173
03/12/23	06:00	54.0	0.172
03/12/23	07:00	53.9	0.172
03/12/23	08:00	54.2	0.173
03/12/23	09:00	54.2	0.173
03/12/23	10:00	54.2	0.173
03/12/23	11:00	54.2	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/12/23	12:00	54.3	0.173
03/12/23	13:00	54.3	0.173
03/12/23	14:00	54.4	0.173
03/12/23	15:00	54.8	0.174
03/12/23	16:00	54.8	0.174
03/12/23	17:00	54.7	0.174
03/12/23	18:00	54.6	0.173
03/12/23	19:00	54.6	0.173
03/12/23	20:00	54.6	0.173
03/12/23	21:00	54.5	0.173
03/12/23	22:00	54.6	0.173
03/12/23	23:00	54.8	0.174
03/13/23	00:00	54.9	0.174
03/13/23	01:00	54.9	0.174
03/13/23	02:00	54.9	0.174
03/13/23	03:00	55.0	0.174
03/13/23	04:00	55.0	0.174
03/13/23	05:00	54.9	0.174
03/13/23	06:00	54.8	0.173
03/13/23	07:00	54.9	0.173
03/13/23	08:00	54.9	0.173
03/13/23	09:00	55.0	0.173
03/13/23	10:00	55.0	0.174
03/13/23	11:00	55.1	0.174
03/13/23	12:00	55.0	0.173
03/13/23	13:00	55.1	0.174
03/13/23	14:00	55.2	0.174
03/13/23	15:00	54.9	0.173
03/13/23	16:00	55.0	0.173
03/13/23	17:00	55.2	0.173
03/13/23	18:00	56.5	0.175
03/13/23	19:00	58.9	0.176
03/13/23	20:00	59.4	0.176
03/13/23	21:00	59.2	0.175
03/13/23	22:00	59.0	0.175
03/13/23	23:00	58.8	0.175
03/14/23	00:00	58.7	0.174
03/14/23	01:00	58.5	0.174
03/14/23	02:00	58.4	0.174
03/14/23	03:00	58.3	0.174
03/14/23	04:00	58.2	0.173
03/14/23	05:00	58.1	0.173
03/14/23	06:00	58.1	0.173
03/14/23	07:00	58.0	0.173
03/14/23	08:00	57.8	0.173
03/14/23	09:00	57.6	0.173
03/14/23	10:00	57.6	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/14/23	11:00	57.5	0.173
03/14/23	12:00	57.4	0.173
03/14/23	13:00	57.3	0.172
03/14/23	14:00	57.2	0.173
03/14/23	15:00	57.2	0.173
03/14/23	16:00	57.1	0.172
03/14/23	17:00	57.0	0.173
03/14/23	18:00	55.7	0.171
03/14/23	19:00	53.4	0.170
03/14/23	20:00	52.7	0.171
03/14/23	21:00	53.0	0.172
03/14/23	22:00	52.9	0.171
03/14/23	23:00	53.0	0.172
03/15/23	00:00	53.0	0.172
03/15/23	01:00	53.2	0.172
03/15/23	02:00	53.2	0.172
03/15/23	03:00	53.3	0.173
03/15/23	04:00	53.4	0.173
03/15/23	05:00	55.0	0.175
03/15/23	06:00	57.4	0.177
03/15/23	07:00	57.7	0.176
03/15/23	08:00	57.7	0.177
03/15/23	09:00	57.8	0.177
03/15/23	10:00	57.7	0.177
03/15/23	11:00	57.7	0.177
03/15/23	12:00	57.6	0.177
03/15/23	13:00	57.6	0.177
03/15/23	14:00	57.5	0.177
03/15/23	15:00	57.5	0.177
03/15/23	16:00	57.4	0.177
03/15/23	17:00	57.4	0.177
03/15/23	18:00	57.4	0.177
03/15/23	19:00	57.4	0.177
03/15/23	20:00	57.5	0.177
03/15/23	21:00	57.5	0.177
03/15/23	22:00	57.6	0.177
03/15/23	23:00	57.7	0.177
03/16/23	00:00	57.8	0.178
03/16/23	01:00	57.9	0.178
03/16/23	02:00	57.9	0.178
03/16/23	03:00	57.9	0.178
03/16/23	04:00	58.0	0.178
03/16/23	05:00	56.5	0.176
03/16/23	06:00	54.2	0.174
03/16/23	07:00	53.8	0.175
03/16/23	08:00	53.8	0.174
03/16/23	09:00	53.7	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/16/23	10:00	53.8	0.174
03/16/23	11:00	53.7	0.173
03/16/23	12:00	53.6	0.173
03/16/23	13:00	53.5	0.173
03/16/23	14:00	53.5	0.173
03/16/23	15:00	53.5	0.173
03/16/23	16:00	53.6	0.173
03/16/23	17:00	53.6	0.174
03/16/23	18:00	53.7	0.174
03/16/23	19:00	53.7	0.174
03/16/23	20:00	53.7	0.174
03/16/23	21:00	53.6	0.173
03/16/23	22:00	53.6	0.173
03/16/23	23:00	53.5	0.173
03/17/23	00:00	53.5	0.173
03/17/23	01:00	53.4	0.172
03/17/23	02:00	53.3	0.172
03/17/23	03:00	53.3	0.172
03/17/23	04:00	53.2	0.171
03/17/23	05:00	53.2	0.171
03/17/23	06:00	53.2	0.171
03/17/23	07:00	53.4	0.171
03/17/23	08:00	53.5	0.171
03/17/23	09:00	53.7	0.172
03/17/23	10:00	53.9	0.172
03/17/23	11:00	53.8	0.172
03/17/23	12:00	53.9	0.171
03/17/23	13:00	54.0	0.171
03/17/23	14:00	53.8	0.171
03/17/23	15:00	53.8	0.170
03/17/23	16:00	53.8	0.170
03/17/23	17:00	53.7	0.169
03/17/23	18:00	53.6	0.169
03/17/23	19:00	53.5	0.168
03/17/23	20:00	53.3	0.167
03/17/23	21:00	53.2	0.167
03/17/23	22:00	53.0	0.166
03/17/23	23:00	52.9	0.165
03/18/23	00:00	52.7	0.165
03/18/23	01:00	52.5	0.164
03/18/23	02:00	52.5	0.164
03/18/23	03:00	52.2	0.163
03/18/23	04:00	52.1	0.163
03/18/23	05:00	52.0	0.163
03/18/23	06:00	52.0	0.163
03/18/23	07:00	51.9	0.163
03/18/23	08:00	51.7	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/18/23	09:00	51.6	0.162
03/18/23	10:00	51.5	0.161
03/18/23	11:00	51.7	0.162
03/18/23	12:00	51.8	0.162
03/18/23	13:00	51.9	0.163
03/18/23	14:00	52.0	0.163
03/18/23	15:00	52.1	0.163
03/18/23	16:00	52.2	0.163
03/18/23	17:00	52.2	0.163
03/18/23	18:00	52.3	0.164
03/18/23	19:00	52.5	0.165
03/18/23	20:00	52.7	0.165
03/18/23	21:00	52.9	0.166
03/18/23	22:00	53.0	0.166
03/18/23	23:00	53.1	0.166
03/19/23	00:00	53.1	0.167
03/19/23	01:00	53.1	0.167
03/19/23	02:00	53.2	0.167
03/19/23	03:00	53.3	0.167
03/19/23	04:00	53.2	0.167
03/19/23	05:00	53.0	0.166
03/19/23	06:00	52.8	0.166
03/19/23	07:00	52.7	0.165
03/19/23	08:00	52.6	0.165
03/19/23	09:00	52.5	0.165
03/19/23	10:00	52.4	0.165
03/19/23	11:00	52.3	0.164
03/19/23	12:00	52.2	0.164
03/19/23	13:00	52.2	0.164
03/19/23	14:00	52.1	0.164
03/19/23	15:00	51.9	0.163
03/19/23	16:00	51.6	0.162
03/19/23	17:00	51.5	0.162
03/19/23	18:00	51.4	0.162
03/19/23	19:00	51.2	0.161
03/19/23	20:00	51.1	0.161
03/19/23	21:00	51.0	0.160
03/19/23	22:00	51.0	0.161
03/19/23	23:00	50.8	0.160
03/20/23	00:00	50.9	0.160
03/20/23	01:00	50.9	0.160
03/20/23	02:00	50.6	0.160
03/20/23	03:00	50.6	0.160
03/20/23	04:00	50.6	0.160
03/20/23	05:00	50.6	0.160
03/20/23	06:00	50.9	0.161
03/20/23	07:00	51.3	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/20/23	08:00	51.8	0.164
03/20/23	09:00	52.0	0.165
03/20/23	10:00	51.9	0.165
03/20/23	11:00	52.1	0.166
03/20/23	12:00	52.2	0.167
03/20/23	13:00	52.5	0.168
03/20/23	14:00	52.7	0.169
03/20/23	15:00	52.9	0.170
03/20/23	16:00	53.1	0.171
03/20/23	17:00	53.1	0.171
03/20/23	18:00	53.1	0.171
03/20/23	19:00	53.0	0.171
03/20/23	20:00	53.0	0.171
03/20/23	21:00	52.9	0.171
03/20/23	22:00	52.9	0.171
03/20/23	23:00	53.0	0.171
03/21/23	00:00	53.0	0.171
03/21/23	01:00	53.2	0.172
03/21/23	02:00	53.5	0.173
03/21/23	03:00	53.7	0.174
03/21/23	04:00	53.9	0.175
03/21/23	05:00	54.0	0.175
03/21/23	06:00	53.8	0.175
03/21/23	07:00	53.5	0.174
03/21/23	08:00	53.2	0.172
03/21/23	09:00	53.0	0.172
03/21/23	10:00	53.1	0.172
03/21/23	11:00	53.0	0.172
03/21/23	12:00	52.9	0.172
03/21/23	13:00	52.7	0.171
03/21/23	14:00	52.6	0.171
03/21/23	15:00	52.6	0.171
03/21/23	16:00	52.8	0.171
03/21/23	17:00	52.9	0.171
03/21/23	18:00	53.1	0.172
03/21/23	19:00	53.3	0.172
03/21/23	20:00	53.4	0.173
03/21/23	21:00	53.5	0.173
03/21/23	22:00	53.7	0.174
03/21/23	23:00	53.9	0.174
03/22/23	00:00	54.1	0.175
03/22/23	01:00	54.1	0.175
03/22/23	02:00	54.2	0.175
03/22/23	03:00	54.2	0.175
03/22/23	04:00	54.3	0.175
03/22/23	05:00	54.6	0.176
03/22/23	06:00	54.7	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/22/23	07:00	54.7	0.176
03/22/23	08:00	54.9	0.177
03/22/23	09:00	54.9	0.177
03/22/23	10:00	55.0	0.177
03/22/23	11:00	55.0	0.177
03/22/23	12:00	55.1	0.177
03/22/23	13:00	55.1	0.177
03/22/23	14:00	55.1	0.177
03/22/23	15:00	55.1	0.177
03/22/23	16:00	55.0	0.177
03/22/23	17:00	55.0	0.177
03/22/23	18:00	54.9	0.176
03/22/23	19:00	54.9	0.176
03/22/23	20:00	55.0	0.177
03/22/23	21:00	55.1	0.177
03/22/23	22:00	55.1	0.177
03/22/23	23:00	55.0	0.176
03/23/23	00:00	55.0	0.176
03/23/23	01:00	54.9	0.176
03/23/23	02:00	54.9	0.176
03/23/23	03:00	54.8	0.176
03/23/23	04:00	54.9	0.176
03/23/23	05:00	54.8	0.176
03/23/23	06:00	54.8	0.176
03/23/23	07:00	54.8	0.175
03/23/23	08:00	54.8	0.175
03/23/23	09:00	54.8	0.175
03/23/23	10:00	54.8	0.174
03/23/23	11:00	54.7	0.174
03/23/23	12:00	54.7	0.174
03/23/23	13:00	54.6	0.173
03/23/23	14:00	54.6	0.173
03/23/23	15:00	54.6	0.173
03/23/23	16:00	54.6	0.173
03/23/23	17:00	54.6	0.172
03/23/23	18:00	54.6	0.172
03/23/23	19:00	54.5	0.172
03/23/23	20:00	54.5	0.172
03/23/23	21:00	54.5	0.171
03/23/23	22:00	54.4	0.171
03/23/23	23:00	54.4	0.171
03/24/23	00:00	54.3	0.171
03/24/23	01:00	54.4	0.171
03/24/23	02:00	54.5	0.171
03/24/23	03:00	54.5	0.171
03/24/23	04:00	54.4	0.171
03/24/23	05:00	54.5	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/24/23	06:00	54.4	0.171
03/24/23	07:00	54.2	0.170
03/24/23	08:00	54.1	0.170
03/24/23	09:00	54.2	0.171
03/24/23	10:00	54.3	0.172
03/24/23	11:00	54.5	0.172
03/24/23	12:00	54.6	0.173
03/24/23	13:00	54.6	0.173
03/24/23	14:00	54.6	0.174
03/24/23	15:00	54.6	0.174
03/24/23	16:00	54.6	0.174
03/24/23	17:00	54.6	0.174
03/24/23	18:00	54.5	0.174
03/24/23	19:00	54.5	0.174
03/24/23	20:00	54.5	0.174
03/24/23	21:00	54.6	0.175
03/24/23	22:00	54.6	0.175
03/24/23	23:00	54.5	0.174
03/25/23	00:00	54.5	0.174
03/25/23	01:00	54.4	0.174
03/25/23	02:00	54.5	0.174
03/25/23	03:00	54.4	0.174
03/25/23	04:00	54.4	0.174
03/25/23	05:00	54.3	0.173
03/25/23	06:00	54.4	0.173
03/25/23	07:00	54.4	0.173
03/25/23	08:00	54.4	0.173
03/25/23	09:00	54.4	0.172
03/25/23	10:00	54.5	0.172
03/25/23	11:00	54.5	0.171
03/25/23	12:00	54.4	0.170
03/25/23	13:00	54.5	0.170
03/25/23	14:00	54.8	0.171
03/25/23	15:00	54.9	0.170
03/25/23	16:00	54.9	0.170
03/25/23	17:00	54.8	0.169
03/25/23	18:00	54.7	0.169
03/25/23	19:00	54.6	0.168
03/25/23	20:00	54.5	0.168
03/25/23	21:00	54.4	0.167
03/25/23	22:00	54.3	0.167
03/25/23	23:00	54.4	0.167
03/26/23	00:00	54.4	0.167
03/26/23	01:00	54.3	0.167
03/26/23	02:00	54.1	0.166
03/26/23	03:00	54.1	0.166
03/26/23	04:00	54.0	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/26/23	05:00	54.0	0.165
03/26/23	06:00	54.0	0.165
03/26/23	07:00	54.1	0.166
03/26/23	08:00	54.1	0.166
03/26/23	09:00	54.1	0.166
03/26/23	10:00	53.9	0.166
03/26/23	11:00	53.8	0.166
03/26/23	12:00	53.7	0.166
03/26/23	13:00	53.5	0.166
03/26/23	14:00	53.2	0.166
03/26/23	15:00	53.1	0.166
03/26/23	16:00	53.0	0.166
03/26/23	17:00	53.0	0.167
03/26/23	18:00	52.9	0.167
03/26/23	19:00	52.9	0.168
03/26/23	20:00	53.0	0.168
03/26/23	21:00	53.0	0.168
03/26/23	22:00	52.9	0.168
03/26/23	23:00	52.8	0.168
03/27/23	00:00	52.8	0.168
03/27/23	01:00	52.7	0.167
03/27/23	02:00	52.6	0.167
03/27/23	03:00	52.6	0.167
03/27/23	04:00	52.6	0.167
03/27/23	05:00	52.6	0.166
03/27/23	06:00	52.5	0.166
03/27/23	07:00	52.5	0.166
03/27/23	08:00	52.5	0.166
03/27/23	09:00	52.4	0.166
03/27/23	10:00	52.4	0.166
03/27/23	11:00	52.6	0.167
03/27/23	12:00	52.8	0.167
03/27/23	13:00	52.8	0.168
03/27/23	14:00	52.8	0.167
03/27/23	15:00	52.8	0.167
03/27/23	16:00	53.0	0.167
03/27/23	17:00	53.1	0.168
03/27/23	18:00	53.2	0.168
03/27/23	19:00	53.4	0.168
03/27/23	20:00	53.4	0.168
03/27/23	21:00	53.4	0.168
03/27/23	22:00	53.5	0.169
03/27/23	23:00	53.6	0.169
03/28/23	00:00	53.5	0.169
03/28/23	01:00	53.6	0.169
03/28/23	02:00	53.6	0.169
03/28/23	03:00	53.6	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/28/23	04:00	53.8	0.171
03/28/23	05:00	53.8	0.171
03/28/23	06:00	53.9	0.172
03/28/23	07:00	54.1	0.172
03/28/23	08:00	54.2	0.173
03/28/23	09:00	54.2	0.173
03/28/23	10:00	54.3	0.173
03/28/23	11:00	54.0	0.172
03/28/23	12:00	53.9	0.172
03/28/23	13:00	53.8	0.172
03/28/23	14:00	53.8	0.172
03/28/23	15:00	53.7	0.172
03/28/23	16:00	53.6	0.172
03/28/23	17:00	53.5	0.171
03/28/23	18:00	53.5	0.171
03/28/23	19:00	53.4	0.171
03/28/23	20:00	53.4	0.171
03/28/23	21:00	53.3	0.170
03/28/23	22:00	53.1	0.170
03/28/23	23:00	53.1	0.170
03/29/23	00:00	53.3	0.170
03/29/23	01:00	53.2	0.170
03/29/23	02:00	53.2	0.170
03/29/23	03:00	53.2	0.170
03/29/23	04:00	53.2	0.169
03/29/23	05:00	53.2	0.169
03/29/23	06:00	53.3	0.169
03/29/23	07:00	53.1	0.168
03/29/23	08:00	53.1	0.169
03/29/23	09:00	53.3	0.169
03/29/23	10:00	53.5	0.170
03/29/23	11:00	53.7	0.171
03/29/23	12:00	53.9	0.171
03/29/23	13:00	53.8	0.171
03/29/23	14:00	53.8	0.170
03/29/23	15:00	54.0	0.171
03/29/23	16:00	54.2	0.171
03/29/23	17:00	54.4	0.172
03/29/23	18:00	54.5	0.172
03/29/23	19:00	54.7	0.172
03/29/23	20:00	54.8	0.173
03/29/23	21:00	55.0	0.173
03/29/23	22:00	55.1	0.173
03/29/23	23:00	55.3	0.174
03/30/23	00:00	55.3	0.174
03/30/23	01:00	55.3	0.174
03/30/23	02:00	55.5	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
03/30/23	03:00	55.4	0.175
03/30/23	04:00	55.3	0.175
03/30/23	05:00	55.1	0.175
03/30/23	06:00	54.9	0.174
03/30/23	07:00	54.9	0.174
03/30/23	08:00	54.7	0.173
03/30/23	09:00	54.3	0.172
03/30/23	10:00	54.0	0.171
03/30/23	11:00	53.7	0.170
03/30/23	12:00	53.4	0.169
03/30/23	13:00	53.5	0.169
03/30/23	14:00	53.3	0.169
03/30/23	15:00	53.1	0.168
03/30/23	16:00	52.8	0.167
03/30/23	17:00	52.6	0.167
03/30/23	18:00	52.5	0.166
03/30/23	19:00	52.4	0.166
03/30/23	20:00	52.2	0.166
03/30/23	21:00	52.2	0.166
03/30/23	22:00	52.2	0.166
03/30/23	23:00	52.1	0.166
03/31/23	00:00	52.2	0.166
03/31/23	01:00	52.2	0.166
03/31/23	02:00	52.2	0.166
03/31/23	03:00	52.5	0.166
03/31/23	04:00	52.5	0.166
03/31/23	05:00	52.7	0.167
03/31/23	06:00	52.8	0.167
03/31/23	07:00	53.1	0.168
03/31/23	08:00	53.2	0.168
03/31/23	09:00	53.3	0.168
03/31/23	10:00	53.4	0.168
03/31/23	11:00	53.6	0.168
03/31/23	12:00	53.7	0.168
03/31/23	13:00	53.8	0.169
03/31/23	14:00	54.1	0.169
03/31/23	15:00	54.1	0.169
03/31/23	16:00	54.2	0.169
03/31/23	17:00	54.3	0.169
03/31/23	18:00	54.3	0.169
03/31/23	19:00	54.5	0.169
03/31/23	20:00	54.7	0.168
03/31/23	21:00	54.8	0.168
03/31/23	22:00	54.8	0.168
03/31/23	23:00	55.3	0.168
04/01/23	00:00	55.4	0.168
04/01/23	01:00	55.7	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/01/23	02:00	56.2	0.168
04/01/23	03:00	56.3	0.168
04/01/23	04:00	56.6	0.168
04/01/23	05:00	56.6	0.168
04/01/23	06:00	56.6	0.168
04/01/23	07:00	56.4	0.167
04/01/23	08:00	56.2	0.166
04/01/23	09:00	56.0	0.166
04/01/23	10:00	55.9	0.165
04/01/23	11:00	55.8	0.165
04/01/23	12:00	55.7	0.164
04/01/23	13:00	55.6	0.164
04/01/23	14:00	55.5	0.164
04/01/23	15:00	55.4	0.163
04/01/23	16:00	55.2	0.162
04/01/23	17:00	55.1	0.162
04/01/23	18:00	55.0	0.162
04/01/23	19:00	54.8	0.161
04/01/23	20:00	54.5	0.161
04/01/23	21:00	54.2	0.160
04/01/23	22:00	54.1	0.160
04/01/23	23:00	53.6	0.159
04/02/23	00:00	53.2	0.159
04/02/23	01:00	53.0	0.159
04/02/23	02:00	52.4	0.158
04/02/23	03:00	52.2	0.158
04/02/23	04:00	51.9	0.158
04/02/23	05:00	51.9	0.158
04/02/23	06:00	51.8	0.158
04/02/23	07:00	51.8	0.158
04/02/23	08:00	51.9	0.158
04/02/23	09:00	51.9	0.159
04/02/23	10:00	51.8	0.159
04/02/23	11:00	51.8	0.160
04/02/23	12:00	51.8	0.161
04/02/23	13:00	51.9	0.161
04/02/23	14:00	51.9	0.162
04/02/23	15:00	52.0	0.162
04/02/23	16:00	52.1	0.163
04/02/23	17:00	52.1	0.164
04/02/23	18:00	52.0	0.164
04/02/23	19:00	52.0	0.164
04/02/23	20:00	52.0	0.165
04/02/23	21:00	52.0	0.165
04/02/23	22:00	52.1	0.165
04/02/23	23:00	52.1	0.165
04/03/23	00:00	52.2	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/03/23	01:00	52.1	0.166
04/03/23	02:00	52.1	0.166
04/03/23	03:00	52.0	0.166
04/03/23	04:00	51.8	0.165
04/03/23	05:00	51.6	0.165
04/03/23	06:00	51.5	0.165
04/03/23	07:00	51.5	0.165
04/03/23	08:00	51.5	0.165
04/03/23	09:00	51.6	0.165
04/03/23	10:00	51.7	0.165
04/03/23	11:00	51.8	0.165
04/03/23	12:00	51.9	0.165
04/03/23	13:00	52.1	0.165
04/03/23	14:00	52.1	0.166
04/03/23	15:00	52.1	0.166
04/03/23	16:00	52.0	0.166
04/03/23	17:00	52.1	0.166
04/03/23	18:00	52.2	0.166
04/03/23	19:00	52.3	0.167
04/03/23	20:00	52.4	0.167
04/03/23	21:00	52.5	0.167
04/03/23	22:00	52.5	0.167
04/03/23	23:00	52.6	0.168
04/04/23	00:00	52.6	0.168
04/04/23	01:00	53.0	0.169
04/04/23	02:00	53.5	0.170
04/04/23	03:00	53.9	0.170
04/04/23	04:00	54.2	0.171
04/04/23	05:00	54.6	0.171
04/04/23	06:00	55.0	0.172
04/04/23	07:00	55.4	0.172
04/04/23	08:00	55.6	0.172
04/04/23	09:00	55.7	0.173
04/04/23	10:00	55.9	0.173
04/04/23	11:00	55.9	0.173
04/04/23	12:00	56.1	0.173
04/04/23	13:00	56.1	0.173
04/04/23	14:00	56.2	0.172
04/04/23	15:00	56.4	0.173
04/04/23	16:00	56.5	0.173
04/04/23	17:00	56.6	0.173
04/04/23	18:00	56.7	0.173
04/04/23	19:00	56.8	0.173
04/04/23	20:00	56.8	0.173
04/04/23	21:00	56.8	0.173
04/04/23	22:00	56.8	0.173
04/04/23	23:00	56.8	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/05/23	00:00	56.7	0.173
04/05/23	01:00	56.2	0.172
04/05/23	02:00	55.7	0.170
04/05/23	03:00	55.4	0.170
04/05/23	04:00	55.1	0.170
04/05/23	05:00	54.9	0.170
04/05/23	06:00	54.6	0.169
04/05/23	07:00	54.3	0.169
04/05/23	08:00	54.2	0.169
04/05/23	09:00	54.0	0.169
04/05/23	10:00	53.9	0.169
04/05/23	11:00	53.9	0.169
04/05/23	12:00	54.3	0.169
04/05/23	13:00	54.5	0.169
04/05/23	14:00	54.9	0.169
04/05/23	15:00	55.1	0.169
04/05/23	16:00	55.1	0.170
04/05/23	17:00	55.2	0.169
04/05/23	18:00	55.1	0.169
04/05/23	19:00	55.0	0.168
04/05/23	20:00	54.8	0.168
04/05/23	21:00	54.7	0.167
04/05/23	22:00	54.6	0.167
04/05/23	23:00	54.6	0.167
04/06/23	00:00	54.6	0.167
04/06/23	01:00	54.4	0.166
04/06/23	02:00	54.4	0.166
04/06/23	03:00	54.3	0.166
04/06/23	04:00	54.3	0.166
04/06/23	05:00	54.3	0.166
04/06/23	06:00	54.2	0.166
04/06/23	07:00	54.3	0.166
04/06/23	08:00	54.3	0.166
04/06/23	09:00	54.4	0.166
04/06/23	10:00	54.4	0.166
04/06/23	11:00	54.3	0.167
04/06/23	12:00	53.9	0.166
04/06/23	13:00	53.5	0.167
04/06/23	14:00	53.2	0.167
04/06/23	15:00	52.9	0.166
04/06/23	16:00	52.8	0.166
04/06/23	17:00	52.6	0.166
04/06/23	18:00	52.6	0.166
04/06/23	19:00	52.6	0.167
04/06/23	20:00	52.6	0.167
04/06/23	21:00	52.7	0.167
04/06/23	22:00	52.8	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/06/23	23:00	52.8	0.167
04/07/23	00:00	52.8	0.168
04/07/23	01:00	53.0	0.168
04/07/23	02:00	53.0	0.168
04/07/23	03:00	53.1	0.168
04/07/23	04:00	53.1	0.169
04/07/23	05:00	53.0	0.169
04/07/23	06:00	53.0	0.169
04/07/23	07:00	53.0	0.169
04/07/23	08:00	52.9	0.169
04/07/23	09:00	52.8	0.168
04/07/23	10:00	52.6	0.168
04/07/23	11:00	52.4	0.167
04/07/23	12:00	52.4	0.167
04/07/23	13:00	52.2	0.167
04/07/23	14:00	52.2	0.167
04/07/23	15:00	52.1	0.166
04/07/23	16:00	52.1	0.166
04/07/23	17:00	52.1	0.166
04/07/23	18:00	52.2	0.166
04/07/23	19:00	52.2	0.166
04/07/23	20:00	52.2	0.166
04/07/23	21:00	52.2	0.165
04/07/23	22:00	52.1	0.165
04/07/23	23:00	52.0	0.164
04/08/23	00:00	51.9	0.164
04/08/23	01:00	51.7	0.163
04/08/23	02:00	51.6	0.163
04/08/23	03:00	51.5	0.163
04/08/23	04:00	51.4	0.162
04/08/23	05:00	51.4	0.162
04/08/23	06:00	51.3	0.161
04/08/23	07:00	51.3	0.161
04/08/23	08:00	51.2	0.160
04/08/23	09:00	51.4	0.161
04/08/23	10:00	51.6	0.161
04/08/23	11:00	51.7	0.161
04/08/23	12:00	51.6	0.161
04/08/23	13:00	51.9	0.161
04/08/23	14:00	51.8	0.161
04/08/23	15:00	51.8	0.161
04/08/23	16:00	51.7	0.161
04/08/23	17:00	51.6	0.161
04/08/23	18:00	51.4	0.161
04/08/23	19:00	51.2	0.160
04/08/23	20:00	51.1	0.160
04/08/23	21:00	50.9	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/08/23	22:00	50.9	0.160
04/08/23	23:00	50.9	0.160
04/09/23	00:00	50.9	0.160
04/09/23	01:00	50.9	0.160
04/09/23	02:00	51.0	0.160
04/09/23	03:00	51.0	0.160
04/09/23	04:00	51.0	0.160
04/09/23	05:00	50.9	0.159
04/09/23	06:00	50.8	0.159
04/09/23	07:00	50.7	0.159
04/09/23	08:00	50.6	0.159
04/09/23	09:00	50.5	0.159
04/09/23	10:00	50.4	0.159
04/09/23	11:00	50.2	0.159
04/09/23	12:00	50.1	0.159
04/09/23	13:00	49.9	0.159
04/09/23	14:00	49.8	0.159
04/09/23	15:00	49.8	0.159
04/09/23	16:00	49.8	0.159
04/09/23	17:00	49.7	0.159
04/09/23	18:00	49.7	0.160
04/09/23	19:00	49.8	0.160
04/09/23	20:00	49.9	0.161
04/09/23	21:00	50.0	0.161
04/09/23	22:00	50.0	0.162
04/09/23	23:00	50.1	0.162
04/10/23	00:00	50.1	0.163
04/10/23	01:00	50.2	0.163
04/10/23	02:00	50.2	0.164
04/10/23	03:00	50.4	0.165
04/10/23	04:00	50.6	0.166
04/10/23	05:00	50.8	0.167
04/10/23	06:00	50.9	0.167
04/10/23	07:00	51.0	0.167
04/10/23	08:00	51.3	0.168
04/10/23	09:00	51.5	0.169
04/10/23	10:00	51.6	0.168
04/10/23	11:00	51.8	0.169
04/10/23	12:00	52.0	0.169
04/10/23	13:00	52.0	0.169
04/10/23	14:00	52.1	0.169
04/10/23	15:00	52.2	0.169
04/10/23	16:00	52.3	0.169
04/10/23	17:00	52.5	0.169
04/10/23	18:00	52.6	0.169
04/10/23	19:00	52.7	0.169
04/10/23	20:00	52.7	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/10/23	21:00	52.7	0.169
04/10/23	22:00	52.8	0.169
04/10/23	23:00	52.8	0.169
04/11/23	00:00	52.8	0.169
04/11/23	01:00	52.8	0.169
04/11/23	02:00	52.8	0.168
04/11/23	03:00	52.7	0.168
04/11/23	04:00	52.6	0.168
04/11/23	05:00	52.6	0.167
04/11/23	06:00	52.6	0.167
04/11/23	07:00	52.5	0.167
04/11/23	08:00	52.3	0.167
04/11/23	09:00	52.2	0.167
04/11/23	10:00	52.2	0.167
04/11/23	11:00	52.2	0.167
04/11/23	12:00	52.1	0.167
04/11/23	13:00	52.1	0.167
04/11/23	14:00	52.1	0.167
04/11/23	15:00	52.1	0.167
04/11/23	16:00	52.1	0.167
04/11/23	17:00	52.1	0.167
04/11/23	18:00	52.2	0.167
04/11/23	19:00	52.3	0.168
04/11/23	20:00	52.4	0.168
04/11/23	21:00	52.7	0.169
04/11/23	22:00	52.9	0.170
04/11/23	23:00	53.1	0.170
04/12/23	00:00	53.2	0.171
04/12/23	01:00	53.3	0.171
04/12/23	02:00	53.5	0.171
04/12/23	03:00	53.7	0.172
04/12/23	04:00	53.8	0.172
04/12/23	05:00	53.9	0.172
04/12/23	06:00	54.0	0.172
04/12/23	07:00	54.1	0.173
04/12/23	08:00	54.3	0.173
04/12/23	09:00	54.3	0.173
04/12/23	10:00	54.4	0.173
04/12/23	11:00	54.4	0.174
04/12/23	12:00	54.5	0.174
04/12/23	13:00	54.6	0.174
04/12/23	14:00	54.8	0.174
04/12/23	15:00	54.9	0.174
04/12/23	16:00	55.1	0.174
04/12/23	17:00	55.1	0.174
04/12/23	18:00	55.1	0.174
04/12/23	19:00	55.1	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/12/23	20:00	55.0	0.173
04/12/23	21:00	54.9	0.172
04/12/23	22:00	54.7	0.172
04/12/23	23:00	54.6	0.171
04/13/23	00:00	54.5	0.171
04/13/23	01:00	54.6	0.171
04/13/23	02:00	54.4	0.171
04/13/23	03:00	54.3	0.170
04/13/23	04:00	54.2	0.170
04/13/23	05:00	54.2	0.170
04/13/23	06:00	54.1	0.170
04/13/23	07:00	54.1	0.170
04/13/23	08:00	54.0	0.170
04/13/23	09:00	54.0	0.170
04/13/23	10:00	54.1	0.170
04/13/23	11:00	54.1	0.170
04/13/23	12:00	54.0	0.169
04/13/23	13:00	54.0	0.169
04/13/23	14:00	53.8	0.169
04/13/23	15:00	53.8	0.169
04/13/23	16:00	53.9	0.170
04/13/23	17:00	54.0	0.170
04/13/23	18:00	54.1	0.170
04/13/23	19:00	54.2	0.170
04/13/23	20:00	54.3	0.170
04/13/23	21:00	54.4	0.170
04/13/23	22:00	54.5	0.170
04/13/23	23:00	54.6	0.170
04/14/23	00:00	54.7	0.170
04/14/23	01:00	54.9	0.170
04/14/23	02:00	54.9	0.170
04/14/23	03:00	55.0	0.170
04/14/23	04:00	55.1	0.170
04/14/23	05:00	55.2	0.170
04/14/23	06:00	55.2	0.170
04/14/23	07:00	55.3	0.170
04/14/23	08:00	55.4	0.169
04/14/23	09:00	55.4	0.169
04/14/23	10:00	55.4	0.169
04/14/23	11:00	55.3	0.168
04/14/23	12:00	55.3	0.168
04/14/23	13:00	55.3	0.168
04/14/23	14:00	55.2	0.167
04/14/23	15:00	55.2	0.167
04/14/23	16:00	55.0	0.167
04/14/23	17:00	54.8	0.166
04/14/23	18:00	54.7	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/14/23	19:00	54.5	0.166
04/14/23	20:00	54.3	0.165
04/14/23	21:00	54.0	0.165
04/14/23	22:00	53.8	0.165
04/14/23	23:00	53.7	0.165
04/15/23	00:00	53.5	0.165
04/15/23	01:00	53.3	0.164
04/15/23	02:00	53.3	0.165
04/15/23	03:00	53.3	0.165
04/15/23	04:00	53.2	0.164
04/15/23	05:00	53.0	0.164
04/15/23	06:00	52.9	0.164
04/15/23	07:00	52.6	0.163
04/15/23	08:00	52.3	0.163
04/15/23	09:00	52.1	0.162
04/15/23	10:00	51.9	0.162
04/15/23	11:00	51.7	0.161
04/15/23	12:00	51.6	0.161
04/15/23	13:00	51.3	0.160
04/15/23	14:00	51.2	0.161
04/15/23	15:00	51.0	0.160
04/15/23	16:00	50.9	0.160
04/15/23	17:00	50.8	0.160
04/15/23	18:00	50.7	0.160
04/15/23	19:00	50.7	0.159
04/15/23	20:00	50.7	0.159
04/15/23	21:00	50.7	0.159
04/15/23	22:00	50.7	0.159
04/15/23	23:00	50.6	0.159
04/16/23	00:00	50.7	0.159
04/16/23	01:00	50.5	0.158
04/16/23	02:00	50.4	0.158
04/16/23	03:00	50.4	0.158
04/16/23	04:00	50.3	0.158
04/16/23	05:00	50.4	0.158
04/16/23	06:00	50.4	0.158
04/16/23	07:00	50.5	0.158
04/16/23	08:00	50.5	0.158
04/16/23	09:00	50.5	0.158
04/16/23	10:00	50.5	0.158
04/16/23	11:00	50.5	0.159
04/16/23	12:00	50.6	0.159
04/16/23	13:00	50.7	0.159
04/16/23	14:00	50.8	0.159
04/16/23	15:00	50.8	0.159
04/16/23	16:00	50.9	0.159
04/16/23	17:00	50.9	0.159

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/16/23	18:00	51.1	0.160
04/16/23	19:00	51.2	0.160
04/16/23	20:00	51.2	0.160
04/16/23	21:00	51.4	0.161
04/16/23	22:00	51.6	0.161
04/16/23	23:00	51.7	0.162
04/17/23	00:00	51.8	0.162
04/17/23	01:00	51.8	0.162
04/17/23	02:00	51.9	0.162
04/17/23	03:00	51.9	0.162
04/17/23	04:00	52.0	0.162
04/17/23	05:00	52.0	0.162
04/17/23	06:00	52.1	0.163
04/17/23	07:00	52.2	0.163
04/17/23	08:00	52.3	0.163
04/17/23	09:00	52.5	0.164
04/17/23	10:00	52.7	0.164
04/17/23	11:00	52.9	0.165
04/17/23	12:00	53.0	0.165
04/17/23	13:00	53.2	0.166
04/17/23	14:00	53.3	0.166
04/17/23	15:00	53.4	0.166
04/17/23	16:00	53.5	0.167
04/17/23	17:00	53.6	0.167
04/17/23	18:00	53.6	0.167
04/17/23	19:00	53.7	0.167
04/17/23	20:00	53.7	0.167
04/17/23	21:00	53.7	0.167
04/17/23	22:00	53.7	0.167
04/17/23	23:00	53.7	0.167
04/18/23	00:00	53.7	0.166
04/18/23	01:00	53.8	0.166
04/18/23	02:00	54.0	0.167
04/18/23	03:00	54.1	0.167
04/18/23	04:00	54.2	0.168
04/18/23	05:00	54.3	0.168
04/18/23	06:00	54.4	0.168
04/18/23	07:00	54.5	0.168
04/18/23	08:00	54.6	0.169
04/18/23	09:00	54.7	0.169
04/18/23	10:00	54.8	0.169
04/18/23	11:00	54.8	0.169
04/18/23	12:00	54.9	0.170
04/18/23	13:00	55.0	0.170
04/18/23	14:00	55.1	0.170
04/18/23	15:00	55.2	0.170
04/18/23	16:00	55.2	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/18/23	17:00	55.3	0.171
04/18/23	18:00	55.4	0.171
04/18/23	19:00	55.4	0.171
04/18/23	20:00	55.5	0.171
04/18/23	21:00	55.6	0.172
04/18/23	22:00	55.6	0.172
04/18/23	23:00	55.6	0.172
04/19/23	00:00	55.6	0.172
04/19/23	01:00	55.6	0.172
04/19/23	02:00	55.4	0.172
04/19/23	03:00	55.3	0.172
04/19/23	04:00	55.3	0.172
04/19/23	05:00	55.3	0.172
04/19/23	06:00	55.2	0.172
04/19/23	07:00	55.2	0.172
04/19/23	08:00	55.1	0.171
04/19/23	09:00	55.0	0.171
04/19/23	10:00	55.2	0.171
04/19/23	11:00	55.3	0.172
04/19/23	12:00	55.5	0.172
04/19/23	13:00	55.5	0.172
04/19/23	14:00	55.4	0.172
04/19/23	15:00	55.4	0.173
04/19/23	16:00	55.5	0.173
04/19/23	17:00	55.5	0.173
04/19/23	18:00	55.6	0.174
04/19/23	19:00	55.7	0.174
04/19/23	20:00	55.7	0.174
04/19/23	21:00	55.7	0.174
04/19/23	22:00	55.8	0.175
04/19/23	23:00	55.9	0.175
04/20/23	00:00	56.0	0.175
04/20/23	01:00	56.0	0.175
04/20/23	02:00	56.2	0.176
04/20/23	03:00	56.3	0.177
04/20/23	04:00	56.4	0.177
04/20/23	05:00	56.5	0.177
04/20/23	06:00	56.5	0.177
04/20/23	07:00	56.5	0.178
04/20/23	08:00	56.6	0.178
04/20/23	09:00	56.6	0.178
04/20/23	10:00	56.5	0.178
04/20/23	11:00	56.4	0.178
04/20/23	12:00	56.3	0.178
04/20/23	13:00	56.3	0.177
04/20/23	14:00	56.4	0.177
04/20/23	15:00	56.4	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/20/23	16:00	56.3	0.177
04/20/23	17:00	56.3	0.176
04/20/23	18:00	56.2	0.176
04/20/23	19:00	56.2	0.176
04/20/23	20:00	56.2	0.175
04/20/23	21:00	56.1	0.175
04/20/23	22:00	56.1	0.175
04/20/23	23:00	56.0	0.175
04/21/23	00:00	56.0	0.176
04/21/23	01:00	56.0	0.176
04/21/23	02:00	56.0	0.175
04/21/23	03:00	55.9	0.175
04/21/23	04:00	55.9	0.175
04/21/23	05:00	55.8	0.174
04/21/23	06:00	55.8	0.174
04/21/23	07:00	55.7	0.174
04/21/23	08:00	55.8	0.174
04/21/23	09:00	55.9	0.174
04/21/23	10:00	55.8	0.174
04/21/23	11:00	55.8	0.174
04/21/23	12:00	55.8	0.174
04/21/23	13:00	55.8	0.174
04/21/23	14:00	55.9	0.174
04/21/23	15:00	55.9	0.174
04/21/23	16:00	55.9	0.175
04/21/23	17:00	56.0	0.175
04/21/23	18:00	56.1	0.175
04/21/23	19:00	56.1	0.175
04/21/23	20:00	56.1	0.175
04/21/23	21:00	56.2	0.176
04/21/23	22:00	56.2	0.175
04/21/23	23:00	56.3	0.175
04/22/23	00:00	56.3	0.175
04/22/23	01:00	56.3	0.175
04/22/23	02:00	56.4	0.176
04/22/23	03:00	56.5	0.176
04/22/23	04:00	56.6	0.176
04/22/23	05:00	56.7	0.176
04/22/23	06:00	56.9	0.177
04/22/23	07:00	57.1	0.177
04/22/23	08:00	57.1	0.177
04/22/23	09:00	57.2	0.177
04/22/23	10:00	57.3	0.177
04/22/23	11:00	57.4	0.177
04/22/23	12:00	57.5	0.177
04/22/23	13:00	57.6	0.178
04/22/23	14:00	57.7	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/22/23	15:00	57.7	0.178
04/22/23	16:00	57.7	0.178
04/22/23	17:00	57.7	0.178
04/22/23	18:00	57.6	0.178
04/22/23	19:00	57.7	0.178
04/22/23	20:00	57.7	0.178
04/22/23	21:00	57.8	0.178
04/22/23	22:00	57.8	0.178
04/22/23	23:00	57.8	0.178
04/23/23	00:00	57.8	0.179
04/23/23	01:00	57.7	0.178
04/23/23	02:00	57.7	0.178
04/23/23	03:00	57.6	0.178
04/23/23	04:00	57.6	0.178
04/23/23	05:00	57.6	0.178
04/23/23	06:00	57.5	0.178
04/23/23	07:00	57.3	0.177
04/23/23	08:00	57.3	0.177
04/23/23	09:00	57.3	0.178
04/23/23	10:00	57.2	0.178
04/23/23	11:00	57.1	0.178
04/23/23	12:00	57.0	0.177
04/23/23	13:00	56.9	0.177
04/23/23	14:00	56.7	0.177
04/23/23	15:00	56.7	0.177
04/23/23	16:00	56.6	0.176
04/23/23	17:00	56.6	0.176
04/23/23	18:00	56.6	0.176
04/23/23	19:00	58.3	0.178
04/23/23	20:00	60.7	0.179
04/23/23	21:00	61.1	0.179
04/23/23	22:00	60.9	0.178
04/23/23	23:00	60.7	0.177
04/24/23	00:00	60.5	0.177
04/24/23	01:00	60.3	0.177
04/24/23	02:00	60.1	0.176
04/24/23	03:00	59.9	0.176
04/24/23	04:00	59.7	0.175
04/24/23	05:00	59.7	0.175
04/24/23	06:00	59.8	0.176
04/24/23	07:00	59.8	0.176
04/24/23	08:00	59.7	0.176
04/24/23	09:00	59.6	0.176
04/24/23	10:00	59.6	0.176
04/24/23	11:00	59.6	0.176
04/24/23	12:00	59.6	0.176
04/24/23	13:00	59.4	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/24/23	14:00	59.4	0.176
04/24/23	15:00	59.3	0.176
04/24/23	16:00	59.3	0.176
04/24/23	17:00	59.2	0.176
04/24/23	18:00	59.0	0.176
04/24/23	19:00	57.2	0.174
04/24/23	20:00	54.6	0.172
04/24/23	21:00	54.0	0.172
04/24/23	22:00	54.1	0.172
04/24/23	23:00	54.1	0.172
04/25/23	00:00	54.3	0.173
04/25/23	01:00	54.8	0.174
04/25/23	02:00	54.8	0.173
04/25/23	03:00	54.7	0.173
04/25/23	04:00	54.7	0.173
04/25/23	05:00	54.5	0.172
04/25/23	06:00	54.5	0.172
04/25/23	07:00	54.5	0.172
04/25/23	08:00	54.5	0.173
04/25/23	09:00	54.6	0.172
04/25/23	10:00	54.5	0.172
04/25/23	11:00	54.5	0.172
04/25/23	12:00	54.5	0.172
04/25/23	13:00	54.4	0.172
04/25/23	14:00	54.3	0.171
04/25/23	15:00	54.3	0.171
04/25/23	16:00	54.4	0.171
04/25/23	17:00	54.4	0.171
04/25/23	18:00	54.6	0.171
04/25/23	19:00	54.6	0.171
04/25/23	20:00	54.6	0.171
04/25/23	21:00	54.5	0.171
04/25/23	22:00	54.5	0.171
04/25/23	23:00	54.5	0.171
04/26/23	00:00	54.4	0.171
04/26/23	01:00	54.0	0.170
04/26/23	02:00	54.0	0.170
04/26/23	03:00	54.0	0.170
04/26/23	04:00	54.0	0.170
04/26/23	05:00	54.1	0.170
04/26/23	06:00	54.1	0.170
04/26/23	07:00	54.1	0.170
04/26/23	08:00	54.0	0.170
04/26/23	09:00	54.0	0.169
04/26/23	10:00	54.0	0.169
04/26/23	11:00	54.0	0.169
04/26/23	12:00	54.0	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/26/23	13:00	54.0	0.169
04/26/23	14:00	54.1	0.170
04/26/23	15:00	54.1	0.170
04/26/23	16:00	54.2	0.170
04/26/23	17:00	54.2	0.170
04/26/23	18:00	54.1	0.170
04/26/23	19:00	54.0	0.170
04/26/23	20:00	54.0	0.170
04/26/23	21:00	54.0	0.170
04/26/23	22:00	53.9	0.170
04/26/23	23:00	53.8	0.170
04/27/23	00:00	53.8	0.170
04/27/23	01:00	53.7	0.169
04/27/23	02:00	53.8	0.170
04/27/23	03:00	53.9	0.170
04/27/23	04:00	54.0	0.170
04/27/23	05:00	54.0	0.170
04/27/23	06:00	54.1	0.170
04/27/23	07:00	54.1	0.170
04/27/23	08:00	54.1	0.170
04/27/23	09:00	54.1	0.170
04/27/23	10:00	54.2	0.170
04/27/23	11:00	54.2	0.170
04/27/23	12:00	54.2	0.170
04/27/23	13:00	54.1	0.170
04/27/23	14:00	54.1	0.170
04/27/23	15:00	54.1	0.170
04/27/23	16:00	54.1	0.170
04/27/23	17:00	54.2	0.170
04/27/23	18:00	54.3	0.170
04/27/23	19:00	54.4	0.170
04/27/23	20:00	54.4	0.170
04/27/23	21:00	54.6	0.171
04/27/23	22:00	54.6	0.171
04/27/23	23:00	54.7	0.171
04/28/23	00:00	54.7	0.171
04/28/23	01:00	54.7	0.171
04/28/23	02:00	54.7	0.171
04/28/23	03:00	54.6	0.171
04/28/23	04:00	54.6	0.171
04/28/23	05:00	54.5	0.171
04/28/23	06:00	54.5	0.171
04/28/23	07:00	54.4	0.171
04/28/23	08:00	54.4	0.171
04/28/23	09:00	54.5	0.171
04/28/23	10:00	54.5	0.171
04/28/23	11:00	54.6	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/28/23	12:00	54.7	0.171
04/28/23	13:00	54.7	0.172
04/28/23	14:00	54.9	0.171
04/28/23	15:00	54.9	0.171
04/28/23	16:00	54.9	0.171
04/28/23	17:00	54.9	0.171
04/28/23	18:00	54.9	0.171
04/28/23	19:00	55.0	0.171
04/28/23	20:00	55.0	0.171
04/28/23	21:00	55.0	0.170
04/28/23	22:00	55.2	0.171
04/28/23	23:00	55.5	0.171
04/29/23	00:00	55.7	0.172
04/29/23	01:00	56.0	0.173
04/29/23	02:00	56.2	0.173
04/29/23	03:00	56.3	0.173
04/29/23	04:00	56.4	0.173
04/29/23	05:00	56.5	0.173
04/29/23	06:00	56.7	0.173
04/29/23	07:00	56.7	0.173
04/29/23	08:00	56.8	0.172
04/29/23	09:00	56.8	0.172
04/29/23	10:00	56.9	0.172
04/29/23	11:00	56.9	0.172
04/29/23	12:00	57.0	0.172
04/29/23	13:00	57.0	0.172
04/29/23	14:00	57.0	0.172
04/29/23	15:00	57.1	0.172
04/29/23	16:00	57.1	0.171
04/29/23	17:00	57.1	0.171
04/29/23	18:00	57.1	0.171
04/29/23	19:00	57.1	0.171
04/29/23	20:00	57.1	0.171
04/29/23	21:00	57.1	0.170
04/29/23	22:00	57.1	0.170
04/29/23	23:00	57.1	0.170
04/30/23	00:00	57.1	0.170
04/30/23	01:00	57.0	0.169
04/30/23	02:00	57.0	0.169
04/30/23	03:00	57.0	0.170
04/30/23	04:00	57.0	0.170
04/30/23	05:00	57.1	0.170
04/30/23	06:00	57.0	0.170
04/30/23	07:00	57.0	0.170
04/30/23	08:00	57.0	0.170
04/30/23	09:00	57.1	0.170
04/30/23	10:00	57.1	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
04/30/23	11:00	57.1	0.170
04/30/23	12:00	57.2	0.170
04/30/23	13:00	57.2	0.170
04/30/23	14:00	57.3	0.171
04/30/23	15:00	57.4	0.171
04/30/23	16:00	57.4	0.171
04/30/23	17:00	57.5	0.171
04/30/23	18:00	57.0	0.172
04/30/23	19:00	57.0	0.172
04/30/23	20:00	57.0	0.172
04/30/23	21:00	57.0	0.172
04/30/23	22:00	57.0	0.172
04/30/23	23:00	57.0	0.172
05/01/23	00:00	57.0	0.172
05/01/23	01:00	57.0	0.172
05/01/23	02:00	57.0	0.172
05/01/23	03:00	57.0	0.172
05/01/23	04:00	57.0	0.172
05/01/23	05:00	57.0	0.172
05/01/23	06:00	57.0	0.172
05/01/23	07:00	57.0	0.172
05/01/23	08:00	57.0	0.172
05/01/23	09:00	57.0	0.172
05/01/23	10:00	57.0	0.172
05/01/23	11:00	57.0	0.172
05/01/23	12:00	57.0	0.172
05/01/23	13:00	57.0	0.172
05/01/23	14:00	57.0	0.172
05/01/23	15:00	57.0	0.172
05/01/23	16:00	57.0	0.172
05/01/23	17:00	57.0	0.172
05/01/23	18:00	57.0	0.172
05/01/23	19:00	57.0	0.172
05/01/23	20:00	57.0	0.172
05/01/23	21:00	57.0	0.172
05/01/23	22:00	57.0	0.172
05/01/23	23:00	57.0	0.172
05/02/23	00:00	57.0	0.172
05/02/23	01:00	57.0	0.172
05/02/23	02:00	57.0	0.172
05/02/23	03:00	57.0	0.172
05/02/23	04:00	57.0	0.172
05/02/23	05:00	57.0	0.172
05/02/23	06:00	57.0	0.172
05/02/23	07:00	57.0	0.172
05/02/23	08:00	57.0	0.172
05/02/23	09:00	57.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/02/23	10:00	57.0	0.172
05/02/23	11:00	57.0	0.172
05/02/23	12:00	57.0	0.172
05/02/23	13:00	57.0	0.172
05/02/23	14:00	57.0	0.172
05/02/23	15:00	57.0	0.172
05/02/23	16:00	57.0	0.172
05/02/23	17:00	57.0	0.172
05/02/23	18:00	57.0	0.172
05/02/23	19:00	57.0	0.172
05/02/23	20:00	57.0	0.172
05/02/23	21:00	57.0	0.172
05/02/23	22:00	57.0	0.172
05/02/23	23:00	57.0	0.172
05/03/23	00:00	57.0	0.172
05/03/23	01:00	57.0	0.172
05/03/23	02:00	57.0	0.172
05/03/23	03:00	57.0	0.172
05/03/23	04:00	57.0	0.172
05/03/23	05:00	57.0	0.172
05/03/23	06:00	57.0	0.172
05/03/23	07:00	57.0	0.172
05/03/23	08:00	57.0	0.172
05/03/23	09:00	57.0	0.172
05/03/23	10:00	57.0	0.172
05/03/23	11:00	57.0	0.172
05/03/23	12:00	57.0	0.172
05/03/23	13:00	57.0	0.172
05/03/23	14:00	57.0	0.172
05/03/23	15:00	57.0	0.172
05/03/23	16:00	57.0	0.172
05/03/23	17:00	57.0	0.172
05/03/23	18:00	57.0	0.172
05/03/23	19:00	57.0	0.172
05/03/23	20:00	57.0	0.172
05/03/23	21:00	57.0	0.172
05/03/23	22:00	57.0	0.172
05/03/23	23:00	57.0	0.172
05/04/23	00:00	57.0	0.172
05/04/23	01:00	57.0	0.172
05/04/23	02:00	57.0	0.172
05/04/23	03:00	57.0	0.172
05/04/23	04:00	57.0	0.172
05/04/23	05:00	57.0	0.172
05/04/23	06:00	57.0	0.172
05/04/23	07:00	57.0	0.172
05/04/23	08:00	57.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/04/23	09:00	57.0	0.172
05/04/23	10:00	57.0	0.172
05/04/23	11:00	57.0	0.172
05/04/23	12:00	57.0	0.172
05/04/23	13:00	57.0	0.172
05/04/23	14:00	57.0	0.172
05/04/23	15:00	57.0	0.172
05/04/23	16:00	57.0	0.172
05/04/23	17:00	57.0	0.172
05/04/23	18:00	57.0	0.172
05/04/23	19:00	57.0	0.172
05/04/23	20:00	57.0	0.172
05/04/23	21:00	57.0	0.172
05/04/23	22:00	57.0	0.172
05/04/23	23:00	57.0	0.172
05/05/23	00:00	57.0	0.172
05/05/23	01:00	57.0	0.172
05/05/23	02:00	57.0	0.172
05/05/23	03:00	57.0	0.172
05/05/23	04:00	57.0	0.172
05/05/23	05:00	57.0	0.172
05/05/23	06:00	57.0	0.172
05/05/23	07:00	57.0	0.172
05/05/23	08:00	57.0	0.172
05/05/23	09:00	57.0	0.172
05/05/23	10:00	57.0	0.172
05/05/23	11:00	57.0	0.172
05/05/23	12:00	57.0	0.172
05/05/23	13:00	57.0	0.172
05/05/23	14:00	57.0	0.172
05/05/23	15:00	57.0	0.172
05/05/23	16:00	57.0	0.172
05/05/23	17:00	57.0	0.172
05/05/23	18:00	57.0	0.172
05/05/23	19:00	57.0	0.172
05/05/23	20:00	57.0	0.172
05/05/23	21:00	57.0	0.172
05/05/23	22:00	57.0	0.172
05/05/23	23:00	57.0	0.172
05/06/23	00:00	57.0	0.172
05/06/23	01:00	57.0	0.172
05/06/23	02:00	57.0	0.172
05/06/23	03:00	57.0	0.172
05/06/23	04:00	57.0	0.172
05/06/23	05:00	57.0	0.172
05/06/23	06:00	57.0	0.172
05/06/23	07:00	57.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/06/23	08:00	57.0	0.172
05/06/23	09:00	57.0	0.172
05/06/23	10:00	57.0	0.172
05/06/23	11:00	57.0	0.172
05/06/23	12:00	57.0	0.172
05/06/23	13:00	57.0	0.172
05/06/23	14:00	57.0	0.172
05/06/23	15:00	57.0	0.172
05/06/23	16:00	57.0	0.172
05/06/23	17:00	57.0	0.172
05/06/23	18:00	57.0	0.172
05/06/23	19:00	57.0	0.172
05/06/23	20:00	57.0	0.172
05/06/23	21:00	57.0	0.172
05/06/23	22:00	57.0	0.172
05/06/23	23:00	57.0	0.172
05/07/23	00:00	57.0	0.172
05/07/23	01:00	57.0	0.172
05/07/23	02:00	57.0	0.172
05/07/23	03:00	57.0	0.172
05/07/23	04:00	57.0	0.172
05/07/23	05:00	57.0	0.172
05/07/23	06:00	57.0	0.172
05/07/23	07:00	57.0	0.172
05/07/23	08:00	57.0	0.172
05/07/23	09:00	57.0	0.172
05/07/23	10:00	57.0	0.172
05/07/23	11:00	57.0	0.172
05/07/23	12:00	57.0	0.172
05/07/23	13:00	57.0	0.172
05/07/23	14:00	57.0	0.172
05/07/23	15:00	57.0	0.172
05/07/23	16:00	57.0	0.172
05/07/23	17:00	57.0	0.172
05/07/23	18:00	57.0	0.172
05/07/23	19:00	57.0	0.172
05/07/23	20:00	57.0	0.172
05/07/23	21:00	57.0	0.172
05/07/23	22:00	57.0	0.172
05/07/23	23:00	57.0	0.172
05/08/23	00:00	57.0	0.172
05/08/23	01:00	57.0	0.172
05/08/23	02:00	57.0	0.172
05/08/23	03:00	57.0	0.172
05/08/23	04:00	57.0	0.172
05/08/23	05:00	57.0	0.172
05/08/23	06:00	57.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/08/23	07:00	57.0	0.172
05/08/23	08:00	57.0	0.172
05/08/23	09:00	57.0	0.172
05/08/23	10:00	57.0	0.172
05/08/23	11:00	57.0	0.172
05/08/23	12:00	57.0	0.172
05/08/23	13:00	57.0	0.172
05/08/23	14:00	57.0	0.172
05/08/23	15:00	57.0	0.172
05/08/23	16:00	57.0	0.172
05/08/23	17:00	57.0	0.172
05/08/23	18:00	57.0	0.172
05/08/23	19:00	57.0	0.172
05/08/23	20:00	57.0	0.172
05/08/23	21:00	57.0	0.172
05/08/23	22:00	57.0	0.172
05/08/23	23:00	57.0	0.172
05/09/23	00:00	57.0	0.172
05/09/23	01:00	57.0	0.172
05/09/23	02:00	57.0	0.172
05/09/23	03:00	57.0	0.172
05/09/23	04:00	57.0	0.172
05/09/23	05:00	57.0	0.172
05/09/23	06:00	57.0	0.172
05/09/23	07:00	57.0	0.172
05/09/23	08:00	57.0	0.172
05/09/23	09:00	57.0	0.172
05/09/23	10:00	57.0	0.172
05/09/23	11:00	57.0	0.172
05/09/23	12:00	57.0	0.172
05/09/23	13:00	57.0	0.172
05/09/23	14:00	57.0	0.172
05/09/23	15:00	57.0	0.172
05/09/23	16:00	57.0	0.172
05/09/23	17:00	57.0	0.172
05/09/23	18:00	57.0	0.172
05/09/23	19:00	57.0	0.172
05/09/23	20:00	57.0	0.172
05/09/23	21:00	57.0	0.172
05/09/23	22:00	57.0	0.172
05/09/23	23:00	57.0	0.172
05/10/23	00:00	54.7	0.172
05/10/23	01:00	52.4	0.172
05/10/23	02:00	50.1	0.172
05/10/23	03:00	47.8	0.172
05/10/23	04:00	45.5	0.172
05/10/23	05:00	43.2	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/10/23	06:00	40.9	0.172I
05/10/23	07:00	38.8	0.172I
05/10/23	08:00	37.3	0.172I
05/10/23	09:00	35.7	0.172I
05/10/23	10:00	35.7	0.172I
05/10/23	11:00	35.7	0.172I
05/10/23	12:00	33.3	0.172I
05/10/23	13:00	30.9	0.173I
05/10/23	14:00	31.2	0.173I
05/10/23	15:00	29.3	0.173I
05/10/23	16:00	29.1	0.174I
05/10/23	17:00	27.9	0.173I
05/10/23	18:00	26.7	0.172I
05/10/23	19:00	25.5	0.169I
05/10/23	20:00	24.4	0.167I
05/10/23	21:00	23.2	0.165I
05/10/23	22:00	22.5	0.160I
05/10/23	23:00	22.4	0.159I
05/11/23	00:00	22.1	0.156I
05/11/23	01:00	22.4	0.156I
05/11/23	02:00	24.5	0.156I
05/11/23	03:00	26.6	0.156I
05/11/23	04:00	28.8	0.156I
05/11/23	05:00	31.0	0.157I
05/11/23	06:00	33.0	0.157I
05/11/23	07:00	35.2	0.158I
05/11/23	08:00	37.4	0.158I
05/11/23	09:00	39.3	0.159I
05/11/23	10:00	40.4	0.158I
05/11/23	11:00	41.8	0.158
05/11/23	12:00	44.0	0.158
05/11/23	13:00	46.2	0.159
05/11/23	14:00	45.7	0.159
05/11/23	15:00	47.4	0.159
05/11/23	16:00	47.4	0.159
05/11/23	17:00	48.2	0.159
05/11/23	18:00	49.0	0.159
05/11/23	19:00	49.8	0.158
05/11/23	20:00	50.6	0.158
05/11/23	21:00	51.3	0.157
05/11/23	22:00	51.6	0.158
05/11/23	23:00	51.4	0.158
05/12/23	00:00	51.4	0.158
05/12/23	01:00	51.3	0.158
05/12/23	02:00	51.1	0.157
05/12/23	03:00	51.0	0.157
05/12/23	04:00	50.8	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/12/23	05:00	50.6	0.156
05/12/23	06:00	50.6	0.155
05/12/23	07:00	50.5	0.155
05/12/23	08:00	50.3	0.155
05/12/23	09:00	50.4	0.155
05/12/23	10:00	50.6	0.156
05/12/23	11:00	50.8	0.156
05/12/23	12:00	50.8	0.156
05/12/23	13:00	50.8	0.156
05/12/23	14:00	50.9	0.156
05/12/23	15:00	51.0	0.157
05/12/23	16:00	51.1	0.157
05/12/23	17:00	51.3	0.157
05/12/23	18:00	51.5	0.158
05/12/23	19:00	51.6	0.158
05/12/23	20:00	51.8	0.159
05/12/23	21:00	52.2	0.160
05/12/23	22:00	52.4	0.161
05/12/23	23:00	52.6	0.161
05/13/23	00:00	52.7	0.162
05/13/23	01:00	52.8	0.162
05/13/23	02:00	53.1	0.163
05/13/23	03:00	53.3	0.164
05/13/23	04:00	53.4	0.164
05/13/23	05:00	53.4	0.164
05/13/23	06:00	53.4	0.164
05/13/23	07:00	53.4	0.164
05/13/23	08:00	53.3	0.164
05/13/23	09:00	53.1	0.163
05/13/23	10:00	52.9	0.163
05/13/23	11:00	52.8	0.163
05/13/23	12:00	52.8	0.163
05/13/23	13:00	52.7	0.162
05/13/23	14:00	52.7	0.163
05/13/23	15:00	52.6	0.162
05/13/23	16:00	52.6	0.163
05/13/23	17:00	52.6	0.162
05/13/23	18:00	52.5	0.162
05/13/23	19:00	52.6	0.162
05/13/23	20:00	52.5	0.162
05/13/23	21:00	52.3	0.162
05/13/23	22:00	52.1	0.161
05/13/23	23:00	52.0	0.161
05/14/23	00:00	52.1	0.161
05/14/23	01:00	52.2	0.162
05/14/23	02:00	52.3	0.162
05/14/23	03:00	52.5	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/14/23	04:00	52.5	0.163
05/14/23	05:00	52.7	0.163
05/14/23	06:00	52.9	0.164
05/14/23	07:00	52.8	0.164
05/14/23	08:00	52.9	0.164
05/14/23	09:00	53.1	0.164
05/14/23	10:00	53.4	0.165
05/14/23	11:00	53.6	0.166
05/14/23	12:00	53.8	0.166
05/14/23	13:00	54.0	0.167
05/14/23	14:00	53.8	0.167
05/14/23	15:00	53.9	0.167
05/14/23	16:00	54.0	0.168
05/14/23	17:00	54.1	0.168
05/14/23	18:00	54.2	0.168
05/14/23	19:00	54.4	0.169
05/14/23	20:00	54.5	0.169
05/14/23	21:00	54.7	0.169
05/14/23	22:00	55.0	0.170
05/14/23	23:00	55.3	0.171
05/15/23	00:00	55.4	0.171
05/15/23	01:00	55.6	0.171
05/15/23	02:00	55.7	0.172
05/15/23	03:00	55.7	0.172
05/15/23	04:00	55.9	0.172
05/15/23	05:00	55.9	0.172
05/15/23	06:00	56.0	0.172
05/15/23	07:00	56.1	0.173
05/15/23	08:00	56.0	0.172
05/15/23	09:00	55.9	0.172
05/15/23	10:00	55.5	0.171
05/15/23	11:00	55.2	0.170
05/15/23	12:00	55.1	0.170
05/15/23	13:00	54.9	0.170
05/15/23	14:00	54.8	0.169
05/15/23	15:00	54.8	0.169
05/15/23	16:00	54.4	0.167
05/15/23	17:00	54.1	0.166
05/15/23	18:00	53.8	0.166
05/15/23	19:00	53.5	0.165
05/15/23	20:00	53.3	0.165
05/15/23	21:00	52.9	0.164
05/15/23	22:00	52.5	0.162
05/15/23	23:00	52.0	0.161
05/16/23	00:00	51.7	0.160
05/16/23	01:00	51.1	0.158
05/16/23	02:00	50.4	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/16/23	03:00	49.9	0.155
05/16/23	04:00	49.3	0.153
05/16/23	05:00	48.9	0.152
05/16/23	06:00	48.4	0.150
05/16/23	07:00	48.1	0.150
05/16/23	08:00	48.4	0.151
05/16/23	09:00	48.7	0.151
05/16/23	10:00	49.3	0.153
05/16/23	11:00	49.6	0.153
05/16/23	12:00	49.8	0.153
05/16/23	13:00	50.1	0.154
05/16/23	14:00	50.3	0.154
05/16/23	15:00	50.4	0.154
05/16/23	16:00	50.8	0.155
05/16/23	17:00	51.1	0.157
05/16/23	18:00	51.4	0.157
05/16/23	19:00	51.9	0.159
05/16/23	20:00	52.2	0.160
05/16/23	21:00	52.8	0.162
05/16/23	22:00	53.2	0.163
05/16/23	23:00	53.6	0.165
05/17/23	00:00	54.2	0.166
05/17/23	01:00	54.5	0.167
05/17/23	02:00	55.0	0.169
05/17/23	03:00	55.4	0.170
05/17/23	04:00	55.9	0.171
05/17/23	05:00	56.2	0.173
05/17/23	06:00	56.7	0.174
05/17/23	07:00	57.0	0.175
05/17/23	08:00	56.9	0.175
05/17/23	09:00	56.9	0.175
05/17/23	10:00	56.7	0.175
05/17/23	11:00	56.7	0.175
05/17/23	12:00	56.6	0.175
05/17/23	13:00	56.6	0.175
05/17/23	14:00	56.6	0.175
05/17/23	15:00	56.6	0.175
05/17/23	16:00	56.7	0.175
05/17/23	17:00	56.4	0.174
05/17/23	18:00	56.4	0.174
05/17/23	19:00	56.0	0.173
05/17/23	20:00	56.1	0.173
05/17/23	21:00	55.8	0.172
05/17/23	22:00	55.6	0.171
05/17/23	23:00	55.3	0.171
05/18/23	00:00	55.2	0.170
05/18/23	01:00	55.2	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/18/23	02:00	55.2	0.170
05/18/23	03:00	55.4	0.171
05/18/23	04:00	55.4	0.171
05/18/23	05:00	55.6	0.172
05/18/23	06:00	55.8	0.173
05/18/23	07:00	55.9	0.173
05/18/23	08:00	56.0	0.173
05/18/23	09:00	56.0	0.173
05/18/23	10:00	56.0	0.173
05/18/23	11:00	55.8	0.173
05/18/23	12:00	55.8	0.172
05/18/23	13:00	55.6	0.172
05/18/23	14:00	55.5	0.172
05/18/23	15:00	55.4	0.171
05/18/23	16:00	55.3	0.171
05/18/23	17:00	55.3	0.171
05/18/23	18:00	55.3	0.171
05/18/23	19:00	55.4	0.172
05/18/23	20:00	55.5	0.172
05/18/23	21:00	55.7	0.173
05/18/23	22:00	55.9	0.173
05/18/23	23:00	56.0	0.174
05/19/23	00:00	56.0	0.174
05/19/23	01:00	56.0	0.174
05/19/23	02:00	56.0	0.174
05/19/23	03:00	55.9	0.174
05/19/23	04:00	55.9	0.174
05/19/23	05:00	55.8	0.173
05/19/23	06:00	55.6	0.173
05/19/23	07:00	55.6	0.173
05/19/23	08:00	55.5	0.173
05/19/23	09:00	55.6	0.173
05/19/23	10:00	55.7	0.174
05/19/23	11:00	55.8	0.174
05/19/23	12:00	56.2	0.175
05/19/23	13:00	56.4	0.175
05/19/23	14:00	56.3	0.176
05/19/23	15:00	56.4	0.176
05/19/23	16:00	56.7	0.176
05/19/23	17:00	57.0	0.177
05/19/23	18:00	57.6	0.178
05/19/23	19:00	58.1	0.179
05/19/23	20:00	58.5	0.180
05/19/23	21:00	58.8	0.180
05/19/23	22:00	59.0	0.180
05/19/23	23:00	59.0	0.180
05/20/23	00:00	59.2	0.180

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/20/23	01:00	59.3	0.180
05/20/23	02:00	59.4	0.180
05/20/23	03:00	59.6	0.180
05/20/23	04:00	60.0	0.181
05/20/23	05:00	60.2	0.181
05/20/23	06:00	60.1	0.180
05/20/23	07:00	60.6	0.181
05/20/23	08:00	60.5	0.181
05/20/23	09:00	60.2	0.179
05/20/23	10:00	60.0	0.179
05/20/23	11:00	59.6	0.177
05/20/23	12:00	59.3	0.176
05/20/23	13:00	59.2	0.175
05/20/23	14:00	59.2	0.175
05/20/23	15:00	59.2	0.175
05/20/23	16:00	59.0	0.174
05/20/23	17:00	58.8	0.173
05/20/23	18:00	58.5	0.173
05/20/23	19:00	58.2	0.172
05/20/23	20:00	57.8	0.171
05/20/23	21:00	57.4	0.170
05/20/23	22:00	57.1	0.170
05/20/23	23:00	56.8	0.169
05/21/23	00:00	56.7	0.169
05/21/23	01:00	56.8	0.170
05/21/23	02:00	56.9	0.170
05/21/23	03:00	56.7	0.170
05/21/23	04:00	56.4	0.169
05/21/23	05:00	56.3	0.169
05/21/23	06:00	56.4	0.169
05/21/23	07:00	56.2	0.169
05/21/23	08:00	56.1	0.169
05/21/23	09:00	56.2	0.169
05/21/23	10:00	56.2	0.170
05/21/23	11:00	56.6	0.171
05/21/23	12:00	56.6	0.171
05/21/23	13:00	56.6	0.172
05/21/23	14:00	56.5	0.172
05/21/23	15:00	56.5	0.172
05/21/23	16:00	56.5	0.173
05/21/23	17:00	56.5	0.173
05/21/23	18:00	56.6	0.173
05/21/23	19:00	56.6	0.173
05/21/23	20:00	56.5	0.173
05/21/23	21:00	56.6	0.174
05/21/23	22:00	56.6	0.174
05/21/23	23:00	56.8	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/22/23	00:00	56.8	0.174
05/22/23	01:00	56.6	0.174
05/22/23	02:00	56.6	0.174
05/22/23	03:00	56.6	0.174
05/22/23	04:00	56.6	0.174
05/22/23	05:00	56.7	0.175
05/22/23	06:00	56.6	0.175
05/22/23	07:00	56.6	0.175
05/22/23	08:00	58.0	0.176
05/22/23	09:00	60.5	0.178
05/22/23	10:00	62.5	0.179
05/22/23	11:00	65.2	0.181
05/22/23	12:00	67.3	0.183
05/22/23	13:00	69.6	0.185
05/22/23	14:00	71.6	0.186
05/22/23	15:00	73.7	0.187
05/22/23	16:00	75.5	0.188
05/22/23	17:00	77.2	0.188
05/22/23	18:00	77.2	0.187
05/22/23	19:00	77.1	0.187
05/22/23	20:00	77.0	0.186
05/22/23	21:00	77.0	0.186
05/22/23	22:00	77.2	0.186
05/22/23	23:00	77.3	0.186
05/23/23	00:00	77.5	0.186
05/23/23	01:00	77.5	0.186
05/23/23	02:00	77.4	0.186
05/23/23	03:00	77.3	0.185
05/23/23	04:00	77.2	0.184
05/23/23	05:00	78.3	0.184
05/23/23	06:00	80.6	0.185
05/23/23	07:00	81.9	0.186
05/23/23	08:00	79.8	0.184
05/23/23	09:00	76.4	0.183
05/23/23	10:00	73.3	0.181
05/23/23	11:00	69.5	0.178
05/23/23	12:00	66.3	0.176
05/23/23	13:00	63.0	0.175
05/23/23	14:00	60.1	0.174
05/23/23	15:00	57.9	0.172
05/23/23	16:00	58.2	0.172
05/23/23	17:00	58.2	0.172
05/23/23	18:00	60.2	0.174
05/23/23	19:00	60.9	0.174
05/23/23	20:00	60.7	0.174
05/23/23	21:00	60.4	0.174
05/23/23	22:00	60.1	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/23/23	23:00	59.8	0.173
05/24/23	00:00	59.5	0.172
05/24/23	01:00	59.6	0.172
05/24/23	02:00	59.6	0.173
05/24/23	03:00	59.6	0.173
05/24/23	04:00	59.7	0.173
05/24/23	05:00	58.6	0.173
05/24/23	06:00	56.3	0.172
05/24/23	07:00	55.2	0.172
05/24/23	08:00	56.2	0.173
05/24/23	09:00	57.2	0.173
05/24/23	10:00	58.1	0.173
05/24/23	11:00	58.9	0.172
05/24/23	12:00	59.6	0.172
05/24/23	13:00	60.3	0.171
05/24/23	14:00	61.0	0.170
05/24/23	15:00	61.0	0.170
05/24/23	16:00	58.5	0.167
05/24/23	17:00	56.4	0.166
05/24/23	18:00	53.9	0.164
05/24/23	19:00	53.0	0.163
05/24/23	20:00	53.0	0.164
05/24/23	21:00	53.0	0.164
05/24/23	22:00	53.0	0.163
05/24/23	23:00	53.0	0.163
05/25/23	00:00	52.9	0.163
05/25/23	01:00	52.8	0.163
05/25/23	02:00	52.7	0.163
05/25/23	03:00	52.7	0.163
05/25/23	04:00	52.4	0.163
05/25/23	05:00	52.2	0.162
05/25/23	06:00	52.0	0.162
05/25/23	07:00	51.6	0.161
05/25/23	08:00	51.5	0.161
05/25/23	09:00	51.6	0.161
05/25/23	10:00	53.9	0.163
05/25/23	11:00	56.8	0.167
05/25/23	12:00	56.5	0.166
05/25/23	13:00	56.9	0.168
05/25/23	14:00	57.2	0.169
05/25/23	15:00	57.5	0.170
05/25/23	16:00	57.9	0.171
05/25/23	17:00	58.0	0.172
05/25/23	18:00	58.4	0.173
05/25/23	19:00	58.6	0.174
05/25/23	20:00	58.8	0.175
05/25/23	21:00	58.8	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/25/23	22:00	58.9	0.175
05/25/23	23:00	59.0	0.175
05/26/23	00:00	59.0	0.176
05/26/23	01:00	58.7	0.175
05/26/23	02:00	58.6	0.175
05/26/23	03:00	58.5	0.175
05/26/23	04:00	58.5	0.175
05/26/23	05:00	58.6	0.175
05/26/23	06:00	58.6	0.175
05/26/23	07:00	58.4	0.174
05/26/23	08:00	58.3	0.174
05/26/23	09:00	58.1	0.174
05/26/23	10:00	55.9	0.172
05/26/23	11:00	53.1	0.169
05/26/23	12:00	53.5	0.170
05/26/23	13:00	53.3	0.170
05/26/23	14:00	53.1	0.169
05/26/23	15:00	53.0	0.168
05/26/23	16:00	53.0	0.168
05/26/23	17:00	52.9	0.168
05/26/23	18:00	52.7	0.168
05/26/23	19:00	52.6	0.167
05/26/23	20:00	52.5	0.167
05/26/23	21:00	52.5	0.167
05/26/23	22:00	52.7	0.168
05/26/23	23:00	52.6	0.168
05/27/23	00:00	52.9	0.169
05/27/23	01:00	53.1	0.169
05/27/23	02:00	53.2	0.169
05/27/23	03:00	53.3	0.170
05/27/23	04:00	53.3	0.170
05/27/23	05:00	53.4	0.170
05/27/23	06:00	53.5	0.171
05/27/23	07:00	53.7	0.171
05/27/23	08:00	53.9	0.172
05/27/23	09:00	54.0	0.172
05/27/23	10:00	54.1	0.173
05/27/23	11:00	54.1	0.173
05/27/23	12:00	54.3	0.173
05/27/23	13:00	54.4	0.173
05/27/23	14:00	54.5	0.174
05/27/23	15:00	54.5	0.174
05/27/23	16:00	54.5	0.173
05/27/23	17:00	54.6	0.174
05/27/23	18:00	54.7	0.174
05/27/23	19:00	54.7	0.174
05/27/23	20:00	54.7	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/27/23	21:00	54.8	0.174
05/27/23	22:00	54.7	0.174
05/27/23	23:00	54.7	0.173
05/28/23	00:00	54.5	0.173
05/28/23	01:00	54.6	0.173
05/28/23	02:00	54.6	0.173
05/28/23	03:00	54.5	0.172
05/28/23	04:00	54.4	0.172
05/28/23	05:00	54.4	0.172
05/28/23	06:00	54.4	0.172
05/28/23	07:00	54.4	0.172
05/28/23	08:00	54.4	0.172
05/28/23	09:00	54.3	0.172
05/28/23	10:00	54.3	0.172
05/28/23	11:00	54.4	0.172
05/28/23	12:00	54.5	0.172
05/28/23	13:00	54.5	0.172
05/28/23	14:00	54.6	0.172
05/28/23	15:00	54.5	0.172
05/28/23	16:00	54.4	0.172
05/28/23	17:00	54.6	0.172
05/28/23	18:00	54.7	0.172
05/28/23	19:00	54.7	0.172
05/28/23	20:00	54.7	0.172
05/28/23	21:00	54.7	0.172
05/28/23	22:00	54.7	0.172
05/28/23	23:00	54.7	0.172
05/29/23	00:00	54.7	0.172
05/29/23	01:00	54.9	0.173
05/29/23	02:00	55.0	0.173
05/29/23	03:00	55.2	0.174
05/29/23	04:00	55.4	0.174
05/29/23	05:00	55.5	0.174
05/29/23	06:00	55.5	0.174
05/29/23	07:00	55.4	0.174
05/29/23	08:00	55.4	0.174
05/29/23	09:00	55.4	0.173
05/29/23	10:00	55.4	0.173
05/29/23	11:00	55.2	0.173
05/29/23	12:00	55.1	0.172
05/29/23	13:00	55.1	0.172
05/29/23	14:00	55.1	0.172
05/29/23	15:00	55.3	0.173
05/29/23	16:00	55.4	0.173
05/29/23	17:00	55.4	0.173
05/29/23	18:00	55.4	0.173
05/29/23	19:00	55.5	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/29/23	20:00	55.6	0.174
05/29/23	21:00	55.8	0.174
05/29/23	22:00	56.2	0.175
05/29/23	23:00	56.5	0.176
05/30/23	00:00	56.4	0.176
05/30/23	01:00	56.3	0.175
05/30/23	02:00	56.3	0.175
05/30/23	03:00	56.5	0.176
05/30/23	04:00	56.5	0.175
05/30/23	05:00	56.5	0.175
05/30/23	06:00	56.4	0.175
05/30/23	07:00	56.3	0.174
05/30/23	08:00	56.2	0.174
05/30/23	09:00	56.0	0.173
05/30/23	10:00	55.9	0.173
05/30/23	11:00	55.8	0.172
05/30/23	12:00	55.6	0.171
05/30/23	13:00	55.5	0.171
05/30/23	14:00	56.6	0.171
05/30/23	15:00	58.3	0.172
05/30/23	16:00	60.2	0.173
05/30/23	17:00	62.0	0.175
05/30/23	18:00	63.9	0.176
05/30/23	19:00	63.8	0.175
05/30/23	20:00	63.8	0.175
05/30/23	21:00	63.8	0.175
05/30/23	22:00	63.7	0.175
05/30/23	23:00	63.7	0.174
05/31/23	00:00	63.8	0.175
05/31/23	01:00	63.7	0.175
05/31/23	02:00	63.7	0.175
05/31/23	03:00	63.6	0.175
05/31/23	04:00	63.6	0.175
05/31/23	05:00	63.6	0.175
05/31/23	06:00	63.7	0.175
05/31/23	07:00	62.9	0.175
05/31/23	08:00	62.0	0.175
05/31/23	09:00	61.1	0.175
05/31/23	10:00	60.1	0.175
05/31/23	11:00	59.3	0.176
05/31/23	12:00	59.9	0.177
05/31/23	13:00	62.2	0.179
05/31/23	14:00	63.3	0.180
05/31/23	15:00	61.5	0.178
05/31/23	16:00	58.3	0.176
05/31/23	17:00	55.7	0.173
05/31/23	18:00	53.9	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
05/31/23	19:00	53.9	0.172
05/31/23	20:00	53.9	0.172
05/31/23	21:00	53.9	0.172
05/31/23	22:00	53.9	0.172
05/31/23	23:00	53.0	0.172
06/01/23	00:00	51.7	0.170
06/01/23	01:00	50.5	0.170
06/01/23	02:00	49.3	0.168
06/01/23	03:00	48.2	0.168
06/01/23	04:00	47.0	0.167
06/01/23	05:00	45.8	0.166
06/01/23	06:00	44.7	0.166
06/01/23	07:00	44.6	0.166
06/01/23	08:00	44.3	0.166
06/01/23	09:00	44.4	0.166
06/01/23	10:00	44.3	0.166
06/01/23	11:00	44.2	0.165
06/01/23	12:00	44.3	0.165
06/01/23	13:00	44.2	0.164
06/01/23	14:00	43.3	0.163
06/01/23	15:00	44.7	0.164
06/01/23	16:00	47.9	0.166
06/01/23	17:00	50.6	0.169
06/01/23	18:00	50.1	0.167
06/01/23	19:00	48.8	0.165
06/01/23	20:00	47.5	0.164
06/01/23	21:00	46.2	0.162
06/01/23	22:00	44.7	0.161
06/01/23	23:00	44.2	0.159
06/02/23	00:00	44.2	0.159
06/02/23	01:00	44.2	0.159
06/02/23	02:00	44.2	0.159
06/02/23	03:00	44.1	0.158
06/02/23	04:00	44.1	0.158
06/02/23	05:00	44.1	0.158
06/02/23	06:00	44.0	0.157
06/02/23	07:00	43.9	0.156
06/02/23	08:00	43.9	0.156
06/02/23	09:00	43.8	0.155
06/02/23	10:00	43.8	0.154
06/02/23	11:00	44.3	0.153
06/02/23	12:00	45.7	0.154
06/02/23	13:00	45.4	0.153
06/02/23	14:00	45.7	0.153
06/02/23	15:00	46.3	0.154
06/02/23	16:00	46.1	0.153
06/02/23	17:00	45.9	0.153

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/02/23	18:00	46.0	0.153
06/02/23	19:00	46.0	0.153
06/02/23	20:00	46.1	0.154
06/02/23	21:00	46.2	0.154
06/02/23	22:00	46.4	0.155
06/02/23	23:00	46.7	0.157
06/03/23	00:00	46.6	0.156
06/03/23	01:00	46.6	0.156
06/03/23	02:00	46.6	0.157
06/03/23	03:00	46.7	0.157
06/03/23	04:00	46.7	0.158
06/03/23	05:00	46.8	0.158
06/03/23	06:00	46.9	0.159
06/03/23	07:00	46.9	0.159
06/03/23	08:00	47.0	0.159
06/03/23	09:00	47.0	0.159
06/03/23	10:00	47.1	0.160
06/03/23	11:00	46.5	0.161
06/03/23	12:00	43.5	0.159
06/03/23	13:00	40.5	0.157
06/03/23	14:00	37.6	0.156
06/03/23	15:00	34.6	0.154
06/03/23	16:00	31.7	0.153
06/03/23	17:00	28.7	0.151
06/03/23	18:00	27.9	0.152
06/03/23	19:00	28.1	0.153
06/03/23	20:00	28.1	0.153
06/03/23	21:00	28.2	0.153
06/03/23	22:00	28.1	0.152
06/03/23	23:00	27.9	0.151
06/04/23	00:00	27.9	0.150
06/04/23	01:00	27.9	0.150
06/04/23	02:00	28.0	0.150
06/04/23	03:00	27.9	0.149
06/04/23	04:00	27.9	0.149
06/04/23	05:00	27.9	0.149
06/04/23	06:00	27.9	0.149
06/04/23	07:00	28.0	0.149
06/04/23	08:00	28.1	0.149
06/04/23	09:00	28.1	0.149
06/04/23	10:00	28.1	0.149
06/04/23	11:00	28.1	0.149
06/04/23	12:00	27.9	0.148
06/04/23	13:00	28.0	0.148
06/04/23	14:00	28.1	0.148
06/04/23	15:00	28.1	0.148
06/04/23	16:00	28.1	0.148

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/04/23	17:00	28.2	0.148
06/04/23	18:00	28.2	0.148
06/04/23	19:00	28.2	0.148
06/04/23	20:00	28.3	0.149
06/04/23	21:00	28.3	0.149
06/04/23	22:00	28.5	0.150
06/04/23	23:00	28.7	0.151
06/05/23	00:00	28.9	0.152
06/05/23	01:00	29.0	0.153
06/05/23	02:00	29.1	0.154
06/05/23	03:00	29.2	0.154
06/05/23	04:00	29.3	0.155
06/05/23	05:00	29.3	0.155
06/05/23	06:00	29.3	0.155
06/05/23	07:00	29.2	0.155
06/05/23	08:00	29.3	0.155
06/05/23	09:00	29.3	0.155
06/05/23	10:00	29.4	0.156
06/05/23	11:00	29.6	0.157
06/05/23	12:00	30.0	0.159
06/05/23	13:00	29.9	0.160
06/05/23	14:00	29.8	0.160
06/05/23	15:00	29.7	0.159
06/05/23	16:00	29.7	0.159
06/05/23	17:00	29.6	0.159
06/05/23	18:00	29.6	0.158
06/05/23	19:00	29.5	0.158
06/05/23	20:00	29.3	0.158
06/05/23	21:00	29.2	0.157
06/05/23	22:00	29.0	0.156
06/05/23	23:00	28.8	0.155
06/06/23	00:00	28.8	0.154
06/06/23	01:00	28.8	0.154
06/06/23	02:00	28.7	0.154
06/06/23	03:00	28.7	0.154
06/06/23	04:00	28.7	0.154
06/06/23	05:00	28.7	0.155
06/06/23	06:00	28.8	0.155
06/06/23	07:00	28.9	0.155
06/06/23	08:00	28.9	0.155
06/06/23	09:00	28.8	0.155
06/06/23	10:00	28.4	0.152
06/06/23	11:00	27.9	0.150
06/06/23	12:00	27.5	0.148
06/06/23	13:00	27.4	0.147
06/06/23	14:00	27.6	0.147
06/06/23	15:00	27.7	0.148

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/06/23	16:00	27.9	0.149
06/06/23	17:00	28.1	0.150
06/06/23	18:00	28.3	0.151
06/06/23	19:00	28.4	0.152
06/06/23	20:00	28.6	0.153
06/06/23	21:00	28.8	0.154
06/06/23	22:00	28.9	0.154
06/06/23	23:00	29.0	0.155
06/07/23	00:00	28.9	0.154
06/07/23	01:00	29.0	0.154
06/07/23	02:00	28.8	0.154
06/07/23	03:00	28.8	0.154
06/07/23	04:00	28.8	0.153
06/07/23	05:00	28.8	0.153
06/07/23	06:00	28.8	0.153
06/07/23	07:00	28.7	0.153
06/07/23	08:00	28.7	0.153
06/07/23	09:00	28.7	0.154
06/07/23	10:00	29.2	0.156
06/07/23	11:00	29.6	0.159
06/07/23	12:00	29.9	0.161
06/07/23	13:00	29.9	0.162
06/07/23	14:00	29.9	0.161
06/07/23	15:00	29.9	0.162
06/07/23	16:00	29.9	0.162
06/07/23	17:00	29.9	0.162
06/07/23	18:00	29.8	0.161
06/07/23	19:00	29.9	0.162
06/07/23	20:00	29.9	0.162
06/07/23	21:00	29.9	0.162
06/07/23	22:00	30.0	0.162
06/07/23	23:00	30.0	0.162
06/08/23	00:00	30.0	0.162
06/08/23	01:00	30.0	0.163
06/08/23	02:00	30.0	0.163
06/08/23	03:00	30.0	0.163
06/08/23	04:00	30.0	0.163
06/08/23	05:00	30.0	0.163
06/08/23	06:00	30.0	0.163
06/08/23	07:00	30.0	0.163
06/08/23	08:00	30.1	0.163
06/08/23	09:00	30.0	0.163
06/08/23	10:00	30.0	0.163
06/08/23	11:00	30.0	0.163
06/08/23	12:00	30.1	0.163
06/08/23	13:00	30.2	0.164
06/08/23	14:00	30.2	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/08/23	15:00	30.2	0.164
06/08/23	16:00	30.2	0.164
06/08/23	17:00	30.1	0.164
06/08/23	18:00	30.1	0.164
06/08/23	19:00	30.1	0.164
06/08/23	20:00	30.1	0.164
06/08/23	21:00	30.1	0.164
06/08/23	22:00	30.1	0.164
06/08/23	23:00	30.2	0.165
06/09/23	00:00	30.2	0.165
06/09/23	01:00	30.2	0.165
06/09/23	02:00	30.2	0.165
06/09/23	03:00	30.2	0.165
06/09/23	04:00	30.3	0.165
06/09/23	05:00	30.2	0.165
06/09/23	06:00	30.3	0.165
06/09/23	07:00	30.3	0.165
06/09/23	08:00	30.3	0.165
06/09/23	09:00	30.4	0.166
06/09/23	10:00	30.4	0.166
06/09/23	11:00	30.4	0.166
06/09/23	12:00	30.3	0.166
06/09/23	13:00	30.3	0.166
06/09/23	14:00	30.4	0.166
06/09/23	15:00	30.5	0.167
06/09/23	16:00	30.6	0.167
06/09/23	17:00	30.7	0.167
06/09/23	18:00	30.7	0.167
06/09/23	19:00	30.7	0.167
06/09/23	20:00	30.7	0.167
06/09/23	21:00	30.6	0.167
06/09/23	22:00	30.6	0.167
06/09/23	23:00	30.5	0.167
06/10/23	00:00	30.6	0.167
06/10/23	01:00	30.6	0.168
06/10/23	02:00	30.6	0.168
06/10/23	03:00	30.7	0.168
06/10/23	04:00	30.7	0.169
06/10/23	05:00	30.8	0.170
06/10/23	06:00	30.9	0.170
06/10/23	07:00	30.8	0.170
06/10/23	08:00	30.9	0.170
06/10/23	09:00	30.9	0.171
06/10/23	10:00	30.9	0.171
06/10/23	11:00	30.9	0.171
06/10/23	12:00	30.9	0.171
06/10/23	13:00	31.0	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/10/23	14:00	31.0	0.171
06/10/23	15:00	31.0	0.171
06/10/23	16:00	31.1	0.171
06/10/23	17:00	31.2	0.172
06/10/23	18:00	31.2	0.172
06/10/23	19:00	31.3	0.173
06/10/23	20:00	31.3	0.173
06/10/23	21:00	31.5	0.173
06/10/23	22:00	31.5	0.174
06/10/23	23:00	31.6	0.174
06/11/23	00:00	31.7	0.175
06/11/23	01:00	31.7	0.175
06/11/23	02:00	31.8	0.175
06/11/23	03:00	31.8	0.175
06/11/23	04:00	31.8	0.175
06/11/23	05:00	31.9	0.175
06/11/23	06:00	31.9	0.175
06/11/23	07:00	32.0	0.176
06/11/23	08:00	32.2	0.176
06/11/23	09:00	32.3	0.176
06/11/23	10:00	32.4	0.177
06/11/23	11:00	32.6	0.177
06/11/23	12:00	32.7	0.178
06/11/23	13:00	32.7	0.178
06/11/23	14:00	32.9	0.178
06/11/23	15:00	33.0	0.178
06/11/23	16:00	33.0	0.178
06/11/23	17:00	33.1	0.178
06/11/23	18:00	33.1	0.178
06/11/23	19:00	33.2	0.178
06/11/23	20:00	33.2	0.178
06/11/23	21:00	33.2	0.178
06/11/23	22:00	33.2	0.177
06/11/23	23:00	33.2	0.177
06/12/23	00:00	33.0	0.175
06/12/23	01:00	33.0	0.175
06/12/23	02:00	33.1	0.174
06/12/23	03:00	33.1	0.174
06/12/23	04:00	33.1	0.173
06/12/23	05:00	33.1	0.173
06/12/23	06:00	33.1	0.172
06/12/23	07:00	33.0	0.171
06/12/23	08:00	34.2	0.171
06/12/23	09:00	37.4	0.172
06/12/23	10:00	40.4	0.173
06/12/23	11:00	43.4	0.174
06/12/23	12:00	46.2	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/12/23	13:00	49.2	0.177
06/12/23	14:00	52.0	0.177
06/12/23	15:00	54.3	0.177
06/12/23	16:00	53.7	0.173
06/12/23	17:00	53.3	0.171
06/12/23	18:00	53.0	0.170
06/12/23	19:00	52.7	0.168
06/12/23	20:00	52.5	0.167
06/12/23	21:00	52.3	0.167
06/12/23	22:00	52.1	0.166
06/12/23	23:00	52.0	0.165
06/13/23	00:00	52.0	0.166
06/13/23	01:00	51.8	0.165
06/13/23	02:00	51.7	0.165
06/13/23	03:00	51.5	0.164
06/13/23	04:00	51.4	0.164
06/13/23	05:00	52.3	0.163
06/13/23	06:00	55.1	0.164
06/13/23	07:00	58.3	0.167
06/13/23	08:00	60.0	0.168
06/13/23	09:00	59.4	0.167
06/13/23	10:00	56.7	0.165
06/13/23	11:00	53.5	0.163
06/13/23	12:00	50.5	0.161
06/13/23	13:00	47.3	0.159
06/13/23	14:00	44.1	0.157
06/13/23	15:00	41.6	0.156
06/13/23	16:00	42.0	0.159
06/13/23	17:00	42.1	0.160
06/13/23	18:00	42.2	0.160
06/13/23	19:00	42.2	0.160
06/13/23	20:00	42.2	0.160
06/13/23	21:00	42.2	0.160
06/13/23	22:00	42.2	0.160
06/13/23	23:00	42.2	0.160
06/14/23	00:00	42.3	0.160
06/14/23	01:00	42.5	0.161
06/14/23	02:00	42.6	0.162
06/14/23	03:00	42.7	0.162
06/14/23	04:00	42.8	0.163
06/14/23	05:00	41.9	0.164
06/14/23	06:00	39.0	0.163
06/14/23	07:00	35.7	0.161
06/14/23	08:00	32.7	0.159
06/14/23	09:00	29.9	0.158
06/14/23	10:00	29.4	0.158
06/14/23	11:00	29.5	0.158

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/14/23	12:00	29.4	0.158
06/14/23	13:00	29.5	0.158
06/14/23	14:00	29.6	0.158
06/14/23	15:00	29.5	0.158
06/14/23	16:00	29.5	0.158
06/14/23	17:00	29.5	0.158
06/14/23	18:00	29.6	0.159
06/14/23	19:00	29.6	0.159
06/14/23	20:00	29.7	0.160
06/14/23	21:00	29.7	0.160
06/14/23	22:00	29.7	0.160
06/14/23	23:00	29.7	0.161
06/15/23	00:00	29.8	0.161
06/15/23	01:00	29.9	0.162
06/15/23	02:00	29.8	0.162
06/15/23	03:00	29.8	0.161
06/15/23	04:00	29.8	0.162
06/15/23	05:00	29.8	0.162
06/15/23	06:00	29.8	0.162
06/15/23	07:00	29.7	0.161
06/15/23	08:00	29.7	0.161
06/15/23	09:00	29.7	0.161
06/15/23	10:00	29.7	0.160
06/15/23	11:00	29.7	0.160
06/15/23	12:00	29.7	0.160
06/15/23	13:00	29.8	0.160
06/15/23	14:00	29.7	0.160
06/15/23	15:00	29.7	0.160
06/15/23	16:00	29.7	0.160
06/15/23	17:00	29.7	0.160
06/15/23	18:00	29.7	0.159
06/15/23	19:00	29.8	0.159
06/15/23	20:00	29.9	0.159
06/15/23	21:00	29.9	0.159
06/15/23	22:00	30.1	0.159
06/15/23	23:00	30.2	0.159
06/16/23	00:00	30.3	0.159
06/16/23	01:00	30.1	0.158
06/16/23	02:00	30.2	0.158
06/16/23	03:00	30.3	0.158
06/16/23	04:00	30.3	0.158
06/16/23	05:00	30.4	0.158
06/16/23	06:00	30.6	0.159
06/16/23	07:00	30.7	0.159
06/16/23	08:00	30.8	0.159
06/16/23	09:00	30.8	0.159
06/16/23	10:00	30.9	0.159

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/16/23	11:00	30.9	0.159
06/16/23	12:00	31.0	0.159
06/16/23	13:00	31.1	0.160
06/16/23	14:00	31.3	0.161
06/16/23	15:00	31.4	0.161
06/16/23	16:00	31.5	0.162
06/16/23	17:00	31.6	0.162
06/16/23	18:00	31.6	0.162
06/16/23	19:00	31.6	0.163
06/16/23	20:00	31.7	0.163
06/16/23	21:00	31.6	0.163
06/16/23	22:00	31.5	0.163
06/16/23	23:00	31.5	0.163
06/17/23	00:00	31.5	0.163
06/17/23	01:00	31.6	0.164
06/17/23	02:00	31.5	0.163
06/17/23	03:00	31.4	0.163
06/17/23	04:00	31.4	0.163
06/17/23	05:00	31.4	0.164
06/17/23	06:00	31.3	0.163
06/17/23	07:00	31.2	0.163
06/17/23	08:00	31.1	0.163
06/17/23	09:00	31.3	0.164
06/17/23	10:00	31.4	0.165
06/17/23	11:00	31.5	0.166
06/17/23	12:00	31.5	0.166
06/17/23	13:00	31.5	0.166
06/17/23	14:00	31.4	0.166
06/17/23	15:00	31.4	0.167
06/17/23	16:00	31.5	0.168
06/17/23	17:00	31.5	0.168
06/17/23	18:00	31.5	0.168
06/17/23	19:00	31.5	0.168
06/17/23	20:00	31.3	0.168
06/17/23	21:00	31.4	0.169
06/17/23	22:00	31.4	0.169
06/17/23	23:00	31.3	0.169
06/18/23	00:00	31.2	0.168
06/18/23	01:00	31.1	0.168
06/18/23	02:00	31.2	0.168
06/18/23	03:00	31.2	0.168
06/18/23	04:00	31.1	0.168
06/18/23	05:00	31.0	0.167
06/18/23	06:00	30.9	0.167
06/18/23	07:00	30.8	0.166
06/18/23	08:00	30.6	0.165
06/18/23	09:00	30.5	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/18/23	10:00	30.4	0.164
06/18/23	11:00	30.2	0.163
06/18/23	12:00	30.1	0.162
06/18/23	13:00	30.0	0.162
06/18/23	14:00	29.9	0.162
06/18/23	15:00	29.8	0.161
06/18/23	16:00	29.6	0.160
06/18/23	17:00	29.6	0.160
06/18/23	18:00	29.6	0.160
06/18/23	19:00	29.7	0.160
06/18/23	20:00	29.7	0.160
06/18/23	21:00	29.7	0.160
06/18/23	22:00	29.7	0.160
06/18/23	23:00	29.7	0.160
06/19/23	00:00	29.7	0.160
06/19/23	01:00	29.6	0.160
06/19/23	02:00	29.5	0.159
06/19/23	03:00	29.4	0.159
06/19/23	04:00	29.3	0.159
06/19/23	05:00	29.3	0.159
06/19/23	06:00	29.3	0.159
06/19/23	07:00	28.9	0.157
06/19/23	08:00	28.6	0.155
06/19/23	09:00	28.4	0.153
06/19/23	10:00	27.9	0.151
06/19/23	11:00	28.0	0.151
06/19/23	12:00	28.2	0.151
06/19/23	13:00	28.2	0.151
06/19/23	14:00	29.4	0.151
06/19/23	15:00	33.0	0.153
06/19/23	16:00	36.9	0.156
06/19/23	17:00	38.4	0.156
06/19/23	18:00	38.4	0.156
06/19/23	19:00	38.4	0.156
06/19/23	20:00	38.4	0.156
06/19/23	21:00	38.5	0.157
06/19/23	22:00	38.5	0.157
06/19/23	23:00	38.5	0.157
06/20/23	00:00	38.6	0.158
06/20/23	01:00	38.7	0.158
06/20/23	02:00	38.9	0.159
06/20/23	03:00	38.9	0.159
06/20/23	04:00	39.0	0.160
06/20/23	05:00	39.0	0.160
06/20/23	06:00	39.2	0.161
06/20/23	07:00	39.8	0.164
06/20/23	08:00	39.8	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/20/23	09:00	39.8	0.164
06/20/23	10:00	39.8	0.164
06/20/23	11:00	39.8	0.164
06/20/23	12:00	39.8	0.164
06/20/23	13:00	40.2	0.166
06/20/23	14:00	40.7	0.169
06/20/23	15:00	41.3	0.172
06/20/23	16:00	41.3	0.173
06/20/23	17:00	41.1	0.173
06/20/23	18:00	41.1	0.173
06/20/23	19:00	40.0	0.173
06/20/23	20:00	36.4	0.171
06/20/23	21:00	32.6	0.169
06/20/23	22:00	31.1	0.169
06/20/23	23:00	31.1	0.169
06/21/23	00:00	31.2	0.170
06/21/23	01:00	31.2	0.170
06/21/23	02:00	31.3	0.170
06/21/23	03:00	31.3	0.170
06/21/23	04:00	31.3	0.170
06/21/23	05:00	31.3	0.170
06/21/23	06:00	31.2	0.170
06/21/23	07:00	31.2	0.170
06/21/23	08:00	31.1	0.170
06/21/23	09:00	30.8	0.168
06/21/23	10:00	30.8	0.168
06/21/23	11:00	30.7	0.168
06/21/23	12:00	30.8	0.168
06/21/23	13:00	30.8	0.168
06/21/23	14:00	31.0	0.169
06/21/23	15:00	31.6	0.168
06/21/23	16:00	32.1	0.167
06/21/23	17:00	33.0	0.166
06/21/23	18:00	33.1	0.164
06/21/23	19:00	33.2	0.165
06/21/23	20:00	33.3	0.165
06/21/23	21:00	33.4	0.165
06/21/23	22:00	33.4	0.165
06/21/23	23:00	33.4	0.165
06/22/23	00:00	33.3	0.164
06/22/23	01:00	33.3	0.164
06/22/23	02:00	33.3	0.163
06/22/23	03:00	33.3	0.163
06/22/23	04:00	33.2	0.163
06/22/23	05:00	33.3	0.163
06/22/23	06:00	33.3	0.163
06/22/23	07:00	33.5	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/22/23	08:00	33.5	0.163
06/22/23	09:00	33.5	0.163
06/22/23	10:00	33.9	0.165
06/22/23	11:00	34.0	0.165
06/22/23	12:00	34.1	0.165
06/22/23	13:00	34.2	0.165
06/22/23	14:00	35.4	0.165
06/22/23	15:00	38.4	0.168
06/22/23	16:00	41.5	0.172
06/22/23	17:00	44.7	0.176
06/22/23	18:00	46.3	0.178
06/22/23	19:00	46.2	0.177
06/22/23	20:00	46.1	0.177
06/22/23	21:00	46.1	0.177
06/22/23	22:00	46.1	0.177
06/22/23	23:00	46.1	0.176
06/23/23	00:00	46.1	0.176
06/23/23	01:00	46.1	0.176
06/23/23	02:00	46.1	0.176
06/23/23	03:00	46.1	0.176
06/23/23	04:00	46.1	0.176
06/23/23	05:00	46.1	0.176
06/23/23	06:00	46.0	0.176
06/23/23	07:00	46.1	0.176
06/23/23	08:00	46.2	0.176
06/23/23	09:00	46.3	0.177
06/23/23	10:00	46.2	0.176
06/23/23	11:00	46.2	0.176
06/23/23	12:00	46.1	0.176
06/23/23	13:00	46.1	0.176
06/23/23	14:00	44.8	0.176
06/23/23	15:00	41.3	0.174
06/23/23	16:00	37.5	0.171
06/23/23	17:00	33.4	0.168
06/23/23	18:00	31.8	0.167
06/23/23	19:00	32.0	0.168
06/23/23	20:00	32.0	0.168
06/23/23	21:00	32.1	0.168
06/23/23	22:00	32.1	0.167
06/23/23	23:00	32.2	0.167
06/24/23	00:00	32.2	0.167
06/24/23	01:00	32.4	0.167
06/24/23	02:00	32.3	0.167
06/24/23	03:00	32.3	0.167
06/24/23	04:00	32.4	0.166
06/24/23	05:00	32.4	0.166
06/24/23	06:00	32.4	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/24/23	07:00	32.4	0.166
06/24/23	08:00	32.4	0.166
06/24/23	09:00	32.5	0.165
06/24/23	10:00	32.5	0.165
06/24/23	11:00	32.6	0.166
06/24/23	12:00	32.7	0.166
06/24/23	13:00	32.7	0.166
06/24/23	14:00	32.8	0.167
06/24/23	15:00	34.4	0.167
06/24/23	16:00	37.8	0.169
06/24/23	17:00	41.7	0.172
06/24/23	18:00	45.9	0.176
06/24/23	19:00	46.3	0.175
06/24/23	20:00	46.0	0.174
06/24/23	21:00	45.8	0.173
06/24/23	22:00	45.7	0.173
06/24/23	23:00	45.7	0.173
06/25/23	00:00	45.7	0.174
06/25/23	01:00	45.8	0.174
06/25/23	02:00	45.8	0.174
06/25/23	03:00	45.8	0.174
06/25/23	04:00	45.8	0.174
06/25/23	05:00	45.8	0.174
06/25/23	06:00	45.8	0.174
06/25/23	07:00	45.6	0.174
06/25/23	08:00	45.4	0.174
06/25/23	09:00	45.3	0.173
06/25/23	10:00	45.2	0.172
06/25/23	11:00	45.1	0.172
06/25/23	12:00	44.9	0.171
06/25/23	13:00	44.8	0.171
06/25/23	14:00	44.7	0.170
06/25/23	15:00	43.1	0.169
06/25/23	16:00	39.8	0.168
06/25/23	17:00	35.9	0.166
06/25/23	18:00	31.7	0.162
06/25/23	19:00	31.4	0.163
06/25/23	20:00	31.5	0.164
06/25/23	21:00	31.7	0.165
06/25/23	22:00	31.8	0.166
06/25/23	23:00	31.9	0.166
06/26/23	00:00	31.9	0.166
06/26/23	01:00	31.8	0.166
06/26/23	02:00	31.9	0.167
06/26/23	03:00	31.9	0.167
06/26/23	04:00	32.0	0.167
06/26/23	05:00	32.0	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/26/23	06:00	32.1	0.167
06/26/23	07:00	32.3	0.168
06/26/23	08:00	32.5	0.168
06/26/23	09:00	32.6	0.168
06/26/23	10:00	32.7	0.169
06/26/23	11:00	32.9	0.169
06/26/23	12:00	33.0	0.169
06/26/23	13:00	33.1	0.169
06/26/23	14:00	33.0	0.169
06/26/23	15:00	33.0	0.169
06/26/23	16:00	32.9	0.168
06/26/23	17:00	33.0	0.167
06/26/23	18:00	33.0	0.167
06/26/23	19:00	33.1	0.167
06/26/23	20:00	33.2	0.167
06/26/23	21:00	33.3	0.167
06/26/23	22:00	33.3	0.167
06/26/23	23:00	33.3	0.167
06/27/23	00:00	33.3	0.167
06/27/23	01:00	33.4	0.167
06/27/23	02:00	33.4	0.167
06/27/23	03:00	33.4	0.167
06/27/23	04:00	33.4	0.167
06/27/23	05:00	33.3	0.167
06/27/23	06:00	33.3	0.167
06/27/23	07:00	33.1	0.166
06/27/23	08:00	33.0	0.166
06/27/23	09:00	33.0	0.166
06/27/23	10:00	33.0	0.166
06/27/23	11:00	32.9	0.166
06/27/23	12:00	32.8	0.165
06/27/23	13:00	32.6	0.165
06/27/23	14:00	32.6	0.164
06/27/23	15:00	32.5	0.164
06/27/23	16:00	32.4	0.164
06/27/23	17:00	32.3	0.164
06/27/23	18:00	32.2	0.164
06/27/23	19:00	32.1	0.164
06/27/23	20:00	31.9	0.164
06/27/23	21:00	31.8	0.164
06/27/23	22:00	31.7	0.164
06/27/23	23:00	31.7	0.164
06/28/23	00:00	31.6	0.164
06/28/23	01:00	31.4	0.164
06/28/23	02:00	31.4	0.163
06/28/23	03:00	31.4	0.163
06/28/23	04:00	31.3	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/28/23	05:00	31.3	0.163
06/28/23	06:00	31.5	0.164
06/28/23	07:00	31.5	0.164
06/28/23	08:00	31.6	0.165
06/28/23	09:00	31.6	0.165
06/28/23	10:00	31.6	0.166
06/28/23	11:00	31.7	0.167
06/28/23	12:00	31.7	0.167
06/28/23	13:00	31.8	0.168
06/28/23	14:00	33.2	0.169
06/28/23	15:00	36.8	0.172
06/28/23	16:00	40.7	0.175
06/28/23	17:00	44.4	0.178
06/28/23	18:00	45.3	0.178
06/28/23	19:00	45.1	0.177
06/28/23	20:00	45.1	0.177
06/28/23	21:00	45.1	0.177
06/28/23	22:00	45.1	0.177
06/28/23	23:00	45.0	0.177
06/29/23	00:00	45.0	0.177
06/29/23	01:00	45.1	0.177
06/29/23	02:00	45.0	0.177
06/29/23	03:00	45.0	0.177
06/29/23	04:00	45.0	0.176
06/29/23	05:00	44.9	0.176
06/29/23	06:00	44.9	0.175
06/29/23	07:00	44.7	0.175
06/29/23	08:00	44.4	0.173
06/29/23	09:00	43.4	0.167
06/29/23	10:00	42.4	0.162
06/29/23	11:00	43.2	0.161
06/29/23	12:00	47.3	0.163
06/29/23	13:00	51.8	0.167
06/29/23	14:00	53.6	0.169
06/29/23	15:00	51.2	0.166
06/29/23	16:00	50.2	0.166
06/29/23	17:00	50.9	0.166
06/29/23	18:00	54.4	0.169
06/29/23	19:00	58.0	0.173
06/29/23	20:00	58.2	0.172
06/29/23	21:00	58.1	0.172
06/29/23	22:00	57.9	0.170
06/29/23	23:00	58.0	0.171
06/30/23	00:00	58.1	0.171
06/30/23	01:00	58.1	0.171
06/30/23	02:00	58.1	0.171
06/30/23	03:00	58.0	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
06/30/23	04:00	57.9	0.170
06/30/23	05:00	57.9	0.170
06/30/23	06:00	57.9	0.170
06/30/23	07:00	58.0	0.171
06/30/23	08:00	58.3	0.172
06/30/23	09:00	58.8	0.175
06/30/23	10:00	60.3	0.178
06/30/23	11:00	63.0	0.181
06/30/23	12:00	62.3	0.180
06/30/23	13:00	61.3	0.177
06/30/23	14:00	61.9	0.177
06/30/23	15:00	64.4	0.179
06/30/23	16:00	65.3	0.180
06/30/23	17:00	64.7	0.179
06/30/23	18:00	64.1	0.178
06/30/23	19:00	64.7	0.178
06/30/23	20:00	65.7	0.179
06/30/23	21:00	65.7	0.179
06/30/23	22:00	65.9	0.181
06/30/23	23:00	65.9	0.181
07/01/23	00:00	65.8	0.181
07/01/23	01:00	65.7	0.180
07/01/23	02:00	65.6	0.180
07/01/23	03:00	65.7	0.180
07/01/23	04:00	65.8	0.181
07/01/23	05:00	65.8	0.181
07/01/23	06:00	65.8	0.181
07/01/23	07:00	65.7	0.181
07/01/23	08:00	65.6	0.181
07/01/23	09:00	66.0	0.183
07/01/23	10:00	65.2	0.184
07/01/23	11:00	61.4	0.181
07/01/23	12:00	57.7	0.178
07/01/23	13:00	53.8	0.175
07/01/23	14:00	50.0	0.172
07/01/23	15:00	46.1	0.169
07/01/23	16:00	42.3	0.166
07/01/23	17:00	38.5	0.164
07/01/23	18:00	34.6	0.160
07/01/23	19:00	30.6	0.157
07/01/23	20:00	29.3	0.157
07/01/23	21:00	29.3	0.157
07/01/23	22:00	29.1	0.156
07/01/23	23:00	29.0	0.154
07/02/23	00:00	29.0	0.153
07/02/23	01:00	29.0	0.153
07/02/23	02:00	29.0	0.154

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/02/23	03:00	29.0	0.153
07/02/23	04:00	28.9	0.153
07/02/23	05:00	28.8	0.152
07/02/23	06:00	28.7	0.152
07/02/23	07:00	28.6	0.151
07/02/23	08:00	28.6	0.151
07/02/23	09:00	28.6	0.151
07/02/23	10:00	28.7	0.151
07/02/23	11:00	28.8	0.152
07/02/23	12:00	29.0	0.152
07/02/23	13:00	29.2	0.153
07/02/23	14:00	29.2	0.153
07/02/23	15:00	29.2	0.153
07/02/23	16:00	29.3	0.153
07/02/23	17:00	29.4	0.154
07/02/23	18:00	29.4	0.154
07/02/23	19:00	29.5	0.154
07/02/23	20:00	29.7	0.155
07/02/23	21:00	29.8	0.156
07/02/23	22:00	29.9	0.156
07/02/23	23:00	30.1	0.157
07/03/23	00:00	30.0	0.157
07/03/23	01:00	30.3	0.158
07/03/23	02:00	30.4	0.158
07/03/23	03:00	30.4	0.159
07/03/23	04:00	30.5	0.159
07/03/23	05:00	30.6	0.159
07/03/23	06:00	30.8	0.160
07/03/23	07:00	30.8	0.160
07/03/23	08:00	30.9	0.160
07/03/23	09:00	31.0	0.160
07/03/23	10:00	31.1	0.161
07/03/23	11:00	31.2	0.161
07/03/23	12:00	31.3	0.161
07/03/23	13:00	31.3	0.161
07/03/23	14:00	31.7	0.159
07/03/23	15:00	34.5	0.160
07/03/23	16:00	37.7	0.162
07/03/23	17:00	41.4	0.164
07/03/23	18:00	42.7	0.164
07/03/23	19:00	42.7	0.165
07/03/23	20:00	42.6	0.164
07/03/23	21:00	42.6	0.165
07/03/23	22:00	42.6	0.165
07/03/23	23:00	42.6	0.165
07/04/23	00:00	42.6	0.165
07/04/23	01:00	42.7	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/04/23	02:00	42.6	0.166
07/04/23	03:00	42.5	0.166
07/04/23	04:00	42.5	0.166
07/04/23	05:00	42.5	0.166
07/04/23	06:00	42.4	0.166
07/04/23	07:00	42.3	0.166
07/04/23	08:00	42.2	0.166
07/04/23	09:00	42.2	0.166
07/04/23	10:00	42.0	0.166
07/04/23	11:00	41.9	0.166
07/04/23	12:00	41.8	0.166
07/04/23	13:00	41.9	0.166
07/04/23	14:00	41.5	0.169
07/04/23	15:00	39.3	0.166
07/04/23	16:00	39.3	0.166
07/04/23	17:00	36.6	0.163
07/04/23	18:00	35.4	0.163
07/04/23	19:00	35.4	0.163
07/04/23	20:00	35.3	0.163
07/04/23	21:00	35.3	0.163
07/04/23	22:00	35.2	0.163
07/04/23	23:00	35.2	0.164
07/05/23	00:00	35.2	0.164
07/05/23	01:00	35.0	0.164
07/05/23	02:00	35.1	0.164
07/05/23	03:00	35.1	0.163
07/05/23	04:00	35.0	0.163
07/05/23	05:00	34.9	0.163
07/05/23	06:00	35.0	0.163
07/05/23	07:00	35.1	0.164
07/05/23	08:00	35.2	0.164
07/05/23	09:00	35.4	0.164
07/05/23	10:00	35.5	0.164
07/05/23	11:00	36.2	0.163
07/05/23	12:00	39.5	0.165
07/05/23	13:00	42.9	0.167
07/05/23	14:00	46.6	0.170
07/05/23	15:00	49.7	0.174
07/05/23	16:00	50.2	0.174
07/05/23	17:00	52.8	0.178
07/05/23	18:00	56.4	0.180
07/05/23	19:00	58.0	0.179
07/05/23	20:00	58.0	0.179
07/05/23	21:00	58.0	0.179
07/05/23	22:00	58.0	0.178
07/05/23	23:00	57.9	0.178
07/06/23	00:00	57.9	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/06/23	01:00	57.8	0.176
07/06/23	02:00	57.8	0.176
07/06/23	03:00	57.8	0.175
07/06/23	04:00	57.8	0.175
07/06/23	05:00	57.8	0.175
07/06/23	06:00	57.9	0.175
07/06/23	07:00	57.9	0.175
07/06/23	08:00	57.9	0.174
07/06/23	09:00	57.7	0.174
07/06/23	10:00	57.5	0.174
07/06/23	11:00	56.7	0.176
07/06/23	12:00	53.1	0.175
07/06/23	13:00	49.4	0.173
07/06/23	14:00	45.4	0.170
07/06/23	15:00	45.4	0.170
07/06/23	16:00	45.4	0.170
07/06/23	17:00	45.4	0.170
07/06/23	18:00	45.4	0.170
07/06/23	19:00	45.4	0.170
07/06/23	20:00	45.4	0.170
07/06/23	21:00	45.4	0.170
07/06/23	22:00	45.4	0.170
07/06/23	23:00	45.4	0.170
07/07/23	00:00	45.4	0.170
07/07/23	01:00	45.4	0.170
07/07/23	02:00	45.4	0.170
07/07/23	03:00	45.4	0.170
07/07/23	04:00	45.4	0.170
07/07/23	05:00	45.4	0.170
07/07/23	06:00	45.4	0.170
07/07/23	07:00	45.4	0.170
07/07/23	08:00	45.4	0.170
07/07/23	09:00	45.4	0.170
07/07/23	10:00	45.4	0.170
07/07/23	11:00	45.4	0.170
07/07/23	12:00	45.4	0.170
07/07/23	13:00	45.4	0.170
07/07/23	14:00	45.4	0.170
07/07/23	15:00	45.4	0.170
07/07/23	16:00	45.4	0.170
07/07/23	17:00	45.4	0.170
07/07/23	18:00	45.4	0.170
07/07/23	19:00	45.4	0.170
07/07/23	20:00	45.4	0.170
07/07/23	21:00	45.4	0.170
07/07/23	22:00	45.4	0.170
07/07/23	23:00	45.4	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/08/23	00:00	45.4	0.170
07/08/23	01:00	45.4	0.170
07/08/23	02:00	45.4	0.170
07/08/23	03:00	45.4	0.170
07/08/23	04:00	45.4	0.170
07/08/23	05:00	45.4	0.170
07/08/23	06:00	45.4	0.170
07/08/23	07:00	45.4	0.170
07/08/23	08:00	45.4	0.170
07/08/23	09:00	45.4	0.170
07/08/23	10:00	45.4	0.170
07/08/23	11:00	45.4	0.170
07/08/23	12:00	45.4	0.170
07/08/23	13:00	45.4	0.170
07/08/23	14:00	45.4	0.170
07/08/23	15:00	45.4	0.170
07/08/23	16:00	45.4	0.170
07/08/23	17:00	45.4	0.170
07/08/23	18:00	45.4	0.170
07/08/23	19:00	45.4	0.170
07/08/23	20:00	45.4	0.170
07/08/23	21:00	45.4	0.170
07/08/23	22:00	45.4	0.170
07/08/23	23:00	45.4	0.170
07/09/23	00:00	45.4	0.170
07/09/23	01:00	45.4	0.170
07/09/23	02:00	45.4	0.170
07/09/23	03:00	45.4	0.170
07/09/23	04:00	45.4	0.170
07/09/23	05:00	45.4	0.170
07/09/23	06:00	45.4	0.170
07/09/23	07:00	45.4	0.170
07/09/23	08:00	45.4	0.170
07/09/23	09:00	45.4	0.170
07/09/23	10:00	45.4	0.170
07/09/23	11:00	45.4	0.170
07/09/23	12:00	45.4	0.170
07/09/23	13:00	45.4	0.170
07/09/23	14:00	45.4	0.170
07/09/23	15:00	45.4	0.170
07/09/23	16:00	45.4	0.170
07/09/23	17:00	45.4	0.170
07/09/23	18:00	45.4	0.170
07/09/23	19:00	45.4	0.170
07/09/23	20:00	45.4	0.170
07/09/23	21:00	45.4	0.170
07/09/23	22:00	45.4	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/09/23	23:00	45.4	0.170
07/10/23	00:00	45.4	0.170
07/10/23	01:00	45.4	0.170
07/10/23	02:00	45.4	0.170
07/10/23	03:00	45.4	0.170
07/10/23	04:00	45.4	0.170
07/10/23	05:00	45.4	0.170
07/10/23	06:00	45.4	0.170
07/10/23	07:00	45.4	0.170
07/10/23	08:00	45.4	0.170
07/10/23	09:00	45.4	0.170
07/10/23	10:00	45.4	0.170
07/10/23	11:00	45.4	0.170
07/10/23	12:00	45.4	0.170
07/10/23	13:00	45.4	0.170
07/10/23	14:00	45.4	0.170
07/10/23	15:00	45.4	0.170
07/10/23	16:00	45.4	0.170
07/10/23	17:00	45.4	0.170
07/10/23	18:00	45.4	0.170
07/10/23	19:00	45.4	0.170
07/10/23	20:00	40.5	0.167
07/10/23	21:00	35.6	0.164I
07/10/23	22:00	30.8	0.161I
07/10/23	23:00	25.7	0.157I
07/11/23	00:00	23.0	0.156I
07/11/23	01:00	21.8	0.156I
07/11/23	02:00	20.6	0.156I
07/11/23	03:00	19.5	0.156I
07/11/23	04:00	18.9	0.156I
07/11/23	05:00	18.5	0.156I
07/11/23	06:00	18.3	0.158I
07/11/23	07:00	18.4	0.156I
07/11/23	08:00	18.6	0.159I
07/11/23	09:00	18.6	0.158I
07/11/23	10:00	18.6	0.157I
07/11/23	11:00	18.7	0.157I
07/11/23	12:00	18.6	0.157I
07/11/23	13:00	18.5	0.158I
07/11/23	14:00	18.6	0.159I
07/11/23	15:00	18.8	0.158I
07/11/23	16:00	19.0	0.158I
07/11/23	17:00	19.4	0.159I
07/11/23	18:00	19.5	0.160I
07/11/23	19:00	19.8	0.159I
07/11/23	20:00	20.9	0.159I
07/11/23	21:00	22.1	0.160I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/11/23	22:00	23.3	0.160I
07/11/23	23:00	24.5	0.159I
07/12/23	00:00	25.7	0.160
07/12/23	01:00	27.0	0.160
07/12/23	02:00	28.2	0.160
07/12/23	03:00	29.4	0.160
07/12/23	04:00	29.9	0.160
07/12/23	05:00	30.4	0.160
07/12/23	06:00	30.5	0.160
07/12/23	07:00	30.3	0.160
07/12/23	08:00	30.1	0.159
07/12/23	09:00	30.0	0.159
07/12/23	10:00	29.8	0.159
07/12/23	11:00	29.7	0.159
07/12/23	12:00	29.6	0.159
07/12/23	13:00	29.6	0.158
07/12/23	14:00	29.5	0.158
07/12/23	15:00	29.4	0.159
07/12/23	16:00	29.2	0.159
07/12/23	17:00	29.0	0.158
07/12/23	18:00	28.9	0.157
07/12/23	19:00	28.9	0.157
07/12/23	20:00	28.8	0.156
07/12/23	21:00	28.9	0.156
07/12/23	22:00	29.0	0.156
07/12/23	23:00	29.1	0.155
07/13/23	00:00	29.2	0.155
07/13/23	01:00	29.5	0.154
07/13/23	02:00	29.8	0.154
07/13/23	03:00	29.9	0.154
07/13/23	04:00	30.1	0.154
07/13/23	05:00	30.4	0.154
07/13/23	06:00	30.7	0.155
07/13/23	07:00	31.1	0.155
07/13/23	08:00	31.4	0.156
07/13/23	09:00	31.7	0.156
07/13/23	10:00	31.9	0.156
07/13/23	11:00	32.4	0.156
07/13/23	12:00	32.6	0.156
07/13/23	13:00	33.2	0.157
07/13/23	14:00	34.5	0.157
07/13/23	15:00	36.7	0.158
07/13/23	16:00	37.7	0.158
07/13/23	17:00	38.1	0.158
07/13/23	18:00	38.1	0.155
07/13/23	19:00	39.5	0.156
07/13/23	20:00	40.2	0.157

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/13/23	21:00	40.4	0.158
07/13/23	22:00	40.4	0.159
07/13/23	23:00	40.4	0.159
07/14/23	00:00	40.3	0.160
07/14/23	01:00	40.2	0.161
07/14/23	02:00	40.0	0.162
07/14/23	03:00	39.9	0.163
07/14/23	04:00	39.8	0.163
07/14/23	05:00	39.7	0.164
07/14/23	06:00	39.6	0.164
07/14/23	07:00	39.5	0.165
07/14/23	08:00	39.4	0.165
07/14/23	09:00	39.3	0.165
07/14/23	10:00	39.1	0.165
07/14/23	11:00	38.9	0.165
07/14/23	12:00	38.6	0.165
07/14/23	13:00	38.2	0.164
07/14/23	14:00	39.0	0.164
07/14/23	15:00	40.0	0.165
07/14/23	16:00	42.2	0.166
07/14/23	17:00	44.8	0.166
07/14/23	18:00	46.2	0.169
07/14/23	19:00	45.2	0.169
07/14/23	20:00	44.6	0.169
07/14/23	21:00	44.4	0.168
07/14/23	22:00	44.5	0.168
07/14/23	23:00	44.5	0.168
07/15/23	00:00	44.5	0.169
07/15/23	01:00	44.3	0.168
07/15/23	02:00	44.4	0.168
07/15/23	03:00	44.4	0.167
07/15/23	04:00	44.4	0.167
07/15/23	05:00	44.4	0.167
07/15/23	06:00	44.4	0.166
07/15/23	07:00	44.3	0.166
07/15/23	08:00	44.3	0.166
07/15/23	09:00	44.2	0.166
07/15/23	10:00	44.2	0.166
07/15/23	11:00	44.2	0.165
07/15/23	12:00	44.2	0.165
07/15/23	13:00	44.0	0.165
07/15/23	14:00	42.1	0.165
07/15/23	15:00	39.1	0.164
07/15/23	16:00	36.1	0.164
07/15/23	17:00	33.3	0.163
07/15/23	18:00	32.0	0.164
07/15/23	19:00	31.9	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/15/23	20:00	31.8	0.164
07/15/23	21:00	31.8	0.164
07/15/23	22:00	31.9	0.165
07/15/23	23:00	32.0	0.165
07/16/23	00:00	31.9	0.165
07/16/23	01:00	31.9	0.165
07/16/23	02:00	31.7	0.164
07/16/23	03:00	31.7	0.164
07/16/23	04:00	31.6	0.164
07/16/23	05:00	31.4	0.163
07/16/23	06:00	31.3	0.163
07/16/23	07:00	31.3	0.163
07/16/23	08:00	31.3	0.164
07/16/23	09:00	31.3	0.164
07/16/23	10:00	31.3	0.164
07/16/23	11:00	31.3	0.165
07/16/23	12:00	31.3	0.165
07/16/23	13:00	31.3	0.166
07/16/23	14:00	31.3	0.166
07/16/23	15:00	31.3	0.166
07/16/23	16:00	31.2	0.166
07/16/23	17:00	31.2	0.166
07/16/23	18:00	31.2	0.167
07/16/23	19:00	31.2	0.167
07/16/23	20:00	31.3	0.167
07/16/23	21:00	31.3	0.167
07/16/23	22:00	31.3	0.167
07/16/23	23:00	31.2	0.167
07/17/23	00:00	31.3	0.168
07/17/23	01:00	31.3	0.169
07/17/23	02:00	31.5	0.170
07/17/23	03:00	31.5	0.170
07/17/23	04:00	31.6	0.170
07/17/23	05:00	31.6	0.170
07/17/23	06:00	31.5	0.170
07/17/23	07:00	31.5	0.170
07/17/23	08:00	31.4	0.169
07/17/23	09:00	31.4	0.169
07/17/23	10:00	31.3	0.169
07/17/23	11:00	31.3	0.168
07/17/23	12:00	31.2	0.168
07/17/23	13:00	31.1	0.168
07/17/23	14:00	31.1	0.168
07/17/23	15:00	31.1	0.167
07/17/23	16:00	31.0	0.167
07/17/23	17:00	30.9	0.166
07/17/23	18:00	30.8	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/17/23	19:00	30.7	0.164
07/17/23	20:00	30.5	0.163
07/17/23	21:00	30.5	0.163
07/17/23	22:00	30.3	0.162
07/17/23	23:00	30.1	0.161
07/18/23	00:00	30.0	0.161
07/18/23	01:00	29.9	0.161
07/18/23	02:00	29.9	0.160
07/18/23	03:00	29.9	0.160
07/18/23	04:00	29.8	0.160
07/18/23	05:00	29.9	0.161
07/18/23	06:00	29.9	0.161
07/18/23	07:00	29.9	0.161
07/18/23	08:00	29.9	0.161
07/18/23	09:00	29.9	0.161
07/18/23	10:00	29.9	0.162
07/18/23	11:00	29.9	0.162
07/18/23	12:00	29.9	0.162
07/18/23	13:00	30.0	0.162
07/18/23	14:00	30.0	0.162
07/18/23	15:00	31.1	0.162
07/18/23	16:00	34.5	0.163
07/18/23	17:00	35.6	0.163
07/18/23	18:00	35.5	0.162
07/18/23	19:00	35.5	0.162
07/18/23	20:00	35.6	0.162
07/18/23	21:00	35.6	0.162
07/18/23	22:00	35.8	0.162
07/18/23	23:00	35.8	0.162
07/19/23	00:00	36.0	0.163
07/19/23	01:00	36.1	0.163
07/19/23	02:00	36.0	0.162
07/19/23	03:00	35.9	0.162
07/19/23	04:00	36.0	0.163
07/19/23	05:00	36.0	0.163
07/19/23	06:00	36.1	0.163
07/19/23	07:00	36.1	0.163
07/19/23	08:00	36.1	0.163
07/19/23	09:00	36.1	0.163
07/19/23	10:00	36.1	0.163
07/19/23	11:00	36.2	0.163
07/19/23	12:00	36.2	0.163
07/19/23	13:00	35.9	0.163
07/19/23	14:00	36.9	0.162
07/19/23	15:00	39.0	0.164
07/19/23	16:00	39.0	0.164
07/19/23	17:00	41.4	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/19/23	18:00	44.8	0.170
07/19/23	19:00	46.3	0.171
07/19/23	20:00	46.2	0.170
07/19/23	21:00	46.1	0.170
07/19/23	22:00	46.1	0.170
07/19/23	23:00	46.1	0.170
07/20/23	00:00	46.0	0.169
07/20/23	01:00	46.0	0.169
07/20/23	02:00	45.9	0.168
07/20/23	03:00	45.8	0.168
07/20/23	04:00	45.8	0.167
07/20/23	05:00	45.7	0.167
07/20/23	06:00	45.7	0.167
07/20/23	07:00	45.7	0.167
07/20/23	08:00	45.8	0.168
07/20/23	09:00	45.8	0.168
07/20/23	10:00	45.7	0.167
07/20/23	11:00	45.7	0.167
07/20/23	12:00	45.7	0.168
07/20/23	13:00	45.9	0.168
07/20/23	14:00	45.1	0.169
07/20/23	15:00	42.0	0.168
07/20/23	16:00	38.7	0.167
07/20/23	17:00	35.3	0.165
07/20/23	18:00	32.2	0.164
07/20/23	19:00	30.9	0.165
07/20/23	20:00	31.0	0.166
07/20/23	21:00	31.2	0.166
07/20/23	22:00	31.1	0.167
07/20/23	23:00	31.1	0.167
07/21/23	00:00	31.2	0.167
07/21/23	01:00	31.3	0.168
07/21/23	02:00	31.4	0.168
07/21/23	03:00	31.5	0.168
07/21/23	04:00	31.4	0.169
07/21/23	05:00	31.5	0.169
07/21/23	06:00	31.4	0.168
07/21/23	07:00	30.5	0.168
07/21/23	08:00	30.5	0.167
07/21/23	09:00	30.7	0.167
07/21/23	10:00	30.9	0.166
07/21/23	11:00	31.1	0.166
07/21/23	12:00	31.2	0.166
07/21/23	13:00	31.4	0.166
07/21/23	14:00	31.4	0.165
07/21/23	15:00	31.6	0.165
07/21/23	16:00	31.7	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/21/23	17:00	31.9	0.164
07/21/23	18:00	32.0	0.164
07/21/23	19:00	32.1	0.164
07/21/23	20:00	32.3	0.164
07/21/23	21:00	32.4	0.163
07/21/23	22:00	32.6	0.163
07/21/23	23:00	32.8	0.163
07/22/23	00:00	32.9	0.163
07/22/23	01:00	33.0	0.163
07/22/23	02:00	33.3	0.163
07/22/23	03:00	33.4	0.163
07/22/23	04:00	33.7	0.164
07/22/23	05:00	33.9	0.164
07/22/23	06:00	34.1	0.164
07/22/23	07:00	35.2	0.165
07/22/23	08:00	35.3	0.166
07/22/23	09:00	35.4	0.167
07/22/23	10:00	35.4	0.167
07/22/23	11:00	35.4	0.168
07/22/23	12:00	35.5	0.169
07/22/23	13:00	35.6	0.169
07/22/23	14:00	35.5	0.169
07/22/23	15:00	35.5	0.169
07/22/23	16:00	35.5	0.169
07/22/23	17:00	35.4	0.169
07/22/23	18:00	35.4	0.169
07/22/23	19:00	35.4	0.170
07/22/23	20:00	35.3	0.170
07/22/23	21:00	35.3	0.170
07/22/23	22:00	35.3	0.170
07/22/23	23:00	35.2	0.169
07/23/23	00:00	35.2	0.169
07/23/23	01:00	35.2	0.170
07/23/23	02:00	35.1	0.169
07/23/23	03:00	35.2	0.170
07/23/23	04:00	35.2	0.170
07/23/23	05:00	35.2	0.170
07/23/23	06:00	35.2	0.170
07/23/23	07:00	35.2	0.170
07/23/23	08:00	35.2	0.170
07/23/23	09:00	35.2	0.169
07/23/23	10:00	35.3	0.170
07/23/23	11:00	35.3	0.170
07/23/23	12:00	35.3	0.169
07/23/23	13:00	35.3	0.169
07/23/23	14:00	36.1	0.169
07/23/23	15:00	39.2	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/23/23	16:00	42.3	0.171
07/23/23	17:00	45.4	0.172
07/23/23	18:00	48.4	0.173
07/23/23	19:00	49.7	0.173
07/23/23	20:00	49.3	0.170
07/23/23	21:00	48.9	0.168
07/23/23	22:00	48.6	0.166
07/23/23	23:00	48.5	0.165
07/24/23	00:00	48.3	0.164
07/24/23	01:00	48.0	0.163
07/24/23	02:00	47.7	0.161
07/24/23	03:00	47.4	0.160
07/24/23	04:00	47.2	0.158
07/24/23	05:00	46.9	0.156
07/24/23	06:00	46.6	0.154
07/24/23	07:00	46.3	0.153
07/24/23	08:00	45.9	0.151
07/24/23	09:00	45.6	0.150
07/24/23	10:00	45.3	0.147
07/24/23	11:00	45.1	0.146
07/24/23	12:00	46.2	0.146
07/24/23	13:00	49.5	0.148
07/24/23	14:00	52.0	0.150
07/24/23	15:00	52.0	0.151
07/24/23	16:00	51.4	0.150
07/24/23	17:00	51.0	0.150
07/24/23	18:00	51.2	0.150
07/24/23	19:00	53.0	0.152
07/24/23	20:00	54.3	0.153
07/24/23	21:00	54.4	0.154
07/24/23	22:00	54.6	0.155
07/24/23	23:00	54.5	0.155
07/25/23	00:00	54.4	0.154
07/25/23	01:00	54.3	0.154
07/25/23	02:00	54.1	0.153
07/25/23	03:00	54.0	0.152
07/25/23	04:00	53.8	0.151
07/25/23	05:00	53.8	0.151
07/25/23	06:00	53.8	0.151
07/25/23	07:00	53.8	0.151
07/25/23	08:00	53.9	0.152
07/25/23	09:00	54.0	0.152
07/25/23	10:00	55.4	0.154
07/25/23	11:00	58.8	0.157
07/25/23	12:00	60.8	0.158
07/25/23	13:00	60.5	0.158
07/25/23	14:00	60.0	0.157

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/25/23	15:00	59.8	0.156
07/25/23	16:00	60.1	0.156
07/25/23	17:00	60.4	0.157
07/25/23	18:00	60.2	0.156
07/25/23	19:00	59.9	0.156
07/25/23	20:00	62.1	0.159
07/25/23	21:00	62.6	0.158
07/25/23	22:00	62.6	0.158
07/25/23	23:00	62.8	0.160
07/26/23	00:00	63.0	0.161
07/26/23	01:00	63.4	0.163
07/26/23	02:00	63.9	0.165
07/26/23	03:00	64.3	0.168
07/26/23	04:00	64.6	0.169
07/26/23	05:00	64.9	0.171
07/26/23	06:00	65.1	0.172
07/26/23	07:00	65.2	0.173
07/26/23	08:00	65.4	0.174
07/26/23	09:00	65.5	0.175
07/26/23	10:00	65.6	0.175
07/26/23	11:00	65.4	0.174
07/26/23	12:00	65.1	0.174
07/26/23	13:00	65.0	0.173
07/26/23	14:00	64.4	0.172
07/26/23	15:00	63.8	0.172
07/26/23	16:00	63.1	0.170
07/26/23	17:00	62.4	0.170
07/26/23	18:00	61.8	0.169
07/26/23	19:00	61.1	0.168
07/26/23	20:00	58.8	0.165
07/26/23	21:00	58.6	0.167
07/26/23	22:00	58.7	0.168
07/26/23	23:00	58.8	0.168
07/27/23	00:00	58.9	0.168
07/27/23	01:00	58.9	0.168
07/27/23	02:00	59.0	0.168
07/27/23	03:00	58.9	0.168
07/27/23	04:00	58.9	0.168
07/27/23	05:00	59.0	0.168
07/27/23	06:00	59.0	0.168
07/27/23	07:00	59.1	0.169
07/27/23	08:00	59.1	0.168
07/27/23	09:00	60.0	0.168
07/27/23	10:00	61.8	0.169
07/27/23	11:00	61.7	0.169
07/27/23	12:00	61.6	0.169
07/27/23	13:00	61.6	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/27/23	14:00	62.5	0.170
07/27/23	15:00	63.4	0.172
07/27/23	16:00	63.8	0.172
07/27/23	17:00	64.4	0.172
07/27/23	18:00	64.9	0.173
07/27/23	19:00	65.4	0.173
07/27/23	20:00	67.6	0.176
07/27/23	21:00	68.0	0.174
07/27/23	22:00	67.8	0.173
07/27/23	23:00	67.9	0.173
07/28/23	00:00	68.0	0.173
07/28/23	01:00	68.0	0.173
07/28/23	02:00	68.0	0.173
07/28/23	03:00	68.0	0.173
07/28/23	04:00	68.0	0.173
07/28/23	05:00	67.9	0.173
07/28/23	06:00	67.9	0.173
07/28/23	07:00	67.9	0.173
07/28/23	08:00	67.9	0.174
07/28/23	09:00	67.6	0.173
07/28/23	10:00	67.5	0.173
07/28/23	11:00	67.5	0.173
07/28/23	12:00	67.9	0.174
07/28/23	13:00	67.4	0.173
07/28/23	14:00	67.2	0.173
07/28/23	15:00	67.1	0.173
07/28/23	16:00	67.2	0.173
07/28/23	17:00	67.4	0.173
07/28/23	18:00	67.5	0.174
07/28/23	19:00	67.9	0.174
07/28/23	20:00	68.2	0.175
07/28/23	21:00	69.2	0.177
07/28/23	22:00	69.4	0.178
07/28/23	23:00	69.2	0.177
07/29/23	00:00	69.2	0.177
07/29/23	01:00	69.2	0.176
07/29/23	02:00	69.1	0.176
07/29/23	03:00	69.2	0.176
07/29/23	04:00	69.2	0.176
07/29/23	05:00	69.2	0.176
07/29/23	06:00	69.2	0.176
07/29/23	07:00	69.2	0.176
07/29/23	08:00	69.3	0.177
07/29/23	09:00	68.9	0.179
07/29/23	10:00	66.0	0.178
07/29/23	11:00	63.0	0.176
07/29/23	12:00	59.8	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/29/23	13:00	57.4	0.174
07/29/23	14:00	54.5	0.173
07/29/23	15:00	52.2	0.170
07/29/23	16:00	52.4	0.170
07/29/23	17:00	52.1	0.170
07/29/23	18:00	50.1	0.168
07/29/23	19:00	47.0	0.166
07/29/23	20:00	43.7	0.165
07/29/23	21:00	42.3	0.164
07/29/23	22:00	42.3	0.164
07/29/23	23:00	42.4	0.165
07/30/23	00:00	42.4	0.165
07/30/23	01:00	42.4	0.165
07/30/23	02:00	42.3	0.165
07/30/23	03:00	42.3	0.165
07/30/23	04:00	42.3	0.165
07/30/23	05:00	42.4	0.166
07/30/23	06:00	42.4	0.166
07/30/23	07:00	42.4	0.166
07/30/23	08:00	42.4	0.166
07/30/23	09:00	42.5	0.167
07/30/23	10:00	42.6	0.167
07/30/23	11:00	42.7	0.168
07/30/23	12:00	42.7	0.169
07/30/23	13:00	42.7	0.169
07/30/23	14:00	42.5	0.169
07/30/23	15:00	41.9	0.170
07/30/23	16:00	39.0	0.170
07/30/23	17:00	36.1	0.169
07/30/23	18:00	35.2	0.170
07/30/23	19:00	35.2	0.170
07/30/23	20:00	35.2	0.170
07/30/23	21:00	35.2	0.170
07/30/23	22:00	35.2	0.170
07/30/23	23:00	35.2	0.171
07/31/23	00:00	35.1	0.171
07/31/23	01:00	35.1	0.171
07/31/23	02:00	35.2	0.172
07/31/23	03:00	35.1	0.171
07/31/23	04:00	35.1	0.171
07/31/23	05:00	35.0	0.171
07/31/23	06:00	35.1	0.171
07/31/23	07:00	35.0	0.172
07/31/23	08:00	35.0	0.171
07/31/23	09:00	34.8	0.171
07/31/23	10:00	34.7	0.170
07/31/23	11:00	34.5	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
07/31/23	12:00	34.6	0.170
07/31/23	13:00	34.7	0.170
07/31/23	14:00	34.7	0.170
07/31/23	15:00	34.9	0.168
07/31/23	16:00	37.6	0.168
07/31/23	17:00	40.6	0.169
07/31/23	18:00	41.8	0.169
07/31/23	19:00	41.9	0.169
07/31/23	20:00	41.9	0.169
07/31/23	21:00	42.0	0.169
07/31/23	22:00	42.0	0.169
07/31/23	23:00	42.1	0.170
08/01/23	00:00	42.1	0.170
08/01/23	01:00	42.2	0.170
08/01/23	02:00	42.1	0.169
08/01/23	03:00	42.1	0.169
08/01/23	04:00	42.1	0.169
08/01/23	05:00	42.1	0.169
08/01/23	06:00	42.1	0.168
08/01/23	07:00	42.1	0.168
08/01/23	08:00	42.1	0.168
08/01/23	09:00	42.2	0.168
08/01/23	10:00	42.2	0.168
08/01/23	11:00	42.3	0.168
08/01/23	12:00	42.3	0.168
08/01/23	13:00	42.2	0.168
08/01/23	14:00	42.3	0.165
08/01/23	15:00	45.2	0.168
08/01/23	16:00	45.3	0.168
08/01/23	17:00	45.3	0.169
08/01/23	18:00	45.0	0.168
08/01/23	19:00	44.8	0.167
08/01/23	20:00	44.8	0.167
08/01/23	21:00	44.6	0.166
08/01/23	22:00	44.5	0.165
08/01/23	23:00	44.3	0.165
08/02/23	00:00	44.2	0.164
08/02/23	01:00	44.0	0.163
08/02/23	02:00	44.0	0.163
08/02/23	03:00	44.0	0.163
08/02/23	04:00	44.0	0.163
08/02/23	05:00	43.9	0.163
08/02/23	06:00	43.8	0.163
08/02/23	07:00	43.7	0.162
08/02/23	08:00	43.7	0.162
08/02/23	09:00	43.7	0.162
08/02/23	10:00	43.7	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/02/23	11:00	43.7	0.162
08/02/23	12:00	43.7	0.162
08/02/23	13:00	43.7	0.162
08/02/23	14:00	43.8	0.162
08/02/23	15:00	43.7	0.162
08/02/23	16:00	43.8	0.162
08/02/23	17:00	43.8	0.162
08/02/23	18:00	43.6	0.162
08/02/23	19:00	43.4	0.161
08/02/23	20:00	43.5	0.162
08/02/23	21:00	43.5	0.162
08/02/23	22:00	43.5	0.162
08/02/23	23:00	43.6	0.162
08/03/23	00:00	43.6	0.162
08/03/23	01:00	43.7	0.163
08/03/23	02:00	43.6	0.162
08/03/23	03:00	43.6	0.162
08/03/23	04:00	43.5	0.162
08/03/23	05:00	43.6	0.162
08/03/23	06:00	43.8	0.163
08/03/23	07:00	43.9	0.164
08/03/23	08:00	44.0	0.164
08/03/23	09:00	44.0	0.164
08/03/23	10:00	44.0	0.164
08/03/23	11:00	44.0	0.164
08/03/23	12:00	44.0	0.164
08/03/23	13:00	44.1	0.164
08/03/23	14:00	44.0	0.164
08/03/23	15:00	43.8	0.164
08/03/23	16:00	43.9	0.165
08/03/23	17:00	44.0	0.165
08/03/23	18:00	44.6	0.166
08/03/23	19:00	44.6	0.167
08/03/23	20:00	44.6	0.167
08/03/23	21:00	44.7	0.167
08/03/23	22:00	44.8	0.167
08/03/23	23:00	44.8	0.168
08/04/23	00:00	44.8	0.168
08/04/23	01:00	44.7	0.167
08/04/23	02:00	44.7	0.167
08/04/23	03:00	44.7	0.168
08/04/23	04:00	44.7	0.167
08/04/23	05:00	44.5	0.167
08/04/23	06:00	44.3	0.166
08/04/23	07:00	44.2	0.166
08/04/23	08:00	44.1	0.166
08/04/23	09:00	44.0	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/04/23	10:00	43.9	0.166
08/04/23	11:00	44.0	0.166
08/04/23	12:00	43.9	0.166
08/04/23	13:00	44.6	0.165
08/04/23	14:00	47.5	0.169
08/04/23	15:00	48.3	0.171
08/04/23	16:00	48.5	0.171
08/04/23	17:00	48.7	0.172
08/04/23	18:00	48.2	0.171
08/04/23	19:00	48.2	0.171
08/04/23	20:00	48.1	0.171
08/04/23	21:00	48.2	0.172
08/04/23	22:00	48.2	0.172
08/04/23	23:00	48.2	0.172
08/05/23	00:00	48.3	0.173
08/05/23	01:00	48.4	0.173
08/05/23	02:00	48.4	0.174
08/05/23	03:00	48.5	0.174
08/05/23	04:00	48.6	0.174
08/05/23	05:00	48.6	0.174
08/05/23	06:00	48.5	0.174
08/05/23	07:00	48.4	0.174
08/05/23	08:00	48.4	0.174
08/05/23	09:00	48.4	0.173
08/05/23	10:00	48.4	0.173
08/05/23	11:00	48.2	0.173
08/05/23	12:00	48.2	0.173
08/05/23	13:00	47.4	0.173
08/05/23	14:00	44.2	0.172
08/05/23	15:00	41.6	0.169
08/05/23	16:00	41.7	0.170
08/05/23	17:00	39.6	0.167
08/05/23	18:00	38.9	0.169
08/05/23	19:00	39.0	0.170
08/05/23	20:00	39.0	0.169
08/05/23	21:00	39.0	0.170
08/05/23	22:00	38.9	0.169
08/05/23	23:00	38.8	0.169
08/06/23	00:00	38.8	0.169
08/06/23	01:00	38.8	0.169
08/06/23	02:00	38.9	0.170
08/06/23	03:00	38.9	0.170
08/06/23	04:00	38.8	0.170
08/06/23	05:00	38.7	0.169
08/06/23	06:00	38.8	0.170
08/06/23	07:00	39.0	0.171
08/06/23	08:00	39.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/06/23	09:00	39.0	0.172
08/06/23	10:00	39.0	0.172
08/06/23	11:00	39.0	0.172
08/06/23	12:00	39.0	0.172
08/06/23	13:00	39.1	0.172
08/06/23	14:00	39.1	0.172
08/06/23	15:00	38.2	0.171
08/06/23	16:00	34.8	0.169
08/06/23	17:00	33.7	0.171
08/06/23	18:00	33.7	0.170
08/06/23	19:00	33.7	0.170
08/06/23	20:00	33.7	0.170
08/06/23	21:00	33.7	0.170
08/06/23	22:00	33.7	0.170
08/06/23	23:00	33.7	0.170
08/07/23	00:00	33.7	0.170
08/07/23	01:00	33.7	0.170
08/07/23	02:00	33.7	0.170
08/07/23	03:00	33.7	0.170
08/07/23	04:00	33.7	0.170
08/07/23	05:00	33.7	0.170
08/07/23	06:00	33.7	0.170
08/07/23	07:00	33.7	0.170
08/07/23	08:00	33.7	0.170
08/07/23	09:00	33.7	0.170
08/07/23	10:00	33.7	0.170
08/07/23	11:00	33.7	0.170
08/07/23	12:00	33.7	0.170
08/07/23	13:00	33.7	0.170
08/07/23	14:00	33.7	0.170
08/07/23	15:00	33.7	0.170
08/07/23	16:00	33.7	0.170
08/07/23	17:00	33.7	0.170
08/07/23	18:00	33.7	0.170
08/07/23	19:00	33.7	0.170
08/07/23	20:00	33.7	0.170
08/07/23	21:00	33.7	0.170
08/07/23	22:00	33.7	0.170
08/07/23	23:00	33.7	0.170
08/08/23	00:00	33.7	0.170
08/08/23	01:00	33.7	0.170
08/08/23	02:00	33.7	0.170
08/08/23	03:00	33.7	0.170
08/08/23	04:00	33.7	0.170
08/08/23	05:00	33.7	0.170
08/08/23	06:00	33.7	0.170
08/08/23	07:00	33.7	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/08/23	08:00	33.7	0.170
08/08/23	09:00	33.7	0.170
08/08/23	10:00	33.7	0.170
08/08/23	11:00	33.7	0.170
08/08/23	12:00	33.7	0.170
08/08/23	13:00	33.7	0.170
08/08/23	14:00	33.7	0.170
08/08/23	15:00	33.7	0.170
08/08/23	16:00	33.7	0.170
08/08/23	17:00	33.7	0.170
08/08/23	18:00	33.7	0.170
08/08/23	19:00	33.7	0.170
08/08/23	20:00	33.7	0.170
08/08/23	21:00	33.7	0.170
08/08/23	22:00	33.7	0.170
08/08/23	23:00	33.7	0.170
08/09/23	00:00	33.7	0.170
08/09/23	01:00	33.7	0.170
08/09/23	02:00	33.7	0.170
08/09/23	03:00	32.3	0.170
08/09/23	04:00	31.0	0.170
08/09/23	05:00	29.6	0.170
08/09/23	06:00	28.4	0.170
08/09/23	07:00	27.2	0.170
08/09/23	08:00	26.0	0.170I
08/09/23	09:00	24.7	0.170I
08/09/23	10:00	23.3	0.169I
08/09/23	11:00	22.6	0.170I
08/09/23	12:00	22.1	0.170I
08/09/23	13:00	22.0	0.167I
08/09/23	14:00	22.3	0.168I
08/09/23	15:00	22.4	0.167I
08/09/23	16:00	22.6	0.168I
08/09/23	17:00	22.8	0.169I
08/09/23	18:00	22.9	0.169I
08/09/23	19:00	23.0	0.169I
08/09/23	20:00	23.0	0.168I
08/09/23	21:00	22.8	0.167I
08/09/23	22:00	22.8	0.167I
08/09/23	23:00	22.8	0.167I
08/10/23	00:00	22.8	0.167I
08/10/23	01:00	22.7	0.165I
08/10/23	02:00	22.4	0.165I
08/10/23	03:00	23.8	0.165I
08/10/23	04:00	25.2	0.165I
08/10/23	05:00	26.5	0.165I
08/10/23	06:00	27.8	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/10/23	07:00	29.1	0.165
08/10/23	08:00	30.4	0.165
08/10/23	09:00	31.6	0.165
08/10/23	10:00	32.9	0.165
08/10/23	11:00	33.6	0.165
08/10/23	12:00	34.1	0.164
08/10/23	13:00	34.2	0.165
08/10/23	14:00	34.0	0.165
08/10/23	15:00	34.4	0.163
08/10/23	16:00	36.8	0.162
08/10/23	17:00	37.2	0.160
08/10/23	18:00	37.2	0.160
08/10/23	19:00	37.3	0.161
08/10/23	20:00	37.4	0.162
08/10/23	21:00	37.6	0.163
08/10/23	22:00	37.7	0.164
08/10/23	23:00	37.7	0.164
08/11/23	00:00	37.7	0.164
08/11/23	01:00	37.8	0.164
08/11/23	02:00	37.9	0.165
08/11/23	03:00	37.9	0.165
08/11/23	04:00	37.9	0.165
08/11/23	05:00	37.9	0.165
08/11/23	06:00	37.8	0.165
08/11/23	07:00	37.7	0.165
08/11/23	08:00	37.6	0.164
08/11/23	09:00	37.5	0.164
08/11/23	10:00	37.5	0.164
08/11/23	11:00	37.5	0.164
08/11/23	12:00	37.6	0.164
08/11/23	13:00	37.4	0.164
08/11/23	14:00	38.1	0.164
08/11/23	15:00	39.3	0.166
08/11/23	16:00	39.5	0.166
08/11/23	17:00	41.3	0.168
08/11/23	18:00	41.6	0.166
08/11/23	19:00	41.6	0.165
08/11/23	20:00	41.6	0.165
08/11/23	21:00	41.5	0.164
08/11/23	22:00	41.4	0.164
08/11/23	23:00	41.5	0.164
08/12/23	00:00	41.5	0.163
08/12/23	01:00	41.2	0.162
08/12/23	02:00	41.3	0.162
08/12/23	03:00	41.3	0.161
08/12/23	04:00	41.3	0.161
08/12/23	05:00	41.2	0.160

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/12/23	06:00	41.3	0.160
08/12/23	07:00	41.5	0.160
08/12/23	08:00	41.6	0.160
08/12/23	09:00	41.6	0.160
08/12/23	10:00	41.7	0.160
08/12/23	11:00	41.7	0.160
08/12/23	12:00	41.9	0.160
08/12/23	13:00	42.2	0.162
08/12/23	14:00	41.7	0.161
08/12/23	15:00	40.9	0.160
08/12/23	16:00	41.3	0.161
08/12/23	17:00	41.8	0.162
08/12/23	18:00	41.9	0.162
08/12/23	19:00	41.8	0.161
08/12/23	20:00	41.7	0.161
08/12/23	21:00	41.7	0.160
08/12/23	22:00	41.6	0.160
08/12/23	23:00	41.5	0.160
08/13/23	00:00	41.3	0.159
08/13/23	01:00	41.4	0.160
08/13/23	02:00	41.3	0.159
08/13/23	03:00	41.3	0.160
08/13/23	04:00	41.3	0.160
08/13/23	05:00	41.3	0.160
08/13/23	06:00	41.2	0.160
08/13/23	07:00	41.0	0.160
08/13/23	08:00	40.9	0.160
08/13/23	09:00	40.9	0.160
08/13/23	10:00	40.7	0.160
08/13/23	11:00	40.6	0.160
08/13/23	12:00	40.3	0.160
08/13/23	13:00	40.1	0.158
08/13/23	14:00	39.9	0.158
08/13/23	15:00	38.7	0.158
08/13/23	16:00	35.5	0.156
08/13/23	17:00	32.4	0.154
08/13/23	18:00	31.6	0.155
08/13/23	19:00	31.6	0.155
08/13/23	20:00	31.6	0.155
08/13/23	21:00	31.6	0.155
08/13/23	22:00	31.5	0.155
08/13/23	23:00	31.5	0.155
08/14/23	00:00	31.6	0.155
08/14/23	01:00	31.8	0.155
08/14/23	02:00	31.8	0.155
08/14/23	03:00	31.8	0.155
08/14/23	04:00	31.9	0.155

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/14/23	05:00	31.9	0.155
08/14/23	06:00	31.9	0.156
08/14/23	07:00	31.9	0.155
08/14/23	08:00	31.9	0.154
08/14/23	09:00	31.9	0.154
08/14/23	10:00	31.9	0.153
08/14/23	11:00	32.0	0.154
08/14/23	12:00	32.3	0.155
08/14/23	13:00	32.4	0.156
08/14/23	14:00	32.8	0.157
08/14/23	15:00	33.2	0.159
08/14/23	16:00	33.3	0.159
08/14/23	17:00	33.4	0.160
08/14/23	18:00	33.5	0.160
08/14/23	19:00	33.6	0.161
08/14/23	20:00	33.6	0.161
08/14/23	21:00	33.6	0.161
08/14/23	22:00	33.7	0.161
08/14/23	23:00	33.7	0.161
08/15/23	00:00	33.6	0.161
08/15/23	01:00	33.6	0.161
08/15/23	02:00	33.6	0.160
08/15/23	03:00	33.5	0.160
08/15/23	04:00	33.4	0.159
08/15/23	05:00	33.4	0.159
08/15/23	06:00	33.4	0.159
08/15/23	07:00	33.5	0.159
08/15/23	08:00	33.7	0.160
08/15/23	09:00	33.8	0.161
08/15/23	10:00	33.9	0.162
08/15/23	11:00	33.8	0.161
08/15/23	12:00	33.7	0.160
08/15/23	13:00	33.7	0.159
08/15/23	14:00	33.9	0.158
08/15/23	15:00	34.7	0.156
08/15/23	16:00	35.2	0.156
08/15/23	17:00	35.3	0.156
08/15/23	18:00	35.3	0.155
08/15/23	19:00	35.2	0.155
08/15/23	20:00	35.4	0.155
08/15/23	21:00	35.6	0.156
08/15/23	22:00	35.7	0.156
08/15/23	23:00	35.8	0.155
08/16/23	00:00	36.0	0.156
08/16/23	01:00	36.3	0.157
08/16/23	02:00	36.6	0.158
08/16/23	03:00	36.7	0.159

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/16/23	04:00	36.9	0.159
08/16/23	05:00	36.9	0.160
08/16/23	06:00	37.0	0.160
08/16/23	07:00	37.1	0.160
08/16/23	08:00	37.3	0.160
08/16/23	09:00	39.3	0.160
08/16/23	10:00	41.8	0.160
08/16/23	11:00	44.4	0.161
08/16/23	12:00	47.0	0.162
08/16/23	13:00	49.8	0.164
08/16/23	14:00	52.2	0.165
08/16/23	15:00	54.0	0.167
08/16/23	16:00	56.1	0.168
08/16/23	17:00	57.3	0.168
08/16/23	18:00	57.3	0.168
08/16/23	19:00	57.5	0.170
08/16/23	20:00	57.5	0.170
08/16/23	21:00	57.4	0.169
08/16/23	22:00	57.4	0.170
08/16/23	23:00	57.2	0.169
08/17/23	00:00	57.1	0.169
08/17/23	01:00	56.7	0.167
08/17/23	02:00	56.4	0.166
08/17/23	03:00	56.3	0.166
08/17/23	04:00	56.5	0.166
08/17/23	05:00	58.8	0.167
08/17/23	06:00	61.6	0.168
08/17/23	07:00	64.7	0.169
08/17/23	08:00	67.4	0.171
08/17/23	09:00	68.6	0.172
08/17/23	10:00	69.3	0.173
08/17/23	11:00	69.9	0.174
08/17/23	12:00	69.8	0.175
08/17/23	13:00	69.5	0.174
08/17/23	14:00	67.4	0.172
08/17/23	15:00	64.6	0.171
08/17/23	16:00	62.0	0.171
08/17/23	17:00	60.9	0.171
08/17/23	18:00	61.0	0.172
08/17/23	19:00	61.0	0.172
08/17/23	20:00	61.1	0.172
08/17/23	21:00	61.2	0.173
08/17/23	22:00	61.2	0.173
08/17/23	23:00	61.4	0.174
08/18/23	00:00	61.6	0.175
08/18/23	01:00	61.7	0.176
08/18/23	02:00	61.8	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/18/23	03:00	61.9	0.177
08/18/23	04:00	62.4	0.177
08/18/23	05:00	63.0	0.177
08/18/23	06:00	63.3	0.178
08/18/23	07:00	63.5	0.178
08/18/23	08:00	63.5	0.178
08/18/23	09:00	63.4	0.178
08/18/23	10:00	63.2	0.178
08/18/23	11:00	60.3	0.175
08/18/23	12:00	57.6	0.173
08/18/23	13:00	55.1	0.173
08/18/23	14:00	54.5	0.173
08/18/23	15:00	54.5	0.173
08/18/23	16:00	54.4	0.173
08/18/23	17:00	54.3	0.173
08/18/23	18:00	54.3	0.173
08/18/23	19:00	54.1	0.173
08/18/23	20:00	53.9	0.172
08/18/23	21:00	53.7	0.171
08/18/23	22:00	53.5	0.170
08/18/23	23:00	53.3	0.169
08/19/23	00:00	53.1	0.169
08/19/23	01:00	52.9	0.168
08/19/23	02:00	52.8	0.167
08/19/23	03:00	52.8	0.167
08/19/23	04:00	51.9	0.167
08/19/23	05:00	48.8	0.166
08/19/23	06:00	45.7	0.164
08/19/23	07:00	42.2	0.162
08/19/23	08:00	39.1	0.161
08/19/23	09:00	35.9	0.159
08/19/23	10:00	32.8	0.157
08/19/23	11:00	32.4	0.158
08/19/23	12:00	32.4	0.158
08/19/23	13:00	32.5	0.158
08/19/23	14:00	32.4	0.158
08/19/23	15:00	32.1	0.157
08/19/23	16:00	31.9	0.156
08/19/23	17:00	31.8	0.156
08/19/23	18:00	31.7	0.155
08/19/23	19:00	31.5	0.155
08/19/23	20:00	31.4	0.154
08/19/23	21:00	31.3	0.154
08/19/23	22:00	31.3	0.154
08/19/23	23:00	31.3	0.155
08/20/23	00:00	31.3	0.156
08/20/23	01:00	31.3	0.156

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/20/23	02:00	31.3	0.156
08/20/23	03:00	31.2	0.156
08/20/23	04:00	31.2	0.156
08/20/23	05:00	31.2	0.156
08/20/23	06:00	31.2	0.156
08/20/23	07:00	31.1	0.156
08/20/23	08:00	31.0	0.155
08/20/23	09:00	30.9	0.155
08/20/23	10:00	30.8	0.154
08/20/23	11:00	30.8	0.154
08/20/23	12:00	30.9	0.154
08/20/23	13:00	30.6	0.153
08/20/23	14:00	30.8	0.151
08/20/23	15:00	32.4	0.150
08/20/23	16:00	34.1	0.150
08/20/23	17:00	35.7	0.150
08/20/23	18:00	37.4	0.150
08/20/23	19:00	37.5	0.148
08/20/23	20:00	37.5	0.147
08/20/23	21:00	37.6	0.147
08/20/23	22:00	37.7	0.147
08/20/23	23:00	37.7	0.146
08/21/23	00:00	37.7	0.145
08/21/23	01:00	37.7	0.145
08/21/23	02:00	37.9	0.146
08/21/23	03:00	38.1	0.146
08/21/23	04:00	38.3	0.147
08/21/23	05:00	38.4	0.147
08/21/23	06:00	39.2	0.146
08/21/23	07:00	40.7	0.146
08/21/23	08:00	42.0	0.146
08/21/23	09:00	42.9	0.146
08/21/23	10:00	43.7	0.146
08/21/23	11:00	44.4	0.146
08/21/23	12:00	45.2	0.145
08/21/23	13:00	46.0	0.145
08/21/23	14:00	46.5	0.146
08/21/23	15:00	47.1	0.148
08/21/23	16:00	48.2	0.150
08/21/23	17:00	49.1	0.151
08/21/23	18:00	49.9	0.152
08/21/23	19:00	52.7	0.156
08/21/23	20:00	53.6	0.155
08/21/23	21:00	53.5	0.155
08/21/23	22:00	53.7	0.155
08/21/23	23:00	53.7	0.156
08/22/23	00:00	53.9	0.157

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/22/23	01:00	53.9	0.157
08/22/23	02:00	53.8	0.157
08/22/23	03:00	53.6	0.156
08/22/23	04:00	53.5	0.156
08/22/23	05:00	53.4	0.156
08/22/23	06:00	52.7	0.157
08/22/23	07:00	51.2	0.157
08/22/23	08:00	50.0	0.157
08/22/23	09:00	49.3	0.158
08/22/23	10:00	48.5	0.158
08/22/23	11:00	48.0	0.159
08/22/23	12:00	47.3	0.160
08/22/23	13:00	46.6	0.161
08/22/23	14:00	46.0	0.161
08/22/23	15:00	43.9	0.161
08/22/23	16:00	41.1	0.159
08/22/23	17:00	40.2	0.159
08/22/23	18:00	40.6	0.159
08/22/23	19:00	39.1	0.158
08/22/23	20:00	38.4	0.161
08/22/23	21:00	38.6	0.162
08/22/23	22:00	38.5	0.162
08/22/23	23:00	38.4	0.161
08/23/23	00:00	38.3	0.161
08/23/23	01:00	38.3	0.161
08/23/23	02:00	38.4	0.161
08/23/23	03:00	38.4	0.161
08/23/23	04:00	38.4	0.161
08/23/23	05:00	38.4	0.161
08/23/23	06:00	38.4	0.162
08/23/23	07:00	38.5	0.162
08/23/23	08:00	38.6	0.163
08/23/23	09:00	38.7	0.164
08/23/23	10:00	38.8	0.164
08/23/23	11:00	40.1	0.164
08/23/23	12:00	42.5	0.163
08/23/23	13:00	45.6	0.165
08/23/23	14:00	47.9	0.166
08/23/23	15:00	50.2	0.168
08/23/23	16:00	52.8	0.169
08/23/23	17:00	53.8	0.170
08/23/23	18:00	53.4	0.170
08/23/23	19:00	54.5	0.171
08/23/23	20:00	56.9	0.171
08/23/23	21:00	57.5	0.169
08/23/23	22:00	57.5	0.169
08/23/23	23:00	57.5	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/24/23	00:00	57.7	0.169
08/24/23	01:00	57.7	0.169
08/24/23	02:00	57.6	0.168
08/24/23	03:00	57.7	0.168
08/24/23	04:00	57.8	0.168
08/24/23	05:00	57.9	0.167
08/24/23	06:00	58.2	0.168
08/24/23	07:00	58.3	0.168
08/24/23	08:00	59.1	0.168
08/24/23	09:00	62.0	0.169
08/24/23	10:00	64.9	0.171
08/24/23	11:00	66.2	0.172
08/24/23	12:00	66.1	0.173
08/24/23	13:00	65.4	0.172
08/24/23	14:00	65.6	0.172
08/24/23	15:00	65.5	0.172
08/24/23	16:00	65.1	0.171
08/24/23	17:00	64.7	0.171
08/24/23	18:00	64.4	0.170
08/24/23	19:00	63.9	0.170
08/24/23	20:00	63.3	0.169
08/24/23	21:00	64.0	0.170
08/24/23	22:00	64.4	0.169
08/24/23	23:00	64.6	0.170
08/25/23	00:00	64.5	0.169
08/25/23	01:00	64.6	0.169
08/25/23	02:00	64.6	0.170
08/25/23	03:00	64.6	0.170
08/25/23	04:00	64.7	0.170
08/25/23	05:00	64.6	0.170
08/25/23	06:00	64.5	0.170
08/25/23	07:00	64.4	0.170
08/25/23	08:00	63.6	0.169
08/25/23	09:00	60.6	0.168
08/25/23	10:00	57.6	0.166
08/25/23	11:00	56.0	0.164
08/25/23	12:00	56.1	0.163
08/25/23	13:00	56.2	0.163
08/25/23	14:00	56.1	0.162
08/25/23	15:00	56.4	0.163
08/25/23	16:00	57.2	0.163
08/25/23	17:00	57.3	0.163
08/25/23	18:00	57.7	0.163
08/25/23	19:00	56.2	0.161
08/25/23	20:00	54.1	0.160
08/25/23	21:00	53.0	0.161
08/25/23	22:00	52.7	0.162

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/25/23	23:00	52.6	0.162
08/26/23	00:00	52.6	0.162
08/26/23	01:00	52.5	0.162
08/26/23	02:00	52.6	0.162
08/26/23	03:00	52.6	0.162
08/26/23	04:00	52.5	0.162
08/26/23	05:00	52.6	0.162
08/26/23	06:00	52.4	0.162
08/26/23	07:00	52.4	0.162
08/26/23	08:00	52.5	0.163
08/26/23	09:00	52.6	0.164
08/26/23	10:00	52.7	0.165
08/26/23	11:00	51.9	0.166
08/26/23	12:00	49.5	0.166
08/26/23	13:00	47.2	0.166
08/26/23	14:00	44.8	0.166
08/26/23	15:00	42.2	0.164
08/26/23	16:00	39.2	0.163
08/26/23	17:00	36.9	0.162
08/26/23	18:00	34.6	0.162
08/26/23	19:00	34.3	0.164
08/26/23	20:00	34.5	0.165
08/26/23	21:00	34.4	0.165
08/26/23	22:00	34.4	0.165
08/26/23	23:00	34.4	0.165
08/27/23	00:00	34.4	0.166
08/27/23	01:00	34.3	0.166
08/27/23	02:00	34.1	0.165
08/27/23	03:00	34.1	0.165
08/27/23	04:00	34.1	0.166
08/27/23	05:00	34.1	0.166
08/27/23	06:00	34.1	0.166
08/27/23	07:00	34.1	0.167
08/27/23	08:00	34.2	0.167
08/27/23	09:00	34.2	0.167
08/27/23	10:00	34.3	0.167
08/27/23	11:00	34.4	0.168
08/27/23	12:00	34.4	0.170
08/27/23	13:00	34.3	0.169
08/27/23	14:00	34.3	0.170
08/27/23	15:00	34.5	0.172
08/27/23	16:00	34.7	0.173
08/27/23	17:00	34.8	0.174
08/27/23	18:00	34.6	0.174
08/27/23	19:00	34.5	0.174
08/27/23	20:00	34.4	0.173
08/27/23	21:00	34.2	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/27/23	22:00	34.2	0.173
08/27/23	23:00	34.1	0.172
08/28/23	00:00	34.0	0.172
08/28/23	01:00	34.2	0.173
08/28/23	02:00	34.1	0.173
08/28/23	03:00	34.0	0.173
08/28/23	04:00	34.0	0.173
08/28/23	05:00	33.9	0.172
08/28/23	06:00	33.7	0.171
08/28/23	07:00	33.5	0.171
08/28/23	08:00	33.2	0.169
08/28/23	09:00	33.1	0.168
08/28/23	10:00	32.9	0.168
08/28/23	11:00	32.9	0.167
08/28/23	12:00	32.8	0.166
08/28/23	13:00	32.9	0.167
08/28/23	14:00	32.9	0.166
08/28/23	15:00	32.7	0.165
08/28/23	16:00	32.7	0.164
08/28/23	17:00	32.6	0.163
08/28/23	18:00	32.6	0.163
08/28/23	19:00	32.6	0.162
08/28/23	20:00	32.7	0.162
08/28/23	21:00	32.8	0.163
08/28/23	22:00	32.8	0.163
08/28/23	23:00	32.8	0.162
08/29/23	00:00	32.7	0.162
08/29/23	01:00	32.6	0.161
08/29/23	02:00	32.6	0.161
08/29/23	03:00	32.6	0.161
08/29/23	04:00	32.6	0.161
08/29/23	05:00	32.7	0.161
08/29/23	06:00	32.7	0.162
08/29/23	07:00	32.8	0.162
08/29/23	08:00	33.0	0.163
08/29/23	09:00	33.1	0.164
08/29/23	10:00	33.1	0.164
08/29/23	11:00	33.0	0.163
08/29/23	12:00	33.0	0.163
08/29/23	13:00	32.9	0.162
08/29/23	14:00	32.9	0.163
08/29/23	15:00	33.0	0.163
08/29/23	16:00	33.1	0.163
08/29/23	17:00	33.2	0.164
08/29/23	18:00	33.3	0.164
08/29/23	19:00	33.3	0.164
08/29/23	20:00	33.3	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/29/23	21:00	33.4	0.164
08/29/23	22:00	33.4	0.164
08/29/23	23:00	33.4	0.164
08/30/23	00:00	33.5	0.164
08/30/23	01:00	33.5	0.164
08/30/23	02:00	33.6	0.165
08/30/23	03:00	33.6	0.165
08/30/23	04:00	33.6	0.164
08/30/23	05:00	33.5	0.163
08/30/23	06:00	33.4	0.163
08/30/23	07:00	33.5	0.163
08/30/23	08:00	33.5	0.163
08/30/23	09:00	33.5	0.163
08/30/23	10:00	33.6	0.163
08/30/23	11:00	33.7	0.163
08/30/23	12:00	33.9	0.164
08/30/23	13:00	34.0	0.164
08/30/23	14:00	34.0	0.164
08/30/23	15:00	34.0	0.164
08/30/23	16:00	33.9	0.163
08/30/23	17:00	33.8	0.163
08/30/23	18:00	33.7	0.163
08/30/23	19:00	33.7	0.162
08/30/23	20:00	33.6	0.162
08/30/23	21:00	33.5	0.162
08/30/23	22:00	33.5	0.161
08/30/23	23:00	33.5	0.162
08/31/23	00:00	33.6	0.162
08/31/23	01:00	33.6	0.162
08/31/23	02:00	33.5	0.162
08/31/23	03:00	33.6	0.162
08/31/23	04:00	33.7	0.163
08/31/23	05:00	33.8	0.164
08/31/23	06:00	33.8	0.164
08/31/23	07:00	33.9	0.165
08/31/23	08:00	33.9	0.165
08/31/23	09:00	33.8	0.165
08/31/23	10:00	33.7	0.164
08/31/23	11:00	33.5	0.164
08/31/23	12:00	33.4	0.163
08/31/23	13:00	33.3	0.163
08/31/23	14:00	33.4	0.163
08/31/23	15:00	33.4	0.164
08/31/23	16:00	33.4	0.164
08/31/23	17:00	33.3	0.163
08/31/23	18:00	33.3	0.163
08/31/23	19:00	33.4	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
08/31/23	20:00	33.5	0.164
08/31/23	21:00	33.6	0.164
08/31/23	22:00	33.6	0.164
08/31/23	23:00	33.6	0.164
09/01/23	00:00	33.5	0.164
09/01/23	01:00	33.5	0.165
09/01/23	02:00	33.6	0.165
09/01/23	03:00	33.7	0.165
09/01/23	04:00	33.7	0.166
09/01/23	05:00	33.9	0.166
09/01/23	06:00	34.0	0.167
09/01/23	07:00	34.0	0.167
09/01/23	08:00	34.0	0.168
09/01/23	09:00	34.1	0.168
09/01/23	10:00	34.2	0.168
09/01/23	11:00	34.3	0.168
09/01/23	12:00	34.4	0.169
09/01/23	13:00	34.5	0.169
09/01/23	14:00	34.3	0.169
09/01/23	15:00	34.3	0.169
09/01/23	16:00	34.4	0.170
09/01/23	17:00	34.5	0.171
09/01/23	18:00	34.6	0.171
09/01/23	19:00	34.6	0.171
09/01/23	20:00	34.7	0.171
09/01/23	21:00	34.7	0.172
09/01/23	22:00	34.7	0.172
09/01/23	23:00	34.8	0.172
09/02/23	00:00	34.8	0.172
09/02/23	01:00	34.8	0.172
09/02/23	02:00	34.7	0.172
09/02/23	03:00	34.7	0.172
09/02/23	04:00	34.6	0.171
09/02/23	05:00	34.4	0.171
09/02/23	06:00	34.4	0.170
09/02/23	07:00	34.3	0.170
09/02/23	08:00	34.2	0.169
09/02/23	09:00	34.2	0.169
09/02/23	10:00	34.1	0.168
09/02/23	11:00	33.9	0.167
09/02/23	12:00	33.8	0.166
09/02/23	13:00	33.6	0.165
09/02/23	14:00	33.7	0.165
09/02/23	15:00	33.8	0.165
09/02/23	16:00	33.8	0.164
09/02/23	17:00	33.8	0.163
09/02/23	18:00	33.9	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/02/23	19:00	34.1	0.163
09/02/23	20:00	34.4	0.163
09/02/23	21:00	34.6	0.163
09/02/23	22:00	34.7	0.163
09/02/23	23:00	34.9	0.164
09/03/23	00:00	35.1	0.165
09/03/23	01:00	35.2	0.165
09/03/23	02:00	35.3	0.166
09/03/23	03:00	35.4	0.166
09/03/23	04:00	35.6	0.166
09/03/23	05:00	35.7	0.167
09/03/23	06:00	35.8	0.167
09/03/23	07:00	35.8	0.167
09/03/23	08:00	35.9	0.168
09/03/23	09:00	36.0	0.169
09/03/23	10:00	36.2	0.170
09/03/23	11:00	36.3	0.171
09/03/23	12:00	36.5	0.172
09/03/23	13:00	36.7	0.173
09/03/23	14:00	36.8	0.173
09/03/23	15:00	38.0	0.174
09/03/23	16:00	40.5	0.175
09/03/23	17:00	43.0	0.177
09/03/23	18:00	45.4	0.178
09/03/23	19:00	46.4	0.178
09/03/23	20:00	46.1	0.178
09/03/23	21:00	45.9	0.178
09/03/23	22:00	45.8	0.178
09/03/23	23:00	45.6	0.178
09/04/23	00:00	45.5	0.177
09/04/23	01:00	45.4	0.176
09/04/23	02:00	45.3	0.175
09/04/23	03:00	45.2	0.175
09/04/23	04:00	45.1	0.174
09/04/23	05:00	45.0	0.173
09/04/23	06:00	44.8	0.172
09/04/23	07:00	44.8	0.172
09/04/23	08:00	44.7	0.172
09/04/23	09:00	44.6	0.171
09/04/23	10:00	44.5	0.170
09/04/23	11:00	44.5	0.170
09/04/23	12:00	45.6	0.170
09/04/23	13:00	48.0	0.171
09/04/23	14:00	50.3	0.171
09/04/23	15:00	51.2	0.172
09/04/23	16:00	51.1	0.172
09/04/23	17:00	51.0	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/04/23	18:00	49.9	0.171
09/04/23	19:00	48.6	0.168
09/04/23	20:00	48.7	0.167
09/04/23	21:00	48.7	0.167
09/04/23	22:00	48.8	0.168
09/04/23	23:00	48.8	0.168
09/05/23	00:00	48.8	0.168
09/05/23	01:00	48.8	0.168
09/05/23	02:00	49.0	0.169
09/05/23	03:00	49.2	0.170
09/05/23	04:00	49.4	0.171
09/05/23	05:00	49.4	0.172
09/05/23	06:00	49.6	0.172
09/05/23	07:00	49.7	0.173
09/05/23	08:00	49.9	0.173
09/05/23	09:00	50.7	0.173
09/05/23	10:00	53.3	0.174
09/05/23	11:00	55.8	0.176
09/05/23	12:00	57.2	0.177
09/05/23	13:00	57.1	0.177
09/05/23	14:00	57.2	0.178
09/05/23	15:00	57.5	0.179
09/05/23	16:00	57.7	0.179
09/05/23	17:00	58.0	0.180
09/05/23	18:00	59.2	0.181
09/05/23	19:00	61.7	0.184
09/05/23	20:00	64.1	0.186
09/05/23	21:00	65.0	0.186
09/05/23	22:00	65.0	0.185
09/05/23	23:00	65.0	0.185
09/06/23	00:00	64.9	0.184
09/06/23	01:00	64.8	0.184
09/06/23	02:00	64.6	0.183
09/06/23	03:00	64.6	0.183
09/06/23	04:00	64.5	0.182
09/06/23	05:00	64.4	0.181
09/06/23	06:00	64.2	0.180
09/06/23	07:00	64.0	0.179
09/06/23	08:00	63.8	0.178
09/06/23	09:00	62.9	0.178
09/06/23	10:00	60.2	0.176
09/06/23	11:00	57.6	0.174
09/06/23	12:00	55.0	0.171
09/06/23	13:00	52.5	0.170
09/06/23	14:00	50.0	0.167
09/06/23	15:00	49.7	0.166
09/06/23	16:00	50.0	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/06/23	17:00	50.6	0.166
09/06/23	18:00	50.5	0.166
09/06/23	19:00	48.1	0.164
09/06/23	20:00	45.5	0.162
09/06/23	21:00	44.6	0.163
09/06/23	22:00	44.7	0.163
09/06/23	23:00	44.7	0.164
09/07/23	00:00	44.9	0.164
09/07/23	01:00	44.9	0.165
09/07/23	02:00	45.1	0.165
09/07/23	03:00	45.0	0.165
09/07/23	04:00	45.0	0.166
09/07/23	05:00	45.2	0.167
09/07/23	06:00	45.4	0.168
09/07/23	07:00	45.5	0.169
09/07/23	08:00	45.6	0.169
09/07/23	09:00	45.8	0.170
09/07/23	10:00	45.9	0.171
09/07/23	11:00	46.0	0.171
09/07/23	12:00	46.2	0.173
09/07/23	13:00	46.3	0.173
09/07/23	14:00	46.4	0.175
09/07/23	15:00	44.3	0.175
09/07/23	16:00	41.5	0.174
09/07/23	17:00	38.5	0.173
09/07/23	18:00	36.1	0.172
09/07/23	19:00	36.1	0.174
09/07/23	20:00	36.1	0.174
09/07/23	21:00	36.1	0.174
09/07/23	22:00	36.0	0.174
09/07/23	23:00	36.0	0.173
09/08/23	00:00	36.0	0.173
09/08/23	01:00	36.1	0.174
09/08/23	02:00	36.1	0.174
09/08/23	03:00	36.1	0.174
09/08/23	04:00	36.1	0.174
09/08/23	05:00	36.1	0.174
09/08/23	06:00	36.1	0.174
09/08/23	07:00	36.1	0.174
09/08/23	08:00	36.2	0.175
09/08/23	09:00	36.3	0.175
09/08/23	10:00	36.3	0.176
09/08/23	11:00	36.4	0.176
09/08/23	12:00	36.5	0.177
09/08/23	13:00	36.6	0.178
09/08/23	14:00	36.6	0.178
09/08/23	15:00	36.4	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/08/23	16:00	36.4	0.177
09/08/23	17:00	36.3	0.177
09/08/23	18:00	36.3	0.177
09/08/23	19:00	36.4	0.178
09/08/23	20:00	36.4	0.178
09/08/23	21:00	36.4	0.179
09/08/23	22:00	36.5	0.179
09/08/23	23:00	36.4	0.179
09/09/23	00:00	36.3	0.180
09/09/23	01:00	36.4	0.179
09/09/23	02:00	36.3	0.179
09/09/23	03:00	36.2	0.179
09/09/23	04:00	36.1	0.179
09/09/23	05:00	36.1	0.179
09/09/23	06:00	35.9	0.179
09/09/23	07:00	35.9	0.179
09/09/23	08:00	35.8	0.179
09/09/23	09:00	35.7	0.178
09/09/23	10:00	35.7	0.179
09/09/23	11:00	35.6	0.178
09/09/23	12:00	35.4	0.177
09/09/23	13:00	35.2	0.177
09/09/23	14:00	35.2	0.177
09/09/23	15:00	35.2	0.177
09/09/23	16:00	35.1	0.177
09/09/23	17:00	35.1	0.177
09/09/23	18:00	35.1	0.177
09/09/23	19:00	35.0	0.176
09/09/23	20:00	35.0	0.177
09/09/23	21:00	35.0	0.177
09/09/23	22:00	35.0	0.177
09/09/23	23:00	35.1	0.177
09/10/23	00:00	35.1	0.177
09/10/23	01:00	35.0	0.177
09/10/23	02:00	34.9	0.177
09/10/23	03:00	34.9	0.177
09/10/23	04:00	34.9	0.176
09/10/23	05:00	34.8	0.176
09/10/23	06:00	34.8	0.176
09/10/23	07:00	34.8	0.175
09/10/23	08:00	34.8	0.175
09/10/23	09:00	34.7	0.174
09/10/23	10:00	34.6	0.174
09/10/23	11:00	34.5	0.173
09/10/23	12:00	34.4	0.173
09/10/23	13:00	34.4	0.172
09/10/23	14:00	34.5	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/10/23	15:00	34.7	0.172
09/10/23	16:00	34.7	0.172
09/10/23	17:00	34.7	0.172
09/10/23	18:00	34.8	0.172
09/10/23	19:00	34.8	0.172
09/10/23	20:00	34.7	0.172
09/10/23	21:00	34.7	0.172
09/10/23	22:00	34.7	0.172
09/10/23	23:00	34.6	0.171
09/11/23	00:00	34.6	0.171
09/11/23	01:00	34.6	0.171
09/11/23	02:00	34.6	0.171
09/11/23	03:00	34.6	0.171
09/11/23	04:00	34.7	0.171
09/11/23	05:00	34.7	0.172
09/11/23	06:00	34.7	0.172
09/11/23	07:00	34.7	0.172
09/11/23	08:00	34.7	0.172
09/11/23	09:00	34.7	0.172
09/11/23	10:00	34.8	0.173
09/11/23	11:00	35.0	0.173
09/11/23	12:00	34.9	0.173
09/11/23	13:00	35.0	0.174
09/11/23	14:00	34.9	0.173
09/11/23	15:00	34.7	0.173
09/11/23	16:00	34.7	0.173
09/11/23	17:00	34.7	0.173
09/11/23	18:00	34.6	0.172
09/11/23	19:00	34.7	0.172
09/11/23	20:00	34.7	0.173
09/11/23	21:00	34.8	0.173
09/11/23	22:00	34.8	0.173
09/11/23	23:00	34.8	0.173
09/12/23	00:00	35.0	0.173
09/12/23	01:00	35.0	0.173
09/12/23	02:00	35.1	0.173
09/12/23	03:00	35.2	0.173
09/12/23	04:00	35.2	0.173
09/12/23	05:00	35.3	0.173
09/12/23	06:00	35.4	0.174
09/12/23	07:00	35.4	0.174
09/12/23	08:00	35.5	0.175
09/12/23	09:00	35.5	0.175
09/12/23	10:00	35.6	0.175
09/12/23	11:00	35.7	0.175
09/12/23	12:00	35.9	0.176
09/12/23	13:00	36.0	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/12/23	14:00	36.2	0.177
09/12/23	15:00	36.3	0.178
09/12/23	16:00	36.5	0.179
09/12/23	17:00	36.5	0.178
09/12/23	18:00	36.5	0.178
09/12/23	19:00	36.6	0.178
09/12/23	20:00	36.6	0.178
09/12/23	21:00	36.5	0.178
09/12/23	22:00	36.6	0.179
09/12/23	23:00	36.6	0.179
09/13/23	00:00	36.5	0.179
09/13/23	01:00	36.5	0.179
09/13/23	02:00	36.5	0.179
09/13/23	03:00	36.5	0.179
09/13/23	04:00	36.4	0.179
09/13/23	05:00	36.3	0.179
09/13/23	06:00	36.4	0.179
09/13/23	07:00	36.3	0.179
09/13/23	08:00	36.3	0.179
09/13/23	09:00	36.3	0.180
09/13/23	10:00	36.3	0.180
09/13/23	11:00	36.3	0.181
09/13/23	12:00	36.2	0.180
09/13/23	13:00	36.1	0.180
09/13/23	14:00	35.9	0.179
09/13/23	15:00	35.8	0.179
09/13/23	16:00	35.6	0.178
09/13/23	17:00	35.5	0.178
09/13/23	18:00	35.6	0.179
09/13/23	19:00	35.5	0.179
09/13/23	20:00	35.3	0.178
09/13/23	21:00	35.2	0.178
09/13/23	22:00	35.1	0.177
09/13/23	23:00	34.9	0.177
09/14/23	00:00	34.8	0.177
09/14/23	01:00	34.7	0.176
09/14/23	02:00	34.6	0.176
09/14/23	03:00	34.5	0.175
09/14/23	04:00	34.4	0.174
09/14/23	05:00	34.3	0.173
09/14/23	06:00	34.2	0.172
09/14/23	07:00	34.0	0.171
09/14/23	08:00	33.8	0.170
09/14/23	09:00	33.6	0.169
09/14/23	10:00	33.5	0.168
09/14/23	11:00	34.3	0.167
09/14/23	12:00	34.2	0.167

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/14/23	13:00	34.1	0.166
09/14/23	14:00	34.0	0.166
09/14/23	15:00	34.0	0.166
09/14/23	16:00	34.0	0.166
09/14/23	17:00	34.1	0.166
09/14/23	18:00	34.1	0.166
09/14/23	19:00	34.1	0.165
09/14/23	20:00	34.2	0.166
09/14/23	21:00	34.3	0.166
09/14/23	22:00	34.3	0.166
09/14/23	23:00	33.5	0.165
09/15/23	00:00	32.7	0.165
09/15/23	01:00	32.7	0.165
09/15/23	02:00	32.7	0.165
09/15/23	03:00	32.7	0.165
09/15/23	04:00	32.7	0.165
09/15/23	05:00	32.7	0.165
09/15/23	06:00	32.7	0.165
09/15/23	07:00	32.7	0.165
09/15/23	08:00	32.7	0.165
09/15/23	09:00	32.7	0.165
09/15/23	10:00	32.7	0.165
09/15/23	11:00	32.7	0.165
09/15/23	12:00	32.7	0.165
09/15/23	13:00	32.7	0.165
09/15/23	14:00	32.7	0.165
09/15/23	15:00	32.7	0.165
09/15/23	16:00	32.7	0.165
09/15/23	17:00	32.7	0.165
09/15/23	18:00	32.7	0.165
09/15/23	19:00	32.7	0.165
09/15/23	20:00	32.7	0.165
09/15/23	21:00	32.7	0.165
09/15/23	22:00	32.7	0.165
09/15/23	23:00	32.7	0.165
09/16/23	00:00	32.7	0.165
09/16/23	01:00	32.7	0.165
09/16/23	02:00	32.7	0.165
09/16/23	03:00	32.7	0.165
09/16/23	04:00	32.7	0.165
09/16/23	05:00	32.7	0.165
09/16/23	06:00	32.7	0.165
09/16/23	07:00	32.7	0.165
09/16/23	08:00	32.7	0.165
09/16/23	09:00	32.7	0.165
09/16/23	10:00	32.7	0.165
09/16/23	11:00	32.7	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/16/23	12:00	31.3	0.165
09/16/23	13:00	29.9	0.165
09/16/23	14:00	28.6	0.165
09/16/23	15:00	27.4	0.165I
09/16/23	16:00	26.2	0.165I
09/16/23	17:00	24.9	0.166I
09/16/23	18:00	23.7	0.166I
09/16/23	19:00	22.9	0.167I
09/16/23	20:00	22.6	0.168I
09/16/23	21:00	22.3	0.169I
09/16/23	22:00	21.7	0.170I
09/16/23	23:00	21.7	0.170I
09/17/23	00:00	21.7	0.170I
09/17/23	01:00	21.7	0.170I
09/17/23	02:00	21.7	0.170I
09/17/23	03:00	21.7	0.170I
09/17/23	04:00	21.7	0.170I
09/17/23	05:00	21.7	0.170I
09/17/23	06:00	21.7	0.170I
09/17/23	07:00	21.7	0.170I
09/17/23	08:00	21.7	0.170I
09/17/23	09:00	19.4	0.170I
09/17/23	10:00	18.1	0.171I
09/17/23	11:00	16.8	0.172I
09/17/23	12:00	15.5	0.173I
09/17/23	13:00	14.3	0.174I
09/17/23	14:00	13.3	0.175I
09/17/23	15:00	12.8	0.174I
09/17/23	16:00	12.7	0.174I
09/17/23	17:00	13.1	0.188I
09/17/23	18:00	13.2	0.192I
09/17/23	19:00	12.7	0.167I
09/17/23	20:00	13.1	0.152I
09/17/23	21:00	13.8	0.147I
09/17/23	22:00	15.0	0.147I
09/17/23	23:00	16.1	0.145I
09/18/23	00:00	17.3	0.146I
09/18/23	01:00	18.5	0.148I
09/18/23	02:00	19.7	0.149I
09/18/23	03:00	21.0	0.150I
09/18/23	04:00	22.2	0.151I
09/18/23	05:00	23.1	0.152I
09/18/23	06:00	23.5	0.152I
09/18/23	07:00	23.5	0.152I
09/18/23	08:00	23.5	0.152I
09/18/23	09:00	23.5	0.152I
09/18/23	10:00	23.5	0.152I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/18/23	11:00	23.5	0.152I
09/18/23	12:00	23.5	0.152I
09/18/23	13:00	23.5	0.152I
09/18/23	14:00	23.5	0.152I
09/18/23	15:00	23.5	0.152I
09/18/23	16:00	23.5	0.152I
09/18/23	17:00	23.5	0.152I
09/18/23	18:00	23.5	0.152I
09/18/23	19:00	23.5	0.152I
09/18/23	20:00	23.5	0.152I
09/18/23	21:00	23.5	0.152I
09/18/23	22:00	23.5	0.152I
09/18/23	23:00	23.5	0.152I
09/19/23	00:00	23.5	0.152I
09/19/23	01:00	23.5	0.152I
09/19/23	02:00	23.5	0.152I
09/19/23	03:00	23.5	0.152I
09/19/23	04:00	23.5	0.152I
09/19/23	05:00	23.5	0.152I
09/19/23	06:00	23.5	0.152I
09/19/23	07:00	23.5	0.152I
09/19/23	08:00	23.5	0.152I
09/19/23	09:00	23.5	0.152I
09/19/23	10:00	23.5	0.152I
09/19/23	11:00	23.5	0.152I
09/19/23	12:00	23.5	0.152I
09/19/23	13:00	23.5	0.152I
09/19/23	14:00	23.5	0.152I
09/19/23	15:00	23.5	0.152I
09/19/23	16:00	23.5	0.152I
09/19/23	17:00	23.5	0.152I
09/19/23	18:00	23.5	0.152I
09/19/23	19:00	23.5	0.152I
09/19/23	20:00	23.5	0.152I
09/19/23	21:00	23.5	0.152I
09/19/23	22:00	23.5	0.152I
09/19/23	23:00	23.5	0.152I
09/20/23	00:00	23.5	0.152I
09/20/23	01:00	23.5	0.152I
09/20/23	02:00	23.5	0.152I
09/20/23	03:00	23.5	0.152I
09/20/23	04:00	23.5	0.152I
09/20/23	05:00	23.5	0.152I
09/20/23	06:00	23.5	0.152I
09/20/23	07:00	23.5	0.152I
09/20/23	08:00	23.5	0.152I
09/20/23	09:00	23.5	0.152I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/20/23	10:00	23.5	0.152I
09/20/23	11:00	23.5	0.152I
09/20/23	12:00	23.5	0.152I
09/20/23	13:00	23.5	0.152I
09/20/23	14:00	22.5	0.152I
09/20/23	15:00	21.8	0.152I
09/20/23	16:00	21.8	0.152I
09/20/23	17:00	21.8	0.152I
09/20/23	18:00	21.8	0.152I
09/20/23	19:00	21.8	0.152I
09/20/23	20:00	21.7	0.152I
09/20/23	21:00	21.4	0.152I
09/20/23	22:00	20.6	0.152I
09/20/23	23:00	19.5	0.152I
09/21/23	00:00	18.8	0.148I
09/21/23	01:00	18.3	0.145I
09/21/23	02:00	17.2	0.148I
09/21/23	03:00	17.2	0.148I
09/21/23	04:00	17.2	0.148I
09/21/23	05:00	17.2	0.148I
09/21/23	06:00	17.2	0.148I
09/21/23	07:00	17.2	0.148I
09/21/23	08:00	17.2	0.148I
09/21/23	09:00	17.2	0.148I
09/21/23	10:00	17.2	0.148I
09/21/23	11:00	17.2	0.148I
09/21/23	12:00	17.2	0.148I
09/21/23	13:00	17.2	0.148I
09/21/23	14:00	17.2	0.148I
09/21/23	15:00	17.2	0.148I
09/21/23	16:00	17.2	0.148I
09/21/23	17:00	17.2	0.148I
09/21/23	18:00	17.2	0.148I
09/21/23	19:00	17.2	0.148I
09/21/23	20:00	17.2	0.148I
09/21/23	21:00	17.2	0.148I
09/21/23	22:00	16.3	0.152I
09/21/23	23:00	15.2	0.155I
09/22/23	00:00	14.1	0.157I
09/22/23	01:00	13.1	0.161I
09/22/23	02:00	11.9	0.161I
09/22/23	03:00	10.6	0.162I
09/22/23	04:00	9.4	0.163I
09/22/23	05:00	8.6	0.163I
09/22/23	06:00	7.8	0.162I
09/22/23	07:00	7.2	0.000I
09/22/23	08:00	7.4	0.000I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/22/23	09:00	8.7	0.000I
09/22/23	10:00	10.2	0.175I
09/22/23	11:00	11.8	0.184I
09/22/23	12:00	12.9	0.167I
09/22/23	13:00	13.9	0.159I
09/22/23	14:00	15.2	0.155I
09/22/23	15:00	16.4	0.156I
09/22/23	16:00	17.6	0.157I
09/22/23	17:00	19.1	0.162I
09/22/23	18:00	20.3	0.165I
09/22/23	19:00	20.8	0.166I
09/22/23	20:00	21.3	0.168I
09/22/23	21:00	22.8	0.169I
09/22/23	22:00	24.4	0.170I
09/22/23	23:00	25.8	0.171I
09/23/23	00:00	27.2	0.172I
09/23/23	01:00	28.7	0.173I
09/23/23	02:00	30.1	0.174I
09/23/23	03:00	31.5	0.175
09/23/23	04:00	32.8	0.175
09/23/23	05:00	33.8	0.176
09/23/23	06:00	34.7	0.176
09/23/23	07:00	35.4	0.176
09/23/23	08:00	35.3	0.177
09/23/23	09:00	35.4	0.177
09/23/23	10:00	35.4	0.177
09/23/23	11:00	35.3	0.176
09/23/23	12:00	35.6	0.178
09/23/23	13:00	35.9	0.179
09/23/23	14:00	36.1	0.181
09/23/23	15:00	36.1	0.181
09/23/23	16:00	36.2	0.181
09/23/23	17:00	35.9	0.180
09/23/23	18:00	35.8	0.179
09/23/23	19:00	35.7	0.179
09/23/23	20:00	35.6	0.178
09/23/23	21:00	35.5	0.178
09/23/23	22:00	35.4	0.177
09/23/23	23:00	35.4	0.177
09/24/23	00:00	35.5	0.177
09/24/23	01:00	35.4	0.177
09/24/23	02:00	35.4	0.177
09/24/23	03:00	35.4	0.177
09/24/23	04:00	35.4	0.177
09/24/23	05:00	35.4	0.177
09/24/23	06:00	35.5	0.177
09/24/23	07:00	35.5	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/24/23	08:00	35.5	0.177
09/24/23	09:00	35.6	0.177
09/24/23	10:00	35.6	0.177
09/24/23	11:00	35.5	0.177
09/24/23	12:00	35.6	0.177
09/24/23	13:00	35.6	0.177
09/24/23	14:00	35.6	0.177
09/24/23	15:00	35.6	0.177
09/24/23	16:00	35.5	0.176
09/24/23	17:00	35.4	0.176
09/24/23	18:00	35.3	0.175
09/24/23	19:00	35.4	0.176
09/24/23	20:00	35.5	0.177
09/24/23	21:00	35.5	0.177
09/24/23	22:00	35.4	0.176
09/24/23	23:00	35.4	0.177
09/25/23	00:00	35.3	0.177
09/25/23	01:00	35.3	0.176
09/25/23	02:00	35.3	0.176
09/25/23	03:00	35.3	0.175
09/25/23	04:00	35.4	0.175
09/25/23	05:00	35.5	0.176
09/25/23	06:00	35.5	0.176
09/25/23	07:00	35.4	0.175
09/25/23	08:00	35.4	0.175
09/25/23	09:00	35.5	0.176
09/25/23	10:00	35.6	0.176
09/25/23	11:00	35.5	0.175
09/25/23	12:00	36.1	0.175
09/25/23	13:00	36.1	0.175
09/25/23	14:00	36.2	0.176
09/25/23	15:00	36.3	0.176
09/25/23	16:00	36.4	0.177
09/25/23	17:00	36.6	0.177
09/25/23	18:00	36.7	0.178
09/25/23	19:00	36.9	0.178
09/25/23	20:00	36.9	0.179
09/25/23	21:00	36.9	0.179
09/25/23	22:00	36.9	0.179
09/25/23	23:00	37.0	0.179
09/26/23	00:00	37.1	0.179
09/26/23	01:00	37.1	0.179
09/26/23	02:00	37.1	0.179
09/26/23	03:00	37.1	0.180
09/26/23	04:00	37.1	0.180
09/26/23	05:00	37.2	0.180
09/26/23	06:00	37.2	0.180

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/26/23	07:00	37.2	0.180
09/26/23	08:00	37.2	0.179
09/26/23	09:00	37.2	0.179
09/26/23	10:00	37.2	0.179
09/26/23	11:00	37.8	0.178
09/26/23	12:00	38.1	0.178
09/26/23	13:00	37.6	0.179
09/26/23	14:00	37.5	0.178
09/26/23	15:00	37.5	0.179
09/26/23	16:00	37.6	0.179
09/26/23	17:00	37.6	0.179
09/26/23	18:00	37.7	0.179
09/26/23	19:00	37.8	0.180
09/26/23	20:00	37.8	0.180
09/26/23	21:00	37.8	0.180
09/26/23	22:00	37.8	0.181
09/26/23	23:00	37.8	0.181
09/27/23	00:00	37.8	0.181
09/27/23	01:00	37.6	0.180
09/27/23	02:00	37.5	0.180
09/27/23	03:00	37.6	0.180
09/27/23	04:00	37.5	0.180
09/27/23	05:00	37.5	0.180
09/27/23	06:00	37.5	0.180
09/27/23	07:00	37.5	0.181
09/27/23	08:00	37.5	0.181
09/27/23	09:00	37.5	0.181
09/27/23	10:00	37.5	0.182
09/27/23	11:00	36.9	0.182
09/27/23	12:00	36.6	0.182
09/27/23	13:00	36.5	0.182
09/27/23	14:00	36.6	0.182
09/27/23	15:00	36.6	0.182
09/27/23	16:00	36.6	0.182
09/27/23	17:00	36.6	0.181
09/27/23	18:00	36.5	0.181
09/27/23	19:00	36.4	0.180
09/27/23	20:00	36.4	0.180
09/27/23	21:00	36.3	0.179
09/27/23	22:00	36.2	0.178
09/27/23	23:00	36.1	0.177
09/28/23	00:00	36.1	0.177
09/28/23	01:00	36.3	0.177
09/28/23	02:00	36.4	0.177
09/28/23	03:00	36.5	0.177
09/28/23	04:00	36.4	0.176
09/28/23	05:00	36.3	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/28/23	06:00	36.3	0.174
09/28/23	07:00	36.2	0.173
09/28/23	08:00	36.2	0.173
09/28/23	09:00	36.2	0.172
09/28/23	10:00	36.2	0.171
09/28/23	11:00	36.1	0.170
09/28/23	12:00	36.2	0.170
09/28/23	13:00	36.2	0.170
09/28/23	14:00	36.1	0.169
09/28/23	15:00	36.1	0.169
09/28/23	16:00	36.2	0.169
09/28/23	17:00	36.3	0.169
09/28/23	18:00	36.5	0.170
09/28/23	19:00	36.6	0.170
09/28/23	20:00	36.6	0.170
09/28/23	21:00	36.7	0.170
09/28/23	22:00	36.8	0.171
09/28/23	23:00	36.9	0.171
09/29/23	00:00	36.9	0.172
09/29/23	01:00	36.7	0.171
09/29/23	02:00	36.6	0.171
09/29/23	03:00	36.6	0.170
09/29/23	04:00	36.6	0.170
09/29/23	05:00	36.6	0.171
09/29/23	06:00	36.6	0.171
09/29/23	07:00	36.6	0.170
09/29/23	08:00	36.5	0.170
09/29/23	09:00	36.6	0.170
09/29/23	10:00	36.7	0.171
09/29/23	11:00	36.8	0.172
09/29/23	12:00	37.0	0.173
09/29/23	13:00	37.1	0.173
09/29/23	14:00	38.0	0.173
09/29/23	15:00	40.1	0.175
09/29/23	16:00	42.3	0.176
09/29/23	17:00	44.7	0.178
09/29/23	18:00	45.4	0.178
09/29/23	19:00	45.3	0.177
09/29/23	20:00	45.6	0.178
09/29/23	21:00	45.8	0.179
09/29/23	22:00	46.0	0.179
09/29/23	23:00	46.2	0.180
09/30/23	00:00	46.3	0.181
09/30/23	01:00	46.5	0.182
09/30/23	02:00	46.5	0.183
09/30/23	03:00	46.7	0.184
09/30/23	04:00	46.5	0.183

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
09/30/23	05:00	46.4	0.182
09/30/23	06:00	46.3	0.182
09/30/23	07:00	46.2	0.182
09/30/23	08:00	46.1	0.181
09/30/23	09:00	45.9	0.181
09/30/23	10:00	45.6	0.179
09/30/23	11:00	45.5	0.178
09/30/23	12:00	45.1	0.177
09/30/23	13:00	45.0	0.176
09/30/23	14:00	45.2	0.177
09/30/23	15:00	44.9	0.177
09/30/23	16:00	44.5	0.177
09/30/23	17:00	44.1	0.176
09/30/23	18:00	44.0	0.177
09/30/23	19:00	44.0	0.177
09/30/23	20:00	43.7	0.176
09/30/23	21:00	43.5	0.175
09/30/23	22:00	43.3	0.175
09/30/23	23:00	43.1	0.174
10/01/23	00:00	43.0	0.174
10/01/23	01:00	43.0	0.174
10/01/23	02:00	42.8	0.173
10/01/23	03:00	42.7	0.173
10/01/23	04:00	42.8	0.173
10/01/23	05:00	42.9	0.174
10/01/23	06:00	43.0	0.175
10/01/23	07:00	43.1	0.176
10/01/23	08:00	43.3	0.176
10/01/23	09:00	43.4	0.177
10/01/23	10:00	43.6	0.178
10/01/23	11:00	43.6	0.179
10/01/23	12:00	43.9	0.180
10/01/23	13:00	43.9	0.180
10/01/23	14:00	42.7	0.179
10/01/23	15:00	42.2	0.179
10/01/23	16:00	42.4	0.180
10/01/23	17:00	42.5	0.180
10/01/23	18:00	44.2	0.181
10/01/23	19:00	45.0	0.182
10/01/23	20:00	45.0	0.182
10/01/23	21:00	45.0	0.182
10/01/23	22:00	45.0	0.182
10/01/23	23:00	44.9	0.181
10/02/23	00:00	45.0	0.181
10/02/23	01:00	44.8	0.181
10/02/23	02:00	44.9	0.181
10/02/23	03:00	45.0	0.181

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/02/23	04:00	45.0	0.181
10/02/23	05:00	45.0	0.181
10/02/23	06:00	45.0	0.181
10/02/23	07:00	45.0	0.181
10/02/23	08:00	45.0	0.181
10/02/23	09:00	45.0	0.181
10/02/23	10:00	45.0	0.181
10/02/23	11:00	45.0	0.180
10/02/23	12:00	45.7	0.181
10/02/23	13:00	47.4	0.183
10/02/23	14:00	48.8	0.184
10/02/23	15:00	48.9	0.184
10/02/23	16:00	48.3	0.184
10/02/23	17:00	47.8	0.184
10/02/23	18:00	47.1	0.184
10/02/23	19:00	48.0	0.186
10/02/23	20:00	48.5	0.186
10/02/23	21:00	48.5	0.186
10/02/23	22:00	48.3	0.186
10/02/23	23:00	48.2	0.185
10/03/23	00:00	48.1	0.185
10/03/23	01:00	48.0	0.184
10/03/23	02:00	47.9	0.185
10/03/23	03:00	47.9	0.184
10/03/23	04:00	47.8	0.184
10/03/23	05:00	47.7	0.184
10/03/23	06:00	47.6	0.183
10/03/23	07:00	47.6	0.183
10/03/23	08:00	47.5	0.183
10/03/23	09:00	47.4	0.182
10/03/23	10:00	48.1	0.182
10/03/23	11:00	49.2	0.183
10/03/23	12:00	48.1	0.183
10/03/23	13:00	46.4	0.180
10/03/23	14:00	46.0	0.179
10/03/23	15:00	45.7	0.178
10/03/23	16:00	45.3	0.177
10/03/23	17:00	45.0	0.177
10/03/23	18:00	44.7	0.176
10/03/23	19:00	44.3	0.175
10/03/23	20:00	44.2	0.175
10/03/23	21:00	44.5	0.176
10/03/23	22:00	44.7	0.177
10/03/23	23:00	44.7	0.177
10/04/23	00:00	44.8	0.177
10/04/23	01:00	45.0	0.177
10/04/23	02:00	44.9	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/04/23	03:00	44.9	0.177
10/04/23	04:00	44.9	0.177
10/04/23	05:00	45.0	0.177
10/04/23	06:00	45.1	0.177
10/04/23	07:00	45.0	0.177
10/04/23	08:00	45.1	0.177
10/04/23	09:00	45.1	0.177
10/04/23	10:00	44.4	0.177
10/04/23	11:00	43.2	0.176
10/04/23	12:00	44.5	0.176
10/04/23	13:00	46.3	0.179
10/04/23	14:00	47.1	0.180
10/04/23	15:00	47.7	0.181
10/04/23	16:00	48.2	0.181
10/04/23	17:00	48.7	0.182
10/04/23	18:00	49.2	0.183
10/04/23	19:00	49.9	0.184
10/04/23	20:00	49.9	0.184
10/04/23	21:00	49.9	0.184
10/04/23	22:00	50.0	0.184
10/04/23	23:00	50.0	0.184
10/05/23	00:00	50.1	0.185
10/05/23	01:00	50.1	0.184
10/05/23	02:00	50.1	0.184
10/05/23	03:00	50.1	0.184
10/05/23	04:00	50.1	0.184
10/05/23	05:00	50.1	0.184
10/05/23	06:00	50.1	0.183
10/05/23	07:00	50.2	0.184
10/05/23	08:00	50.3	0.185
10/05/23	09:00	50.4	0.186
10/05/23	10:00	50.5	0.186
10/05/23	11:00	50.5	0.187
10/05/23	12:00	49.1	0.185
10/05/23	13:00	47.4	0.183
10/05/23	14:00	45.8	0.182
10/05/23	15:00	44.2	0.181
10/05/23	16:00	42.5	0.179
10/05/23	17:00	40.6	0.177
10/05/23	18:00	38.7	0.174
10/05/23	19:00	36.6	0.171
10/05/23	20:00	36.2	0.170
10/05/23	21:00	36.1	0.170
10/05/23	22:00	36.1	0.169
10/05/23	23:00	36.3	0.171
10/06/23	00:00	36.4	0.172
10/06/23	01:00	36.5	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/06/23	02:00	36.6	0.173
10/06/23	03:00	36.7	0.173
10/06/23	04:00	36.9	0.174
10/06/23	05:00	37.0	0.175
10/06/23	06:00	37.0	0.176
10/06/23	07:00	37.1	0.176
10/06/23	08:00	37.0	0.176
10/06/23	09:00	37.0	0.176
10/06/23	10:00	37.6	0.175
10/06/23	11:00	40.1	0.177
10/06/23	12:00	41.0	0.178
10/06/23	13:00	41.1	0.179
10/06/23	14:00	41.1	0.180
10/06/23	15:00	41.2	0.180
10/06/23	16:00	41.3	0.181
10/06/23	17:00	41.4	0.182
10/06/23	18:00	41.6	0.183
10/06/23	19:00	41.7	0.184
10/06/23	20:00	41.6	0.184
10/06/23	21:00	41.5	0.184
10/06/23	22:00	41.4	0.184
10/06/23	23:00	41.4	0.184
10/07/23	00:00	41.4	0.183
10/07/23	01:00	41.4	0.184
10/07/23	02:00	41.3	0.184
10/07/23	03:00	41.2	0.184
10/07/23	04:00	41.1	0.183
10/07/23	05:00	40.9	0.182
10/07/23	06:00	40.7	0.181
10/07/23	07:00	40.5	0.180
10/07/23	08:00	40.3	0.179
10/07/23	09:00	40.3	0.178
10/07/23	10:00	39.7	0.179
10/07/23	11:00	37.3	0.178
10/07/23	12:00	36.7	0.178
10/07/23	13:00	36.6	0.178
10/07/23	14:00	36.7	0.177
10/07/23	15:00	36.7	0.177
10/07/23	16:00	36.7	0.177
10/07/23	17:00	36.7	0.177
10/07/23	18:00	36.5	0.175
10/07/23	19:00	36.5	0.175
10/07/23	20:00	36.4	0.175
10/07/23	21:00	36.3	0.174
10/07/23	22:00	36.3	0.174
10/07/23	23:00	36.2	0.174
10/08/23	00:00	36.1	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/08/23	01:00	36.0	0.173
10/08/23	02:00	36.1	0.173
10/08/23	03:00	36.2	0.173
10/08/23	04:00	36.2	0.173
10/08/23	05:00	36.2	0.174
10/08/23	06:00	36.3	0.174
10/08/23	07:00	36.5	0.175
10/08/23	08:00	36.6	0.176
10/08/23	09:00	36.7	0.177
10/08/23	10:00	38.0	0.177
10/08/23	11:00	38.6	0.177
10/08/23	12:00	38.4	0.176
10/08/23	13:00	38.5	0.176
10/08/23	14:00	38.4	0.177
10/08/23	15:00	38.4	0.177
10/08/23	16:00	38.2	0.176
10/08/23	17:00	38.1	0.176
10/08/23	18:00	38.5	0.179
10/08/23	19:00	38.5	0.179
10/08/23	20:00	38.5	0.179
10/08/23	21:00	38.5	0.179
10/08/23	22:00	38.5	0.179
10/08/23	23:00	38.5	0.179
10/09/23	00:00	38.5	0.179
10/09/23	01:00	38.5	0.179
10/09/23	02:00	38.5	0.179
10/09/23	03:00	38.5	0.179
10/09/23	04:00	38.5	0.179
10/09/23	05:00	38.5	0.179
10/09/23	06:00	38.5	0.179
10/09/23	07:00	38.5	0.179
10/09/23	08:00	38.5	0.179
10/09/23	09:00	38.5	0.179
10/09/23	10:00	38.5	0.179
10/09/23	11:00	38.5	0.179
10/09/23	12:00	38.5	0.179
10/09/23	13:00	38.5	0.179
10/09/23	14:00	38.5	0.179
10/09/23	15:00	38.5	0.179
10/09/23	16:00	38.5	0.179
10/09/23	17:00	38.5	0.179
10/09/23	18:00	38.5	0.179
10/09/23	19:00	38.5	0.179
10/09/23	20:00	38.5	0.179
10/09/23	21:00	38.5	0.179
10/09/23	22:00	38.5	0.179
10/09/23	23:00	38.5	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/10/23	00:00	38.5	0.179
10/10/23	01:00	38.5	0.179
10/10/23	02:00	38.5	0.179
10/10/23	03:00	38.5	0.179
10/10/23	04:00	38.5	0.179
10/10/23	05:00	38.5	0.179
10/10/23	06:00	38.5	0.179
10/10/23	07:00	38.5	0.179
10/10/23	08:00	38.5	0.179
10/10/23	09:00	38.5	0.179
10/10/23	10:00	38.5	0.179
10/10/23	11:00	37.0	0.180
10/10/23	12:00	35.6	0.180
10/10/23	13:00	34.2	0.181
10/10/23	14:00	32.8	0.181
10/10/23	15:00	31.4	0.182
10/10/23	16:00	30.0	0.182
10/10/23	17:00	28.6	0.183I
10/10/23	18:00	27.2	0.182I
10/10/23	19:00	26.6	0.183I
10/10/23	20:00	26.4	0.183I
10/10/23	21:00	26.4	0.183I
10/10/23	22:00	26.3	0.182I
10/10/23	23:00	26.1	0.180I
10/11/23	00:00	25.9	0.179I
10/11/23	01:00	25.6	0.177I
10/11/23	02:00	24.1	0.176I
10/11/23	03:00	23.4	0.176I
10/11/23	04:00	23.4	0.176I
10/11/23	05:00	23.3	0.176I
10/11/23	06:00	23.2	0.175I
10/11/23	07:00	23.2	0.175I
10/11/23	08:00	23.1	0.175I
10/11/23	09:00	23.0	0.175I
10/11/23	10:00	22.7	0.172I
10/11/23	11:00	24.2	0.173I
10/11/23	12:00	25.6	0.173I
10/11/23	13:00	27.2	0.173I
10/11/23	14:00	28.5	0.173
10/11/23	15:00	29.8	0.173
10/11/23	16:00	31.1	0.174
10/11/23	17:00	32.4	0.174
10/11/23	18:00	33.7	0.174
10/11/23	19:00	34.2	0.174
10/11/23	20:00	34.4	0.175
10/11/23	21:00	34.5	0.176
10/11/23	22:00	34.7	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/11/23	23:00	34.9	0.178
10/12/23	00:00	35.0	0.179
10/12/23	01:00	35.1	0.180
10/12/23	02:00	35.2	0.180
10/12/23	03:00	35.4	0.181
10/12/23	04:00	35.6	0.182
10/12/23	05:00	35.5	0.182
10/12/23	06:00	35.4	0.182
10/12/23	07:00	35.4	0.181
10/12/23	08:00	35.4	0.181
10/12/23	09:00	35.3	0.181
10/12/23	10:00	35.2	0.181
10/12/23	11:00	35.2	0.180
10/12/23	12:00	35.2	0.180
10/12/23	13:00	35.2	0.181
10/12/23	14:00	35.3	0.181
10/12/23	15:00	35.2	0.181
10/12/23	16:00	35.2	0.181
10/12/23	17:00	35.2	0.181
10/12/23	18:00	35.2	0.181
10/12/23	19:00	35.2	0.181
10/12/23	20:00	35.2	0.181
10/12/23	21:00	35.1	0.180
10/12/23	22:00	35.1	0.180
10/12/23	23:00	35.0	0.180
10/13/23	00:00	35.0	0.180
10/13/23	01:00	35.1	0.180
10/13/23	02:00	35.0	0.180
10/13/23	03:00	34.9	0.180
10/13/23	04:00	34.9	0.179
10/13/23	05:00	34.8	0.179
10/13/23	06:00	34.8	0.179
10/13/23	07:00	34.6	0.178
10/13/23	08:00	34.5	0.178
10/13/23	09:00	34.5	0.177
10/13/23	10:00	34.5	0.177
10/13/23	11:00	35.1	0.177
10/13/23	12:00	35.3	0.177
10/13/23	13:00	35.1	0.176
10/13/23	14:00	35.0	0.176
10/13/23	15:00	35.0	0.176
10/13/23	16:00	35.0	0.176
10/13/23	17:00	35.1	0.176
10/13/23	18:00	35.1	0.176
10/13/23	19:00	35.1	0.176
10/13/23	20:00	35.1	0.176
10/13/23	21:00	35.1	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/13/23	22:00	35.1	0.175
10/13/23	23:00	35.1	0.174
10/14/23	00:00	35.0	0.173
10/14/23	01:00	35.0	0.173
10/14/23	02:00	35.0	0.172
10/14/23	03:00	34.8	0.171
10/14/23	04:00	34.9	0.171
10/14/23	05:00	35.0	0.171
10/14/23	06:00	34.9	0.170
10/14/23	07:00	35.1	0.171
10/14/23	08:00	35.2	0.171
10/14/23	09:00	35.3	0.171
10/14/23	10:00	35.4	0.171
10/14/23	11:00	34.8	0.171
10/14/23	12:00	34.7	0.171
10/14/23	13:00	34.8	0.170
10/14/23	14:00	34.9	0.169
10/14/23	15:00	35.1	0.169
10/14/23	16:00	35.2	0.170
10/14/23	17:00	35.3	0.170
10/14/23	18:00	35.4	0.170
10/14/23	19:00	35.4	0.170
10/14/23	20:00	35.4	0.170
10/14/23	21:00	35.4	0.170
10/14/23	22:00	35.5	0.170
10/14/23	23:00	35.5	0.170
10/15/23	00:00	35.6	0.171
10/15/23	01:00	35.6	0.171
10/15/23	02:00	35.7	0.172
10/15/23	03:00	35.9	0.173
10/15/23	04:00	35.9	0.172
10/15/23	05:00	35.9	0.173
10/15/23	06:00	36.1	0.174
10/15/23	07:00	36.1	0.174
10/15/23	08:00	36.3	0.175
10/15/23	09:00	36.4	0.176
10/15/23	10:00	36.4	0.176
10/15/23	11:00	36.5	0.177
10/15/23	12:00	36.5	0.177
10/15/23	13:00	36.5	0.177
10/15/23	14:00	36.6	0.178
10/15/23	15:00	36.7	0.179
10/15/23	16:00	36.7	0.179
10/15/23	17:00	37.6	0.178
10/15/23	18:00	41.3	0.180
10/15/23	19:00	43.3	0.182
10/15/23	20:00	43.0	0.180

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/15/23	21:00	42.7	0.179
10/15/23	22:00	42.5	0.178
10/15/23	23:00	42.4	0.178
10/16/23	00:00	42.4	0.178
10/16/23	01:00	42.3	0.178
10/16/23	02:00	42.3	0.178
10/16/23	03:00	42.3	0.179
10/16/23	04:00	42.4	0.179
10/16/23	05:00	42.5	0.180
10/16/23	06:00	42.5	0.180
10/16/23	07:00	42.6	0.181
10/16/23	08:00	42.6	0.181
10/16/23	09:00	42.7	0.182
10/16/23	10:00	42.7	0.182
10/16/23	11:00	42.8	0.183
10/16/23	12:00	42.9	0.184
10/16/23	13:00	42.9	0.184
10/16/23	14:00	42.9	0.183
10/16/23	15:00	42.7	0.183
10/16/23	16:00	42.7	0.183
10/16/23	17:00	42.8	0.184
10/16/23	18:00	42.9	0.185
10/16/23	19:00	44.0	0.186
10/16/23	20:00	44.3	0.186
10/16/23	21:00	44.3	0.187
10/16/23	22:00	44.3	0.187
10/16/23	23:00	44.3	0.186
10/17/23	00:00	44.2	0.185
10/17/23	01:00	44.0	0.184
10/17/23	02:00	43.8	0.183
10/17/23	03:00	43.4	0.181
10/17/23	04:00	43.1	0.179
10/17/23	05:00	44.5	0.179
10/17/23	06:00	47.8	0.180
10/17/23	07:00	49.1	0.180
10/17/23	08:00	49.1	0.180
10/17/23	09:00	48.9	0.179
10/17/23	10:00	48.9	0.179
10/17/23	11:00	48.9	0.178
10/17/23	12:00	48.8	0.178
10/17/23	13:00	48.8	0.178
10/17/23	14:00	48.9	0.179
10/17/23	15:00	49.0	0.179
10/17/23	16:00	49.1	0.180
10/17/23	17:00	48.1	0.180
10/17/23	18:00	44.3	0.177
10/17/23	19:00	41.3	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/17/23	20:00	41.4	0.178
10/17/23	21:00	41.6	0.179
10/17/23	22:00	42.0	0.180
10/17/23	23:00	42.1	0.181
10/18/23	00:00	42.2	0.181
10/18/23	01:00	42.4	0.183
10/18/23	02:00	42.6	0.183
10/18/23	03:00	42.8	0.184
10/18/23	04:00	43.1	0.186
10/18/23	05:00	41.6	0.185
10/18/23	06:00	38.3	0.183
10/18/23	07:00	37.0	0.183
10/18/23	08:00	37.0	0.184
10/18/23	09:00	37.0	0.184
10/18/23	10:00	36.7	0.183
10/18/23	11:00	36.7	0.183
10/18/23	12:00	36.8	0.184
10/18/23	13:00	36.8	0.184
10/18/23	14:00	36.8	0.183
10/18/23	15:00	36.7	0.183
10/18/23	16:00	36.6	0.182
10/18/23	17:00	36.6	0.182
10/18/23	18:00	36.7	0.182
10/18/23	19:00	36.6	0.182
10/18/23	20:00	36.6	0.182
10/18/23	21:00	36.7	0.182
10/18/23	22:00	36.8	0.183
10/18/23	23:00	36.8	0.183
10/19/23	00:00	36.7	0.182
10/19/23	01:00	36.8	0.183
10/19/23	02:00	36.9	0.184
10/19/23	03:00	37.0	0.184
10/19/23	04:00	37.0	0.184
10/19/23	05:00	37.0	0.184
10/19/23	06:00	37.0	0.184
10/19/23	07:00	37.0	0.184
10/19/23	08:00	36.8	0.183
10/19/23	09:00	36.9	0.183
10/19/23	10:00	37.1	0.184
10/19/23	11:00	37.1	0.184
10/19/23	12:00	37.1	0.184
10/19/23	13:00	37.1	0.184
10/19/23	14:00	37.1	0.184
10/19/23	15:00	37.2	0.184
10/19/23	16:00	37.2	0.184
10/19/23	17:00	37.2	0.184
10/19/23	18:00	37.1	0.184

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/19/23	19:00	37.1	0.184
10/19/23	20:00	37.1	0.183
10/19/23	21:00	37.1	0.183
10/19/23	22:00	37.1	0.183
10/19/23	23:00	37.1	0.183
10/20/23	00:00	37.2	0.183
10/20/23	01:00	37.3	0.183
10/20/23	02:00	37.5	0.184
10/20/23	03:00	37.5	0.184
10/20/23	04:00	37.5	0.183
10/20/23	05:00	37.4	0.182
10/20/23	06:00	37.4	0.182
10/20/23	07:00	37.3	0.181
10/20/23	08:00	37.5	0.182
10/20/23	09:00	37.4	0.181
10/20/23	10:00	37.5	0.181
10/20/23	11:00	37.4	0.180
10/20/23	12:00	37.3	0.179
10/20/23	13:00	37.1	0.177
10/20/23	14:00	37.1	0.176
10/20/23	15:00	37.4	0.175
10/20/23	16:00	37.4	0.175
10/20/23	17:00	37.3	0.174
10/20/23	18:00	37.3	0.174
10/20/23	19:00	37.3	0.174
10/20/23	20:00	37.3	0.174
10/20/23	21:00	37.2	0.173
10/20/23	22:00	37.2	0.173
10/20/23	23:00	37.1	0.172
10/21/23	00:00	37.0	0.172
10/21/23	01:00	37.0	0.172
10/21/23	02:00	36.8	0.171
10/21/23	03:00	36.8	0.171
10/21/23	04:00	36.9	0.171
10/21/23	05:00	36.9	0.171
10/21/23	06:00	36.9	0.171
10/21/23	07:00	37.0	0.172
10/21/23	08:00	37.0	0.172
10/21/23	09:00	37.0	0.172
10/21/23	10:00	37.1	0.172
10/21/23	11:00	37.1	0.173
10/21/23	12:00	37.2	0.173
10/21/23	13:00	37.4	0.174
10/21/23	14:00	37.3	0.175
10/21/23	15:00	37.1	0.176
10/21/23	16:00	37.2	0.176
10/21/23	17:00	37.2	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/21/23	18:00	37.2	0.177
10/21/23	19:00	37.3	0.177
10/21/23	20:00	37.2	0.177
10/21/23	21:00	37.3	0.177
10/21/23	22:00	37.5	0.178
10/21/23	23:00	37.6	0.178
10/22/23	00:00	37.8	0.179
10/22/23	01:00	37.7	0.179
10/22/23	02:00	37.9	0.179
10/22/23	03:00	37.9	0.180
10/22/23	04:00	37.9	0.180
10/22/23	05:00	38.0	0.180
10/22/23	06:00	38.0	0.181
10/22/23	07:00	38.0	0.181
10/22/23	08:00	37.9	0.181
10/22/23	09:00	38.0	0.181
10/22/23	10:00	38.0	0.181
10/22/23	11:00	38.0	0.181
10/22/23	12:00	38.1	0.182
10/22/23	13:00	38.0	0.181
10/22/23	14:00	38.0	0.182
10/22/23	15:00	38.0	0.181
10/22/23	16:00	38.0	0.181
10/22/23	17:00	38.0	0.181
10/22/23	18:00	38.1	0.182
10/22/23	19:00	38.1	0.182
10/22/23	20:00	38.1	0.182
10/22/23	21:00	37.9	0.182
10/22/23	22:00	37.8	0.182
10/22/23	23:00	37.8	0.182
10/23/23	00:00	37.9	0.182
10/23/23	01:00	37.8	0.182
10/23/23	02:00	37.6	0.182
10/23/23	03:00	37.5	0.181
10/23/23	04:00	37.4	0.181
10/23/23	05:00	38.4	0.181
10/23/23	06:00	41.9	0.183
10/23/23	07:00	45.3	0.184
10/23/23	08:00	46.8	0.184
10/23/23	09:00	46.7	0.184
10/23/23	10:00	46.7	0.184
10/23/23	11:00	46.6	0.184
10/23/23	12:00	46.6	0.184
10/23/23	13:00	46.5	0.184
10/23/23	14:00	46.5	0.185
10/23/23	15:00	46.5	0.185
10/23/23	16:00	47.2	0.185

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/23/23	17:00	50.1	0.187
10/23/23	18:00	51.1	0.186
10/23/23	19:00	51.0	0.186
10/23/23	20:00	50.8	0.185
10/23/23	21:00	50.7	0.184
10/23/23	22:00	50.6	0.183
10/23/23	23:00	50.5	0.183
10/24/23	00:00	50.5	0.183
10/24/23	01:00	50.5	0.183
10/24/23	02:00	50.5	0.184
10/24/23	03:00	50.5	0.184
10/24/23	04:00	50.6	0.185
10/24/23	05:00	49.5	0.185
10/24/23	06:00	45.9	0.183
10/24/23	07:00	42.2	0.180
10/24/23	08:00	40.7	0.179
10/24/23	09:00	40.7	0.180
10/24/23	10:00	40.5	0.179
10/24/23	11:00	40.6	0.179
10/24/23	12:00	40.6	0.179
10/24/23	13:00	41.1	0.179
10/24/23	14:00	41.3	0.178
10/24/23	15:00	41.2	0.178
10/24/23	16:00	40.4	0.178
10/24/23	17:00	37.4	0.175
10/24/23	18:00	36.3	0.175
10/24/23	19:00	36.4	0.176
10/24/23	20:00	36.6	0.177
10/24/23	21:00	36.7	0.177
10/24/23	22:00	36.8	0.177
10/24/23	23:00	36.8	0.177
10/25/23	00:00	36.9	0.176
10/25/23	01:00	36.7	0.174
10/25/23	02:00	36.8	0.174
10/25/23	03:00	36.8	0.173
10/25/23	04:00	37.1	0.174
10/25/23	05:00	37.3	0.174
10/25/23	06:00	37.3	0.174
10/25/23	07:00	37.7	0.176
10/25/23	08:00	37.8	0.176
10/25/23	09:00	38.3	0.176
10/25/23	10:00	41.8	0.179
10/25/23	11:00	45.0	0.181
10/25/23	12:00	46.4	0.182
10/25/23	13:00	45.9	0.182
10/25/23	14:00	45.7	0.182
10/25/23	15:00	45.6	0.182

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/25/23	16:00	45.7	0.182
10/25/23	17:00	45.8	0.183
10/25/23	18:00	45.7	0.182
10/25/23	19:00	45.7	0.182
10/25/23	20:00	45.5	0.180
10/25/23	21:00	45.3	0.179
10/25/23	22:00	45.3	0.179
10/25/23	23:00	45.1	0.179
10/26/23	00:00	44.9	0.177
10/26/23	01:00	44.8	0.178
10/26/23	02:00	44.7	0.177
10/26/23	03:00	44.6	0.177
10/26/23	04:00	44.3	0.175
10/26/23	05:00	44.0	0.174
10/26/23	06:00	44.0	0.174
10/26/23	07:00	43.9	0.173
10/26/23	08:00	43.8	0.172
10/26/23	09:00	43.3	0.172
10/26/23	10:00	40.0	0.169
10/26/23	11:00	36.9	0.167
10/26/23	12:00	35.4	0.165
10/26/23	13:00	35.5	0.165
10/26/23	14:00	35.5	0.164
10/26/23	15:00	35.6	0.164
10/26/23	16:00	35.5	0.163
10/26/23	17:00	35.4	0.163
10/26/23	18:00	35.3	0.162
10/26/23	19:00	35.4	0.162
10/26/23	20:00	35.7	0.164
10/26/23	21:00	35.9	0.165
10/26/23	22:00	36.1	0.165
10/26/23	23:00	36.2	0.166
10/27/23	00:00	36.3	0.167
10/27/23	01:00	36.5	0.167
10/27/23	02:00	36.7	0.169
10/27/23	03:00	36.7	0.169
10/27/23	04:00	36.9	0.170
10/27/23	05:00	37.1	0.171
10/27/23	06:00	37.1	0.171
10/27/23	07:00	37.2	0.171
10/27/23	08:00	37.1	0.170
10/27/23	09:00	36.9	0.170
10/27/23	10:00	36.7	0.169
10/27/23	11:00	37.6	0.169
10/27/23	12:00	37.5	0.169
10/27/23	13:00	37.5	0.170
10/27/23	14:00	37.4	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/27/23	15:00	37.4	0.170
10/27/23	16:00	37.5	0.171
10/27/23	17:00	37.8	0.172
10/27/23	18:00	37.9	0.173
10/27/23	19:00	37.9	0.173
10/27/23	20:00	37.8	0.173
10/27/23	21:00	37.8	0.173
10/27/23	22:00	37.8	0.174
10/27/23	23:00	37.8	0.173
10/28/23	00:00	37.9	0.175
10/28/23	01:00	37.9	0.175
10/28/23	02:00	37.9	0.175
10/28/23	03:00	38.0	0.175
10/28/23	04:00	38.0	0.176
10/28/23	05:00	38.0	0.176
10/28/23	06:00	38.0	0.176
10/28/23	07:00	38.0	0.176
10/28/23	08:00	38.0	0.177
10/28/23	09:00	38.2	0.178
10/28/23	10:00	38.3	0.179
10/28/23	11:00	37.4	0.179
10/28/23	12:00	37.5	0.180
10/28/23	13:00	37.5	0.180
10/28/23	14:00	37.4	0.179
10/28/23	15:00	37.4	0.180
10/28/23	16:00	37.5	0.180
10/28/23	17:00	37.3	0.180
10/28/23	18:00	37.3	0.180
10/28/23	19:00	37.4	0.181
10/28/23	20:00	37.5	0.182
10/28/23	21:00	37.6	0.183
10/28/23	22:00	37.5	0.183
10/28/23	23:00	37.5	0.183
10/29/23	00:00	37.4	0.183
10/29/23	01:00	37.3	0.183
10/29/23	02:00	37.2	0.183
10/29/23	03:00	37.1	0.182
10/29/23	04:00	37.0	0.182
10/29/23	05:00	36.8	0.182
10/29/23	06:00	36.8	0.181
10/29/23	07:00	36.6	0.181
10/29/23	08:00	36.5	0.180
10/29/23	09:00	36.4	0.180
10/29/23	10:00	36.4	0.180
10/29/23	11:00	36.4	0.180
10/29/23	12:00	36.4	0.181
10/29/23	13:00	36.5	0.181

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/29/23	14:00	36.5	0.181
10/29/23	15:00	36.4	0.180
10/29/23	16:00	37.5	0.180
10/29/23	17:00	41.4	0.184
10/29/23	18:00	45.4	0.186
10/29/23	19:00	47.3	0.187
10/29/23	20:00	47.1	0.186
10/29/23	21:00	46.8	0.185
10/29/23	22:00	46.7	0.184
10/29/23	23:00	46.7	0.184
10/30/23	00:00	46.8	0.184
10/30/23	01:00	46.7	0.184
10/30/23	02:00	46.7	0.183
10/30/23	03:00	46.6	0.183
10/30/23	04:00	46.5	0.183
10/30/23	05:00	46.5	0.182
10/30/23	06:00	47.5	0.183
10/30/23	07:00	51.5	0.186
10/30/23	08:00	55.8	0.190
10/30/23	09:00	58.2	0.193
10/30/23	10:00	58.2	0.191
10/30/23	11:00	57.8	0.189
10/30/23	12:00	57.5	0.187
10/30/23	13:00	57.2	0.186
10/30/23	14:00	57.2	0.186
10/30/23	15:00	57.1	0.185
10/30/23	16:00	56.7	0.185
10/30/23	17:00	53.7	0.182
10/30/23	18:00	50.8	0.180
10/30/23	19:00	49.1	0.178
10/30/23	20:00	49.1	0.178
10/30/23	21:00	49.0	0.178
10/30/23	22:00	49.0	0.178
10/30/23	23:00	48.8	0.177
10/31/23	00:00	48.7	0.177
10/31/23	01:00	48.7	0.177
10/31/23	02:00	48.6	0.177
10/31/23	03:00	48.3	0.175
10/31/23	04:00	47.8	0.172
10/31/23	05:00	47.4	0.171
10/31/23	06:00	48.4	0.172
10/31/23	07:00	48.6	0.173
10/31/23	08:00	46.2	0.170
10/31/23	09:00	43.7	0.167
10/31/23	10:00	43.7	0.168
10/31/23	11:00	43.8	0.169
10/31/23	12:00	44.1	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
10/31/23	13:00	44.2	0.171
10/31/23	14:00	44.2	0.171
10/31/23	15:00	44.2	0.172
10/31/23	16:00	45.1	0.173
10/31/23	17:00	48.4	0.176
10/31/23	18:00	50.5	0.178
10/31/23	19:00	54.6	0.182
10/31/23	20:00	56.2	0.183
10/31/23	21:00	56.0	0.182
10/31/23	22:00	55.8	0.181
10/31/23	23:00	55.6	0.180
11/01/23	00:00	55.2	0.178
11/01/23	01:00	55.1	0.177
11/01/23	02:00	54.9	0.176
11/01/23	03:00	55.1	0.177
11/01/23	04:00	56.5	0.178
11/01/23	05:00	60.6	0.183
11/01/23	06:00	62.7	0.184
11/01/23	07:00	62.5	0.184
11/01/23	08:00	64.6	0.185
11/01/23	09:00	66.0	0.186
11/01/23	10:00	66.0	0.186
11/01/23	11:00	66.0	0.186
11/01/23	12:00	65.8	0.184
11/01/23	13:00	65.7	0.184
11/01/23	14:00	65.5	0.183
11/01/23	15:00	65.3	0.182
11/01/23	16:00	64.5	0.180
11/01/23	17:00	64.1	0.179
11/01/23	18:00	64.8	0.179
11/01/23	19:00	64.4	0.179
11/01/23	20:00	64.4	0.179
11/01/23	21:00	64.4	0.179
11/01/23	22:00	64.3	0.179
11/01/23	23:00	64.3	0.178
11/02/23	00:00	64.4	0.179
11/02/23	01:00	64.3	0.179
11/02/23	02:00	64.2	0.178
11/02/23	03:00	64.1	0.178
11/02/23	04:00	62.9	0.177
11/02/23	05:00	60.0	0.174
11/02/23	06:00	58.9	0.171
11/02/23	07:00	58.9	0.172
11/02/23	08:00	58.9	0.172
11/02/23	09:00	60.2	0.174
11/02/23	10:00	60.1	0.173
11/02/23	11:00	60.1	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/02/23	12:00	60.1	0.173
11/02/23	13:00	60.3	0.174
11/02/23	14:00	60.2	0.173
11/02/23	15:00	60.3	0.174
11/02/23	16:00	59.2	0.174
11/02/23	17:00	55.3	0.171
11/02/23	18:00	51.4	0.167
11/02/23	19:00	47.4	0.164
11/02/23	20:00	45.9	0.163
11/02/23	21:00	46.2	0.165
11/02/23	22:00	46.6	0.167
11/02/23	23:00	46.9	0.168
11/03/23	00:00	47.4	0.170
11/03/23	01:00	47.7	0.172
11/03/23	02:00	48.1	0.174
11/03/23	03:00	48.5	0.176
11/03/23	04:00	48.8	0.178
11/03/23	05:00	48.0	0.178
11/03/23	06:00	44.9	0.176
11/03/23	07:00	40.9	0.172
11/03/23	08:00	36.7	0.168
11/03/23	09:00	33.9	0.165
11/03/23	10:00	34.3	0.167
11/03/23	11:00	34.5	0.168
11/03/23	12:00	34.7	0.169
11/03/23	13:00	35.3	0.169
11/03/23	14:00	35.7	0.171
11/03/23	15:00	35.9	0.172
11/03/23	16:00	36.0	0.172
11/03/23	17:00	36.1	0.173
11/03/23	18:00	36.0	0.173
11/03/23	19:00	36.1	0.173
11/03/23	20:00	36.1	0.173
11/03/23	21:00	36.1	0.173
11/03/23	22:00	36.1	0.172
11/03/23	23:00	36.0	0.172
11/04/23	00:00	35.9	0.172
11/04/23	01:00	35.7	0.171
11/04/23	02:00	35.7	0.170
11/04/23	03:00	35.7	0.170
11/04/23	04:00	35.6	0.170
11/04/23	05:00	35.6	0.170
11/04/23	06:00	35.7	0.170
11/04/23	07:00	35.7	0.170
11/04/23	08:00	35.9	0.171
11/04/23	09:00	35.9	0.171
11/04/23	10:00	35.7	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/04/23	11:00	35.6	0.169
11/04/23	12:00	35.6	0.169
11/04/23	13:00	35.0	0.169
11/04/23	14:00	34.9	0.168
11/04/23	15:00	34.8	0.168
11/04/23	16:00	34.8	0.167
11/04/23	17:00	34.7	0.166
11/04/23	18:00	34.7	0.166
11/04/23	19:00	34.8	0.166
11/04/23	20:00	34.8	0.166
11/04/23	21:00	34.9	0.166
11/04/23	22:00	34.9	0.167
11/04/23	23:00	35.0	0.167
11/05/23	00:00	35.1	0.167
11/05/23	01:00	35.2	0.168
11/05/23	02:00	35.3	0.169
11/05/23	03:00	35.4	0.170
11/05/23	04:00	35.4	0.170
11/05/23	05:00	35.5	0.170
11/05/23	06:00	35.6	0.171
11/05/23	07:00	35.7	0.171
11/05/23	08:00	35.9	0.172
11/05/23	09:00	36.0	0.173
11/05/23	10:00	36.0	0.173
11/05/23	11:00	36.0	0.174
11/05/23	12:00	36.0	0.174
11/05/23	13:00	36.1	0.174
11/05/23	14:00	36.1	0.174
11/05/23	15:00	36.2	0.175
11/05/23	16:00	36.2	0.175
11/05/23	17:00	36.2	0.175
11/05/23	18:00	36.1	0.175
11/05/23	19:00	36.0	0.175
11/05/23	20:00	36.0	0.175
11/05/23	21:00	35.9	0.175
11/05/23	22:00	35.8	0.174
11/05/23	23:00	35.8	0.174
11/06/23	00:00	35.8	0.174
11/06/23	01:00	35.7	0.174
11/06/23	02:00	35.5	0.173
11/06/23	03:00	35.4	0.172
11/06/23	04:00	35.3	0.172
11/06/23	05:00	35.1	0.171
11/06/23	06:00	34.9	0.171
11/06/23	07:00	34.8	0.170
11/06/23	08:00	34.5	0.169
11/06/23	09:00	34.4	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/06/23	10:00	34.3	0.167
11/06/23	11:00	34.1	0.167
11/06/23	12:00	34.0	0.166
11/06/23	13:00	33.9	0.165
11/06/23	14:00	33.9	0.165
11/06/23	15:00	33.8	0.165
11/06/23	16:00	33.8	0.164
11/06/23	17:00	35.1	0.165
11/06/23	18:00	37.7	0.165
11/06/23	19:00	39.4	0.165
11/06/23	20:00	39.6	0.165
11/06/23	21:00	39.7	0.166
11/06/23	22:00	39.7	0.165
11/06/23	23:00	39.7	0.165
11/07/23	00:00	39.8	0.165
11/07/23	01:00	40.0	0.166
11/07/23	02:00	40.1	0.166
11/07/23	03:00	40.1	0.166
11/07/23	04:00	40.3	0.166
11/07/23	05:00	40.5	0.167
11/07/23	06:00	40.6	0.168
11/07/23	07:00	40.8	0.168
11/07/23	08:00	41.0	0.169
11/07/23	09:00	41.2	0.170
11/07/23	10:00	41.4	0.170
11/07/23	11:00	41.5	0.171
11/07/23	12:00	41.6	0.171
11/07/23	13:00	41.7	0.172
11/07/23	14:00	41.8	0.172
11/07/23	15:00	41.9	0.173
11/07/23	16:00	41.9	0.173
11/07/23	17:00	40.7	0.173
11/07/23	18:00	38.1	0.172
11/07/23	19:00	36.5	0.172
11/07/23	20:00	36.3	0.172
11/07/23	21:00	36.2	0.172
11/07/23	22:00	36.2	0.172
11/07/23	23:00	36.2	0.173
11/08/23	00:00	36.2	0.173
11/08/23	01:00	36.0	0.172
11/08/23	02:00	36.1	0.173
11/08/23	03:00	36.2	0.173
11/08/23	04:00	36.3	0.174
11/08/23	05:00	36.2	0.174
11/08/23	06:00	36.1	0.174
11/08/23	07:00	36.0	0.173
11/08/23	08:00	36.0	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/08/23	09:00	35.9	0.173
11/08/23	10:00	35.9	0.173
11/08/23	11:00	35.7	0.173
11/08/23	12:00	35.6	0.172
11/08/23	13:00	35.4	0.171
11/08/23	14:00	35.3	0.171
11/08/23	15:00	35.2	0.170
11/08/23	16:00	35.1	0.169
11/08/23	17:00	34.9	0.169
11/08/23	18:00	34.8	0.168
11/08/23	19:00	34.7	0.168
11/08/23	20:00	34.7	0.168
11/08/23	21:00	34.6	0.167
11/08/23	22:00	34.5	0.166
11/08/23	23:00	34.4	0.165
11/09/23	00:00	34.4	0.164
11/09/23	01:00	34.4	0.164
11/09/23	02:00	34.4	0.163
11/09/23	03:00	34.4	0.163
11/09/23	04:00	34.4	0.162
11/09/23	05:00	34.5	0.162
11/09/23	06:00	34.7	0.162
11/09/23	07:00	34.7	0.162
11/09/23	08:00	34.7	0.161
11/09/23	09:00	34.8	0.161
11/09/23	10:00	34.9	0.162
11/09/23	11:00	35.1	0.162
11/09/23	12:00	35.2	0.163
11/09/23	13:00	35.4	0.163
11/09/23	14:00	35.5	0.164
11/09/23	15:00	35.8	0.165
11/09/23	16:00	36.0	0.166
11/09/23	17:00	36.2	0.167
11/09/23	18:00	36.4	0.168
11/09/23	19:00	36.6	0.169
11/09/23	20:00	36.6	0.169
11/09/23	21:00	36.7	0.169
11/09/23	22:00	36.8	0.170
11/09/23	23:00	36.8	0.170
11/10/23	00:00	36.7	0.171
11/10/23	01:00	36.7	0.171
11/10/23	02:00	36.6	0.171
11/10/23	03:00	36.6	0.172
11/10/23	04:00	36.5	0.171
11/10/23	05:00	36.4	0.171
11/10/23	06:00	36.3	0.171
11/10/23	07:00	36.3	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/10/23	08:00	36.3	0.172
11/10/23	09:00	36.2	0.172
11/10/23	10:00	36.1	0.171
11/10/23	11:00	36.0	0.171
11/10/23	12:00	36.0	0.171
11/10/23	13:00	35.9	0.171
11/10/23	14:00	35.8	0.170
11/10/23	15:00	35.6	0.170
11/10/23	16:00	36.3	0.169
11/10/23	17:00	39.3	0.170
11/10/23	18:00	39.9	0.167
11/10/23	19:00	39.7	0.166
11/10/23	20:00	39.6	0.166
11/10/23	21:00	39.6	0.166
11/10/23	22:00	39.6	0.166
11/10/23	23:00	39.6	0.166
11/11/23	00:00	39.6	0.166
11/11/23	01:00	39.5	0.166
11/11/23	02:00	39.5	0.165
11/11/23	03:00	39.2	0.164
11/11/23	04:00	39.2	0.164
11/11/23	05:00	39.2	0.164
11/11/23	06:00	39.1	0.164
11/11/23	07:00	39.0	0.163
11/11/23	08:00	38.9	0.163
11/11/23	09:00	38.8	0.163
11/11/23	10:00	38.8	0.163
11/11/23	11:00	38.8	0.163
11/11/23	12:00	38.8	0.163
11/11/23	13:00	38.9	0.163
11/11/23	14:00	38.9	0.163
11/11/23	15:00	39.1	0.164
11/11/23	16:00	38.3	0.165
11/11/23	17:00	35.3	0.163
11/11/23	18:00	34.5	0.165
11/11/23	19:00	34.6	0.165
11/11/23	20:00	34.6	0.165
11/11/23	21:00	34.6	0.165
11/11/23	22:00	34.5	0.164
11/11/23	23:00	34.5	0.165
11/12/23	00:00	34.6	0.165
11/12/23	01:00	34.6	0.165
11/12/23	02:00	34.7	0.165
11/12/23	03:00	34.8	0.166
11/12/23	04:00	34.8	0.166
11/12/23	05:00	34.8	0.166
11/12/23	06:00	34.8	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/12/23	07:00	34.8	0.166
11/12/23	08:00	34.8	0.166
11/12/23	09:00	34.8	0.167
11/12/23	10:00	34.9	0.167
11/12/23	11:00	34.9	0.167
11/12/23	12:00	34.9	0.167
11/12/23	13:00	34.7	0.166
11/12/23	14:00	34.8	0.166
11/12/23	15:00	34.5	0.166
11/12/23	16:00	34.5	0.166
11/12/23	17:00	34.5	0.166
11/12/23	18:00	34.5	0.165
11/12/23	19:00	34.5	0.166
11/12/23	20:00	34.5	0.166
11/12/23	21:00	34.5	0.166
11/12/23	22:00	34.6	0.166
11/12/23	23:00	34.7	0.166
11/13/23	00:00	34.8	0.167
11/13/23	01:00	34.9	0.167
11/13/23	02:00	35.1	0.169
11/13/23	03:00	35.3	0.170
11/13/23	04:00	35.4	0.170
11/13/23	05:00	35.6	0.171
11/13/23	06:00	35.9	0.173
11/13/23	07:00	36.0	0.173
11/13/23	08:00	35.9	0.172
11/13/23	09:00	36.2	0.174
11/13/23	10:00	36.5	0.175
11/13/23	11:00	36.4	0.175
11/13/23	12:00	36.4	0.174
11/13/23	13:00	36.3	0.174
11/13/23	14:00	36.2	0.174
11/13/23	15:00	36.4	0.175
11/13/23	16:00	36.6	0.176
11/13/23	17:00	36.7	0.176
11/13/23	18:00	36.6	0.176
11/13/23	19:00	36.7	0.177
11/13/23	20:00	36.7	0.177
11/13/23	21:00	36.6	0.177
11/13/23	22:00	36.6	0.177
11/13/23	23:00	36.3	0.175
11/14/23	00:00	35.8	0.173
11/14/23	01:00	35.6	0.172
11/14/23	02:00	35.4	0.172
11/14/23	03:00	35.3	0.171
11/14/23	04:00	35.2	0.171
11/14/23	05:00	35.1	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/14/23	06:00	34.9	0.171
11/14/23	07:00	34.8	0.171
11/14/23	08:00	34.9	0.172
11/14/23	09:00	34.6	0.171
11/14/23	10:00	34.3	0.170
11/14/23	11:00	34.5	0.172
11/14/23	12:00	34.7	0.173
11/14/23	13:00	34.9	0.175
11/14/23	14:00	34.8	0.174
11/14/23	15:00	35.4	0.173
11/14/23	16:00	35.3	0.172
11/14/23	17:00	35.2	0.172
11/14/23	18:00	35.4	0.173
11/14/23	19:00	35.6	0.174
11/14/23	20:00	35.6	0.174
11/14/23	21:00	35.4	0.173
11/14/23	22:00	35.4	0.174
11/14/23	23:00	35.7	0.175
11/15/23	00:00	36.2	0.178
11/15/23	01:00	36.4	0.179
11/15/23	02:00	36.3	0.179
11/15/23	03:00	36.3	0.179
11/15/23	04:00	36.3	0.179
11/15/23	05:00	36.4	0.179
11/15/23	06:00	36.4	0.179
11/15/23	07:00	36.3	0.179
11/15/23	08:00	36.3	0.178
11/15/23	09:00	36.3	0.177
11/15/23	10:00	36.3	0.178
11/15/23	11:00	36.3	0.177
11/15/23	12:00	36.2	0.177
11/15/23	13:00	36.2	0.177
11/15/23	14:00	36.4	0.177
11/15/23	15:00	35.7	0.178
11/15/23	16:00	35.7	0.179
11/15/23	17:00	35.8	0.179
11/15/23	18:00	35.6	0.178
11/15/23	19:00	35.3	0.177
11/15/23	20:00	35.2	0.176
11/15/23	21:00	35.3	0.177
11/15/23	22:00	35.2	0.176
11/15/23	23:00	35.1	0.175
11/16/23	00:00	34.8	0.174
11/16/23	01:00	34.6	0.173
11/16/23	02:00	34.5	0.172
11/16/23	03:00	34.5	0.172
11/16/23	04:00	34.4	0.171

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/16/23	05:00	34.2	0.170
11/16/23	06:00	34.0	0.169
11/16/23	07:00	34.1	0.170
11/16/23	08:00	33.9	0.169
11/16/23	09:00	34.1	0.170
11/16/23	10:00	34.0	0.169
11/16/23	11:00	34.0	0.168
11/16/23	12:00	34.0	0.169
11/16/23	13:00	34.0	0.168
11/16/23	14:00	34.0	0.168
11/16/23	15:00	34.1	0.168
11/16/23	16:00	34.0	0.167
11/16/23	17:00	34.1	0.167
11/16/23	18:00	34.3	0.168
11/16/23	19:00	34.5	0.169
11/16/23	20:00	34.6	0.169
11/16/23	21:00	34.8	0.170
11/16/23	22:00	34.8	0.170
11/16/23	23:00	34.9	0.170
11/17/23	00:00	34.9	0.170
11/17/23	01:00	35.0	0.170
11/17/23	02:00	35.0	0.170
11/17/23	03:00	35.1	0.170
11/17/23	04:00	35.0	0.169
11/17/23	05:00	35.1	0.169
11/17/23	06:00	34.9	0.168
11/17/23	07:00	34.9	0.167
11/17/23	08:00	35.1	0.167
11/17/23	09:00	34.9	0.166
11/17/23	10:00	34.8	0.166
11/17/23	11:00	34.7	0.166
11/17/23	12:00	34.7	0.164
11/17/23	13:00	34.3	0.162
11/17/23	14:00	34.3	0.162
11/17/23	15:00	34.2	0.162
11/17/23	16:00	34.2	0.162
11/17/23	17:00	34.2	0.162
11/17/23	18:00	34.1	0.162
11/17/23	19:00	34.2	0.163
11/17/23	20:00	34.2	0.163
11/17/23	21:00	34.3	0.164
11/17/23	22:00	34.4	0.165
11/17/23	23:00	34.5	0.165
11/18/23	00:00	34.6	0.166
11/18/23	01:00	34.7	0.166
11/18/23	02:00	34.9	0.167
11/18/23	03:00	34.8	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/18/23	04:00	34.9	0.168
11/18/23	05:00	34.9	0.168
11/18/23	06:00	35.2	0.169
11/18/23	07:00	35.2	0.170
11/18/23	08:00	35.1	0.170
11/18/23	09:00	35.2	0.171
11/18/23	10:00	35.4	0.172
11/18/23	11:00	35.6	0.173
11/18/23	12:00	35.8	0.175
11/18/23	13:00	36.1	0.177
11/18/23	14:00	36.3	0.178
11/18/23	15:00	36.4	0.178
11/18/23	16:00	36.3	0.177
11/18/23	17:00	36.3	0.177
11/18/23	18:00	36.1	0.177
11/18/23	19:00	36.0	0.176
11/18/23	20:00	36.0	0.176
11/18/23	21:00	36.0	0.176
11/18/23	22:00	36.0	0.176
11/18/23	23:00	35.9	0.175
11/19/23	00:00	35.7	0.174
11/19/23	01:00	35.7	0.174
11/19/23	02:00	35.7	0.174
11/19/23	03:00	35.6	0.173
11/19/23	04:00	35.8	0.175
11/19/23	05:00	35.8	0.175
11/19/23	06:00	35.9	0.175
11/19/23	07:00	36.0	0.175
11/19/23	08:00	36.1	0.175
11/19/23	09:00	36.0	0.175
11/19/23	10:00	35.9	0.175
11/19/23	11:00	35.9	0.175
11/19/23	12:00	35.7	0.174
11/19/23	13:00	35.6	0.173
11/19/23	14:00	35.4	0.172
11/19/23	15:00	35.3	0.171
11/19/23	16:00	35.2	0.171
11/19/23	17:00	35.1	0.171
11/19/23	18:00	35.1	0.171
11/19/23	19:00	35.1	0.171
11/19/23	20:00	35.1	0.171
11/19/23	21:00	35.3	0.172
11/19/23	22:00	35.3	0.172
11/19/23	23:00	35.3	0.172
11/20/23	00:00	35.3	0.173
11/20/23	01:00	35.3	0.172
11/20/23	02:00	35.5	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/20/23	03:00	35.6	0.174
11/20/23	04:00	35.5	0.174
11/20/23	05:00	35.5	0.173
11/20/23	06:00	35.4	0.173
11/20/23	07:00	35.3	0.172
11/20/23	08:00	35.2	0.171
11/20/23	09:00	35.2	0.171
11/20/23	10:00	35.2	0.171
11/20/23	11:00	35.1	0.171
11/20/23	12:00	35.1	0.170
11/20/23	13:00	35.1	0.171
11/20/23	14:00	35.1	0.171
11/20/23	15:00	35.3	0.171
11/20/23	16:00	35.3	0.171
11/20/23	17:00	35.3	0.171
11/20/23	18:00	35.3	0.171
11/20/23	19:00	35.2	0.171
11/20/23	20:00	35.2	0.170
11/20/23	21:00	35.0	0.169
11/20/23	22:00	35.1	0.169
11/20/23	23:00	35.1	0.169
11/21/23	00:00	35.2	0.169
11/21/23	01:00	35.1	0.168
11/21/23	02:00	35.0	0.168
11/21/23	03:00	34.9	0.167
11/21/23	04:00	34.9	0.167
11/21/23	05:00	34.9	0.167
11/21/23	06:00	34.9	0.167
11/21/23	07:00	34.8	0.166
11/21/23	08:00	34.7	0.166
11/21/23	09:00	34.6	0.165
11/21/23	10:00	34.5	0.164
11/21/23	11:00	34.5	0.164
11/21/23	12:00	34.5	0.163
11/21/23	13:00	34.4	0.162
11/21/23	14:00	34.8	0.161
11/21/23	15:00	34.5	0.159
11/21/23	16:00	34.4	0.158
11/21/23	17:00	34.3	0.158
11/21/23	18:00	34.4	0.158
11/21/23	19:00	34.3	0.158
11/21/23	20:00	34.3	0.157
11/21/23	21:00	34.3	0.158
11/21/23	22:00	34.4	0.158
11/21/23	23:00	34.2	0.157
11/22/23	00:00	34.1	0.156
11/22/23	01:00	33.9	0.155

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/22/23	02:00	33.8	0.154
11/22/23	03:00	33.7	0.153
11/22/23	04:00	33.6	0.153
11/22/23	05:00	33.7	0.153
11/22/23	06:00	33.8	0.154
11/22/23	07:00	33.9	0.154
11/22/23	08:00	33.9	0.154
11/22/23	09:00	34.0	0.155
11/22/23	10:00	33.9	0.154
11/22/23	11:00	33.8	0.154
11/22/23	12:00	33.8	0.154
11/22/23	13:00	33.7	0.153
11/22/23	14:00	33.0	0.154
11/22/23	15:00	33.2	0.154
11/22/23	16:00	33.3	0.154
11/22/23	17:00	33.2	0.154
11/22/23	18:00	33.2	0.154
11/22/23	19:00	33.3	0.155
11/22/23	20:00	33.4	0.155
11/22/23	21:00	33.3	0.155
11/22/23	22:00	33.2	0.154
11/22/23	23:00	33.4	0.155
11/23/23	00:00	33.5	0.156
11/23/23	01:00	33.8	0.157
11/23/23	02:00	33.9	0.157
11/23/23	03:00	34.1	0.159
11/23/23	04:00	34.2	0.159
11/23/23	05:00	34.2	0.159
11/23/23	06:00	34.3	0.159
11/23/23	07:00	34.2	0.159
11/23/23	08:00	34.4	0.160
11/23/23	09:00	34.6	0.161
11/23/23	10:00	34.8	0.162
11/23/23	11:00	34.9	0.163
11/23/23	12:00	35.0	0.164
11/23/23	13:00	35.2	0.165
11/23/23	14:00	35.4	0.166
11/23/23	15:00	35.6	0.167
11/23/23	16:00	35.7	0.168
11/23/23	17:00	35.9	0.169
11/23/23	18:00	35.9	0.170
11/23/23	19:00	35.8	0.169
11/23/23	20:00	35.6	0.168
11/23/23	21:00	35.5	0.168
11/23/23	22:00	35.5	0.168
11/23/23	23:00	35.4	0.168
11/24/23	00:00	35.4	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/24/23	01:00	35.3	0.168
11/24/23	02:00	35.3	0.168
11/24/23	03:00	35.2	0.168
11/24/23	04:00	35.0	0.167
11/24/23	05:00	34.9	0.166
11/24/23	06:00	34.8	0.166
11/24/23	07:00	34.8	0.166
11/24/23	08:00	34.6	0.166
11/24/23	09:00	34.4	0.165
11/24/23	10:00	34.3	0.165
11/24/23	11:00	34.4	0.165
11/24/23	12:00	34.5	0.166
11/24/23	13:00	34.4	0.165
11/24/23	14:00	34.4	0.165
11/24/23	15:00	34.2	0.165
11/24/23	16:00	34.3	0.165
11/24/23	17:00	34.2	0.165
11/24/23	18:00	34.2	0.165
11/24/23	19:00	34.2	0.165
11/24/23	20:00	34.2	0.165
11/24/23	21:00	34.2	0.165
11/24/23	22:00	34.3	0.165
11/24/23	23:00	34.5	0.166
11/25/23	00:00	34.7	0.166
11/25/23	01:00	34.7	0.166
11/25/23	02:00	34.6	0.166
11/25/23	03:00	34.6	0.166
11/25/23	04:00	34.6	0.166
11/25/23	05:00	34.6	0.166
11/25/23	06:00	34.6	0.166
11/25/23	07:00	34.6	0.166
11/25/23	08:00	34.6	0.166
11/25/23	09:00	34.7	0.166
11/25/23	10:00	34.7	0.167
11/25/23	11:00	35.0	0.166
11/25/23	12:00	35.3	0.165
11/25/23	13:00	35.4	0.166
11/25/23	14:00	35.4	0.167
11/25/23	15:00	35.5	0.167
11/25/23	16:00	35.5	0.167
11/25/23	17:00	35.7	0.168
11/25/23	18:00	35.8	0.169
11/25/23	19:00	35.9	0.169
11/25/23	20:00	36.0	0.170
11/25/23	21:00	36.0	0.170
11/25/23	22:00	35.9	0.170
11/25/23	23:00	35.8	0.169

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/26/23	00:00	35.7	0.168
11/26/23	01:00	35.6	0.167
11/26/23	02:00	36.0	0.168
11/26/23	03:00	36.3	0.169
11/26/23	04:00	36.5	0.170
11/26/23	05:00	36.7	0.171
11/26/23	06:00	36.8	0.171
11/26/23	07:00	36.9	0.171
11/26/23	08:00	37.1	0.172
11/26/23	09:00	37.2	0.172
11/26/23	10:00	37.2	0.172
11/26/23	11:00	36.8	0.172
11/26/23	12:00	36.5	0.172
11/26/23	13:00	36.6	0.172
11/26/23	14:00	36.6	0.171
11/26/23	15:00	36.5	0.171
11/26/23	16:00	36.3	0.170
11/26/23	17:00	36.2	0.169
11/26/23	18:00	36.3	0.169
11/26/23	19:00	36.5	0.170
11/26/23	20:00	36.6	0.171
11/26/23	21:00	36.7	0.171
11/26/23	22:00	36.8	0.172
11/26/23	23:00	36.9	0.173
11/27/23	00:00	36.9	0.173
11/27/23	01:00	37.1	0.174
11/27/23	02:00	37.0	0.174
11/27/23	03:00	36.8	0.174
11/27/23	04:00	36.7	0.174
11/27/23	05:00	36.6	0.174
11/27/23	06:00	36.7	0.175
11/27/23	07:00	36.8	0.175
11/27/23	08:00	36.8	0.175
11/27/23	09:00	36.8	0.176
11/27/23	10:00	36.7	0.176
11/27/23	11:00	36.7	0.176
11/27/23	12:00	36.7	0.176
11/27/23	13:00	36.6	0.176
11/27/23	14:00	36.8	0.176
11/27/23	15:00	36.8	0.176
11/27/23	16:00	36.7	0.176
11/27/23	17:00	36.7	0.176
11/27/23	18:00	36.5	0.176
11/27/23	19:00	36.3	0.175
11/27/23	20:00	36.1	0.173
11/27/23	21:00	35.9	0.173
11/27/23	22:00	35.9	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/27/23	23:00	35.8	0.172
11/28/23	00:00	35.8	0.172
11/28/23	01:00	35.8	0.172
11/28/23	02:00	35.9	0.172
11/28/23	03:00	35.9	0.172
11/28/23	04:00	35.9	0.171
11/28/23	05:00	35.9	0.171
11/28/23	06:00	37.2	0.172
11/28/23	07:00	40.7	0.173
11/28/23	08:00	42.1	0.173
11/28/23	09:00	42.0	0.173
11/28/23	10:00	42.2	0.174
11/28/23	11:00	42.2	0.174
11/28/23	12:00	42.2	0.175
11/28/23	13:00	42.2	0.175
11/28/23	14:00	42.1	0.175
11/28/23	15:00	42.2	0.175
11/28/23	16:00	42.2	0.175
11/28/23	17:00	42.2	0.175
11/28/23	18:00	42.2	0.175
11/28/23	19:00	42.2	0.174
11/28/23	20:00	42.1	0.174
11/28/23	21:00	42.0	0.173
11/28/23	22:00	41.6	0.172
11/28/23	23:00	41.4	0.171
11/29/23	00:00	41.2	0.170
11/29/23	01:00	40.9	0.168
11/29/23	02:00	40.6	0.167
11/29/23	03:00	40.4	0.166
11/29/23	04:00	40.2	0.165
11/29/23	05:00	40.0	0.164
11/29/23	06:00	39.8	0.164
11/29/23	07:00	40.2	0.165
11/29/23	08:00	40.5	0.165
11/29/23	09:00	40.3	0.164
11/29/23	10:00	40.3	0.164
11/29/23	11:00	40.5	0.164
11/29/23	12:00	40.6	0.165
11/29/23	13:00	40.7	0.165
11/29/23	14:00	40.8	0.166
11/29/23	15:00	40.9	0.167
11/29/23	16:00	40.8	0.167
11/29/23	17:00	40.5	0.165
11/29/23	18:00	40.4	0.164
11/29/23	19:00	40.3	0.164
11/29/23	20:00	40.2	0.163
11/29/23	21:00	40.3	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
11/29/23	22:00	40.4	0.164
11/29/23	23:00	40.5	0.165
11/30/23	00:00	40.6	0.165
11/30/23	01:00	40.6	0.165
11/30/23	02:00	40.5	0.165
11/30/23	03:00	40.4	0.164
11/30/23	04:00	40.4	0.164
11/30/23	05:00	40.3	0.163
11/30/23	06:00	38.9	0.162
11/30/23	07:00	34.8	0.158
11/30/23	08:00	32.7	0.155
11/30/23	09:00	32.7	0.155
11/30/23	10:00	32.8	0.155
11/30/23	11:00	32.9	0.157
11/30/23	12:00	32.6	0.155
11/30/23	13:00	32.3	0.153
11/30/23	14:00	32.1	0.152
11/30/23	15:00	31.8	0.150
11/30/23	16:00	31.9	0.151
11/30/23	17:00	32.1	0.152
11/30/23	18:00	32.2	0.153
11/30/23	19:00	32.4	0.154
11/30/23	20:00	32.6	0.155
11/30/23	21:00	32.7	0.156
11/30/23	22:00	32.9	0.158
11/30/23	23:00	33.0	0.159
12/01/23	00:00	33.2	0.160
12/01/23	01:00	33.5	0.162
12/01/23	02:00	33.8	0.164
12/01/23	03:00	34.1	0.166
12/01/23	04:00	34.4	0.168
12/01/23	05:00	34.8	0.171
12/01/23	06:00	35.1	0.172
12/01/23	07:00	35.3	0.174
12/01/23	08:00	35.6	0.176
12/01/23	09:00	35.8	0.178
12/01/23	10:00	35.7	0.178
12/01/23	11:00	35.4	0.177
12/01/23	12:00	35.6	0.178
12/01/23	13:00	35.7	0.178
12/01/23	14:00	35.7	0.179
12/01/23	15:00	36.7	0.180
12/01/23	16:00	36.7	0.179
12/01/23	17:00	36.5	0.178
12/01/23	18:00	36.7	0.178
12/01/23	19:00	36.7	0.178
12/01/23	20:00	36.6	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/01/23	21:00	36.5	0.176
12/01/23	22:00	36.5	0.176
12/01/23	23:00	36.5	0.175
12/02/23	00:00	36.4	0.175
12/02/23	01:00	36.2	0.173
12/02/23	02:00	36.1	0.172
12/02/23	03:00	36.1	0.171
12/02/23	04:00	36.0	0.171
12/02/23	05:00	35.8	0.169
12/02/23	06:00	35.6	0.167
12/02/23	07:00	35.3	0.166
12/02/23	08:00	35.1	0.164
12/02/23	09:00	35.0	0.163
12/02/23	10:00	34.8	0.161
12/02/23	11:00	34.7	0.160
12/02/23	12:00	34.5	0.159
12/02/23	13:00	34.5	0.159
12/02/23	14:00	34.4	0.158
12/02/23	15:00	33.7	0.158
12/02/23	16:00	33.7	0.159
12/02/23	17:00	33.8	0.159
12/02/23	18:00	33.7	0.158
12/02/23	19:00	33.7	0.159
12/02/23	20:00	33.5	0.158
12/02/23	21:00	33.6	0.159
12/02/23	22:00	33.6	0.159
12/02/23	23:00	33.6	0.159
12/03/23	00:00	33.6	0.159
12/03/23	01:00	33.7	0.160
12/03/23	02:00	33.7	0.160
12/03/23	03:00	33.8	0.161
12/03/23	04:00	33.9	0.161
12/03/23	05:00	34.0	0.162
12/03/23	06:00	34.1	0.163
12/03/23	07:00	34.1	0.163
12/03/23	08:00	34.3	0.164
12/03/23	09:00	34.3	0.165
12/03/23	10:00	34.3	0.165
12/03/23	11:00	34.5	0.166
12/03/23	12:00	34.6	0.167
12/03/23	13:00	34.7	0.168
12/03/23	14:00	34.8	0.168
12/03/23	15:00	34.7	0.168
12/03/23	16:00	34.6	0.167
12/03/23	17:00	34.6	0.167
12/03/23	18:00	34.6	0.167
12/03/23	19:00	34.5	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/03/23	20:00	34.6	0.166
12/03/23	21:00	34.6	0.166
12/03/23	22:00	34.7	0.166
12/03/23	23:00	34.7	0.167
12/04/23	00:00	34.8	0.167
12/04/23	01:00	34.8	0.167
12/04/23	02:00	34.8	0.167
12/04/23	03:00	34.8	0.167
12/04/23	04:00	34.7	0.166
12/04/23	05:00	34.6	0.166
12/04/23	06:00	34.6	0.166
12/04/23	07:00	34.6	0.166
12/04/23	08:00	34.4	0.165
12/04/23	09:00	34.3	0.164
12/04/23	10:00	34.2	0.164
12/04/23	11:00	34.1	0.163
12/04/23	12:00	33.9	0.162
12/04/23	13:00	33.8	0.162
12/04/23	14:00	33.8	0.162
12/04/23	15:00	33.8	0.161
12/04/23	16:00	33.7	0.161
12/04/23	17:00	33.7	0.162
12/04/23	18:00	33.6	0.161
12/04/23	19:00	33.6	0.162
12/04/23	20:00	33.6	0.162
12/04/23	21:00	33.4	0.161
12/04/23	22:00	33.3	0.160
12/04/23	23:00	33.2	0.160
12/05/23	00:00	33.1	0.159
12/05/23	01:00	32.9	0.158
12/05/23	02:00	32.8	0.158
12/05/23	03:00	32.8	0.158
12/05/23	04:00	32.8	0.157
12/05/23	05:00	32.8	0.157
12/05/23	06:00	33.8	0.157
12/05/23	07:00	36.9	0.158
12/05/23	08:00	38.7	0.159
12/05/23	09:00	38.7	0.159
12/05/23	10:00	38.7	0.160
12/05/23	11:00	38.7	0.160
12/05/23	12:00	38.7	0.160
12/05/23	13:00	38.8	0.160
12/05/23	14:00	39.0	0.160
12/05/23	15:00	39.0	0.161
12/05/23	16:00	39.1	0.162
12/05/23	17:00	39.2	0.162
12/05/23	18:00	39.4	0.163

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/05/23	19:00	39.6	0.164
12/05/23	20:00	39.8	0.164
12/05/23	21:00	39.9	0.165
12/05/23	22:00	40.1	0.166
12/05/23	23:00	40.3	0.167
12/06/23	00:00	40.5	0.168
12/06/23	01:00	40.8	0.169
12/06/23	02:00	41.0	0.169
12/06/23	03:00	41.2	0.169
12/06/23	04:00	41.2	0.170
12/06/23	05:00	41.3	0.170
12/06/23	06:00	42.6	0.171
12/06/23	07:00	45.5	0.173
12/06/23	08:00	43.8	0.173
12/06/23	09:00	43.8	0.173
12/06/23	10:00	43.8	0.173
12/06/23	11:00	43.8	0.173
12/06/23	12:00	43.8	0.174
12/06/23	13:00	43.8	0.174
12/06/23	14:00	43.8	0.174
12/06/23	15:00	42.3	0.174
12/06/23	16:00	42.5	0.175
12/06/23	17:00	42.8	0.176
12/06/23	18:00	43.1	0.177
12/06/23	19:00	43.3	0.178
12/06/23	20:00	43.5	0.178
12/06/23	21:00	43.5	0.178
12/06/23	22:00	43.7	0.179
12/06/23	23:00	43.9	0.179
12/07/23	00:00	44.0	0.180
12/07/23	01:00	44.1	0.180
12/07/23	02:00	44.1	0.180
12/07/23	03:00	44.2	0.179
12/07/23	04:00	44.3	0.179
12/07/23	05:00	44.4	0.179
12/07/23	06:00	44.4	0.179
12/07/23	07:00	44.5	0.180
12/07/23	08:00	44.5	0.180
12/07/23	09:00	44.4	0.179
12/07/23	10:00	44.4	0.179
12/07/23	11:00	44.5	0.179
12/07/23	12:00	43.4	0.178
12/07/23	13:00	39.8	0.178
12/07/23	14:00	38.5	0.178
12/07/23	15:00	38.7	0.179
12/07/23	16:00	38.8	0.180
12/07/23	17:00	38.9	0.180

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/07/23	18:00	38.9	0.181
12/07/23	19:00	39.0	0.181
12/07/23	20:00	39.0	0.182
12/07/23	21:00	39.0	0.182
12/07/23	22:00	39.0	0.182
12/07/23	23:00	39.1	0.183
12/08/23	00:00	39.0	0.183
12/08/23	01:00	38.8	0.182
12/08/23	02:00	38.6	0.180
12/08/23	03:00	38.4	0.180
12/08/23	04:00	38.1	0.179
12/08/23	05:00	37.9	0.178
12/08/23	06:00	37.6	0.176
12/08/23	07:00	37.4	0.175
12/08/23	08:00	37.3	0.175
12/08/23	09:00	37.3	0.175
12/08/23	10:00	37.3	0.175
12/08/23	11:00	37.2	0.175
12/08/23	12:00	37.1	0.174
12/08/23	13:00	37.8	0.174
12/08/23	14:00	37.8	0.174
12/08/23	15:00	37.6	0.173
12/08/23	16:00	37.4	0.172
12/08/23	17:00	37.3	0.171
12/08/23	18:00	37.2	0.171
12/08/23	19:00	37.1	0.171
12/08/23	20:00	37.0	0.170
12/08/23	21:00	37.0	0.170
12/08/23	22:00	37.0	0.170
12/08/23	23:00	36.9	0.169
12/09/23	00:00	36.9	0.169
12/09/23	01:00	37.0	0.170
12/09/23	02:00	37.0	0.170
12/09/23	03:00	37.2	0.171
12/09/23	04:00	37.4	0.172
12/09/23	05:00	37.6	0.172
12/09/23	06:00	37.7	0.173
12/09/23	07:00	37.8	0.173
12/09/23	08:00	37.7	0.172
12/09/23	09:00	37.7	0.172
12/09/23	10:00	37.7	0.172
12/09/23	11:00	37.7	0.172
12/09/23	12:00	37.7	0.171
12/09/23	13:00	36.8	0.171
12/09/23	14:00	36.6	0.170
12/09/23	15:00	36.7	0.170
12/09/23	16:00	36.6	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/09/23	17:00	36.6	0.169
12/09/23	18:00	36.4	0.168
12/09/23	19:00	36.3	0.168
12/09/23	20:00	36.2	0.167
12/09/23	21:00	36.1	0.167
12/09/23	22:00	36.1	0.167
12/09/23	23:00	36.1	0.166
12/10/23	00:00	36.0	0.166
12/10/23	01:00	36.1	0.166
12/10/23	02:00	36.2	0.166
12/10/23	03:00	36.1	0.166
12/10/23	04:00	36.0	0.165
12/10/23	05:00	35.9	0.165
12/10/23	06:00	35.9	0.165
12/10/23	07:00	36.0	0.166
12/10/23	08:00	36.0	0.166
12/10/23	09:00	35.9	0.166
12/10/23	10:00	35.9	0.166
12/10/23	11:00	35.9	0.166
12/10/23	12:00	35.9	0.166
12/10/23	13:00	35.9	0.166
12/10/23	14:00	36.0	0.167
12/10/23	15:00	36.0	0.167
12/10/23	16:00	36.1	0.167
12/10/23	17:00	36.1	0.168
12/10/23	18:00	36.1	0.167
12/10/23	19:00	36.1	0.168
12/10/23	20:00	36.2	0.168
12/10/23	21:00	36.3	0.169
12/10/23	22:00	36.3	0.168
12/10/23	23:00	36.3	0.169
12/11/23	00:00	36.4	0.169
12/11/23	01:00	36.4	0.170
12/11/23	02:00	36.4	0.170
12/11/23	03:00	36.4	0.170
12/11/23	04:00	36.5	0.170
12/11/23	05:00	36.5	0.170
12/11/23	06:00	37.7	0.171
12/11/23	07:00	40.9	0.172
12/11/23	08:00	42.5	0.172
12/11/23	09:00	42.5	0.173
12/11/23	10:00	42.5	0.173
12/11/23	11:00	42.5	0.173
12/11/23	12:00	42.6	0.174
12/11/23	13:00	42.6	0.174
12/11/23	14:00	42.6	0.174
12/11/23	15:00	42.7	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/11/23	16:00	42.7	0.175
12/11/23	17:00	42.8	0.176
12/11/23	18:00	43.0	0.176
12/11/23	19:00	42.7	0.175
12/11/23	20:00	42.5	0.174
12/11/23	21:00	42.5	0.174
12/11/23	22:00	42.2	0.173
12/11/23	23:00	41.9	0.171
12/12/23	00:00	41.5	0.169
12/12/23	01:00	41.2	0.167
12/12/23	02:00	40.9	0.166
12/12/23	03:00	40.7	0.165
12/12/23	04:00	40.6	0.164
12/12/23	05:00	40.5	0.165
12/12/23	06:00	39.5	0.165
12/12/23	07:00	36.3	0.164
12/12/23	08:00	34.9	0.164
12/12/23	09:00	34.9	0.164
12/12/23	10:00	35.0	0.164
12/12/23	11:00	35.0	0.164
12/12/23	12:00	35.0	0.164
12/12/23	13:00	35.1	0.163
12/12/23	14:00	35.2	0.163
12/12/23	15:00	35.3	0.164
12/12/23	16:00	35.3	0.164
12/12/23	17:00	35.3	0.164
12/12/23	18:00	35.2	0.163
12/12/23	19:00	35.5	0.165
12/12/23	20:00	35.8	0.166
12/12/23	21:00	35.7	0.165
12/12/23	22:00	36.1	0.168
12/12/23	23:00	36.3	0.169
12/13/23	00:00	36.6	0.171
12/13/23	01:00	36.9	0.174
12/13/23	02:00	37.2	0.176
12/13/23	03:00	37.5	0.178
12/13/23	04:00	37.6	0.179
12/13/23	05:00	37.5	0.178
12/13/23	06:00	37.5	0.178
12/13/23	07:00	37.5	0.178
12/13/23	08:00	37.2	0.177
12/13/23	09:00	37.1	0.177
12/13/23	10:00	37.1	0.177
12/13/23	11:00	37.1	0.176
12/13/23	12:00	37.1	0.176
12/13/23	13:00	37.1	0.176
12/13/23	14:00	37.2	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/13/23	15:00	37.0	0.176
12/13/23	16:00	36.9	0.176
12/13/23	17:00	37.0	0.176
12/13/23	18:00	37.0	0.177
12/13/23	19:00	37.1	0.178
12/13/23	20:00	37.2	0.178
12/13/23	21:00	37.0	0.178
12/13/23	22:00	36.6	0.175
12/13/23	23:00	36.4	0.174
12/14/23	00:00	36.1	0.172
12/14/23	01:00	36.0	0.171
12/14/23	02:00	35.9	0.170
12/14/23	03:00	36.0	0.171
12/14/23	04:00	36.0	0.171
12/14/23	05:00	36.0	0.171
12/14/23	06:00	35.9	0.171
12/14/23	07:00	35.9	0.171
12/14/23	08:00	35.8	0.171
12/14/23	09:00	35.8	0.170
12/14/23	10:00	35.7	0.170
12/14/23	11:00	35.6	0.169
12/14/23	12:00	35.4	0.169
12/14/23	13:00	35.3	0.168
12/14/23	14:00	35.1	0.167
12/14/23	15:00	35.2	0.167
12/14/23	16:00	35.2	0.168
12/14/23	17:00	35.1	0.167
12/14/23	18:00	35.0	0.166
12/14/23	19:00	34.8	0.165
12/14/23	20:00	34.6	0.164
12/14/23	21:00	34.7	0.165
12/14/23	22:00	34.9	0.166
12/14/23	23:00	35.1	0.167
12/15/23	00:00	35.3	0.168
12/15/23	01:00	35.3	0.168
12/15/23	02:00	35.3	0.168
12/15/23	03:00	35.2	0.167
12/15/23	04:00	35.2	0.167
12/15/23	05:00	35.3	0.168
12/15/23	06:00	35.4	0.168
12/15/23	07:00	35.4	0.168
12/15/23	08:00	35.5	0.168
12/15/23	09:00	35.5	0.168
12/15/23	10:00	35.6	0.169
12/15/23	11:00	35.6	0.169
12/15/23	12:00	35.7	0.170
12/15/23	13:00	35.8	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/15/23	14:00	36.4	0.170
12/15/23	15:00	36.3	0.169
12/15/23	16:00	35.9	0.167
12/15/23	17:00	35.8	0.167
12/15/23	18:00	35.8	0.167
12/15/23	19:00	35.8	0.167
12/15/23	20:00	35.9	0.168
12/15/23	21:00	35.9	0.168
12/15/23	22:00	36.1	0.169
12/15/23	23:00	36.1	0.169
12/16/23	00:00	36.2	0.170
12/16/23	01:00	36.4	0.171
12/16/23	02:00	36.4	0.171
12/16/23	03:00	36.4	0.171
12/16/23	04:00	36.4	0.172
12/16/23	05:00	36.4	0.172
12/16/23	06:00	36.4	0.172
12/16/23	07:00	36.4	0.172
12/16/23	08:00	36.5	0.173
12/16/23	09:00	36.7	0.174
12/16/23	10:00	36.8	0.174
12/16/23	11:00	36.8	0.174
12/16/23	12:00	36.7	0.173
12/16/23	13:00	36.6	0.172
12/16/23	14:00	36.0	0.172
12/16/23	15:00	35.8	0.172
12/16/23	16:00	36.0	0.173
12/16/23	17:00	35.9	0.172
12/16/23	18:00	35.9	0.172
12/16/23	19:00	36.0	0.173
12/16/23	20:00	36.1	0.173
12/16/23	21:00	36.0	0.172
12/16/23	22:00	35.9	0.171
12/16/23	23:00	35.7	0.170
12/17/23	00:00	35.6	0.170
12/17/23	01:00	35.4	0.168
12/17/23	02:00	35.4	0.168
12/17/23	03:00	35.4	0.168
12/17/23	04:00	35.3	0.167
12/17/23	05:00	35.2	0.167
12/17/23	06:00	35.1	0.166
12/17/23	07:00	34.9	0.165
12/17/23	08:00	34.8	0.164
12/17/23	09:00	34.7	0.163
12/17/23	10:00	34.7	0.163
12/17/23	11:00	34.8	0.164
12/17/23	12:00	34.9	0.164

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/17/23	13:00	35.0	0.165
12/17/23	14:00	35.1	0.165
12/17/23	15:00	35.3	0.166
12/17/23	16:00	35.4	0.167
12/17/23	17:00	35.4	0.167
12/17/23	18:00	35.4	0.167
12/17/23	19:00	35.3	0.167
12/17/23	20:00	35.2	0.166
12/17/23	21:00	35.3	0.166
12/17/23	22:00	35.3	0.166
12/17/23	23:00	35.5	0.167
12/18/23	00:00	35.6	0.168
12/18/23	01:00	35.9	0.168
12/18/23	02:00	35.8	0.168
12/18/23	03:00	35.8	0.168
12/18/23	04:00	35.6	0.166
12/18/23	05:00	35.7	0.166
12/18/23	06:00	35.8	0.167
12/18/23	07:00	36.0	0.167
12/18/23	08:00	36.1	0.167
12/18/23	09:00	36.2	0.168
12/18/23	10:00	36.2	0.168
12/18/23	11:00	36.3	0.168
12/18/23	12:00	36.4	0.168
12/18/23	13:00	36.4	0.168
12/18/23	14:00	36.3	0.168
12/18/23	15:00	35.2	0.168
12/18/23	16:00	35.2	0.168
12/18/23	17:00	35.2	0.168
12/18/23	18:00	35.2	0.168
12/18/23	19:00	35.2	0.168
12/18/23	20:00	35.2	0.168
12/18/23	21:00	35.2	0.168
12/18/23	22:00	35.2	0.168
12/18/23	23:00	35.2	0.168
12/19/23	00:00	35.2	0.168
12/19/23	01:00	35.2	0.168
12/19/23	02:00	35.2	0.168
12/19/23	03:00	35.2	0.168
12/19/23	04:00	35.2	0.168
12/19/23	05:00	35.2	0.168
12/19/23	06:00	35.2	0.168
12/19/23	07:00	35.2	0.168
12/19/23	08:00	35.2	0.168
12/19/23	09:00	35.2	0.168
12/19/23	10:00	35.2	0.168
12/19/23	11:00	35.2	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/19/23	12:00	35.2	0.168
12/19/23	13:00	35.2	0.168
12/19/23	14:00	35.2	0.168
12/19/23	15:00	35.2	0.168
12/19/23	16:00	35.2	0.168
12/19/23	17:00	35.2	0.168
12/19/23	18:00	35.2	0.168
12/19/23	19:00	35.2	0.168
12/19/23	20:00	35.2	0.168
12/19/23	21:00	35.2	0.168
12/19/23	22:00	35.2	0.168
12/19/23	23:00	35.2	0.168
12/20/23	00:00	35.2	0.168
12/20/23	01:00	35.2	0.168
12/20/23	02:00	35.2	0.168
12/20/23	03:00	35.2	0.168
12/20/23	04:00	35.2	0.168
12/20/23	05:00	35.2	0.168
12/20/23	06:00	35.2	0.168
12/20/23	07:00	35.2	0.168
12/20/23	08:00	35.2	0.168
12/20/23	09:00	35.2	0.168
12/20/23	10:00	35.2	0.168
12/20/23	11:00	35.2	0.168
12/20/23	12:00	35.2	0.168
12/20/23	13:00	35.2	0.168
12/20/23	14:00	35.2	0.168
12/20/23	15:00	35.2	0.168
12/20/23	16:00	35.2	0.168
12/20/23	17:00	35.2	0.168
12/20/23	18:00	35.2	0.168
12/20/23	19:00	35.2	0.168
12/20/23	20:00	35.2	0.168
12/20/23	21:00	35.2	0.168
12/20/23	22:00	35.2	0.168
12/20/23	23:00	35.2	0.168
12/21/23	00:00	35.2	0.168
12/21/23	01:00	35.2	0.168
12/21/23	02:00	35.2	0.168
12/21/23	03:00	35.2	0.168
12/21/23	04:00	35.2	0.168
12/21/23	05:00	35.2	0.168
12/21/23	06:00	35.2	0.168
12/21/23	07:00	35.2	0.168
12/21/23	08:00	35.2	0.168
12/21/23	09:00	35.2	0.168
12/21/23	10:00	35.2	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/21/23	11:00	35.2	0.168
12/21/23	12:00	35.2	0.168
12/21/23	13:00	35.2	0.168
12/21/23	14:00	35.2	0.168
12/21/23	15:00	35.2	0.168
12/21/23	16:00	35.2	0.168
12/21/23	17:00	35.2	0.168
12/21/23	18:00	35.2	0.168
12/21/23	19:00	35.2	0.168
12/21/23	20:00	35.2	0.168
12/21/23	21:00	35.2	0.168
12/21/23	22:00	35.2	0.168
12/21/23	23:00	35.2	0.168
12/22/23	00:00	35.2	0.168
12/22/23	01:00	35.2	0.168
12/22/23	02:00	35.2	0.168
12/22/23	03:00	35.2	0.168
12/22/23	04:00	35.2	0.168
12/22/23	05:00	35.2	0.168
12/22/23	06:00	35.2	0.168
12/22/23	07:00	35.2	0.168
12/22/23	08:00	35.2	0.168
12/22/23	09:00	35.2	0.168
12/22/23	10:00	35.2	0.168
12/22/23	11:00	35.2	0.168
12/22/23	12:00	35.2	0.168
12/22/23	13:00	35.2	0.168
12/22/23	14:00	35.2	0.168
12/22/23	15:00	35.2	0.168
12/22/23	16:00	35.2	0.168
12/22/23	17:00	35.2	0.168
12/22/23	18:00	35.2	0.168
12/22/23	19:00	35.2	0.168
12/22/23	20:00	35.2	0.168
12/22/23	21:00	33.8	0.168
12/22/23	22:00	32.4	0.169
12/22/23	23:00	31.0	0.169
12/23/23	00:00	29.6	0.169
12/23/23	01:00	28.2	0.169I
12/23/23	02:00	26.8	0.169I
12/23/23	03:00	25.5	0.170I
12/23/23	04:00	24.1	0.170I
12/23/23	05:00	22.6	0.169I
12/23/23	06:00	21.4	0.168I
12/23/23	07:00	20.4	0.169I
12/23/23	08:00	19.5	0.170I
12/23/23	09:00	19.0	0.174I

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/23/23	10:00	18.9	0.171I
12/23/23	11:00	19.0	0.171I
12/23/23	12:00	19.1	0.173I
12/23/23	13:00	19.0	0.171I
12/23/23	14:00	19.0	0.170I
12/23/23	15:00	18.7	0.167I
12/23/23	16:00	18.5	0.163I
12/23/23	17:00	18.5	0.162I
12/23/23	18:00	18.5	0.160I
12/23/23	19:00	18.8	0.163I
12/23/23	20:00	19.8	0.163I
12/23/23	21:00	21.2	0.162I
12/23/23	22:00	22.6	0.161I
12/23/23	23:00	23.9	0.161I
12/24/23	00:00	25.4	0.161I
12/24/23	01:00	26.8	0.162I
12/24/23	02:00	28.5	0.163I
12/24/23	03:00	30.0	0.164
12/24/23	04:00	31.4	0.164
12/24/23	05:00	32.8	0.165
12/24/23	06:00	34.0	0.165
12/24/23	07:00	35.2	0.166
12/24/23	08:00	36.2	0.166
12/24/23	09:00	37.0	0.167
12/24/23	10:00	37.2	0.168
12/24/23	11:00	37.2	0.169
12/24/23	12:00	37.1	0.169
12/24/23	13:00	37.3	0.170
12/24/23	14:00	37.2	0.170
12/24/23	15:00	37.4	0.171
12/24/23	16:00	37.6	0.172
12/24/23	17:00	37.5	0.172
12/24/23	18:00	37.4	0.172
12/24/23	19:00	37.3	0.172
12/24/23	20:00	37.4	0.173
12/24/23	21:00	37.5	0.174
12/24/23	22:00	37.7	0.175
12/24/23	23:00	37.9	0.175
12/25/23	00:00	37.9	0.176
12/25/23	01:00	37.9	0.176
12/25/23	02:00	37.9	0.176
12/25/23	03:00	37.8	0.176
12/25/23	04:00	37.8	0.176
12/25/23	05:00	37.9	0.176
12/25/23	06:00	37.9	0.176
12/25/23	07:00	37.9	0.176
12/25/23	08:00	37.9	0.176

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/25/23	09:00	37.9	0.176
12/25/23	10:00	37.8	0.175
12/25/23	11:00	37.6	0.174
12/25/23	12:00	37.4	0.173
12/25/23	13:00	37.4	0.173
12/25/23	14:00	37.4	0.173
12/25/23	15:00	37.4	0.173
12/25/23	16:00	37.3	0.173
12/25/23	17:00	36.9	0.170
12/25/23	18:00	36.8	0.170
12/25/23	19:00	36.6	0.168
12/25/23	20:00	36.7	0.169
12/25/23	21:00	36.8	0.168
12/25/23	22:00	37.2	0.169
12/25/23	23:00	37.6	0.170
12/26/23	00:00	37.6	0.170
12/26/23	01:00	37.6	0.170
12/26/23	02:00	37.5	0.170
12/26/23	03:00	37.6	0.171
12/26/23	04:00	37.6	0.171
12/26/23	05:00	37.7	0.172
12/26/23	06:00	37.6	0.172
12/26/23	07:00	37.5	0.171
12/26/23	08:00	37.5	0.171
12/26/23	09:00	37.5	0.172
12/26/23	10:00	37.6	0.172
12/26/23	11:00	37.7	0.173
12/26/23	12:00	37.8	0.174
12/26/23	13:00	37.9	0.175
12/26/23	14:00	38.0	0.175
12/26/23	15:00	38.2	0.176
12/26/23	16:00	38.2	0.176
12/26/23	17:00	38.7	0.179
12/26/23	18:00	38.8	0.180
12/26/23	19:00	38.9	0.180
12/26/23	20:00	38.8	0.180
12/26/23	21:00	38.7	0.180
12/26/23	22:00	38.3	0.180
12/26/23	23:00	38.0	0.179
12/27/23	00:00	38.1	0.179
12/27/23	01:00	38.0	0.178
12/27/23	02:00	37.8	0.178
12/27/23	03:00	37.8	0.177
12/27/23	04:00	37.9	0.177
12/27/23	05:00	37.7	0.176
12/27/23	06:00	37.6	0.176
12/27/23	07:00	37.5	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/27/23	08:00	37.4	0.175
12/27/23	09:00	37.3	0.175
12/27/23	10:00	37.2	0.174
12/27/23	11:00	37.1	0.174
12/27/23	12:00	37.1	0.174
12/27/23	13:00	36.9	0.173
12/27/23	14:00	36.8	0.173
12/27/23	15:00	36.6	0.172
12/27/23	16:00	36.5	0.172
12/27/23	17:00	36.5	0.171
12/27/23	18:00	36.4	0.171
12/27/23	19:00	36.3	0.171
12/27/23	20:00	36.2	0.170
12/27/23	21:00	36.1	0.170
12/27/23	22:00	36.0	0.170
12/27/23	23:00	35.9	0.169
12/28/23	00:00	35.6	0.168
12/28/23	01:00	35.5	0.167
12/28/23	02:00	35.4	0.167
12/28/23	03:00	35.1	0.166
12/28/23	04:00	35.4	0.167
12/28/23	05:00	35.3	0.167
12/28/23	06:00	35.2	0.166
12/28/23	07:00	35.1	0.166
12/28/23	08:00	35.0	0.165
12/28/23	09:00	34.9	0.165
12/28/23	10:00	34.9	0.165
12/28/23	11:00	34.9	0.165
12/28/23	12:00	34.8	0.164
12/28/23	13:00	34.8	0.164
12/28/23	14:00	34.7	0.164
12/28/23	15:00	34.7	0.163
12/28/23	16:00	34.5	0.163
12/28/23	17:00	34.4	0.162
12/28/23	18:00	34.2	0.161
12/28/23	19:00	34.1	0.160
12/28/23	20:00	33.9	0.159
12/28/23	21:00	33.9	0.158
12/28/23	22:00	33.8	0.158
12/28/23	23:00	33.7	0.157
12/29/23	00:00	33.5	0.156
12/29/23	01:00	33.4	0.155
12/29/23	02:00	33.3	0.154
12/29/23	03:00	33.4	0.154
12/29/23	04:00	32.9	0.152
12/29/23	05:00	32.8	0.151
12/29/23	06:00	32.8	0.151

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/29/23	07:00	32.9	0.151
12/29/23	08:00	33.1	0.152
12/29/23	09:00	33.3	0.152
12/29/23	10:00	33.4	0.153
12/29/23	11:00	33.5	0.153
12/29/23	12:00	33.6	0.154
12/29/23	13:00	33.8	0.155
12/29/23	14:00	34.1	0.155
12/29/23	15:00	34.4	0.155
12/29/23	16:00	34.6	0.156
12/29/23	17:00	34.8	0.157
12/29/23	18:00	34.9	0.158
12/29/23	19:00	35.2	0.160
12/29/23	20:00	35.4	0.161
12/29/23	21:00	35.4	0.161
12/29/23	22:00	35.5	0.162
12/29/23	23:00	35.7	0.163
12/30/23	00:00	36.1	0.166
12/30/23	01:00	36.4	0.167
12/30/23	02:00	36.6	0.169
12/30/23	03:00	36.8	0.170
12/30/23	04:00	37.0	0.171
12/30/23	05:00	37.2	0.173
12/30/23	06:00	37.3	0.174
12/30/23	07:00	37.3	0.173
12/30/23	08:00	37.1	0.173
12/30/23	09:00	37.1	0.173
12/30/23	10:00	37.2	0.173
12/30/23	11:00	37.2	0.173
12/30/23	12:00	37.1	0.173
12/30/23	13:00	37.1	0.173
12/30/23	14:00	37.0	0.173
12/30/23	15:00	36.9	0.174
12/30/23	16:00	36.9	0.173
12/30/23	17:00	36.9	0.173
12/30/23	18:00	36.8	0.172
12/30/23	19:00	36.7	0.172
12/30/23	20:00	36.6	0.171
12/30/23	21:00	36.7	0.171
12/30/23	22:00	36.8	0.172
12/30/23	23:00	36.8	0.172
12/31/23	00:00	36.8	0.171
12/31/23	01:00	37.0	0.172
12/31/23	02:00	37.1	0.172
12/31/23	03:00	37.3	0.173
12/31/23	04:00	37.5	0.174
12/31/23	05:00	37.5	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2023 00:00 Through 12/31/2023 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
12/31/23	06:00	37.7	0.174
12/31/23	07:00	37.8	0.175
12/31/23	08:00	38.0	0.176
12/31/23	09:00	38.2	0.176
12/31/23	10:00	38.2	0.177
12/31/23	11:00	38.3	0.177
12/31/23	12:00	38.3	0.178
12/31/23	13:00	38.4	0.178
12/31/23	14:00	38.2	0.178
12/31/23	15:00	38.0	0.176
12/31/23	16:00	37.9	0.175
12/31/23	17:00	37.7	0.174
12/31/23	18:00	37.5	0.174
12/31/23	19:00	37.4	0.173
12/31/23	20:00	37.3	0.172
12/31/23	21:00	37.1	0.171
12/31/23	22:00	36.8	0.170
12/31/23	23:00	36.5	0.168

Average	42.4	0.169
Minimum	7.2	0.122
Maximum	81.9	0.193
Summation	371,177.6	1,422.676
Geometric Mean	40.9	0.157
Included Data Points	8760	8428
Total number of Data Points	8760	8760

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/01/24	00:00	36.3	0.167
01/01/24	01:00	35.8	0.166
01/01/24	02:00	35.5	0.164
01/01/24	03:00	35.5	0.164
01/01/24	04:00	35.3	0.164
01/01/24	05:00	35.1	0.162
01/01/24	06:00	34.9	0.161
01/01/24	07:00	34.8	0.161
01/01/24	08:00	34.9	0.161
01/01/24	09:00	34.9	0.161
01/01/24	10:00	35.0	0.161
01/01/24	11:00	35.0	0.161
01/01/24	12:00	35.1	0.161
01/01/24	13:00	35.2	0.161
01/01/24	14:00	35.3	0.161
01/01/24	15:00	35.4	0.162
01/01/24	16:00	35.5	0.163
01/01/24	17:00	35.7	0.164
01/01/24	18:00	36.0	0.165
01/01/24	19:00	36.2	0.166
01/01/24	20:00	36.4	0.167
01/01/24	21:00	36.7	0.168
01/01/24	22:00	37.1	0.170
01/01/24	23:00	37.6	0.172
01/02/24	00:00	37.8	0.173
01/02/24	01:00	38.1	0.174
01/02/24	02:00	38.3	0.175
01/02/24	03:00	38.3	0.174
01/02/24	04:00	38.3	0.174
01/02/24	05:00	38.6	0.175
01/02/24	06:00	38.9	0.177
01/02/24	07:00	39.1	0.177
01/02/24	08:00	39.1	0.177
01/02/24	09:00	39.0	0.176
01/02/24	10:00	38.9	0.176
01/02/24	11:00	38.8	0.175
01/02/24	12:00	38.9	0.174
01/02/24	13:00	38.9	0.174
01/02/24	14:00	38.8	0.173
01/02/24	15:00	38.9	0.174
01/02/24	16:00	38.9	0.174
01/02/24	17:00	38.9	0.174
01/02/24	18:00	38.8	0.174
01/02/24	19:00	38.6	0.173
01/02/24	20:00	38.5	0.173
01/02/24	21:00	38.3	0.172
01/02/24	22:00	38.0	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

*** = Suspect**

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/02/24	23:00	37.8	0.170
01/03/24	00:00	37.8	0.169
01/03/24	01:00	37.8	0.169
01/03/24	02:00	37.9	0.170
01/03/24	03:00	37.7	0.169
01/03/24	04:00	37.7	0.169
01/03/24	05:00	37.5	0.169
01/03/24	06:00	37.4	0.169
01/03/24	07:00	37.3	0.169
01/03/24	08:00	37.2	0.168
01/03/24	09:00	37.2	0.168
01/03/24	10:00	37.1	0.168
01/03/24	11:00	37.1	0.167
01/03/24	12:00	36.8	0.168
01/03/24	13:00	36.8	0.169
01/03/24	14:00	36.8	0.168
01/03/24	15:00	37.0	0.169
01/03/24	16:00	37.0	0.169
01/03/24	17:00	37.1	0.169
01/03/24	18:00	37.3	0.169
01/03/24	19:00	37.5	0.170
01/03/24	20:00	37.7	0.171
01/03/24	21:00	37.9	0.172
01/03/24	22:00	38.0	0.173
01/03/24	23:00	38.0	0.172
01/04/24	00:00	37.9	0.172
01/04/24	01:00	37.9	0.173
01/04/24	02:00	37.9	0.172
01/04/24	03:00	37.9	0.172
01/04/24	04:00	37.8	0.172
01/04/24	05:00	37.7	0.171
01/04/24	06:00	37.6	0.171
01/04/24	07:00	37.6	0.171
01/04/24	08:00	37.6	0.171
01/04/24	09:00	37.6	0.171
01/04/24	10:00	37.5	0.170
01/04/24	11:00	37.5	0.170
01/04/24	12:00	37.3	0.169
01/04/24	13:00	37.1	0.169
01/04/24	14:00	37.3	0.169
01/04/24	15:00	37.1	0.169
01/04/24	16:00	37.2	0.170
01/04/24	17:00	37.1	0.170
01/04/24	18:00	37.1	0.169
01/04/24	19:00	36.9	0.169
01/04/24	20:00	36.7	0.168
01/04/24	21:00	36.6	0.168

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/04/24	22:00	36.5	0.167
01/04/24	23:00	36.6	0.167
01/05/24	00:00	36.6	0.167
01/05/24	01:00	36.6	0.167
01/05/24	02:00	36.6	0.167
01/05/24	03:00	36.6	0.167
01/05/24	04:00	36.6	0.167
01/05/24	05:00	36.6	0.167
01/05/24	06:00	36.7	0.167
01/05/24	07:00	36.6	0.167
01/05/24	08:00	36.6	0.166
01/05/24	09:00	36.7	0.166
01/05/24	10:00	36.6	0.166
01/05/24	11:00	36.6	0.166
01/05/24	12:00	36.7	0.166
01/05/24	13:00	36.9	0.166
01/05/24	14:00	36.7	0.166
01/05/24	15:00	36.8	0.165
01/05/24	16:00	36.6	0.164
01/05/24	17:00	36.6	0.164
01/05/24	18:00	36.6	0.164
01/05/24	19:00	36.8	0.165
01/05/24	20:00	36.9	0.165
01/05/24	21:00	37.0	0.165
01/05/24	22:00	37.1	0.166
01/05/24	23:00	37.1	0.166
01/06/24	00:00	37.1	0.165
01/06/24	01:00	37.1	0.165
01/06/24	02:00	37.0	0.165
01/06/24	03:00	37.0	0.165
01/06/24	04:00	37.1	0.165
01/06/24	05:00	37.1	0.165
01/06/24	06:00	37.1	0.166
01/06/24	07:00	37.1	0.166
01/06/24	08:00	37.2	0.166
01/06/24	09:00	37.2	0.166
01/06/24	10:00	37.3	0.167
01/06/24	11:00	37.4	0.167
01/06/24	12:00	37.5	0.167
01/06/24	13:00	38.2	0.167
01/06/24	14:00	38.1	0.167
01/06/24	15:00	37.8	0.166
01/06/24	16:00	37.8	0.166
01/06/24	17:00	37.7	0.166
01/06/24	18:00	37.7	0.166
01/06/24	19:00	37.7	0.166
01/06/24	20:00	37.7	0.166

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/06/24	21:00	37.7	0.166
01/06/24	22:00	37.6	0.165
01/06/24	23:00	37.6	0.165
01/07/24	00:00	37.5	0.165
01/07/24	01:00	37.5	0.165
01/07/24	02:00	37.7	0.166
01/07/24	03:00	37.6	0.166
01/07/24	04:00	37.6	0.166
01/07/24	05:00	37.6	0.165
01/07/24	06:00	37.6	0.166
01/07/24	07:00	37.6	0.166
01/07/24	08:00	37.6	0.166
01/07/24	09:00	37.6	0.166
01/07/24	10:00	37.6	0.166
01/07/24	11:00	37.6	0.166
01/07/24	12:00	37.6	0.166
01/07/24	13:00	36.9	0.166
01/07/24	14:00	37.2	0.167
01/07/24	15:00	37.3	0.168
01/07/24	16:00	37.4	0.169
01/07/24	17:00	37.4	0.169
01/07/24	18:00	37.4	0.169
01/07/24	19:00	37.4	0.169
01/07/24	20:00	37.4	0.168
01/07/24	21:00	37.3	0.168
01/07/24	22:00	37.4	0.168
01/07/24	23:00	37.5	0.169
01/08/24	00:00	37.6	0.169
01/08/24	01:00	37.5	0.169
01/08/24	02:00	37.4	0.169
01/08/24	03:00	37.5	0.169
01/08/24	04:00	37.5	0.169
01/08/24	05:00	37.5	0.169
01/08/24	06:00	37.5	0.169
01/08/24	07:00	37.5	0.169
01/08/24	08:00	37.5	0.169
01/08/24	09:00	37.6	0.169
01/08/24	10:00	37.7	0.170
01/08/24	11:00	37.8	0.170
01/08/24	12:00	37.8	0.170
01/08/24	13:00	37.8	0.170
01/08/24	14:00	37.7	0.170
01/08/24	15:00	37.8	0.170
01/08/24	16:00	37.9	0.171
01/08/24	17:00	38.1	0.172
01/08/24	18:00	38.2	0.172
01/08/24	19:00	38.4	0.173

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/08/24	20:00	38.5	0.174
01/08/24	21:00	38.6	0.175
01/08/24	22:00	38.7	0.175
01/08/24	23:00	38.7	0.175
01/09/24	00:00	38.7	0.175
01/09/24	01:00	38.9	0.176
01/09/24	02:00	38.9	0.176
01/09/24	03:00	38.9	0.176
01/09/24	04:00	38.9	0.177
01/09/24	05:00	39.0	0.177
01/09/24	06:00	39.1	0.177
01/09/24	07:00	39.1	0.177
01/09/24	08:00	39.0	0.177
01/09/24	09:00	38.9	0.176
01/09/24	10:00	38.9	0.176
01/09/24	11:00	38.8	0.175
01/09/24	12:00	38.8	0.175
01/09/24	13:00	38.7	0.174
01/09/24	14:00	38.6	0.174
01/09/24	15:00	38.7	0.173
01/09/24	16:00	38.7	0.173
01/09/24	17:00	38.6	0.172
01/09/24	18:00	38.6	0.171
01/09/24	19:00	38.6	0.171
01/09/24	20:00	38.5	0.170
01/09/24	21:00	38.5	0.169
01/09/24	22:00	38.5	0.169
01/09/24	23:00	38.6	0.169
01/10/24	00:00	38.7	0.169
01/10/24	01:00	38.7	0.169
01/10/24	02:00	38.9	0.169
01/10/24	03:00	39.0	0.169
01/10/24	04:00	39.1	0.169
01/10/24	05:00	39.2	0.169
01/10/24	06:00	39.3	0.169
01/10/24	07:00	39.3	0.169
01/10/24	08:00	39.4	0.169
01/10/24	09:00	39.5	0.169
01/10/24	10:00	39.7	0.170
01/10/24	11:00	39.9	0.170
01/10/24	12:00	40.1	0.171
01/10/24	13:00	40.2	0.172
01/10/24	14:00	40.5	0.173
01/10/24	15:00	40.4	0.173
01/10/24	16:00	41.0	0.173
01/10/24	17:00	43.8	0.175
01/10/24	18:00	44.9	0.175

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/10/24	19:00	44.7	0.175
01/10/24	20:00	44.7	0.175
01/10/24	21:00	44.7	0.175
01/10/24	22:00	44.5	0.175
01/10/24	23:00	44.4	0.175
01/11/24	00:00	44.2	0.174
01/11/24	01:00	44.1	0.174
01/11/24	02:00	44.1	0.175
01/11/24	03:00	44.0	0.175
01/11/24	04:00	43.9	0.175
01/11/24	05:00	43.7	0.174
01/11/24	06:00	43.6	0.174
01/11/24	07:00	43.5	0.174
01/11/24	08:00	43.3	0.173
01/11/24	09:00	43.2	0.173
01/11/24	10:00	43.1	0.173
01/11/24	11:00	43.0	0.173
01/11/24	12:00	42.8	0.172
01/11/24	13:00	42.7	0.172
01/11/24	14:00	42.6	0.172
01/11/24	15:00	42.5	0.171
01/11/24	16:00	43.5	0.172
01/11/24	17:00	43.9	0.172
01/11/24	18:00	45.6	0.174
01/11/24	19:00	46.5	0.174
01/11/24	20:00	46.4	0.174
01/11/24	21:00	46.3	0.174
01/11/24	22:00	46.4	0.174
01/11/24	23:00	46.4	0.174
01/12/24	00:00	46.3	0.174
01/12/24	01:00	46.4	0.174
01/12/24	02:00	46.4	0.174
01/12/24	03:00	46.2	0.174
01/12/24	04:00	46.2	0.174
01/12/24	05:00	46.2	0.174
01/12/24	06:00	46.2	0.174
01/12/24	07:00	46.2	0.175
01/12/24	08:00	46.2	0.175
01/12/24	09:00	46.2	0.175
01/12/24	10:00	46.0	0.174
01/12/24	11:00	46.0	0.174
01/12/24	12:00	45.9	0.174
01/12/24	13:00	45.8	0.174
01/12/24	14:00	45.8	0.174
01/12/24	15:00	45.7	0.174
01/12/24	16:00	44.0	0.173
01/12/24	17:00	40.7	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/12/24	18:00	37.6	0.168
01/12/24	19:00	36.7	0.167
01/12/24	20:00	36.8	0.167
01/12/24	21:00	36.9	0.167
01/12/24	22:00	36.9	0.167
01/12/24	23:00	37.0	0.167
01/13/24	00:00	37.2	0.167
01/13/24	01:00	37.2	0.167
01/13/24	02:00	37.2	0.166
01/13/24	03:00	37.3	0.166
01/13/24	04:00	37.2	0.166
01/13/24	05:00	37.3	0.166
01/13/24	06:00	37.4	0.166
01/13/24	07:00	37.6	0.167
01/13/24	08:00	37.7	0.167
01/13/24	09:00	37.9	0.168
01/13/24	10:00	38.0	0.168
01/13/24	11:00	38.1	0.168
01/13/24	12:00	38.3	0.168
01/13/24	13:00	38.3	0.168
01/13/24	14:00	38.2	0.168
01/13/24	15:00	39.0	0.167
01/13/24	16:00	41.4	0.168
01/13/24	17:00	43.3	0.169
01/13/24	18:00	43.9	0.168
01/13/24	19:00	43.7	0.167
01/13/24	20:00	43.6	0.167
01/13/24	21:00	43.4	0.166
01/13/24	22:00	43.3	0.166
01/13/24	23:00	43.1	0.165
01/14/24	00:00	43.0	0.165
01/14/24	01:00	43.1	0.166
01/14/24	02:00	42.9	0.165
01/14/24	03:00	42.7	0.164
01/14/24	04:00	42.9	0.163
01/14/24	05:00	42.5	0.162
01/14/24	06:00	42.1	0.159
01/14/24	07:00	41.9	0.159
01/14/24	08:00	41.6	0.157
01/14/24	09:00	41.3	0.156
01/14/24	10:00	41.0	0.155
01/14/24	11:00	40.8	0.155
01/14/24	12:00	40.5	0.154
01/14/24	13:00	40.3	0.153
01/14/24	14:00	40.2	0.153
01/14/24	15:00	39.2	0.153
01/14/24	16:00	36.8	0.152

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/14/24	17:00	34.9	0.151
01/14/24	18:00	34.2	0.152
01/14/24	19:00	34.4	0.153
01/14/24	20:00	34.3	0.152
01/14/24	21:00	34.2	0.152
01/14/24	22:00	34.1	0.152
01/14/24	23:00	34.3	0.153
01/15/24	00:00	34.4	0.154
01/15/24	01:00	34.3	0.154
01/15/24	02:00	34.5	0.155
01/15/24	03:00	34.4	0.154
01/15/24	04:00	34.0	0.154
01/15/24	05:00	34.0	0.155
01/15/24	06:00	33.9	0.154
01/15/24	07:00	34.0	0.155
01/15/24	08:00	34.2	0.156
01/15/24	09:00	34.4	0.157
01/15/24	10:00	34.6	0.158
01/15/24	11:00	34.7	0.159
01/15/24	12:00	34.9	0.160
01/15/24	13:00	35.2	0.160
01/15/24	14:00	36.5	0.161
01/15/24	15:00	38.1	0.161
01/15/24	16:00	40.0	0.162
01/15/24	17:00	41.6	0.163
01/15/24	18:00	43.3	0.164
01/15/24	19:00	45.0	0.165
01/15/24	20:00	46.7	0.166
01/15/24	21:00	48.3	0.167
01/15/24	22:00	50.0	0.167
01/15/24	23:00	51.5	0.167
01/16/24	00:00	53.0	0.167
01/16/24	01:00	54.6	0.167
01/16/24	02:00	56.0	0.167
01/16/24	03:00	57.9	0.169
01/16/24	04:00	59.6	0.171
01/16/24	05:00	61.3	0.172
01/16/24	06:00	63.2	0.174
01/16/24	07:00	64.7	0.174
01/16/24	08:00	66.0	0.173
01/16/24	09:00	67.2	0.172
01/16/24	10:00	69.3	0.173
01/16/24	11:00	71.7	0.174
01/16/24	12:00	73.7	0.175
01/16/24	13:00	75.5	0.177
01/16/24	14:00	76.3	0.178
01/16/24	15:00	76.4	0.178

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/16/24	16:00	76.3	0.178
01/16/24	17:00	76.3	0.179
01/16/24	18:00	76.5	0.179
01/16/24	19:00	76.7	0.179
01/16/24	20:00	76.6	0.179
01/16/24	21:00	76.4	0.179
01/16/24	22:00	76.1	0.178
01/16/24	23:00	75.7	0.177
01/17/24	00:00	75.4	0.177
01/17/24	01:00	75.1	0.176
01/17/24	02:00	75.0	0.176
01/17/24	03:00	74.9	0.175
01/17/24	04:00	75.0	0.175
01/17/24	05:00	75.1	0.175
01/17/24	06:00	75.3	0.176
01/17/24	07:00	75.6	0.176
01/17/24	08:00	76.0	0.177
01/17/24	09:00	76.4	0.177
01/17/24	10:00	76.0	0.177
01/17/24	11:00	75.3	0.176
01/17/24	12:00	75.1	0.175
01/17/24	13:00	74.9	0.175
01/17/24	14:00	74.7	0.174
01/17/24	15:00	74.8	0.175
01/17/24	16:00	74.9	0.174
01/17/24	17:00	75.1	0.174
01/17/24	18:00	75.0	0.174
01/17/24	19:00	74.5	0.173
01/17/24	20:00	74.2	0.173
01/17/24	21:00	74.4	0.173
01/17/24	22:00	74.8	0.174
01/17/24	23:00	75.2	0.174
01/18/24	00:00	75.4	0.175
01/18/24	01:00	75.5	0.175
01/18/24	02:00	75.5	0.175
01/18/24	03:00	75.5	0.175
01/18/24	04:00	75.6	0.175
01/18/24	05:00	75.5	0.175
01/18/24	06:00	75.5	0.175
01/18/24	07:00	76.4	0.177
01/18/24	08:00	76.6	0.177
01/18/24	09:00	76.8	0.178
01/18/24	10:00	76.6	0.178
01/18/24	11:00	76.5	0.178
01/18/24	12:00	76.4	0.178
01/18/24	13:00	75.0	0.177
01/18/24	14:00	73.4	0.177

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/18/24	15:00	71.7	0.177
01/18/24	16:00	70.0	0.177
01/18/24	17:00	68.9	0.176
01/18/24	18:00	69.1	0.176
01/18/24	19:00	68.3	0.175
01/18/24	20:00	67.4	0.176
01/18/24	21:00	66.1	0.177
01/18/24	22:00	64.5	0.178
01/18/24	23:00	62.9	0.177
01/19/24	00:00	61.3	0.177
01/19/24	01:00	59.8	0.177
01/19/24	02:00	58.5	0.178
01/19/24	03:00	57.1	0.178
01/19/24	04:00	55.6	0.179
01/19/24	05:00	54.0	0.179
01/19/24	06:00	52.4	0.179
01/19/24	07:00	49.8	0.178
01/19/24	08:00	47.9	0.177
01/19/24	09:00	46.1	0.176
01/19/24	10:00	44.3	0.175
01/19/24	11:00	42.7	0.175
01/19/24	12:00	41.0	0.174
01/19/24	13:00	40.5	0.175
01/19/24	14:00	40.3	0.173
01/19/24	15:00	40.4	0.173
01/19/24	16:00	40.5	0.173
01/19/24	17:00	40.6	0.174
01/19/24	18:00	40.5	0.173
01/19/24	19:00	40.6	0.174
01/19/24	20:00	40.5	0.174
01/19/24	21:00	40.4	0.173
01/19/24	22:00	40.3	0.173
01/19/24	23:00	40.4	0.174
01/20/24	00:00	40.4	0.174
01/20/24	01:00	40.4	0.174
01/20/24	02:00	40.4	0.174
01/20/24	03:00	40.3	0.173
01/20/24	04:00	40.2	0.172
01/20/24	05:00	40.1	0.172
01/20/24	06:00	40.1	0.172
01/20/24	07:00	41.1	0.172
01/20/24	08:00	43.1	0.172
01/20/24	09:00	43.9	0.172
01/20/24	10:00	43.9	0.173
01/20/24	11:00	44.0	0.173
01/20/24	12:00	44.1	0.173
01/20/24	13:00	44.3	0.174

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/20/24	14:00	44.5	0.176
01/20/24	15:00	44.5	0.175
01/20/24	16:00	44.3	0.175
01/20/24	17:00	44.7	0.176
01/20/24	18:00	44.9	0.176
01/20/24	19:00	45.2	0.177
01/20/24	20:00	45.3	0.177
01/20/24	21:00	45.3	0.177
01/20/24	22:00	45.4	0.177
01/20/24	23:00	45.4	0.178
01/21/24	00:00	45.5	0.178
01/21/24	01:00	45.4	0.178
01/21/24	02:00	45.3	0.177
01/21/24	03:00	45.3	0.177
01/21/24	04:00	45.3	0.177
01/21/24	05:00	45.3	0.178
01/21/24	06:00	45.3	0.177
01/21/24	07:00	44.3	0.178
01/21/24	08:00	42.3	0.177
01/21/24	09:00	41.6	0.178
01/21/24	10:00	41.6	0.178
01/21/24	11:00	41.7	0.179
01/21/24	12:00	41.8	0.179
01/21/24	13:00	41.8	0.180
01/21/24	14:00	41.9	0.181
01/21/24	15:00	42.0	0.181
01/21/24	16:00	41.8	0.181
01/21/24	17:00	40.5	0.180
01/21/24	18:00	38.4	0.179
01/21/24	19:00	37.5	0.178
01/21/24	20:00	37.3	0.177
01/21/24	21:00	37.1	0.177
01/21/24	22:00	37.0	0.176
01/21/24	23:00	36.7	0.174
01/22/24	00:00	36.6	0.174
01/22/24	01:00	36.7	0.174
01/22/24	02:00	36.7	0.174
01/22/24	03:00	36.8	0.175
01/22/24	04:00	36.9	0.175
01/22/24	05:00	36.9	0.174
01/22/24	06:00	36.9	0.175
01/22/24	07:00	36.9	0.174
01/22/24	08:00	37.0	0.175
01/22/24	09:00	37.0	0.175
01/22/24	10:00	36.9	0.174
01/22/24	11:00	36.7	0.173
01/22/24	12:00	36.6	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/22/24	13:00	36.4	0.171
01/22/24	14:00	36.2	0.170
01/22/24	15:00	36.1	0.169
01/22/24	16:00	36.2	0.169
01/22/24	17:00	36.3	0.169
01/22/24	18:00	36.3	0.169
01/22/24	19:00	36.4	0.170
01/22/24	20:00	36.5	0.170
01/22/24	21:00	36.6	0.171
01/22/24	22:00	36.7	0.171
01/22/24	23:00	36.9	0.172
01/23/24	00:00	37.0	0.172
01/23/24	01:00	36.8	0.171
01/23/24	02:00	36.9	0.171
01/23/24	03:00	36.9	0.171
01/23/24	04:00	36.9	0.171
01/23/24	05:00	36.8	0.171
01/23/24	06:00	36.8	0.171
01/23/24	07:00	36.8	0.171
01/23/24	08:00	36.7	0.170
01/23/24	09:00	36.6	0.169
01/23/24	10:00	36.6	0.169
01/23/24	11:00	36.6	0.169
01/23/24	12:00	36.7	0.169
01/23/24	13:00	36.7	0.169
01/23/24	14:00	36.8	0.169
01/23/24	15:00	36.9	0.169
01/23/24	16:00	36.9	0.169
01/23/24	17:00	36.9	0.169
01/23/24	18:00	36.8	0.168
01/23/24	19:00	36.7	0.168
01/23/24	20:00	36.6	0.167
01/23/24	21:00	36.5	0.166
01/23/24	22:00	36.5	0.166
01/23/24	23:00	36.5	0.166
01/24/24	00:00	36.4	0.166
01/24/24	01:00	36.4	0.165
01/24/24	02:00	36.4	0.165
01/24/24	03:00	36.3	0.165
01/24/24	04:00	36.2	0.164
01/24/24	05:00	36.2	0.164
01/24/24	06:00	36.2	0.164
01/24/24	07:00	36.2	0.164
01/24/24	08:00	36.2	0.164
01/24/24	09:00	36.3	0.164
01/24/24	10:00	36.4	0.165
01/24/24	11:00	36.4	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/24/24	12:00	36.5	0.165
01/24/24	13:00	36.4	0.165
01/24/24	14:00	36.4	0.165
01/24/24	15:00	36.3	0.164
01/24/24	16:00	36.4	0.164
01/24/24	17:00	36.5	0.165
01/24/24	18:00	36.7	0.165
01/24/24	19:00	36.8	0.166
01/24/24	20:00	36.9	0.166
01/24/24	21:00	36.9	0.166
01/24/24	22:00	36.9	0.166
01/24/24	23:00	36.9	0.166
01/25/24	00:00	36.8	0.165
01/25/24	01:00	36.9	0.165
01/25/24	02:00	36.8	0.165
01/25/24	03:00	36.8	0.165
01/25/24	04:00	36.7	0.165
01/25/24	05:00	36.7	0.165
01/25/24	06:00	36.6	0.164
01/25/24	07:00	36.6	0.164
01/25/24	08:00	36.5	0.164
01/25/24	09:00	36.4	0.163
01/25/24	10:00	36.3	0.162
01/25/24	11:00	36.2	0.162
01/25/24	12:00	36.1	0.162
01/25/24	13:00	36.0	0.161
01/25/24	14:00	36.1	0.161
01/25/24	15:00	36.3	0.163
01/25/24	16:00	36.3	0.163
01/25/24	17:00	36.4	0.163
01/25/24	18:00	36.5	0.164
01/25/24	19:00	36.6	0.165
01/25/24	20:00	36.7	0.165
01/25/24	21:00	36.7	0.166
01/25/24	22:00	36.8	0.166
01/25/24	23:00	36.8	0.166
01/26/24	00:00	36.9	0.167
01/26/24	01:00	36.9	0.167
01/26/24	02:00	36.9	0.167
01/26/24	03:00	37.0	0.168
01/26/24	04:00	37.2	0.168
01/26/24	05:00	37.2	0.168
01/26/24	06:00	37.1	0.167
01/26/24	07:00	36.9	0.166
01/26/24	08:00	36.9	0.166
01/26/24	09:00	36.8	0.165
01/26/24	10:00	36.8	0.165

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/26/24	11:00	36.9	0.165
01/26/24	12:00	37.0	0.165
01/26/24	13:00	37.1	0.166
01/26/24	14:00	37.0	0.165
01/26/24	15:00	37.4	0.164
01/26/24	16:00	37.3	0.163
01/26/24	17:00	37.2	0.163
01/26/24	18:00	37.1	0.163
01/26/24	19:00	37.0	0.162
01/26/24	20:00	36.9	0.162
01/26/24	21:00	36.8	0.161
01/26/24	22:00	36.7	0.161
01/26/24	23:00	36.6	0.160
01/27/24	00:00	36.6	0.160
01/27/24	01:00	36.6	0.160
01/27/24	02:00	36.5	0.160
01/27/24	03:00	36.6	0.161
01/27/24	04:00	36.6	0.161
01/27/24	05:00	36.7	0.161
01/27/24	06:00	36.9	0.162
01/27/24	07:00	37.1	0.164
01/27/24	08:00	37.1	0.164
01/27/24	09:00	37.2	0.165
01/27/24	10:00	37.3	0.165
01/27/24	11:00	37.2	0.166
01/27/24	12:00	37.3	0.166
01/27/24	13:00	37.3	0.166
01/27/24	14:00	37.3	0.166
01/27/24	15:00	36.8	0.167
01/27/24	16:00	36.9	0.168
01/27/24	17:00	36.9	0.168
01/27/24	18:00	37.0	0.168
01/27/24	19:00	37.0	0.168
01/27/24	20:00	37.1	0.168
01/27/24	21:00	37.3	0.169
01/27/24	22:00	37.4	0.170
01/27/24	23:00	37.5	0.170
01/28/24	00:00	37.5	0.170
01/28/24	01:00	37.6	0.170
01/28/24	02:00	37.7	0.170
01/28/24	03:00	37.6	0.170
01/28/24	04:00	37.5	0.170
01/28/24	05:00	37.5	0.170
01/28/24	06:00	37.6	0.170
01/28/24	07:00	37.7	0.171
01/28/24	08:00	37.6	0.171
01/28/24	09:00	37.6	0.170

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/28/24	10:00	37.7	0.170
01/28/24	11:00	37.7	0.170
01/28/24	12:00	37.7	0.170
01/28/24	13:00	37.7	0.170
01/28/24	14:00	38.2	0.171
01/28/24	15:00	38.3	0.172
01/28/24	16:00	38.3	0.172
01/28/24	17:00	38.3	0.172
01/28/24	18:00	38.4	0.172
01/28/24	19:00	38.5	0.173
01/28/24	20:00	38.5	0.173
01/28/24	21:00	38.5	0.173
01/28/24	22:00	38.5	0.173
01/28/24	23:00	38.6	0.173
01/29/24	00:00	38.7	0.174
01/29/24	01:00	38.7	0.174
01/29/24	02:00	38.7	0.174
01/29/24	03:00	38.7	0.175
01/29/24	04:00	38.8	0.174
01/29/24	05:00	38.7	0.174
01/29/24	06:00	38.6	0.173
01/29/24	07:00	38.6	0.173
01/29/24	08:00	38.6	0.173
01/29/24	09:00	38.7	0.174
01/29/24	10:00	38.8	0.174
01/29/24	11:00	38.9	0.175
01/29/24	12:00	38.9	0.175
01/29/24	13:00	38.8	0.175
01/29/24	14:00	38.5	0.174
01/29/24	15:00	38.5	0.174
01/29/24	16:00	38.5	0.174
01/29/24	17:00	38.4	0.174
01/29/24	18:00	38.3	0.173
01/29/24	19:00	38.2	0.172
01/29/24	20:00	38.2	0.172
01/29/24	21:00	38.1	0.172
01/29/24	22:00	38.1	0.172
01/29/24	23:00	38.0	0.171
01/30/24	00:00	37.9	0.171
01/30/24	01:00	38.0	0.171
01/30/24	02:00	38.0	0.171
01/30/24	03:00	38.1	0.171
01/30/24	04:00	38.1	0.171
01/30/24	05:00	38.2	0.172
01/30/24	06:00	38.3	0.172
01/30/24	07:00	38.3	0.172
01/30/24	08:00	38.3	0.172

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
01/30/24	09:00	38.3	0.172
01/30/24	10:00	38.2	0.172
01/30/24	11:00	38.2	0.171
01/30/24	12:00	38.2	0.171
01/30/24	13:00	39.0	0.171
01/30/24	14:00	38.7	0.170
01/30/24	15:00	38.5	0.169
01/30/24	16:00	38.5	0.168
01/30/24	17:00	38.5	0.169
01/30/24	18:00	38.7	0.169
01/30/24	19:00	38.8	0.170
01/30/24	20:00	38.8	0.170
01/30/24	21:00	38.9	0.171
01/30/24	22:00	39.0	0.171
01/30/24	23:00	39.0	0.171
01/31/24	00:00	39.0	0.171
01/31/24	01:00	38.9	0.171
01/31/24	02:00	38.9	0.171
01/31/24	03:00	39.0	0.171
01/31/24	04:00	39.1	0.171
01/31/24	05:00	39.1	0.171
01/31/24	06:00	39.2	0.171
01/31/24	07:00	39.2	0.171
01/31/24	08:00	39.3	0.172
01/31/24	09:00	39.4	0.172
01/31/24	10:00	39.5	0.173
01/31/24	11:00	39.6	0.174
01/31/24	12:00	39.7	0.175
01/31/24	13:00	39.1	0.176
01/31/24	14:00	39.4	0.177
01/31/24	15:00	39.6	0.178
01/31/24	16:00	39.6	0.178
01/31/24	17:00	39.6	0.179
01/31/24	18:00	39.7	0.179
01/31/24	19:00	39.7	0.179
01/31/24	20:00	39.7	0.179
01/31/24	21:00	39.7	0.179
01/31/24	22:00	39.6	0.178
01/31/24	23:00	39.6	0.178
02/01/24	00:00	39.7	0.179
02/01/24	01:00	39.7	0.179
02/01/24	02:00	39.6	0.179
02/01/24	03:00	39.9	0.179
02/01/24	04:00	39.9	0.180
02/01/24	05:00	40.0	0.180
02/01/24	06:00	40.0	0.180
02/01/24	07:00	39.8	0.179

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown

24 Hour Emissions Average

Plant: GENESEE POWER STATION LP

Interval: 24 Hour

Type: Roll

Report Period: 01/01/2024 00:00 Through 02/01/2024 23:59

Time Online Criteria: 1 minute(s)

Source		UNIT1	
Parameter		NOX#/H60 (LB/HR)	NOX#MM60 (LB/MMBTU)
Unit			
Limit		104.64	0.2049
02/01/24	08:00	39.6	0.178
02/01/24	09:00	39.5	0.178
02/01/24	10:00	40.5	0.177
02/01/24	11:00	42.6	0.178
02/01/24	12:00	45.3	0.179
02/01/24	13:00	45.2	0.176
02/01/24	14:00	44.6	0.173
02/01/24	15:00	44.1	0.170
02/01/24	16:00	43.7	0.168
02/01/24	17:00	43.5	0.167
02/01/24	18:00	43.4	0.166
02/01/24	19:00	43.4	0.166
02/01/24	20:00	43.4	0.166
02/01/24	21:00	43.5	0.166
02/01/24	22:00	43.5	0.166
02/01/24	23:00	43.6	0.166
Average		42.1	0.170
Minimum		33.9	0.151
Maximum		76.8	0.181
Summation		32,356.4	130.536
Geometric Mean		41.2	0.170
Included Data Points		768	768
Total number of Data Points		768	768

F = Unit Offline

E = Exceedance

C = Calibration

S = Substituted

I = Invalid

M = Maintenance

T = Out Of Control

* = Suspect

U = Startup

D = Shutdown