

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report


Facility : ANR Pipeline Co. - Goodwell Compressor Station	SRN : N5576
Location : 6759 East Five Mile Rd.	District : Grand Rapids
	County : NEWAYGO
City : WHITE CLOUD State: MI Zip Code : 49349	Compliance Status : Compliance
Source Class : MAJOR	Staff : Chris Robinson
FCE Begin Date : 2/22/2022	FCE Completion Date : 2/22/2023
Comments : FY '23 Inspection	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/19/2023	On-site Inspection	Compliance	FY'23 inspection to determine the facility's compliance status with applicable air quality rules and regulations including Renewable Operating Permit ROP-MI-N5576-2020.
09/29/2022	ROP Semi 1 Cert	Compliance	Semi-Annual report certification for the period of 1/1/2022 through 6/30/2022 received timely and properly certified. No deviations or issues are reported.
05/25/2022	Stack Test	Compliance	Compliance Demonstration under Subpart KKKK. NOx Emissions Compliance Test Report received May 19, 2022 for testing that was conducted on March 22, 2022. Permit limit for both turbines is 25 ppmvd@15% O2. The measured emissions were 4.4213 (unit 6) and 2.1474 (unit 7) ppmvd@15% O2. Testing every other year is allowed only if emissions don't exceed 75% of the limit which is 18.75 ppmvd. Both units were under this limit, therefore the next test will be in 2024. Required production/operating data is included for each turbine.

Activity Date	Activity Type	Compliance Status	Comments
05/06/2022	MAERS	Compliance	MAERS report certification received 3/14/22. Supplemental Control Template submittal certification received on 3/28/22. Reported renewed ROP separately. MAERS and EPA emission factors and stack test results used for determining emissions. No changes made to database as submitted.
03/28/2022	ROP Annual Cert	Compliance	2021 Annual Compliance Certification received on 3/14/2022 timely and properly certified with no deviations or issues reported. The facility provided two Annual Compliance Certifications to cover pre and post issuance of the most recent ROP (Renewal).
03/28/2022	ROP SEMI 2 CERT	Compliance	Semi-Annual report certification for the period of 7/1/2021 through 12/31/2021 received timely and properly certified. No deviations or issues are reported.
03/22/2022	Stack Test Observation	Compliance	Observe NOx emissions stack test for two natural gas fired turbine compressors (EUGDSTurbine6 and EUGSDTurbine7)

Name:



Date:

2/22/2023

Supervisor:

