

### **Regulatory Information**

*Permit No.* Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit No. MI-ROP-N5940-2019A

### **Source Information**

<i>Source Name</i>	<i>Source ID</i>	<i>Target Parameters</i>
Wood Fuel Boiler 2	EU-WOODBOILER2	PM

### **Contact Information**

<i>Test Location</i>	<i>Test Company</i>	<i>Analytical Laboratories</i>
PotlatchDeltic Corporation Gwinn Sawmill 650 A Avenue Gwinn, Michigan 49841	Alliance Technical Group, LLC 4500 Ball Road NE Circle Pines, MN 55014	Civil & Environmental Consultant (CEC) Air Source Testing Group now Alliance Technical Group, LLC 3000 Little Hills Expressway, Suite 102 St. Charles, MO 63301
Facility Contact Amy Benson amy.benson@potlatchdeltic.com (906) 346-8205	Project Manager Edward "EJ" Juers edward.juers@alliancetg.com (651) 247-7873	Pierre Bourgeade pierre.bourgeade@alliancetg.com (307) 683-6679
	Field Team Leader Ryan Schuth ryan.schuth@alliancetg.com (320) 296-2244	
	QA/QC Manager Kathleen Shonk katie.shonk@alliancetg.com (812) 452-4785	
	Report Coordinator Nicholas Venderley nick.venderley@alliancetg.com (812) 452-4785	
	Report Reviewer Tyler Winslow tyler.winslow@alliancetg.com (812) 549-8434	

Alliance Technical Group, LLC (Alliance) has completed the source testing as described in this report. Results apply only to the source(s) tested and operating condition(s) for the specific test date(s) and time(s) identified within this report. All results are intended to be considered in their entirety, and Alliance is not responsible for use of less than the complete test report without written consent. This report shall not be reproduced in full or in part without written approval from the customer.

To the best of my knowledge and abilities, all information, facts and test data are correct. Data presented in this report has been checked for completeness and is accurate, error-free and legible. Onsite testing was conducted in accordance with approved internal Standard Operating Procedures. Any deviations or problems are detailed in the relevant sections in the test report.

This report is only considered valid once an authorized representative of Alliance has signed in the space provided below; any other version is considered draft. This document was prepared in portable document format (.pdf) and contains pages as identified in the bottom footer of this document.



---

**Edward "EJ" Juers**  
Alliance Technical Group, LLC

---

**March 20, 2024**

Date

## TABLE OF CONTENTS

1.0	Introduction .....	1-1
1.1	Facility Description.....	1-1
1.2	Project Team .....	1-1
1.3	Site Specific Test Plan & Notification .....	1-1
2.0	Summary of Results .....	2-1
3.0	Testing Methodology.....	3-1
3.1	U.S. EPA Reference Test Methods 1 and 2 – Sampling/Traverse Points and Volumetric Flow Rate .....	3-1
3.2	U.S. EPA Reference Test Method 3A – Oxygen/Carbon Dioxide.....	<b>Error! Bookmark not defined.</b>
3.3	U.S. EPA Reference Test Method 4 – Moisture Content.....	3-1
3.4	U.S. EPA Reference Test Method 5 – Particulate Matter .....	3-2
3.5	U.S. EPA Reference Test Method 19 – Mass Emission Factors.....	3-2
3.6	Quality Assurance/Quality Control – U.S. EPA Reference Test Method 3A .....	<b>Error! Bookmark not defined.</b>

## LIST OF TABLES

Table 1-1: Project Team .....	1-1
Table 2-1: Summary of Results .....	2-1
Table 3-1: Source Testing Methodology .....	3-1

## APPENDICES

Appendix A	Sample Calculations
Appendix B	Field Data
Appendix C	Laboratory Data
Appendix D	Quality Assurance/Quality Control Data
Appendix E	Process Operating/Control System Data
Appendix F	SSTP and Associated Documentation

## **1.0 Introduction**

Alliance Technical Group, LLC (Alliance) was retained by PotlatchDeltic Corporation (PotlatchDeltic) to conduct compliance testing at the Gwinn Sawmill in Gwinn, Michigan. The facility operates under the Michigan Department of Environment, Great Lakes, and Energy (EGLE) Permit No. MI-ROP-N5940-2019A. Testing was conducted to determine the emission rates of particulate matter (PM) from the exhaust of Wood Fuel Boiler No. 2.

## **1.1 Facility Description**

The PotlatchDeltic Corporation owns and operates the Wood Fuel Boiler. No 2 at the Gwinn Sawmill. The Wood Fuel Boiler 2 is a Hurst and Welding Co. Inc. Model No. HYB-4000-150-WF (SN. No. HYB3948-300-1). It has a capacity of 28.7 MMBtu/hr and is controlled by a primary and secondary multiclone.

## **1.2 Project Team**

Personnel involved in this project are identified in the following table.

**Table 1-1: Project Team**

<b>Facility Personnel</b>	Amy Benson
<b>Alliance Personnel</b>	Ryan Schuth
	Carl Bender
	Leo Peters

## **1.3 Site Specific Test Plan & Notification**

Testing was conducted in accordance with the Site-Specific Test Plan (SSTP) approved by EGLE.

## 2.0 Summary of Results

Alliance conducted compliance testing at the PotlatchDeltic facility in Gwinn, MI on February 27, 2024. Testing consisted of determining the emission rates of PM from the exhaust of Wood Fuel Boiler No. 2.

Table 2-1 provides a summary of the emission testing results with comparisons to the applicable Michigan EGLE permit limits. Any difference between the summary results listed in the following tables and the detailed results contained in appendices is due to rounding for presentation.

**Table 2-1: Summary of Results**

Run Number	Run 1	Run 2	Run 3	Average
Date	2/17/24	2/17/24	2/17/24	--
<b>Filterable Particulate Matter Data</b>				
Concentration, grain/dscf	0.090	0.091	0.085	0.089
Emission Rate, lb/hr	4.2	4.3	4.0	4.2
Permit Limit, lb/hr	--	--	--	5.7
<b>Percent of Limit, %</b>	--	--	--	<b>73</b>
Emission Rate, ton/yr	18.4	18.7	17.6	18.2
Permit Limit, ton/yr	--	--	--	25.1
<b>Percent of Limit, %</b>	--	--	--	<b>73</b>
Emission Factor, lb/MMBtu	0.16	0.16	0.14	0.15
Permit Limit, lb/MMBtu	--	--	--	0.2
<b>Percent of Limit, %</b>	--	--	--	<b>76</b>

### 3.0 Testing Methodology

The emission testing program was conducted in accordance with the test methods listed in Table 3-1. Method descriptions are provided below while quality assurance/quality control data is provided in Appendix D.

**Table 3-1: Source Testing Methodology**

Parameter	U.S. EPA Reference Test Methods	Notes/Remarks
Volumetric Flow Rate	1 & 2	Full Velocity Traverses
Oxygen/Carbon Dioxide	3/3A	Integrated Bag / Instrumental Analysis
Moisture Content	4	Gravimetric Analysis
Particulate Matter	5	Isokinetic Sampling
Mass Emission Factors	19	Fuel Factors/Heat Inputs

#### 3.1 U.S. EPA Reference Test Methods 1 and 2 – Sampling/Traverse Points and Volumetric Flow Rate

The sampling location and number of traverse (sampling) points were selected in accordance with U.S. EPA Reference Test Method 1. To determine the minimum number of traverse points, the upstream and downstream distances were equated into equivalent diameters and compared to Figure 1-1 in U.S. EPA Reference Test Method 1.

Full velocity traverses were conducted in accordance with U.S. EPA Reference Test Method 2 to determine the average stack gas velocity pressure, static pressure and temperature. The velocity and static pressure measurement system consisted of a pitot tube and inclined manometer. The stack gas temperature was measured with a K-type thermocouple and pyrometer.

Stack gas velocity pressure and temperature readings were recorded during each test run. The data collected was utilized to calculate the volumetric flow rate in accordance with U.S. EPA Reference Test Method 2.

#### 3.2 U.S. EPA Reference Test Method 3A – Oxygen/Carbon Dioxide

The oxygen ( $O_2$ ) and carbon dioxide ( $CO_2$ ) testing was conducted in accordance with U.S. EPA Reference Test Method 3A. Data was collected online and reported in one-minute averages. The sampling system consisted of a stainless-steel probe, Teflon sample line(s), gas conditioning system and the identified gas analyzer. The gas conditioning system was a non-contact condenser used to remove moisture from the stack gas. If an unheated Teflon sample line was used, then a portable non-contact condenser was placed in the system directly after the probe. Otherwise, a heated Teflon sample line was used. The quality control measures are described in Section 3.6.

#### 3.3 U.S. EPA Reference Test Method 4 – Moisture Content

The stack gas moisture content (BWS) was determined in accordance with U.S. EPA Reference Test Method 4. The gas conditioning train consisted of a series of chilled impingers. Prior to testing, each impinger was filled with a known quantity of water or silica gel. Each impinger was analyzed gravimetrically before and after each test run on the same balance to determine the amount of moisture condensed.

### **3.4 U.S. EPA Reference Test Method 5 – Particulate Matter**

The filterable particulate matter testing was conducted accordance with U.S. EPA Reference Test Method 5. The complete sampling system consisted of a stainless-steel nozzle, heated glass-lined probe, pre-weighed heated quartz filter, gas conditioning train, pump and calibrated dry gas meter. The gas conditioning train consisted of four (4) chilled impingers – the first and second containing 100 mL of H<sub>2</sub>O, an empty third impinger and the fourth containing 200-300 grams of silica gel. The probe liner and filter heating systems were maintained at a temperature of 120 ± 14°C (248 ± 25°F) and the impinger temperature was maintained at 20°C (68°F) or less throughout the testing.

Following the completion of each test run, the sampling train was leak checked at a vacuum pressure greater than or equal to the highest vacuum pressure observed during the run, and the contents of the impingers were measured for moisture gain. The probe was rinsed and brushed three (3) times and nozzle was rinsed and brushed six (6) times with acetone to remove any adhering particulate matter. This rinse was recovered in container 2. The front half of the filter holder was rinsed three (3) times with acetone and this rinse was added to container 2. The pre-weighed quartz filter was carefully removed and placed in container 1. All containers were sealed, labeled and liquid levels marked for transport to the identified laboratory.

### **3.5 U.S. EPA Reference Test Method 19 – Mass Emission Factors**

The pollutant concentrations were converted to mass emission factors (lb/MMBtu) using procedures outlined in U.S. EPA Reference Test Method 19. The published dry O<sub>2</sub>, wet O<sub>2</sub> or CO<sub>2</sub> based fuel factor (F-Factor) of 9,600 dscf/MMBtu for wood bark was used in the calculations.

### **3.6 Quality Assurance/Quality Control – U.S. EPA Reference Test Method 3/3A**

Cylinder calibration gases used met EPA Protocol 1 (+/- 2%) standards. Copies of all calibration gas certificates can be found in the Quality Assurance/Quality Control Appendix.

Low-Level gas was introduced directly to the analyzer. After adjusting the analyzer to the Low-Level gas concentration and once the analyzer reading was stable, the analyzer value was recorded. This process was repeated for the High-Level gas. For the Calibration Error Test, Low, Mid, and High-Level calibration gases were sequentially introduced directly to the analyzer. All values were within 2.0 percent of the Calibration Span or 0.5% absolute difference.

At the completion of testing, the data was also saved to the Alliance server. All data was reviewed by the Field Team Leader before leaving the facility. Once arriving at Alliance's office, all written and electronic data was relinquished to the report coordinator and then a final review was performed by the Project Manager.



Location: PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

Source: Boiler No. 2

Project No.: AST-2024-1279

Run No.: 1

Parameter: PM

---

Meter Pressure (Pm), in. Hg

$$P_m = P_b + \frac{\Delta H}{13.6}$$

where,

Pb	28.10	= barometric pressure, in. Hg
$\Delta H$	1.192	= pressure differential of orifice, in. H <sub>2</sub> O
Pm	28.19	= in. Hg

Absolute Stack Gas Pressure (Ps), in. Hg

$$P_s = P_b + \frac{P_g}{13.6}$$

where,

Pb	28.10	= barometric pressure, in. Hg
Pg	-0.40	= static pressure, in. H <sub>2</sub> O
Ps	28.07	= in. Hg

Standard Meter Volume (Vmstd), dscf

$$V_{mstd} = \frac{17.636 \times Y \times V_m \times P_m}{T_m}$$

where,

Y	0.995	= meter correction factor
V <sub>m</sub>	36.400	= meter volume, cf
P <sub>m</sub>	28.19	= absolute meter pressure, in. Hg
T <sub>m</sub>	529.2	= absolute meter temperature, °R
V <sub>mstd</sub>	34.021	= dscf

Standard Wet Volume (Vwstd), scf

$$V_{wstd} = 0.04716 \times V_{lc}$$

where,

V <sub>lc</sub>	161.7	= weight of H <sub>2</sub> O collected, g
V <sub>wstd</sub>	7.626	= scf

Moisture Fraction (BWSsat), dimensionless (theoretical at saturated conditions)

$$BWS_{sat} = \frac{10^{6.37 - \left( \frac{2,827}{T_s + 365} \right)}}{P_s}$$

where,

T <sub>s</sub>	341.5	= stack temperature, °F
P <sub>s</sub>	28.07	= absolute stack gas pressure, in. Hg
BWS <sub>sat</sub>	8.267	= dimensionless

Moisture Fraction (BWS), dimensionless (measured)

$$BWS = \frac{V_{wstd}}{(V_{wstd} + V_{mstd})}$$

where,

V <sub>wstd</sub>	7.626	= standard wet volume, scf
V <sub>mstd</sub>	34.021	= standard meter volume, dscf
BWS	0.183	= dimensionless



Location: PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

Source: Boiler No. 2

Project No.: AST-2024-1279

Run No.: 1

Parameter: PM

---

**Moisture Fraction (BWS), dimensionless**

$$BWS = BWS_{msd} \text{ unless } BWS_{sat} < BWS_{msd}$$

where,

$$\frac{BWS_{sat}}{BWS_{msd}} = \frac{8.267}{0.183} = \text{moisture fraction (theoretical at saturated conditions)}$$
$$\frac{BWS_{msd}}{BWS} = \frac{0.183}{0.183} = \text{moisture fraction (measured)}$$

**Molecular Weight (DRY) (Md), lb/lb-mole**

$$Md = (0.44 \times \% CO_2) + (0.32 \times \% O_2) + (0.28 (100 - \% CO_2 - \% O_2))$$

where,

$$\frac{CO_2}{O_2} = \frac{15.4}{4.6} = \text{carbon dioxide concentration, \%}$$
$$\frac{Md}{30.65} = \frac{30.65}{30.65} = \text{oxygen concentration, \%}$$
$$Md = \frac{30.65}{30.65} = \text{lb/lb mol}$$

**Molecular Weight (WET) (Ms), lb/lb-mole**

$$Ms = Md (1 - BWS) + 18.015 (BWS)$$

where,

$$\frac{Md}{BWS} = \frac{30.65}{0.183} = \text{molecular weight (DRY), lb/lb mol}$$
$$\frac{Ms}{28.33} = \frac{0.183}{0.183} = \text{moisture fraction, dimensionless}$$
$$Ms = \frac{28.33}{0.183} = \text{lb/lb mol}$$

**Average Velocity (Vs), ft/sec**

$$Vs = 85.49 \times Cp \times (\Delta P^{1/2})_{avg} \times \sqrt{\frac{Ts}{Ps \times Ms}}$$

where,

$$\frac{Cp}{\Delta P^{1/2}} = \frac{0.840}{0.526} = \text{pitot tube coefficient}$$
$$\frac{Ts}{801.2} = \frac{0.526}{0.526} = \text{velocity head of stack gas, (in. H}_2\text{O)}^{1/2}$$
$$\frac{Ps}{28.07} = \frac{801.2}{28.07} = \text{absolute stack temperature, } ^\circ\text{R}$$
$$\frac{Ms}{28.33} = \frac{28.07}{28.07} = \text{absolute stack gas pressure, in. Hg}$$
$$\frac{Vs}{37.9} = \frac{28.33}{28.33} = \text{molecular weight of stack gas, lb/lb mol}$$
$$Vs = \frac{37.9}{37.9} = \text{ft/sec}$$

**Average Stack Gas Flow at Stack Conditions (Qa), acfm**

$$Qa = 60 \times Vs \times As$$

where,

$$\frac{Vs}{As} = \frac{37.9}{4.75} = \text{stack gas velocity, ft/sec}$$
$$\frac{As}{Qa} = \frac{4.75}{10,787} = \text{cross-sectional area of stack, ft}^2$$
$$Qa = \frac{10,787}{4.75} = \text{acfim}$$



**Location:** PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

**Source:** Boiler No. 2

**Project No.:** AST-2024-1279

**Run No.:** 1

**Parameter:** PM

---

**Average Stack Gas Flow at Standard Conditions (Q<sub>s</sub>), dscfm**

$$Q_s = 17.636 \times Q_a \times (1 - BWS) \times \frac{P_s}{T_s}$$

where,

<u>Q<sub>a</sub></u>	<u>10,787</u>	= average stack gas flow at stack conditions, acfm
<u>BWS</u>	<u>0.183</u>	= moisture fraction, dimensionless
<u>P<sub>s</sub></u>	<u>28.07</u>	= absolute stack gas pressure, in. Hg
<u>T<sub>s</sub></u>	<u>801.2</u>	= absolute stack temperature, °R
<u>Q<sub>s</sub></u>	<u>5,445</u>	= dscfm

**Dry Gas Meter Calibration Check (Y<sub>qa</sub>), dimensionless**

$$Y_{qa} = \frac{Y - \left( \frac{\Theta}{V_m} \sqrt{\frac{0.0319 \times T_m \times 29}{\Delta H @ \times \left( P_b + \frac{\Delta H_{avg.}}{13.6} \right) \times M_d}} \sqrt{\Delta H_{avg.}} \right)}{Y} \times 100$$

where,

<u>Y</u>	<u>0.995</u>	= meter correction factor, dimensionless
<u>Θ</u>	<u>60</u>	= run time, min.
<u>V<sub>m</sub></u>	<u>36.4</u>	= total meter volume, dcf
<u>T<sub>m</sub></u>	<u>529.2</u>	= absolute meter temperature, °R
<u>ΔH @</u>	<u>1.764</u>	= orifice meter calibration coefficient, in. H <sub>2</sub> O
<u>P<sub>b</sub></u>	<u>28.10</u>	= barometric pressure, in. Hg
<u>ΔH avg</u>	<u>1.192</u>	= average pressure differential of orifice, in H <sub>2</sub> O
<u>M<sub>d</sub></u>	<u>30.65</u>	= molecular weight (DRY), lb/lb mol
<u>(Δ H)<sup>1/2</sup></u>	<u>1.084</u>	= average squareroot pressure differential of orifice, (in. H <sub>2</sub> O) <sup>1/2</sup>
<u>Y<sub>qa</sub></u>	<u>-1.8</u>	= percent

**Volume of Nozzle (V<sub>n</sub>), ft<sup>3</sup>**

$$V_n = \frac{T_s}{P_s} \left( 0.002669 \times V_{lc} + \frac{V_m \times P_m \times Y}{T_m} \right)$$

where,

<u>T<sub>s</sub></u>	<u>801.2</u>	= absolute stack temperature, °R
<u>P<sub>s</sub></u>	<u>28.07</u>	= absolute stack gas pressure, in. Hg
<u>V<sub>lc</sub></u>	<u>161.7</u>	= volume of H <sub>2</sub> O collected, ml
<u>V<sub>m</sub></u>	<u>36.400</u>	= meter volume, cf
<u>P<sub>m</sub></u>	<u>28.19</u>	= absolute meter pressure, in. Hg
<u>Y</u>	<u>0.995</u>	= meter correction factor, unitless
<u>T<sub>m</sub></u>	<u>529.2</u>	= absolute meter temperature, °R
<u>V<sub>n</sub></u>	<u>67.376</u>	= volume of nozzle, ft <sup>3</sup>



Location: PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

Source: Boiler No. 2

Project No.: AST-2024-1279

Run No.: 1

Parameter: PM

---

Isokinetic Sampling Rate (I), %

$$I = \left( \frac{Vn}{\theta \times 60 \times An \times Vs} \right) \times 100$$

where,

Vn	67.376	= nozzle volume, ft <sup>3</sup>
$\theta$	60.0	= run time, minutes
An	0.00049	= area of nozzle, ft <sup>2</sup>
Vs	37.9	= average velocity, ft/sec
I	100.7	= %

Filterable PM Concentration (C<sub>s</sub>), grain/dscf

$$C_s = \frac{M_n \times 0.0154}{Vmstd}$$

where,

M <sub>n</sub>	198.4	= filterable PM mass, mg
V <sub>mstd</sub>	34.021	= standard meter volume, dscf
C <sub>s</sub>	0.090	= grain/dscf

Filterable PM Emission Rate (PMR), lb/hr

$$PMR = \frac{C_s \times Qs \times 60}{7.0E + 03}$$

where,

C <sub>s</sub>	0.0900	= filterable PM concentration, grain/dscf
Q <sub>s</sub>	5,445	= average stack gas flow at standard conditions, dscfm
PMR	4.2	= lb/hr

Filterable PM Emission Rate (ER<sub>PMTPY</sub>), ton/yr

$$ER_{PMTPY} = \frac{PMR \times 8,760}{2.0E + 03}$$

where,

PMR	4.2	= filterable PM emission rate, lb/hr
ER <sub>PMTPY</sub>	18.4	= ton/yr

Filterable PM Emission Factor (EF<sub>PM O2d</sub>), lb/MMBtu

$$EF_{PM O2d} = \frac{M_n \times Fd}{Vmstd \times 4.54E + 05} \times \frac{20.9}{20.9 - O_2}$$

where,

M <sub>n</sub>	198.4	= filterable PM mass, mg
F <sub>d</sub>	9,600	= oxygen based fuel factor, dscf/MMBtu
V <sub>mstd</sub>	34.021	= standard meter volume, dscf
O <sub>2</sub>	4.6	= oxygen concentration, %
EF <sub>PM O2d</sub>	0.16	= lb/MMBtu

**Location** PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

**Source** Boiler No. 2

**Project No.** AST-2024-1279

**Parameter** PM

Run Number		Run 1	Run 2	Run 3	Average
Date		2/27/24	2/27/24	2/27/24	--
Start Time		8:10	10:10	12:10	--
Stop Time		9:17	11:14	13:12	--
Run Time, min	(θ)	60.0	60.0	60.0	60.0
<b>INPUT DATA</b>					
Fuel Factor (O2 dry), dscf/MMBtu	(Fd)	9,600	9,600	9,600	9,600
Barometric Pressure, in. Hg	(Pb)	28.10	28.10	28.10	28.10
Meter Correction Factor	(Y)	0.995	0.995	0.995	0.995
Orifice Calibration Value	(ΔH @)	1.764	1.764	1.764	1.764
Meter Volume, ft <sup>3</sup>	(Vm)	36.400	36.750	35.850	36.333
Meter Temperature, °F	(Tm)	69.6	73.9	72.8	72.1
Meter Temperature, °R	(Tm)	529.2	533.6	532.4	531.7
Meter Orifice Pressure, in. WC	(ΔH)	1.192	1.197	1.131	1.173
Volume H <sub>2</sub> O Collected, mL	(Vlc)	161.7	163.4	139.9	155.0
Nozzle Diameter, in	(Dn)	0.300	0.300	0.300	0.300
Area of Nozzle, ft <sup>2</sup>	(An)	0.0005	0.0005	0.0005	0.0005
Filterable PM Mass, mg	(Mn)	198.4	200.8	183.4	194.2
<b>ISOKINETIC DATA</b>					
Standard Meter Volume, ft <sup>3</sup>	(Vmstd)	34.021	34.069	33.300	33.797
Standard Water Volume, ft <sup>3</sup>	(Vwstd)	7.626	7.706	6.598	7.310
Moisture Fraction Measured	(BWSmsd)	0.183	0.184	0.165	0.178
Moisture Fraction @ Saturation	(BWSSat)	8.267	8.529	8.386	8.394
Moisture Fraction	(BWS)	0.183	0.184	0.165	0.178
Meter Pressure, in Hg	(Pm)	28.19	28.19	28.18	28.19
Volume at Nozzle, ft <sup>3</sup>	(Vn)	67.376	67.785	64.637	66.60
Isokinetic Sampling Rate, (%)	(I)	100.7	100.0	97.4	99.3
DGM Calibration Check Value, (+/- 5%)	(Y <sub>qa</sub> )	-1.8	-1.4	-0.8	-1.3
<b>EMISSION CALCULATIONS</b>					
Filterable PM Concentration, grain/dscf	(C <sub>s</sub> )	0.090	0.091	0.085	0.089
Filterable PM Emission Rate, lb/hr	(PMR)	4.2	4.3	4.0	4.2
Filterable PM Emission Rate, ton/yr	(ER <sub>FPM</sub> )	18.4	18.7	17.6	18.2
Filterable PM Emission Factor, lb/MMBtu (O <sub>2</sub> )	(EF <sub>PM O2d</sub> )	0.16	0.16	0.14	0.15

## Method 1 Data

Location PotlatchDeltic / Gwinn Sawmill - Gwinn, MI


Source Boiler No. 2

Project No. AST-2024-1279

Date: 02/26/24

### Stack Parameters

Duct Orientation:	Vertical
Duct Design:	Circular
Distance from Far Wall to Outside of Port:	34.00 in
Nipple Length:	4.50 in
Depth of Duct:	29.50 in
Cross Sectional Area of Duct:	4.75 ft <sup>2</sup>
No. of Test Ports:	2
Distance A:	15.0 ft
Distance A Duct Diameters:	6.1 (must be ≥ 0.5)
Distance B:	14.0 ft
Distance B Duct Diameters:	5.7 (must be ≥ 2)
Minimum Number of Traverse Points:	20
Actual Number of Traverse Points:	20
Number of Readings per Point:	1
Measurer (Initial and Date):	LP 2/26
Reviewer (Initial and Date):	RA 2/26




### CIRCULAR DUCT

	LOCATION OF TRAVERSE POINTS Number of traverse points on a diameter											
	2	3	4	5	6	7	8	9	10	11	12	
1	14.6	--	6.7	--	4.4	--	3.2	--	2.6	--	2.1	
2	85.4	--	25.0	--	14.6	--	10.5	--	8.2	--	6.7	
3	--	--	75.0	--	29.6	--	19.4	--	14.6	--	11.8	
4	--	--	93.3	--	70.4	--	32.3	--	22.6	--	17.7	
5	--	--	--	--	85.4	--	67.7	--	34.2	--	25.0	
6	--	--	--	--	95.6	--	80.6	--	65.8	--	35.6	
7	--	--	--	--	--	--	89.5	--	77.4	--	64.4	
8	--	--	--	--	--	--	96.8	--	85.4	--	75.0	
9	--	--	--	--	--	--	--	--	91.8	--	82.3	
10	--	--	--	--	--	--	--	--	97.4	--	88.2	
11	--	--	--	--	--	--	--	--	--	--	93.3	
12	--	--	--	--	--	--	--	--	--	--	97.9	

\*Percent of stack diameter from inside wall to traverse point.

Stack Diagram  
A = 15 ft.  
B = 14 ft.  
Depth of Duct = 29.5 in.

Traverse Point	% of Diameter	Distance from Inside wall	Distance from outside of port
1	2.6	1.00	5 1/2
2	8.2	2.42	6 15/16
3	14.6	4.31	8 13/16
4	22.6	6.67	11 3/16
5	34.2	10.09	14 9/16
6	65.8	19.41	23 15/16
7	77.4	22.83	27 5/16
8	85.4	25.19	29 11/16
9	91.8	27.08	31 9/16
10	97.4	28.50	33
11	--	--	--
12	--	--	--



**Location** PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

**Source** Boiler No. 2

**Project No.** AST-2024-1279

**Parameter** PM

Run Number	Run 1	Run 2	Run 3	Average
Date	2/27/24	2/27/24	2/27/24	--
Start Time	8:10	10:10	12:10	--
Stop Time	9:17	11:14	13:12	--
Run Time, min	60.0	60.0	60.0	60.0
<b>VELOCITY HEAD, in. WC</b>				
Point 1	0.18	0.23	0.17	0.19
Point 2	0.20	0.25	0.19	0.21
Point 3	0.21	0.27	0.21	0.23
Point 4	0.22	0.29	0.23	0.25
Point 5	0.26	0.35	0.25	0.29
Point 6	0.34	0.43	0.32	0.36
Point 7	0.35	0.40	0.35	0.37
Point 8	0.34	0.38	0.31	0.34
Point 9	0.27	0.30	0.25	0.27
Point 10	0.26	0.27	0.17	0.23
Point 11	0.19	0.16	0.23	0.19
Point 12	0.22	0.20	0.27	0.23
Point 13	0.26	0.22	0.28	0.25
Point 14	0.30	0.24	0.29	0.28
Point 15	0.31	0.26	0.32	0.30
Point 16	0.40	0.34	0.41	0.38
Point 17	0.40	0.35	0.40	0.38
Point 18	0.35	0.33	0.35	0.34
Point 19	0.28	0.24	0.29	0.27
Point 20	0.26	0.22	0.27	0.25
<b>CALCULATED DATA</b>				
Square Root of $\Delta P$ , (in. WC) $^{1/2}$	( $\Delta P$ )	0.526	0.531	0.523
Pitot Tube Coefficient	( $C_p$ )	0.840	0.840	0.840
Barometric Pressure, in. Hg	( $P_b$ )	28.10	28.10	28.10
Static Pressure, in. WC	( $P_g$ )	-0.40	-0.40	-0.40
Stack Pressure, in. Hg	( $P_s$ )	28.07	28.07	28.07
Stack Cross-sectional Area, ft $^2$	( $A_s$ )	4.75	4.75	4.75
Temperature, °F	( $T_s$ )	341.5	343.9	342.6
Temperature, °R	( $T_s$ )	801.2	803.6	802.3
Moisture Fraction Measured	( $BW_{Smsd}$ )	0.183	0.184	0.165
Moisture Fraction @ Saturation	( $BW_{Ssat}$ )	8.267	8.529	8.386
Moisture Fraction	( $BWS$ )	0.183	0.184	0.165
O <sub>2</sub> Concentration, %	(O <sub>2</sub> )	4.6	4.3	3.8
CO <sub>2</sub> Concentration, %	(CO <sub>2</sub> )	15.4	15.5	16
Molecular Weight, lb/lb-mole (dry)	(M <sub>d</sub> )	30.65	30.65	30.71
Molecular Weight, lb/lb-mole (wet)	(M <sub>s</sub> )	28.33	28.32	28.61
Velocity, ft/sec	(V <sub>s</sub> )	37.9	38.4	37.6
<b>VOLUMETRIC FLOW RATE</b>				
At Stack Conditions, acfm	(Q <sub>a</sub> )	10,787	10,924	10,698
At Standard Conditions, scfm	(Q <sub>sw</sub> )	6,665	6,730	6,601
At Standard Conditions, dscfm	(Q <sub>s</sub> )	5,445	5,488	5,510

## Method 2 Data

Location PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

Source Boiler No. 2

Project No. AST-2024-1279

Date 2/27/24

Saturation Moisture Content Check	
Stack Temperature (Ts):	363.0 °F
Moisture Fraction @ Sat.:	10.574

Stack Parameters	
Pitot Tube ID#:	
Pitot Tube Coefficient (Cp):	0.840
Barometric Pressure (Pb):	28.85 in. Hg
Static Pressure(Pg):	-0.40 in. WC
Stack Pressure (Ps):	28.82 in. Hg

Calculations	
Square Root of ΔP, (in. W.C.) <sup>1/2</sup>	0.575
Average ΔP, (in. W.C.)	0.33
Average Temperature (Ts), °F	363.0
Average Temperature (Ts), °R	822.7
Moisture (BWS), % (enter as percent)	16.0
O <sub>2</sub> Concentration, %	6.0
CO <sub>2</sub> Concentration, %	12.0
Molecular Weight (Md), lb/lb-mole (dry)	30.16
Molecular Weight (Ms), lb/lb-mole (wet)	28.21
Velocity (Vs), ft/sec	41.5
VFR at stack conditions (Qa), acfm	11,832
VFR at standard conditions (Qs), dscfm	6,141

Traverse Point	Δ P (in. WC)	Ts (°F)
1	0.24	363
2	0.27	363
3	0.31	363
4	0.32	363
5	0.32	363
6	0.46	363
7	0.42	363
8	0.41	363
9	0.40	363
10	0.36	363
11	0.23	363
12	0.24	363
13	0.27	363
14	0.29	363
15	0.37	363
16	0.38	363
17	0.40	363
18	0.36	363
19	0.33	363
20	0.30	363



## Cyclonic Flow Check

Location PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

Source Boiler No. 2

Project No. AST-2024-1279

Date 02/27/24

Sample Point	Angle ( $\Delta P=0$ )
1	5
2	5
3	5
4	0
5	0
6	0
7	0
8	5
9	0
10	5
11	10
12	10
13	0
14	0
15	0
16	0
17	0
18	0
19	0
20	0
Average	2

Location PotlatchDeltic / Gwinn Sawmill - Gwinn, MI

 Source Boiler No. 2

 Project No. AST-2024-1279

	O <sub>2</sub> Data			CO <sub>2</sub> Data		
	Date/Time	2/28/24	14:30	Date/Time	2/28/24	14:30
<b>Make/Model/SN</b>	Servomex	1420C	TR16	Servomex	1420C	2553-0144001
<b>Parameter</b>	<b>Cylinder ID</b>	<b>Cylinder Concentration, %</b>	<b>Analyzer Concentration, %</b>	<b>Cylinder ID</b>	<b>Cylinder Concentration, %</b>	<b>Analyzer Concentration, %</b>
Zero Gas		0.00	0.00		0.00	0.00
High Range Gas	CC458895	20.90	20.95	CC458895	16.90	16.91
Mid Range Gas	CC480335	10.95	11.03	CC480335	8.43	8.33
<b>Concentration Span, %</b>	20.9			16.9		
<b>Required Accuracy, %</b>	0.42			0.34		
Run No.	<b>Run 1</b>		<b>Run 2</b>		<b>Run 3</b>	
<b>Analysis Date/Time</b>	2/28/2024	15:00	2/28/2024	15:15	2/28/2024	15:30
<b>Parameter</b>	<b>O<sub>2</sub> %</b>	<b>CO<sub>2</sub> %</b>	<b>O<sub>2</sub> %</b>	<b>CO<sub>2</sub> %</b>	<b>O<sub>2</sub> %</b>	<b>CO<sub>2</sub> %</b>
Analysis #1	4.60	15.40	4.30	15.50	3.80	16.00
Analysis #2	4.60	15.40	4.30	15.50	3.80	16.00
Analysis #3	4.60	15.40	4.30	15.50	3.80	16.00
Average	4.6	15.4	4.3	15.5	3.8	16.0

The remaining constituent is assumed to be nitrogen.



## Method 4 Data

Location PotlatchDeltic / Gwinn Sawmill - Gwinn, MI  
Source Boiler No. 2  
Project No. AST-2024-1279  
Parameter PM  
Analysis Gravimetric

Run 1	Date: 2/27/24				
Impinger No.	1	2	3	4	Total
Contents	H2O	H2O	Empty	Silica	--
Initial Mass, g	749.7	769.4	608.9	1590.6	3718.6
Final Mass, g	829.4	830.6	616.5	1603.8	3880.3
Gain	79.7	61.2	7.6	13.2	161.7
Run 2	Date: 2/27/24				
Impinger No.	1	2	3	4	Total
Contents	H2O	H2O	Empty	Silica	--
Initial Mass, g	761.1	806.0	616.5	1566.0	3749.6
Final Mass, g	856.9	840.7	635.3	1580.1	3913.0
Gain	95.8	34.7	18.8	14.1	163.4
Run 3	Date: 2/27/24				
Impinger No.	1	2	3	4	Total
Contents	H2O	H2O	Empty	Silica	--
Initial Mass, g	742.6	795.6	635.3	1580.1	3753.6
Final Mass, g	841.6	823.5	639.9	1588.5	3893.5
Gain	99.0	27.9	4.6	8.4	139.9



## Isokinetic Field Data

Location: PotlatchDeltic / Gwinn Sawmill - Gwinn, MI		Start Time: 8:10		Source: Boiler No. 2											
Date: 2/27/24		Run 1		Project No.: AST-2024-1279											
VALID		End Time: 9:17		Parameter: PM											
STACK DATA (EST)	EQUIPMENT	STACK DATA (EST)	FILTER NO.	STACK DATA (FINAL)	MOIST. DATA										
Moisture: 16.0 % est.	Meter Box ID: 17	Est. Tm: 70 °F	KQ82-23-045	Pb: 28.10 in. Hg	Vlc (ml)										
Barometric: 28.85 in. Hg	Y: 0.995	Est. Ts: 363 °F		Pg: -0.40 in. WC	161.7										
Static Press: -0.40 in. WC	ΔH @ (in.WC): 1.764	Est. ΔP: 0.33 in. WC		O <sub>2</sub> : 4.6 %	K-FACTOR										
Stack Press: 28.82 in. Hg	Probe ID: 05-04-G1	Est. Dn: 0.276 in.		CO <sub>2</sub> : 15.4 %	4.123										
CO <sub>2</sub> : 12.0 %	Liner Material: glass	Target Rate: 0.56 scfm													
O <sub>2</sub> : 6.0 %	Pitot ID: 05-04-G1	LEAK CHECK!	Pre Mid 1 Mid 2 Mid 3 Post	Check Pt. Initial Final Corr.	--										
N <sub>2</sub> /CO: 82.0 %	Pitot Cp/Type: 0.840 S-type	Leak Rate (cfm): 0.000 -- -- --	0.000	Mid 1 (cf)	--										
Md: 30.16 lb/lb-mole	Nozzle ID: ss SS	Vacuum (in Hg): 16 -- -- --	15	Mid 2 (cf)	--										
Ms: 28.21 lb/lb-mole	Nozzle Dn (in.): 0.300	Pitot Tube: Pass -- -- --	Pass	Mid 3 (cf)	--										
				Mid-Point Leak Check Vol (cf):	--										
Sample Pt.	Sample Time (minutes)		Dry Gas Meter Reading (ft <sup>3</sup> )	Pitot Tube ΔP (in WC)	Gas Temperatures (°F)		Orifice Press. ΔH (in. WC)	Pump Vac (in. Hg)	Gas Temperatures (°F)				% ISO	Vs (fps)	
					DGM Average	Stack			Probe	Filter	Imp Exit	Aux			
	Begin	End			Amb.	Amb.			60	34	Ideal	Actual			34
1	0.00	3.00	387.610	0.18	63	336	0.76	0.76	2	253	247	42	-	103.9	30.14
2	3.00	6.00	389.140	0.20	64	338	0.84	0.84	2	251	248	42	-	100.5	31.81
3	6.00	9.00	390.700	0.21	65	342	0.88	0.88	2	251	246	42	-	97.5	32.67
4	9.00	12.00	392.250	0.22	65	342	0.92	0.92	2	252	247	42	-	99.6	33.44
5	12.00	15.00	393.870	0.26	66	341	1.09	1.10	3	253	248	42	-	97.6	36.33
6	15.00	18.00	395.600	0.34	67	348	1.42	1.40	5	251	249	43	-	95.0	41.73
7	18.00	21.00	397.520	0.35	67	344	1.47	1.50	5	255	244	43	-	97.3	42.24
8	21.00	24.00	399.520	0.34	68	334	1.45	1.50	5	251	247	43	-	97.5	41.37
9	24.00	27.00	401.510	0.27	70	340	1.15	1.20	6	254	249	43	-	103.8	37.00
10	27.00	30.00	403.400	0.26	71	339	1.11	1.10	5	251	250	43	-	101.0	36.29
1	30.00	33.00	405.210	0.19	71	334	0.82	0.80	5	251	252	44	-	98.2	30.92
2	33.00	36.00	406.720	0.22	71	338	0.94	0.94	5	251	253	43	-	100.0	33.36
3	36.00	39.00	408.370	0.26	72	340	1.11	1.10	6	250	256	43	-	99.8	36.31
4	39.00	42.00	410.160	0.30	72	345	1.27	1.30	7	251	256	44	-	101.0	39.13
5	42.00	45.00	412.100	0.31	72	346	1.31	1.30	7	252	257	44	-	96.4	39.80
6	45.00	48.00	413.980	0.40	72	349	1.68	1.70	9	251	256	44	-	96.0	45.29
7	48.00	51.00	416.100	0.40	72	353	1.68	1.70	11	253	255	44	-	97.5	45.40
8	51.00	54.00	418.250	0.35	74	344	1.49	1.50	11	254	260	44	-	98.0	42.24
9	54.00	57.00	420.290	0.28	74	339	1.20	1.20	10	256	258	44	-	102.2	37.66
10	57.00	60.00	422.200	0.26	75	338	1.12	1.10	10	258	260	44	-	100.2	36.27
Final DGM:		424.010													
RESULTS	Run Time		Vm	ΔP	Tm	Ts	Max Vac	ΔH	%ISO	BWS	Y <sub>qs</sub>				
	60.0	min	36.400	ft <sup>3</sup>	0.28	in. WC	69.6	°F	341.5	°F	11	1.192	in. WC	100.7	0.183



## Isokinetic Field Data

Location: PotlatchDeltic / Gwinn Sawmill - Gwinn, MI Date: 2/27/24 Run 2 VALID				Start Time: 10:10 End Time: 11:14	Source: Boiler No. 2 Project No.: AST-2024-1279 Parameter: PM									
<b>STACK DATA (EST)</b>		<b>EQUIPMENT</b>		<b>STACK DATA (EST)</b>	<b>FILTER NO.</b>	<b>STACK DATA (FINAL)</b>								
Moisture: 17.0 % est.		Meter Box ID: 17		Est. Tm: 70 °F	KQ82-23-046	Pb: 28.10 in. Hg								
Barometric: 28.85 in. Hg		Y: 0.995		Est. Ts: 342 °F		Pg: -0.40 in. WC								
Static Press: -0.40 in. WC		ΔH @ (in.WC): 1.764		Est. ΔP: 0.28 in. WC		O <sub>2</sub> : 4.3 %								
Stack Press: 28.82 in. Hg		Probe ID: 05-04-A1		Est. Dn: 0.288 in.		CO <sub>2</sub> : 15.5 %								
CO <sub>2</sub> : 12.0 %		Liner Material: glass		Target Rate: 0.56 scfm		K-FACTOR: 4.15								
O <sub>2</sub> : 6.0 %		Pitot ID: 05-04-A1				Check Pt. Initial Final Corr.								
N <sub>2</sub> /CO: 82.0 %		Pitot Cp/Type: 0.840 S-type		LEAK CHECK! Pre Mid 1 Mid 2 Mid 3 Post		Mid 1 (cf) --								
Md: 30.16 lb/lb-mole		Nozzle ID: ss SS		Leak Rate (cfm): 0.000 -- -- --	0.000	Mid 2 (cf) --								
Ms: 28.09 lb/lb-mole		Nozzle Dn (in.): 0.300		Vacuum (in Hg): 16 -- -- --	15	Mid 3 (cf) --								
				Pitot Tube: Pass	-- -- --	Mid-Point Leak Check Vol (cf): --								
Sample Pt.	Sample Time (minutes)		Dry Gas Meter Reading (ft <sup>3</sup> )	Pitot Tube ΔP (in WC)	Gas Temperatures (°F)	Orifice Press. ΔH (in. WC)	Pump Vac (in. Hg)	Gas Temperatures (°F)				% ISO	V <sub>s</sub> (fps)	
	Begin	End	DGM Average	Stack Amb.	Amb.		Ideal	Actual	Probe Amb.	Filter Amb.	Imp Exit Amb.	Aux Amb.		
					Amb.				--	--	--	--		
1	0.00	3.00	424.450	0.23	72	340	0.96	0.96	2	242	245	41	-	102.3 34.23
2	3.00	6.00	426.160	0.25	72	343	1.04	1.00	2	251	252	44	-	100.0 35.75
3	6.00	9.00	427.900	0.27	73	347	1.12	1.10	3	256	253	44	-	98.0 37.25
4	9.00	12.00	429.670	0.29	73	349	1.20	1.20	3	258	260	45	-	99.0 38.65
5	12.00	15.00	431.520	0.35	73	350	1.45	1.50	5	260	256	45	-	99.0 42.48
6	15.00	18.00	433.550	0.43	73	352	1.77	1.70	6	258	258	45	-	97.0 47.15
7	18.00	21.00	435.750	0.40	74	346	1.66	1.70	7	256	254	45	-	96.8 45.31
8	21.00	24.00	437.880	0.38	75	348	1.58	1.60	7	255	258	45	-	98.8 44.21
9	24.00	27.00	440.000	0.30	75	340	1.26	1.30	7	256	256	45	-	101.7 39.09
10	27.00	30.00	441.950	0.27	76	344	1.13	1.10	6	255	257	45	-	99.5 37.18
1	30.00	33.00	443.760	0.16	77	341	0.68	0.67	5	254	256	45	-	103.7 28.56
2	33.00	36.00	445.220	0.20	76	345	0.84	0.84	5	255	258	45	-	99.0 32.02
3	36.00	39.00	446.770	0.22	76	343	0.92	0.92	5	254	258	45	-	97.3 33.54
4	39.00	42.00	448.370	0.24	75	343	1.01	1.00	6	252	256	43	-	98.6 35.03
5	42.00	45.00	450.060	0.26	73	348	1.08	1.10	8	251	255	44	-	99.9 36.57
6	45.00	48.00	451.830	0.34	73	348	1.41	1.40	10	255	258	44	-	96.9 41.82
7	48.00	51.00	453.790	0.35	73	349	1.45	1.50	10	255	254	44	-	96.5 42.46
8	51.00	54.00	455.770	0.33	73	339	1.38	1.40	11	253	255	44	-	100.3 40.97
9	54.00	57.00	457.780	0.24	73	335	1.01	1.00	10	254	256	44	-	103.2 34.85
10	57.00	60.00	459.550	0.22	73	328	0.94	0.94	10	253	255	44	-	100.0 33.22
Final DGM: 461.200														
RESULTS	Run Time	V <sub>m</sub>	ΔP	T <sub>m</sub>	T <sub>s</sub>	Max Vac	ΔH	%ISO	BWS	Y <sub>q</sub>				
	60.0 min	36.750 ft <sup>3</sup>	0.29 in. WC	73.9 °F	343.9 °F	11 in. WC	1.197	100.0	0.184	-1.4				