AIR EMISSION TEST REPORT FOR THE VERIFICATION OF AIR POLLUTANT EMISSIONS FROM RENEWABLE NATURAL GAS PLANT WASTE GAS THERMAL OXIDIZER

Prepared for: Energy Developments Lansing, LLC SRN N5997

ICT Project No.: 2100178 April 8, 2022



ನೆಲೆಟ್ ಕುಗ್ರೆ ಎಂದು ೨೬೩ ರ.೪೬

,

Report Certification

AIR EMISSION TEST REPORT FOR THE VERIFICATION OF AIR POLLUTANT EMISSIONS FROM RENEWABLE NATURAL GAS PLANT WASTE GAS THERMAL OXIDIZER

EDL Lansing, LLC Facility Lansing, Michigan

The material and data in this document were prepared under the supervision and direction of the undersigned.

Impact Compliance and Testing, Inc.

Andy Rusnak, QSTI Technical Manager



APR 2.0 2027



Last Updated: April 8, 2022 AIR QUALITY DIVISION

ENERGY DEVELOPMENTS LANSING, LLC RNG PLANT WASTE GAS TOX EMISSION TEST RESULTS

Energy Developments Lansing, LLC (EDL) contracted Impact Compliance & Testing, Inc. (ICT) to conduct a performance demonstration for the determination of nitrogen oxides (NOx), carbon monoxide (CO) and sulfur dioxide (SO₂) concentrations and emission rates from a thermal oxidizer (TOX) used to control waste gas from the EDL renewable natural gas (RNG) facility located at the Granger Wood Street Landfill in Lansing, Clinton County, Michigan.

The Michigan Department of Environment, Great Lakes, and Energy-Air Quality Division (EGLE-AQD) Permit to Install (PTI) No. 178-19 requires that emission testing be performed on the RNG plant TOX within 180 days of startup. The performance testing was conducted on February 22, 2022.

NO _x Emissions				SO ₂ Emissions	
(lb/hr)	(TpY)*	(lb/hr)	(TpY)*	(lb/hr)	(TpY)*
0.50	2.19	2.59	11.4	0.02	0.10
	6.40	101	21.3	0.40	1.65
	Emis (Ib/hr) 0.50	(lb/hr) (TpY)* 0.50 2.19	Emissions Emis (lb/hr) (TpY)* (lb/hr) 0.50 2.19 2.59	Emissions Emissions (lb/hr) (TpY)* (lb/hr) (TpY)* 0.50 2.19 2.59 11.4	Emissions Emissions Emis (lb/hr) (TpY)* (lb/hr) (TpY)* (lb/hr) 0.50 2.19 2.59 11.4 0.02

The following tables present the results from the performance demonstration.

calculated value based on 8,760 hours operation per year

Emission Unit	TOX	Waste	Waste	Nat. Gas	Waste
	Temp.	Gas Flow	Gas CH₄	Fuel Use	Gas H₂S
	(ºF)	(scfm)	(%)	(scfm)	(ppm)
EUTOX	1,550	1,210	7.40	Undetermined	0.0

The data presented above indicates that EUTOX is in compliance with the lb/hr and TpY emission standards specified in PTI No. 178-19 for NOx, CO and SO₂ or that the CO and NOx compliance status with the lb/MMBtu emission limits cannot be determined.



Table of Contents

1.0	INTRODUCTION	1
2.0	 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS 2.1 Purpose and Objective of the Tests. 2.2 Operating Conditions During the Compliance Tests 2.3 Summary of Air Pollutant Sampling Results 	3 3 3 3
3.0	 SOURCE AND SAMPLING LOCATION DESCRIPTION. 3.1 General Process Description. 3.2 Rated Capacities and Air Emission Controls	5 5 5 5
4.0	 SAMPLING AND ANALYTICAL PROCEDURES. 4.1 Summary of Sampling Methods	6 7 7 8
5.0	QA/QC ACTIVITIES5.1 Flow Measurement Equipment5.2 NOx Converter Efficiency Test5.3 Gas Divider Certification (USEPA Method 205)5.4 Instrumental Analyzer Interference Check5.5 Instrument Calibration and System Bias Checks5.6 Determination of Exhaust Gas Stratification	9 9 9 9 10 10
6.0	RESULTS 6.1 Test Results and Allowable Emission Limits6.2 Variations from Normal Sampling Procedures or Operating Conditions	11 11 11



List of Tables

2.1	Average operating conditions during the test periods	4
2.2	Average measured emission rates for the TOX (three-test average)	4
6.1	Measured exhaust gas conditions and air pollutant emission rates for TOX (EUTOX)	12

List of Appendices

APPENDIX 1	SAMPLING DIAGRAMS
APPENDIX 2	OPERATING RECORDS
APPENDIX 3	FLOWRATE CALCULATIONS AND DATA SHEETS
APPENDIX 4	POLLUTANT CALCULATIONS AND CO2 LAB RESULTS
APPENDIX 5	INSTRUMENTAL ANALYZER RAW DATA
APPENDIX 6	QA/QC RECORDS



1.0 Introduction

Energy Developments Lansing, LLC (EDL) operates a renewable natural gas (RNG) plant and associated waste gas thermal oxidizer (TOX) at the Granger Wood Street Landfill in Lansing, Clinton County, Michigan. The TOX is fueled by waste gas from the process and supplemented with natural gas.

The Michigan Department of Environment, Great Lakes and Energy – Air Quality Division (EGLE-AQD) has issued EDL Permit to Install (PTI) No. 178-19 for operation of the RNG facility, which consists of:

- EUCONDSYS Landfill gas conditioning system using a membrane filtering technology to condition landfill gas into renewable natural gas (RNG) by removing hydrogen sulfide (H2S), volatile organic compounds (VOCs), carbon dioxide (CO2), nitrogen (N2), and oxygen (O2).; and
- EUTOX A 2,000 standard cubic feet per minute (scfm) thermal oxidizer (enclosed flare) used for destruction of waste gas (components removed during the conditioning of the gas and off-spec RNG).

Air emission compliance testing was performed pursuant to PTI No. 178-19. Conditions of the PTI for EUTOX state:

1. Within 180 days after commencement of initial start-up, the permittee shall verify NOx, CO, and SO2 emission rates and operating parameter boundaries for EUTOX by testing at the owner's expense, in accordance with Department requirements.

The compliance testing presented in this report was performed by Impact Compliance & Testing, Inc. (ICT), a Michigan-based environmental consulting and testing company. ICT representatives Clay Gaffey and Andrew Rusnak performed the field sampling and measurements February 22, 2022.

The TOX emission performance tests consisted of triplicate, one-hour sampling periods for nitrogen oxides (NOx), carbon monoxide (CO) and sulfur dioxide (SO₂). Exhaust gas velocity, moisture, oxygen (O₂) content, and carbon dioxide (CO₂) content were determined for each test period to calculate pollutant mass emission rates.

The exhaust gas sampling and analysis was performed using procedures specified in the Test Plan dated September 29, 2021 and follow-up email dated January 4, 2022 that were reviewed and approved by the EGLE-AQD.

EDL and the landfill have also been issued Renewable Operating Permit (ROP) No. MI-ROP-N5997-2020 for the operation of their facilities (however, the RNG plant has not been incorporated into the ROP as of the testing date).



Questions regarding this emission test report should be directed to:

Andy Rusnak, QSTI Technical Manager Impact Compliance and Testing, Inc. 4180 Keller Rd., Ste. B Holt, MI 48842 Ph: (517) 268-0043 andy.rusnak@impactcandt.com

Ms. Courtney Truett Environmental Compliance Systems Advisor for North America Energy Developments P.O. Box 15217 Lansing, MI 48901 (615) 290-4553 Courtney.truett@edlenergy.com



2.0 Summary of Test Results and Operating Conditions

2.1 Purpose and Objective of the Tests

Conditions of PTI No. 178-19 requires EDL to test EUTOX for CO, NOx and SO₂ emissions.

2.2 Operating Conditions During the Compliance Tests

The testing was performed while the TOX was operated at the routine operating conditions. The rated capacity for the TOX is 24.4 MMBtu/hr and it is designed to treat up to 2,000 scfm of waste gas. The TOX operating temperature, waste gas flowrate and waste gas methane content were recorded in 15-minute increments for each test period.

The TOX heat input would be calculated by adding the heat input contributions from the residual methane contained in the waste gas stream to the heat input contribution from the supplemental natural gas stream. During the compliance test program the EDL supplemental natural gas meter was not operating correctly, therefore, the TOX heat input could not be calculated for the test periods.

The hydrogen sulfide (H2S) concentration of the waste gas stream was also sampled once per test period using a Dräeger tube.

Appendix 2 provides operating records taken during the test periods.

Table 2.1 presents a summary of the average operating conditions during the test periods.

2.3 Summary of Air Pollutant Sampling Results

The gases exhausted from EUTOX were sampled for three (3) one-hour test periods during the compliance testing performed February 22, 2022.

Table 2.2 presents the average measured CO, NO_X and SO_2 emission rates for the TOX (average of the three test periods).

Test results for each one-hour sampling period and comparison to the permitted emission rates are presented in Section 6.0 of this report.



APR 20 2072



Emission Unit	TOX Temp. (ºF)	Waste Gas Flow (scfm)	Waste Gas CH₄ (%)	Nat. Gas Fuel Use (scfm)	TOX Heat Input* (MMBtu/hr)	Waste Gas H₂S (ppm)
EUTOX	1,550	1,210	7.40	≥200	N/A	0.0

Table 2.1 Average TOX operating conditions during the test periods

Table 2.2 Average measured emission rates for the TOX (three-test average)

		NO _x Emissions		CO Emissions		SO ₂ Emissions	
Emission Unit	(lb/hr)	(ТрҮ)*	(lb/hr)	(ТрҮ)*	(lb/hr)	(TpY)*	
EUTOX	0.50	2.19	2.59	11.4	0.02	0.10	
Permit Limits	-	6.40	-	21.3	0.40	1.65	

* - calculated value based on 8,760 hour per year of operation



3.0 Source and Sampling Location Description

3.1 General Process Description

Granger (the landfill owner / operator) operates an active LFG collection and control system. Most of the collected gas is directed to the EDL gas conditioning facility to produce RNG. The final RNG product gas is injected into a nearby natural gas pipeline and used by consumers in place of fossil fuel-derived natural gas.

The non-methane components in the incoming LFG, and a small amount of methane, are rejected to a waste gas stream that is directed to a 2,000 standard cubic feet per minute (scfm) TOX (enclosed flare) for the destruction of methane and other hydrocarbons.

3.2 Rated Capacities and Air Emission Controls

The TOX is the device used to control emissions associated with the waste gas stream that the RNG plant produces.

The TOX has a rated design capacity of:

- Waste Gas Capacity: 2,000 ft³/min
- Heat Input: 24.4 MMBtu/hr

3.3 Sampling Locations

The EUTOX exhaust gases are released to the atmosphere through a dedicated vertical exhaust stack with a vertical release point.

The EUTOX exhaust stack sampling ports are located in a vertical portion of the stack with an inner diameter of 56 inches. The stack is equipped with two (2) sample ports, opposed 90°, that provide a sampling location 36 inches (0.6 duct diameters) upstream and 324 inches (5.8 duct diameters) downstream from any flow disturbance.

All sample port locations satisfy the USEPA Method 1 criteria for a representative sample location. Individual traverse points were determined in accordance with USEPA Method 1.

Appendix 1 provides diagrams of the emission test sampling locations.



4.0 Sampling and Analytical Procedures

A test protocol for the air emission testing was reviewed and approved by the EGLE-AQD. This section provides a summary of the sampling and analytical procedures that were used during the testing periods.

4.1 Summary of Sampling Methods

USEPA Method 1	Exhaust gas velocity measurement locations were determined based on the physical stack arrangement and requirements in USEPA Method 1
USEPA Method 2	Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube.
USEPA Method 3A	Exhaust gas O_2 and CO_2 content was determined using paramagnetic and infrared instrumental analyzers, respectively.
USEPA Method 4	Exhaust gas moisture was determined based on the water weight gain in chilled impingers.
USEPA Method 6C	Exhaust gas SO ₂ concentration was determined using pulsed ultraviolet fluorescence.
USEPA Method 7E	Exhaust gas NOx concentration was determined using chemiluminescence instrumental analyzers.
USEPA Method 10	Exhaust gas CO concentration was measured using an infrared instrumental analyzer



4.2 Exhaust Gas Velocity Determination (USEPA Method 2)

The TOX exhaust stack gas velocities and volumetric flow rates were determined using USEPA Method 2 during each test period. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube. The Pitot tube and connective tubing were leak-checked periodically throughout the test periods to verify the integrity of the measurement system.

The absence of significant cyclonic flow at the sampling location was verified using an Stype Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack crosssectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

Appendix 3 provides exhaust gas flowrate calculations and field data sheets.

4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)

 CO_2 and O_2 content in the TOX exhaust gas stream was measured continuously throughout each test period in accordance with USEPA Method 3A. The CO_2 content of the exhaust was monitored using a Servomex 4900 infrared gas analyzer. The O_2 content of the exhaust was monitored using a Servomex 4900 gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the TOX exhaust gas stream was extracted from the stack using a stainless steel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O₂ and CO₂ concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

The CO_2 concentration of the exhaust gas stream exceeded the span of the instrument. The exhaust gas concentrations exceeded 30% CO_2 and the instrument was spanned to 23.14%. Samples of the exhaust gas were collected in Tedlar bags during each test period. The bags were shipped to SPL Laboratories in Traverse City, MI for CO_2 analysis by gas chromatography using test method GPA 2261M.

Appendix 4 provides O_2 and CO_2 calculation sheets. Raw instrument response data are provided in Appendix 5.



4.4 NO_x, CO and SO₂ Concentration Measurements (USEPA Methods 6C, 7E and 10)

 NO_X , CO and SO_2 pollutant concentrations in the TOX exhaust gas streams were determined using a Thermo Environmental Instruments, Inc. (TEI) Model 42i High Level chemiluminescence NO_X analyzer, a Fuji Model ZRF infrared CO analyzer and a TEI Model 43i pulsed ultraviolet fluorescence SO_2 analyzer.

Throughout each test period, a continuous sample of the TOX exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816 data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix 4 provides CO and NO_X calculation sheets. Raw instrument response data are provided in Appendix 5.



5.1 Flow Measurement Equipment

Prior to arriving onsite, the instruments used during the source test to measure exhaust gas properties and velocity (barometer and Pitot tube) were calibrated to specifications in the sampling methods.

The absence of cyclonic flow for each sampling location was verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each of the velocity traverse points with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

5.2 NO_x Converter Efficiency Test

The NO₂ – NO conversion efficiency of the Model 42i analyzer was verified prior to the testing program. A USEPA Protocol 1 certified concentration of NO₂ was injected directly into the analyzer, following the initial three-point calibration, to verify the analyzer's conversion efficiency. The analyzer's NO₂ – NO converter uses a catalyst at high temperatures to convert the NO₂ to NO for measurement. The conversion efficiency of the analyzer is deemed acceptable if the measured NO_x concentration is within 90% of the expected value.

The $NO_2 - NO$ conversion efficiency test satisfied the USEPA Method 7E criteria (measured NO_x concentration was 94.8% of the expected value).

5.3 Gas Divider Certification (USEPA Method 205)

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (within the last 12 months) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivered calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.

5.4 Instrumental Analyzer Interference Check

The instrumental analyzers used to measure NO_X , CO, SO_2 , O_2 and CO_2 have had an interference response test preformed prior to their use in the field, pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 2.5% of the span for all



measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

5.5 Instrument Calibration and System Bias Checks

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the NO_x , CO, SO_2 , CO_2 and O_2 analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the stainless steel sampling probe prior to the particulate filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO_2 , O_2 , NO_x , and CO in nitrogen and zeroed using hydrocarbon free nitrogen. The SO₂ instrument was calibrated with USEPA Protocol 1 certified concentrations of SO₂ in air and zeroed using hydrocarbon-free air. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

5.6 Determination of Exhaust Gas Stratification

A stratification test was performed for the TOX exhaust stack. The stainless steel sample probe was positioned at sample points correlating to 16.7, 50.0 (centroid) and 83.3% of the stack diameter. Pollutant concentration data were recorded at each sample point for a minimum of twice the maximum system response time.

The recorded concentration data for the TOX exhaust stack indicated that the measured NO_x concentrations did not vary by more than 5% of the mean across the stack diameter. Therefore, the TOX exhaust gas was considered to be unstratified and the compliance test sampling was performed at a single sampling location within the TOX exhaust stack.



6.1 Test Results and Allowable Emission Limits

TOX operating data and air pollutant emission measurement results for each one-hour test period are presented in Table No. 6.1.

EUTOX has the following allowable emission limits specified in PTI No. 178-19:

- 0.20 lb/MMBtu and 21.3 TpY for CO;
- 0.060 lb/MMBtu and 6.4 TpY for NO_x; and
- 0.40 lb/hr and 1.65 TpY for SO₂.

Based on the recorded data the measured air pollutant concentrations and emission rates for EUTOX are less than the allowable lb/hr and TpY limits specified in PTI No. 178-19 or the compliance status with the lb/MMBtu emission limits was not able to be determined.

6.2 Variations from Normal Sampling Procedures or Operating Conditions

The testing for all pollutants was performed in accordance with USEPA methods and the approved test protocol with the exceptions noted below. The TOX was operated at the normal routine operating conditions for the amount of gas that was available to be processed on the testing day and no variations from normal operating conditions occurred during the TOX test periods.

The CO_2 concentration of the exhaust gas stream exceeded the span of the instrument. The exhaust gas concentrations exceeded 30% CO_2 (instrument was spanned to 23.14%, which is the highest nonhazardous concentration of CO_2 that the calibration gas supplier will mix). Samples of the exhaust gas were collected in Tedlar bags during each test period. The bags were shipped to SPL Laboratories in Traverse City, MI for CO_2 analysis by gas chromatography using test method GPA 2261M. This variation was discussed with Trevor Drost of EGLE-AQD onsite.

The EDL natural gas meter that measures the amount of supplemental natural gas that is combusted in the TOX was not operating correctly during the testing program. The maximum flowrate of gas that the EDL gas meter can read and record is 200 ft³/min and the EDL gas meter displayed 200 ft³/min at all times during the testing program. Upon reviewing the specifications for the TOX, natural gas utility bills and utility natural gas meter readings that were taken during the testing program it was determined that the 200 ft³/min is likely incorrect and that the facility natural gas meter requires maintenance or calibration. Without an accurate reading of the amount of supplemental natural gas combusted during the testing program, calculating the heat input (MMBtu/hr) or CO and NOx emission factors (lb/MMBtu), for comparison against the permit limits, is not possible. However, the tested mass emission rates (lb/hr and corresponding TpY) are approximately half (CO) or one-third (NOx) of the permitted mass emission rates (TpY).



Test No. Test date Test period (24-hr clock)	1 2/22/22 834-934	2 2/22/22 1012-1112	3 2/22/22 1148-1248	Three Test Average
TOX Temperature (°F) Waste gas flowrate (scfm) Waste gas CH ₄ content (%) Waste gas H ₂ S content (ppm)	1547 1,232 7.30 0.0	1551 1,229 7.18 0.0	1552 1,169 7.72 0.0	1550 1,210 7.40 0.0
Exhaust Gas Composition CO ₂ content (% vol) O ₂ content (% vol) Moisture (% vol)	34.8 6.94 11.2	33.8 6.96 10.5	33.2 6.99 9.63	33.9 6.96 10.4
Exhaust gas flowrate (dscfm)	7,116	6,762	6,635	6,838
Nitrogen Oxides NO _X conc. (ppmvd) NO _X emissions (lb/hr) NO _X emissions (TpY)* <i>Permit Limit (TpY)</i>	10.5 0.54 2.4 -	10.3 0.50 2.2 -	9.80 0.47 2.0 -	10.2 0.50 2.2 6.4
Carbon Monoxide CO conc. (ppmvd) CO emissions (lb/hr) CO emissions (TpY)* <i>Permit Limit (TpY</i>)	123 3.82 16.7 -	74.3 2.19 9.6	61.1 1.77 7.8 -	86.1 2.59 11.4 <i>21.3</i>
Sulfur Dioxide SO ₂ conc. (ppmvd) SO ₂ emissions (lb/hr) <i>Permit Limit (lb/hr)</i> SO ₂ emissions (TpY)* <i>Permit Limit (TpY)</i>	0.29 0.02 - 0.09 -	0.31 0.02 - 0.09 -	0.44 0.03 - 0.13 -	0.35 0.02 <i>0.4</i> 0.10 <i>1.65</i>

Table 6.1 Measured exhaust gas conditions and air pollutant emission rates for the TOX (EUTOX)

* - calculated value based on 8,760 operating hours per year




Impact Compliance & Testing, Inc.

<u>APPENDIX 1</u>

• TOX Sample Port Diagram

Impact Compliance Testing, Inc.



AIR QUALITY DIVISION