

**Derenzo and Associates, Inc.***Environmental Consultants***AIR EMISSION TEST REPORT**

Title                    AIR EMISSION TEST REPORT FOR THE  
VERIFICATION OF AIR POLLUTANT EMISSIONS  
FROM A LANDFILL GAS FUELED INTERNAL  
COMBUSTION ENGINE

Report Date    April 29, 2015

Test Dates     March 11, 2015

<b>Facility Information</b>	
Name	Waste Management of Michigan, Inc.
Street Address	Northern Oaks Recycling and Disposal Facility 513 County Farm Road
City, County	Harrison, Clare
Phone	(989) 539-6111

<b>Facility Permit Information</b>	
ROP No.:	MI-ROP-N6010-2013
Facility SRN :	N6010

<b>Tested Process Information</b>	
Emission Unit Identification	EUICENGINE1
Model:	CAT®G3520C
Serial No.:	GZJ00226

<b>Testing Contractor</b>	
Company	Derenzo and Associates, Inc.
Mailing Address	39395 Schoolcraft Road Livonia, MI 48150
Phone	(734) 464-3880
Project No.	1411011

TABLE OF CONTENTS

	Page
<b>1.0 INTRODUCTION</b> .....	1
<b>2.0 SOURCE AND SAMPLING LOCATION DESCRIPTION</b> .....	3
2.1 General Process Description .....	3
2.2 Rated Capacities and Air Emission Controls.....	3
2.3 Sampling Locations.....	3
<b>3.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS</b> .....	4
3.1 Purpose and Objective of the Tests.....	4
3.2 Operating Conditions During the Compliance Tests .....	4
3.3 Summary of Air Pollutant Sampling Results.....	4
<b>4.0 SAMPLING AND ANALYTICAL PROCEDURES</b> .....	6
4.1 Summary of Sampling Methods.....	6
4.2 Exhaust Gas Velocity Determination (USEPA Method 2).....	6
4.3 Exhaust Gas Molecular Weight Determination (USEPA Methods 3A).....	7
4.4 Exhaust Gas Moisture Content (USEPA Method 4) .....	7
4.5 NO <sub>x</sub> and CO Concentration Measurements (USEPA Methods 7E and 10).....	7
4.6 Measurement of Volatile Organic Compounds (USEPA Method ALT-096) .....	8
<b>5.0 QA/QC ACTIVITIES</b> .....	9
5.1 NO <sub>x</sub> Converter Efficiency Test .....	9
5.2 Gas Divider Certification (USEPA Method 205).....	9
5.3 Instrumental Analyzer Interference Check.....	9
5.4 Instrument Calibration and System Bias Checks.....	9
5.5 Determination of Exhaust Gas Stratification .....	10
5.6 Meter Box Calibrations .....	10
<b>6.0 RESULTS</b> .....	11
6.1 Test Results and Allowable Emission Limits .....	11
6.2 Variations from Normal Sampling Procedures or Operating Conditions.....	11



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**RENEWABLE OPERATING PERMIT  
REPORT CERTIFICATION**

Authorized by 1994 P.A. 451, as amended. Failure to provide this information may result in civil and/or criminal penalties.

Reports submitted pursuant to R 336.1213 (Rule 213), subrules (3)(c) and/or (4)(c), of Michigan's Renewable Operating Permit (ROP) program must be certified by a responsible official. Additional information regarding the reports and documentation listed below must be kept on file for at least 5 years, as specified in Rule 213(3)(b)(ii), and be made available to the Department of Environmental Quality, Air Quality Division upon request.

Source Name Northern Oaks Recycling and Disposal Facility County Clare  
Source Address 513 N. County Farm Road City Harrison  
AQD Source ID (SRN) N6010 ROP No. N6010-2013 ROP Section No. \_\_\_\_\_


Please check the appropriate box(es):

Annual Compliance Certification (Pursuant to Rule 213(4)(c))  
Reporting period (provide inclusive dates): From \_\_\_\_\_ To \_\_\_\_\_  
 1. During the entire reporting period, this source was in compliance with ALL terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference. The method(s) used to determine compliance is/are the method(s) specified in the ROP.  
 2. During the entire reporting period this source was in compliance with all terms and conditions contained in the ROP, each term and condition of which is identified and included by this reference, EXCEPT for the deviations identified on the enclosed deviation report(s). The method used to determine compliance for each term and condition is the method specified in the ROP, unless otherwise indicated and described on the enclosed deviation report(s).

Semi-Annual (or More Frequent) Report Certification (Pursuant to Rule 213(3)(c))  
Reporting period (provide inclusive dates): From \_\_\_\_\_ To \_\_\_\_\_  
 1. During the entire reporting period, ALL monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred.  
 2. During the entire reporting period, all monitoring and associated recordkeeping requirements in the ROP were met and no deviations from these requirements or any other terms or conditions occurred, EXCEPT for the deviations identified on the enclosed deviation report(s).

Other Report Certification  
Reporting period (provide inclusive dates): From \_\_\_\_\_ To \_\_\_\_\_  
Additional monitoring reports or other applicable documents required by the ROP are attached as described:  
NSPS test report for a landfill gas fired IC engine (EUIENGINE1).  
The testing was conducted on 3/11/2015 in accordance with the enclosed test report and  
the facility was operated in compliance with the permit conditions or at the maximum  
routine operating conditions for the facility.

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in this report and the supporting enclosures are true, accurate and complete

Terry Nichols District Manager 989-539-6111  
Name of Responsible Official (print or type) Title Phone Number  
 Signature of Responsible Official  
4-30-2015 Date

\* Photocopy this form as needed.



**LIST OF TABLES**

Table	Page
3.1 Operating conditions during the test periods .....	5
3.2 Average measured emission rates for the tested Waste Management Northern Oaks Facility RICE (three-test average).....	5
6.1 Measured exhaust gas conditions and NO <sub>x</sub> , CO and VOC air pollutant emission rates Waste Management Northern Oaks Engine No. 1 (EUIENGINE1) .....	12

**LIST OF APPENDICES**

APPENDIX A	SAMPLING DIAGRAMS
APPENDIX B	OPERATING RECORDS
APPENDIX C	FLOWRATE CALCULATIONS AND DATA SHEETS
APPENDIX D	CO <sub>2</sub> , O <sub>2</sub> , CO, NO <sub>x</sub> AND VOC CALCULATIONS
APPENDIX E	INSTRUMENTAL ANALYZER RAW DATA
APPENDIX F	QA/QC RECORDS

RECEIVED  
MAY 10 1999  
MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY

**Derenzo and Associates, Inc.**

*Environmental Consultants*

AIR EMISSION TEST REPORT  
FOR THE  
VERIFICATION OF AIR POLLUTANT EMISSIONS  
FROM A  
LANDFILL GAS FUELED INTERNAL COMBUSTION ENGINE  
  
WASTE MANAGEMENT OF MICHIGAN  
NORTHERN OAKS RECYCLING AND DISPOSAL FACILITY

**1.0 INTRODUCTION**

Waste Management of Michigan, Inc. (WMI) operates one (1) Caterpillar (CAT®) Model No. G3520C gas-fired reciprocating internal combustion (IC) engine and electricity generator set at the Northern Oaks Recycling and Disposal Facility (Northern Oaks RDF) in Harrison, Clare County, Michigan. The treated landfill gas (LFG) fueled IC engine generator set is identified as emission unit EUICENGINE1 in Michigan Department of Environmental Quality-Air Quality Division (MDEQ-AQD) Renewable Operating Permit MI-ROP-N6010-2013.

The conditions of MI-ROP-N6010-2013:

1. Allow for the installation and operation of one (1) spark ignition, lean burn reciprocating internal combustion (IC) engine and electricity generation set (CAT® Model G3520C) that has a rated horsepower (hp) output of 2,233 at full load.
2. Specify that ... *Except as provided in 40 CFR 60.4243, the permittee shall conduct an initial performance test for EUICENGINE1 within one year after startup of the engine and every 8760 hours of operation or three years, whichever occurs first, to demonstrate compliance unless the engines have been certified by the manufacturer as required by 40 CFR Part 60 Subpart JJJJ and the permittee maintains the engine as required by 40 CFR 60.4243(a)(1). If a performance test is required, the performance tests shall be conducted according to 40 CFR 60.4244.*

The compliance testing was performed by Derenzo and Associates, Inc. (Derenzo and Associates), a Michigan-based environmental consulting and testing company. Derenzo and Associates representatives Tyler Wilson and Jeff Schlaf performed the field sampling and measurements March 11, 2015.

The exhaust gas sampling and analysis was performed using procedures specified in the Test Plan dated January 16, 2015 that was reviewed and approved by the Michigan Department of Environmental Quality (MDEQ). MDEQ representatives Mr. Jeremy Howe, Ms. Gina McCann, and Ms. Sydney Bruestle observed portions of the testing project. Questions regarding this emission test report should be directed to:

**RECEIVED**

MAY 08 2015

**AIR QUALITY DIV.**

**Derenzo and Associates, Inc.**

Waste Management of Michigan, Inc. (Northern Oaks RDF)  
Air Emission Test Report

April 29, 2015  
Page 2

Tyler J. Wilson  
Environmental Consultant  
Derenzo and Associates, Inc.  
39395 Schoolcraft Road  
Livonia, MI 48150  
Ph: (734) 464-3880

Debora L. Johnston  
Environmental Engineer  
Waste Management of Michigan, Inc.  
Northern Oaks Recycling and Disposal Facility  
513 County Farm Road  
Harrison, MI 48625  
(989) 539-6111

**Report Certification**

This test report was prepared by Derenzo, Associates, Inc. based on field sampling data collected by Derenzo and Associates, Inc. Facility process data were collected and provided to WMI employees or representatives. This test report has been reviewed by WMI representatives and approved for submittal to the MDEQ.

I certify that the testing was conducted in accordance with the specified test methods and submitted test plan unless otherwise specified in this report. I believe the information provided in this report and its attachments are true, accurate, and complete.

Report Prepared By:

Reviewed By:



---

Jeff Schlaf  
Environmental Consultant  
Derenzo and Associates, Inc.

---

Robert L. Harvey, P.E.  
General Manager  
Derenzo and Associates, Inc.

## **2.0 SOURCE AND SAMPLING LOCATION DESCRIPTION**

### **2.1 General Process Description**

Landfill gas (LFG) containing methane is produced in the WMI Northern Oaks RDF from the anaerobic decomposition of disposed waste materials. The LFG is collected from both active and capped landfill cells using a system of wells (gas collection system). The collected LFG is transferred to the Northern Oaks power station facility where it is treated and used as fuel for the one (1) RICE. The RICE is connected to an electricity generator that produces electricity that is transferred to the local utility.

### **2.2 Rated Capacities and Air Emission Controls**

The CAT® Model No. G3520C RICE (EUCENGINE1) has a rated output of 2,233 brake-horsepower (bhp) and the connected generator has a rated electricity output of 1,600 kilowatts (kW). The engine is designed to fire low-pressure, lean fuel mixtures (e.g., LFG) and is equipped with an air-to-fuel ratio controller that monitors engine performance parameters and automatically adjusts the air-to-fuel ratio and ignition timing to maintain efficient fuel combustion.

The engine/generator set is not equipped with add-on emission control devices. Air pollutant emissions are minimized through the proper operation of the gas treatment system and efficient fuel combustion in the engines.

The fuel consumption rate is regulated automatically to maintain the heat input rate required to support engine operations and is dependent on the fuel heat value (methane content) of the treated LFG.

### **2.3 Sampling Locations**

The RICE exhaust gas is directed through a muffler and is released to the atmosphere through a dedicated vertical exhaust stack with a vertical release point.

The exhaust stack sampling location for the CAT® Model G3520C IC engine satisfied the USEPA Method 1 criteria for a representative sample location. The inner diameter of the engine exhaust stack at the sampling location is 15.5 inches. The stack is equipped with two (2) sample ports, opposed 90°, that provide a sampling location 26 inches (1.7 duct diameters) upstream and 96 inches (6.2 duct diameters) downstream from any flow disturbance.

Appendix A presents a diagram of the performance test sampling and measurement location.



### **3.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS**

#### **3.1 Purpose and Objective of the Tests**

The conditions of ROP No. MI-ROP-N6010-2013 and 40 CFR Part 60 Subpart JJJJ require WMI to test EUICENGINE1 for carbon monoxide (CO), nitrogen oxides (NO<sub>x</sub>) and volatile organic compounds (VOCs) every 8,760 hours of operation.

The previous performance test for EUICENGINE1 (Serial No. GZJ00226) was performed on March 12, 2014 (26,713 hours). This most recent test was completed on March 11, 2015, which is within 8,760 engine operating hours from the previous test event (the recorded engine run time at the beginning of Test 1 was 35,075 hours).

#### **3.2 Operating Conditions During the Compliance Tests**

The testing was performed while the WMI engine/generator set was operated at maximum operating conditions (1,600 kW electricity output +/- 10%). WMI representatives monitored and recorded generator electricity output (kW), fuel flowrate (cubic feet per minute), and fuel methane content (%) in 15-minute increments for each test period.

In addition, the engine serial number and operating hours at the beginning of test No. 1 were recorded by the facility operators.

Appendix B provides operating records provided by WMI representatives for the test periods.

Engine output (bhp) cannot be measured directly and was calculated based on the recorded electricity output, the calculated CAT® Model G3520C generator efficiency (96.0%), and the unit conversion factor for kW to horsepower (0.7457 kW/hp).

$$\text{Engine output (bhp)} = \text{Electricity output (kW)} / (0.960) / (0.7457 \text{ kW/hp})$$

Table 3.1 presents a summary of the average engine operating conditions during the test periods.

#### **3.3 Summary of Air Pollutant Sampling Results**

The gas exhausted from the sampled LFG fueled RICE (EUICENGINE1) was sampled for three (3) one-hour test periods during the compliance testing performed March 11, 2015.

Table 3.2 presents the average measured CO, NO<sub>x</sub> and VOC emission rates for the engine (average of the three test periods for the engine) and applicable emission limits.

Test results for each one hour sampling period are presented in Section 6.0 of this report.

Table 3.1 Engine operating conditions during the test periods

Engine Parameter	EUCENGINE1 (Ranges)	EUCENGINE1 (Average)
Generator output (kW)	1,616 – 1,640	1,626
Engine output (bhp)	2,269 – 2,275	2,272
Engine LFG fuel use (scfm)	554 – 570	562
LFG methane content (%)	47.6 – 48.7	48.0
LFG lower heating value (Btu/scf)	433 – 443	437
Exhaust temperature (°F)	839 – 848	845
Fuel to leachate evaporator (scfm)	434 – 459	445

Table 3.2 Average measured emission rates for EUCENGINE1 (three-test average)

Emission Unit	CO Emission Rates		NOx Emission Rates		VOC Emission Rates	
	(lb/hr)	(g/bhp-hr)	(lb/hr)	(g/bhp-hr)	(lb/hr)	(g/bhp-hr)
Engine No. 1	10.3	2.05	3.49	0.70	0.30	0.06
Permit Limit	--	4.15	--	1.5	--	1.0
JJJJ Limit	--	5.0	--	3.0	--	1.0

#### 4.0 SAMPLING AND ANALYTICAL PROCEDURES

A test protocol for the air emission testing was reviewed and approved by the MDEQ. This section provides a summary of the sampling and analytical procedures that were used during the WMI testing periods.

##### 4.1 Summary of Sampling Methods

USEPA Method 1	Exhaust gas velocity measurement locations were determined based on the physical stack arrangement and requirements in USEPA Method 1
USEPA Method 2	Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube.
USEPA Method 3A	Exhaust gas O <sub>2</sub> and CO <sub>2</sub> content was determined using zirconia ion/paramagnetic and infrared instrumental analyzers, respectively.
USEPA Method 4	Exhaust gas moisture was determined based on the water weight gain in chilled impingers.
USEPA Method 7E	Exhaust gas NO <sub>x</sub> concentration was determined using chemiluminescence instrumental analyzers.
USEPA Method 10	Exhaust gas CO concentration was measured using an NDIR instrumental analyzer
USEPA Method 25A / ALT-096	Exhaust gas VOC (as NMHC) concentration was determined using a flame ionization analyzer equipped with methane separation column

##### 4.2 Exhaust Gas Velocity Determination (USEPA Method 2)

The RICE exhaust stack gas velocity and volumetric flow rate was determined using USEPA Method 2 prior to and after each test. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube. The Pitot tube and connective tubing were leak-checked prior to each traverse to verify the integrity of the measurement system.

The absence of significant cyclonic flow for the exhaust configuration was verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

Appendix C provides exhaust gas flowrate calculations and field data sheets.

#### **4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)**

CO<sub>2</sub> and O<sub>2</sub> content in the RICE exhaust gas stream was measured continuously throughout each test period in accordance with USEPA Method 3A. The CO<sub>2</sub> content of the exhaust was monitored using a Servomex 1440D single beam single wavelength (SBSW) infrared gas analyzer. The O<sub>2</sub> content of the exhaust was monitored using a Servomex 1440D gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the IC engine exhaust gas stream was extracted from the stack using a stainless steel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O<sub>2</sub> and CO<sub>2</sub> concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

Appendix D provides O<sub>2</sub> and CO<sub>2</sub> calculation sheets. Raw instrument response data are provided in Appendix E.

#### **4.4 Exhaust Gas Moisture Content (USEPA Method 4)**

Moisture content of the RICE exhaust gas was determined in accordance with USEPA Method 4 using a chilled impinger sampling train. The moisture sampling was performed concurrently with the instrumental analyzer sampling. During each sampling period a gas sample was extracted at a constant rate from the source where moisture was removed from the sampled gas stream using impingers that were submersed in an ice bath. At the conclusion of each sampling period, the moisture gain in the impingers was determined gravimetrically by weighing each impinger to determine net weight gain.

#### **4.5 NO<sub>x</sub> and CO Concentration Measurements (USEPA Methods 7E and 10)**

NO<sub>x</sub> and CO pollutant concentrations in the RICE exhaust gas streams were determined using a Thermo Environmental Instruments, Inc. (TEI) Model 42c High Level chemiluminescence NO<sub>x</sub> analyzer and a TEI Model 48c infrared CO analyzer.

Throughout each test period, a continuous sample of the engine exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816

data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix D provides CO and NO<sub>x</sub> calculation sheets. Raw instrument response data are provided in Appendix E.

#### **4.6 Measurement of Volatile Organic Compounds (USEPA Method 25A/ALT-096)**

The VOC emission rate was determined by measuring the nonmethane hydrocarbon (NMHC) concentration in the engine exhaust gas. NMHC pollutant concentration was determined using a TEI Model 55i Methane / Nonmethane hydrocarbon analyzer. The TEI 55i analyzer contains an internal gas chromatograph column that separates methane from non-methane components. The concentration of NMHC in the sampled gas stream, after separation from methane, is determined relative to a propane standard using a flame ionization detector in accordance with USEPA Method 25A.

The USEPA Office of Air Quality Planning and Standards (OAQPS) has issued several alternate test methods approving the use of the TEI 55-series analyzer as an effective instrument for measuring NMOC from gas-fueled reciprocating internal combustion engines (RICE) in that it uses USEPA Method 25A and 18 (ALT-066, ALT-078 and ALT-096).

Samples of the exhaust gas were delivered directly to the instrumental analyzer using the Teflon® heated sample line to prevent condensation. The sample to the NHMC analyzer was not conditioned to remove moisture. Therefore, VOC measurements correspond to standard conditions with no moisture correction (wet basis).

Prior to, and at the conclusion of each test, the instrument was calibrated using mid-range calibration (propane) and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document).

Appendix D provides VOC calculation sheets. Raw instrument response data for the NMHC analyzer is provided in Appendix E.

## **5.0 QA/QC ACTIVITIES**

### **5.1 NO<sub>x</sub> Converter Efficiency Test**

The NO<sub>2</sub> – NO conversion efficiency of the Model 42c analyzer was verified prior to the testing program. A USEPA Protocol 1 certified concentration of NO<sub>2</sub> was injected directly into the analyzer, following the initial three-point calibration, to verify the analyzer's conversion efficiency. The analyzer's NO<sub>2</sub> – NO converter uses a catalyst at high temperatures to convert the NO<sub>2</sub> to NO for measurement. The conversion efficiency of the analyzer is deemed acceptable if the measured NO<sub>2</sub> concentration is within 90% of the expected value.

The NO<sub>2</sub> – NO conversion efficiency test satisfied the USEPA Method 7E criteria (measured NO<sub>2</sub> concentration was -5.86% of the expected value, i.e., within 10% of the expected value as required by Method 7E).

### **5.2 Gas Divider Certification (USEPA Method 205)**

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (within the last 12 months) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivered calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.

### **5.3 Instrumental Analyzer Interference Check**

The instrumental analyzers used to measure NO<sub>x</sub>, CO, O<sub>2</sub> and CO<sub>2</sub> have had an interference response test performed prior to their use in the field (July 26, 2006, June 21, 2011 and June 12, 2014), pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 3.0% of the span for all measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

### **5.4 Instrument Calibration and System Bias Checks**

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the NO<sub>x</sub>, CO, CO<sub>2</sub> and O<sub>2</sub> analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the stainless steel sampling probe prior to the particulate

filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

At the beginning of each test day, appropriate high-range, mid-range, and low-range span gases followed by a zero gas were introduced to the NMHC analyzer, in series at a tee connection, which is installed between the sample probe and the particulate filter, through a poppet check valve. After each one hour test period, mid-range and zero gases were re-introduced in series at the tee connection in the sampling system to check against the method's performance specifications for calibration drift and zero drift error.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO<sub>2</sub>, O<sub>2</sub>, NO<sub>x</sub>, and CO in nitrogen and zeroed using hydrocarbon free nitrogen. The NMHC (VOC) instrument was calibrated with USEPA Protocol 1 certified concentrations of propane in air and zeroed using hydrocarbon-free air. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

### **5.5 Determination of Exhaust Gas Stratification**

A stratification test was performed for the RICE exhaust stack. The stainless steel sample probe was positioned at sample points correlating to 16.7, 50.0 (centroid) and 83.3% of the stack diameter. Pollutant concentration data were recorded at each sample point for a minimum of twice the maximum system response time.

The recorded concentration data for the RICE exhaust stack indicated that the measured CO, O<sub>2</sub> and CO<sub>2</sub> concentrations did not vary by more than 5% of the mean across the stack diameter. Therefore, the RICE exhaust gas was considered to be unstratified and the compliance test sampling was performed at a single sampling location within the RICE exhaust stack.

### **5.6 Meter Box Calibrations**

The Nutech Model 2010 sampling console, which was used for exhaust gas moisture content sampling, was calibrated prior to and after the testing program. This calibration uses the critical orifice calibration technique presented in USEPA Method 5. The metering console calibration exhibited no data outside the acceptable ranges presented in USEPA Method 5.

The digital pyrometer in the Nutech metering consoles were calibrated using a NIST traceable Omega® Model CL 23A temperature calibrator.

Appendix F presents test equipment quality assurance data (NO<sub>2</sub> – NO conversion efficiency test data, instrument calibration and system bias check records, calibration gas and gas divider certifications, interference test results, meter box calibration records, Pitot tube calibration records).

## 6.0 RESULTS

### 6.1 Test Results and Allowable Emission Limits

Engine operating data and air pollutant emission measurement results for each one hour test period are presented in Table 6.1.

The measured air pollutant emission rates for Engine No. 1 (EUIENGINE1) are less than the allowable limits specified in Subpart JJJ and Permit to Install No. MI-ROP-N6010-2013.

Reference	NO <sub>x</sub> (g/bhp-hr)	CO (g/bhp-hr)	VOC (g/bhp-hr)
ROP Emission Limit	1.5	4.15	1.0
NSPS JJJ Emission Standard	3.0	5.0	1.0

### 6.2 Variations from Normal Sampling Procedures or Operating Conditions

The testing for all pollutants was performed in accordance with USEPA methods and the approved test protocol with the exception noted below. The engine-generator set was operated within 10% of maximum output (1,600 kW generator output) during the engine test periods.

During test No. 2, the test was paused for seventeen (17) minutes because the analyzer probe was dislodged from the exhaust stack while positioning the moisture train. The probe was immediately returned to its location within the exhaust stack, and more than twice greatest system response time passed before resuming the test. Mr. Jeremy Howe of the MDEQ-AQD observed this event and approved the corrective action.



Table 6.1 Measured exhaust gas conditions and NO<sub>x</sub>, CO and VOC air pollutant emission rates  
Waste Management Northern Oaks Facility Engine No. 1 (EUCENGINE1)


Test No.	1	2	3	Three Test
Test date	3/11/15	3/11/15	3/11/15	Average
Test period (24-hr clock)	0810 - 0910	1041 - 1158	1240 - 1340	
Fuel flowrate (scfm)	561	563	561	562
Generator output (kW)	1,628	1,626	1,624	1,626
Engine output (bhp)	2,275	2,272	2,269	2,272
LFG methane content (%)	48.4	47.8	47.9	48.0
LFG heat content (Btu/scf)	440	435	436	437
Fuel to Flare (scfm)	0	0	0	0
Fuel to leachate evap. (scfm)	444	442	450	445
<u>Exhaust Gas Composition</u>				
CO <sub>2</sub> content (% vol)	10.7	11.1	11.1	11.0
O <sub>2</sub> content (% vol)	8.6	8.0	8.1	8.3
Moisture (% vol)	11.2	11.7	12.1	11.7
Exhaust gas temperature (°F)	846	843	843	845
Exhaust gas flowrate (dscfm)	3,677	3,614	3,726	3,672
Exhaust gas flowrate (scfm)	4,165	4,114	4,240	4,173
<u>Nitrogen Oxides</u>				
NO <sub>x</sub> conc. (ppmvd)	136	137	125	133
NO <sub>x</sub> emissions (lb/hr)	3.59	3.56	3.33	3.49
NO <sub>x</sub> emissions (g/bhp*hr)	0.72	0.71	0.67	0.70
Permitted emissions (g/bhp*hr)	-	-	-	1.5
<u>Carbon Monoxide</u>				
CO conc. (ppmvd)	623	653	645	640
CO emissions (lb/hr)	10.0	10.3	10.5	10.3
CO emissions (g/bhp*hr)	2.00	2.06	2.10	2.05
Permitted emissions (g/bhp*hr)	-	-	-	4.15
<u>Volatile Organic Compounds</u>				
VOC conc. (ppmv)	10.0	11.1	10.4	10.5
VOC emissions (lb/hr)	0.29	0.31	0.30	0.30
VOC emissions (g/bhp*hr)	0.06	0.06	0.06	0.06
Permitted emissions (g/bhp*hr)	-	-	-	1.0



**Derenzo and Associates, Inc.**

**APPENDIX A**

- Figure A-1 – Process Flow Diagram
- Figure A-2 – IC Engine No. 1 Sample Port Diagram

Derenzo and Associates, Inc.





Velocity sample locations as measured from stack wall

Pt. #	in.
1	0.50
2	1.63
3	3.01
4	4.99
5	10.49
6	12.49
7	13.87
8	15.00

4/2/15	<b>Waste Management – Northern Oaks Exhaust Sample Location, CAT G3520C</b>		
	Scale None	Sheet 1 of 1	Derenzo and Associates Project No. 1411011

Engine Exhaust

Facility Roof

Muffler

Sample  
Ports  
8.5"

26.0"

15.5"

96.0"

Exhaust Stack  
Cross-Section