

# FINAL REPORT



## BLUE WATER RENEWABLES, LLC

SMITHS CREEK, MICHIGAN

### COMPLIANCE TESTING REPORT: NOX, CO, AND NMOC EU-ICEENGINE 1 & EU-ICEENGINE 2

RWDI #2407209

June 3, 2024

#### SUBMITTED TO

**Jeremy Howe**  
Technical Program Unit Manager  
Michigan Department of Environment,  
Great Lakes, and Energy (EGLE)  
AQD - Technical Programs Unit (TPU)  
Constitution Hall 2<sup>nd</sup> Floor | South  
525 West Allegan Street  
Lansing, Michigan 48933

**Joyce Zhu**  
Michigan Department of Environment,  
Great Lakes, and Energy (EGLE)  
District Supervisor, Air Quality Division  
2700 Donald Court  
Warren, Michigan 48092

**Blue Water Renewables, LLC**  
6779 Smiths Creek Road  
Smith Creek, Michigan 48074

#### SUBMITTED BY

**Brad Bergeron, A.Sc.T., d.E.T.**  
Technical Director | Principal  
Brad.Bergeron@rwdi.com

**Ben Durham**  
Senior Scientist  
Ben.Durham@rwdi.com

**Steve Smith, QSTI**  
Project Manager | Associate  
Steve.Smith@rwdi.com

**RWDI USA LLC**  
Consulting Engineers & Scientists  
2239 Start Court  
Rochester Hills, Michigan 48309

T: 248.841.8442  
F: 519.823.1316



[rwdi.com](http://rwdi.com)



## EXECUTIVE SUMMARY

RWDI USA LLC (RWDI) was retained by Blue Water Renewables, LLC (Blue Water) to complete the emission sampling program at the Smiths Creek Landfill facility located at 6779 Smiths Creek Road, Smiths Creek, Michigan 48074. Blue Water operates two (2) landfill-fired engines (FG-ICEENGINES/FG-ICEENGINES-BWR2) (referred to as Engine 1 and Engine 2). Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), non-methane organic compounds (NMOC). The testing was required by Title 40 of the Code of Federal Regulations (40CFR), Subpart JJJJ, Permit No. MI-ROP-N6207-2018, and Michigan Department of Environment, Great Lakes, and Energy (EGLE) MI-PTI-N6207-2018.

Compliance testing was completed for EU-ICEENGINE 1 (Engine 1) and EU-ICEENGINE 2 (Engine 2) on April 25<sup>th</sup>, 2024.

**Executive Table i: Results Summary – EU-ICEENGINE 1**

Source	Analyte	Units	Average	Limit
Engine 1	NO <sub>x</sub>	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	32.85	150.0
		lb/hr	2.33	3.0
		g/hp-hr	0.53	2.0
	CO	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	356.92	610
		lb/hr	15.44	16.3
		g/hp-hr	3.37	5.0
	NMOC	g/hp-hr	<0.0007	1.0

**Executive Table ii: Results Summary – EU-ICEENGINE 2**

Source	Analyte	Units	Average	Limit
Engine 2	NO <sub>x</sub>	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	35.23	150.0
		lb/hr	2.53	3.0
		g/hp-hr	0.55	2.0
	CO	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	249.46	610
		lb/hr	10.91	16.3
		g/hp-hr	2.59	5.0
	NMOC	g/hp-hr	<0.0007	1.0



# TABLE OF CONTENTS

<b>1</b>	<b>INTRODUCTION.....</b>	<b>1</b>
1.1	Location and Date of Testing.....	1
1.2	Purpose of the Testing.....	1
1.3	Description of the Source.....	1
1.4	Personnel Involved in Testing.....	2
<b>2</b>	<b>SUMMARY OF RESULTS.....</b>	<b>2</b>
2.1	Operating Data.....	2
2.2	Applicable Permit Number.....	2
<b>3</b>	<b>SOURCE DESCRIPTION.....</b>	<b>3</b>
3.1	Description of Process and Emission Control Equipment.....	3
3.2	Process Flow Sheet or Diagram.....	3
3.3	Type and Quantity of Raw and Finished Materials.....	3
3.4	Normal Rated Capacity of Process.....	3
3.5	Process Instrumentation Monitored During the Testing.....	3
<b>4</b>	<b>POLLUTANTS TO BE MEASURED.....</b>	<b>3</b>
<b>5</b>	<b>SAMPLING AND ANALYSIS PROCEDURES.....</b>	<b>4</b>
5.1	Stack Velocity, Temperature, and Volumetric Flow Rate Determination.....	4
5.2	NMOC by USEPA Method 25A.....	4
5.3	Oxides of Nitrogen and Carbon Monoxide.....	5
<b>6</b>	<b>NUMBER AND LENGTH OF SAMPLING RUNS.....</b>	<b>5</b>
<b>7</b>	<b>STACK INFORMATION.....</b>	<b>6</b>
<b>8</b>	<b>FLUE GAS CONDITIONS.....</b>	<b>6</b>
<b>9</b>	<b>TEST RESULTS AND DISCUSSION.....</b>	<b>7</b>
9.1	Detailed Results.....	7
9.2	Discussion of Results.....	7
9.3	Variations in Testing Procedures.....	7
9.4	Process Upset Conditions During Testing.....	8
9.5	Maintenance Performed in Last Three Months.....	8
9.6	Re-Test.....	8
9.7	Audit Samples.....	8
9.8	Process Data.....	8



**9.9 Field Notes..... 8**  
**9.10 Calibration Data..... 8**  
**9.11 Example Calculations ..... 8**  
**9.12 Laboratory Data ..... 8**  
**9.13 Source Testing Plan and EGLE Correspondence ..... 8**

## LIST OF TABLES

(Found Within the Report Text)

**Table 1.4.1:** List of Testing Personnel.....2  
**Table 7.1:** Summary of the Stack Characteristics.....6  
**Table 8.1:** Flue Gas Conditions.....6  
**Table 9.1.1:** Results Summary – EU-ICEENGINE 1.....Executive Summary Table i & 7  
**Table 9.1.2:** Results Summary – EU-ICEENGINE 2.....Executive Summary Table ii & 7

## LIST OF TABLES

(Found After the Report Text)

**Table 1:** Summary of Sampling Parameters and Methodology  
**Table 2A:** Sampling Summary – Engine 1  
**Table 2B:** Sampling Summary – Engine 2  
**Table 3:** Summary of Emissions – EU-ICEENGINE 1  
**Table 4:** EU-ICEENGINE 1 Flow Measurements  
**Table 5:** EU-ICEENGINE 1 Process Data  
**Table 6:** Summary of Emissions – EU-ICEENGINE 2  
**Table 7:** EU-ICEENGINE 2 Flow Measurements  
**Table 8:** EU-ICEENGINE 2 Process Data

## LIST OF FIGURES

**Figure 1:** Engine1 & Engine 2 Exhaust Stack Diagram  
**Figure 2:** USEPA Method 4 Diagram  
**Figure 3:** USEPA Method 3A, 7E, 10 Diagram  
**Figure 4:** USEPA Method 25A Diagram



## LIST OF APPENDICES

<b>Appendix A:</b>	Process Data
<b>Appendix A1:</b>	EU-ICEENGINE 1
<b>Appendix A1:</b>	EU-ICEENGINE 2
<b>Appendix B:</b>	CEMs Results
<b>Appendix B1:</b>	EU-ICEENGINE 1
<b>Appendix B1:</b>	EU-ICEENGINE 2
<b>Appendix C:</b>	Flowrate
<b>Appendix C1:</b>	EU-ICEENGINE 1
<b>Appendix C1:</b>	EU-ICEENGINE 2
<b>Appendix D:</b>	Field Notes
<b>Appendix D1:</b>	EU-ICEENGINE 1
<b>Appendix D1:</b>	EU-ICEENGINE 2
<b>Appendix E:</b>	Calibration Data
<b>Appendix F:</b>	Example Calculation
<b>Appendix F1:</b>	EU-ICEENGINE 1
<b>Appendix F1:</b>	EU-ICEENGINE 2
<b>Appendix G:</b>	EGLE Correspondence and Source Testing Plan



# 1 INTRODUCTION

RWDI USA LLC (RWDI) was retained by Blue Water Renewables, LLC (Blue Water) to complete the emission sampling program at the Smiths Creek Landfill facility located at 6779 Smiths Creek Road, Smiths Creek, Michigan 48074. Blue Water operates two (2) landfill-fired engines (FG-ICEENGINES/FG-ICEENGINES-BWR2) (referred to as Engine 1 and Engine 2). Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), non-methane organic compounds (NMOC). The testing was required by Title 40 of the Code of Federal Regulations (40CFR), Subpart JJJJ, Permit No. MI-ROP-N6207-2018, and Michigan Department of Environment, Great Lakes, and Energy (EGLE) MI-PTI-N6207-2018.

Compliance testing was completed for EU-ICEENGINE 1 and EU-ICEENGINE 2 on April 25<sup>th</sup>, 2024.

## 1.1 Location and Date of Testing

The testing program was completed on April 23<sup>rd</sup>, 2024 – April 25<sup>th</sup>, 2024 at the Smiths Creek Landfill/Blue Water facility located at 6779 Smiths Creek Road, Smiths Creek, Michigan.

## 1.2 Purpose of the Testing

The purpose of testing was to show compliance with Title 40 of the Code of Federal Regulations (40CFR), Subpart JJJJ, Permit No. MI-ROP-N6207-2018, and Michigan Department of Environment, Great Lakes, and Energy (EGLE) MI-PTI-N6207-2018.

## 1.3 Description of the Source

Blue Water Renewables operates two Caterpillar G3520C Engines with associated generator sets. The engines are fueled by landfill gas generated by the landfill and produce electricity which is sent to the electric grid.



## 1.4 Personnel Involved in Testing

**Table 1.4.1:** List of Testing Personnel

<p><b>Maureen Bennett</b>                      Environmental Engineer                      Maureen.Bennett@dteenergy.com</p>	<p><b>Blue Water Renewables, LLC</b>                      6779 Smiths Creek Road                      Smiths Creek, MI 48074</p>	(734) 834-0005
<p><b>Cody Kirkum</b>                      Plant Operator                      Cody.Kirkum@dteenergy.com</p>		(586) 557-4544
<p><b>Brad Bergeron</b>                      Technical Director                      Brad.Bergeron@rwdi.com</p>	<p><b>RWDI USA LLC</b>                      2239 Star Court                      Rochester Hills, MI 48309</p>	(248) 234-3885
<p><b>Steve Smith</b>                      Project Manager                      Steve.Smith@rwdi.com</p>		(971) 940-5038
<p><b>Ben Durham</b>                      Senior Scientist                      Ben.Durham@rwdi.com</p>		(734) 474-1731
<p><b>Kate Strang</b>                      Field Technician                      Kate.Strang@rwdi.com</p>		(248) 841-8442
<p><b>Roy Zimmer</b>                      Field Technician                      Roy.Zimmer@rwdi.com</p>		

## 2 SUMMARY OF RESULTS

### 2.1 Operating Data

Operational data collected during the testing included the following (found in **Appendix A**):

- Engine Power Output (kW);
- Engine Speed;
- Engine Operating Horsepower (BHP);
- Fuel flow;
- Engine Serial Number; and
- Engine Total Operating Hours.

### 2.2 Applicable Permit Number

Title 40 of the Code of Federal Regulations (40CFR), Subpart JJJJ, Permit No. MI-ROP-N6207-2018, and Michigan Department of Environment, Great Lakes, and Energy (EGLE) MI-PTI-N6207-2018.

## 3 SOURCE DESCRIPTION

### 3.1 Description of Process and Emission Control Equipment

Refer to Section 1.3 for a description of the process.

Engine 1 and Engine 2 have catalytic converters for emissions control.

### 3.2 Process Flow Sheet or Diagram

A process schematic can be provided upon request.

### 3.3 Type and Quantity of Raw and Finished Materials

The Engines use landfill gas to produce power.

### 3.4 Normal Rated Capacity of Process

Both engines are identical spark ignition, lean burn, reciprocating internal combustion engines (Caterpillar G3520C, 2,333 bhp at 100% load) for combusting treated landfill gas to produce electricity (1.6-megawatt gross electrical output).

### 3.5 Process Instrumentation Monitored During the Testing

Engine parameters included the following:

- Engine Power Output (kW);
- Engine Speed;
- Engine Operating Horsepower (BHP);
- Fuel flow;
- Engine Serial Number; and
- Engine Total Operating Hours.

## 4 POLLUTANTS TO BE MEASURED

Testing consisted of emissions for nitrogen oxides (NO<sub>x</sub>), carbon monoxide (CO), non-methane organic compounds (NMOC).



## 5 SAMPLING AND ANALYSIS PROCEDURES

The following section provides brief descriptions of the sampling methods and discusses of any modifications to the reference test methods.

### 5.1 Stack Velocity, Temperature, and Volumetric Flow Rate Determination

The exhaust velocities and flow rates were determined following USEPA Method 2, "Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)". Velocity measurements were taken with a pre-calibrated S-Type pitot tube and incline manometer or digital manometer. Volumetric flow rates were determined following the equal area method as outlined in USEPA Method 2. Temperature measurements were made simultaneously with the velocity measurements and were conducted using a chromel-alumel type "k" thermocouple in conjunction with a calibrated digital temperature indicator.

The dry molecular weight of the stack gas was determined following calculations outlined in USEPA Method 3A for oxygen and carbon dioxide.

Stack moisture content was determined in accordance with USEPA Method 4.

### 5.2 NMOC by USEPA Method 25A

The Non-Methane Organic Compounds (NMOC) measurements were taken continuously following the USEPA Method 25A on the outlet.

The compliance test consisted of three 60-minute tests. Regular performance checks on CEMS were carried out by zero and span calibration checks using USEPA Protocol calibration gases. These checks then verify the ongoing precision of the monitor with time by introducing pollutant-free (zero) air followed by known calibration gas (span) into the monitor. The response of the monitor to pollutant-free air and the corresponding sensitivity to the span gases was reviewed frequently as an ongoing indication of analyzer performance. USEPA Method 205 was used to calibrate the analyzer.

Prior to testing, a 4-point analyzer calibration error check was conducted using USEPA protocol gases. The calibration error check was performed by introducing zero, low, mid, and high-level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response is within  $\pm 5\%$  of the certified calibration gas introduced. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre- and post-test system bias checks. The system bias checks were used to confirm that the analyzer did not drift greater than  $\pm 3\%$  throughout a test run.

Zero and upscale calibration checks were conducted both before and after each test run to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases were introduced into the sampling system at the probe outlet so that the calibration gases were analyzed in the same manner as the flue gas samples.



A gas sample was continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers were calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip was equipped with a sintered stainless-steel filter for particulate removal or heated filter system. The end of the probe was connected to a heated Teflon sample line, which delivered the sample gases from the stack to the CEM system. The heated sample line is designed to maintain the gas temperature above 250°F in order to prevent condensation of stack gas moisture within the line.

### **5.3 Oxides of Nitrogen and Carbon Monoxide**

CO and NO<sub>x</sub> concentrations was determined utilizing RWDI's continuous emissions monitoring (CEM) system. Prior to testing, a 3-point analyzer calibration error check was conducted using USEPA protocol gases. The calibration error check was performed by introducing zero, mid and high-level calibration gases directly into the analyzer. The calibration error check was performed to confirm that the analyzer response is within  $\pm 2\%$  of the certified calibration gas introduced. Prior to each test run, a system-bias test was performed where known concentrations of calibration gases were introduced at the probe tip to measure if the analyzers response was within  $\pm 5\%$  of the introduced calibration gas concentrations. At the conclusion of each test run a system-bias check was performed to evaluate the percent drift from pre and post-test system bias checks. The system bias checks were used to confirm that the analyzer did not drift greater than  $\pm 3\%$  throughout a test run.

Zero and upscale calibration checks were conducted both before and after each test run in order to quantify measurement system calibration drift and sampling system bias. Upscale is either the mid- or high-range gas, whichever most closely approximates the flue gas level. During these checks, the calibration gases were introduced into the sampling system at the probe outlet so that the calibration gases were analyzed in the same manner as the flue gas samples.

A gas sample was continuously extracted from the stack and delivered to a series of gas analyzers, which measure the pollutant or diluent concentrations in the gas. The analyzers were calibrated on-site using EPA Protocol No. 1 certified calibration mixtures. The probe tip was equipped with a sintered stainless-steel filter for particulate removal. The end of the probe was connected to a heated Teflon sample line, which delivered the sample gases from the stack to the CEM system. The heated sample line maintained the gas temperature above 250°F in order to prevent condensation of stack gas moisture within the line.

Before entering the analyzers, the gas sample passed directly into a refrigerated condenser, which cools the gas to approximately 35°F to remove the stack gas moisture. After passing through the condenser, the dry gas entered a Teflon-head diaphragm pump and a flow control panel, which then delivered the gas in series to the CO and NO<sub>x</sub> analyzers. Each of these analyzers then measured the respective gas concentrations on a dry volumetric basis.

## **6 NUMBER AND LENGTH OF SAMPLING RUNS**

Testing consisted of triplicate 1-hour tests on each Engine.



## 7 STACK INFORMATION

Engine 1 and Engine 2 had identical stack measurements.

**Table 7.1:** Summary of the Stack Characteristics

Source	Parameter	Diameter	Approximate Duct Diameters from Flow Disturbance	Number of Ports	Points per Traverse	Total Points per Test
<b>EU-ICEENGINE 1</b>	CO, NOx, NMOC, O <sub>2</sub> , CO <sub>2</sub> , moisture, flow	15.5"	72" (4.6 dia.) downstream and 24" (1.5 dia.) upstream	2	8 Flow 3 CEMS	16 Flow 3 CEMS
<b>EU-ICEENGINE 2</b>	CO, NOx, NMOC, O <sub>2</sub> , CO <sub>2</sub> , moisture, flow	15.5"	72" (4.6 dia.) downstream and 24" (1.5 dia.) upstream	2	8 Flow 3 CEMS	16 Flow 3 CEMS

## 8 FLUE GAS CONDITIONS

**Table 8.1:** Flue Gas Conditions

Parameter	Flue Gas Conditions		
	Stack Temperature	Flow Rate	Percent Moisture
<b>EU-ICEENGINE 1</b>	924°F	4,566 dscfm	12.15%
<b>EU-ICEENGINE 2</b>	928°F	4,599 dscfm	12.29%



## 9 TEST RESULTS AND DISCUSSION

### 9.1 Detailed Results

Detailed results for all analytes are provided in **Appendices B & C**.

**Table 9.1.1:** Results Summary – EU-ICEENGINE 1

Source	Analyte	Units	Average	Limit
Engine 1	NO <sub>x</sub>	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	32.85	150.0
		lb/hr	2.33	3.0
		g/hp-hr	0.53	2.0
	CO	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	356.92	610
		lb/hr	15.44	16.3
		g/hp-hr	3.37	5.0
NMOC	g/hp-hr	<0.0007	1.0	

**Table 9.1.2:** Results Summary – EU-ICEENGINE 2

Source	Analyte	Units	Average	Limit
Engine 2	NO <sub>x</sub>	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	35.23	150.0
		lb/hr	2.53	3.0
		g/hp-hr	0.55	2.0
	CO	ppmv <sub>d</sub> @ 15% O <sub>2</sub>	249.46	610
		lb/hr	10.91	16.3
		g/hp-hr	2.59	5.0
NMOC	g/hp-hr	<0.0007	1.0	

### 9.2 Discussion of Results

The detailed results of individual tests can be found in **Appendices B and C**.

### 9.3 Variations in Testing Procedures

In the instance of a negative NMOC number (due to the methane subtraction), a value of <0.10 ppmv was used.



## 9.4 Process Upset Conditions During Testing

There were no upsets in the process during testing.

## 9.5 Maintenance Performed in Last Three Months

All maintenance in the last three months has been routine.

## 9.6 Re-Test

This was not a retest.

## 9.7 Audit Samples

This test did not require any audit samples.

## 9.8 Process Data

Process data can be found in **Appendix A**.

## 9.9 Field Notes

Field notes can be found in **Appendix D**.

## 9.10 Calibration Data

Calibration can be found in **Appendix E**.

## 9.11 Example Calculations

Example calculations can be found in **Appendix F**.

## 9.12 Laboratory Data


There was no laboratory data affiliated with this testing.

## 9.13 Source Testing Plan and EGLE Correspondence

Copy of the correspondence received from the Source Testing Plan from EGLE and the Source Testing Plan submitted can be found in **Appendix G**.



## TABLES



**Table 1: Summary of Sampling Parameters and Methodology**

Source Location	No. of Tests per Stack	Sampling Parameter	Sampling Method
EU-ICEENGINE 1	3	dscfm	U.S. EPA [1] Methods 1-4
	3	O <sub>2</sub>	U.S. EPA [1] Method 3A
	3	NO <sub>x</sub>	U.S. EPA [1] Method 7E
	3	CO <sub>2</sub>	U.S. EPA [1] Method 10
	3	THC & CH <sub>4</sub>	U.S. EPA [1] Method 25A
	N/A	Calibration	U.S. EPA [1] Method 205
EU-ICEENGINE 2	3	dscfm	U.S. EPA [1] Methods 1-4
	3	O <sub>2</sub>	U.S. EPA [1] Method 3A
	3	NO <sub>x</sub>	U.S. EPA [1] Method 7E
	3	CO <sub>2</sub>	U.S. EPA [1] Method 10
	3	THC & CH <sub>4</sub>	U.S. EPA [1] Method 25A
	N/A	Calibration	U.S. EPA [1] Method 205

**Notes:**

[1] U.S. EPA - United States Environmental Protection Agency

**Table 2A: Sampling Summary - Engine 1**

Test #	Sampling Date	Start Time	End Time
1	25-Apr-24	8:35	9:34
2		10:15	11:14
3		11:50	12:49

**Table 2B: Sampling Summary - Engine 2**

Test #	Sampling Date	Start Time	End Time
1	25-Apr-24	13:35	14:34
2		15:05	16:04
3		16:29	17:28

### Table 3: Summary of Emissions - EU-ICEENGINE 1

Blue Water Renewables

Facility: Blue Water Renewables

City: Smith's Creek, MI

Source: Engine #1

Date: 4/25/2024

	Symbol	Units	Test 1	Test 2	Test 3	Average	Corrected to 15% O <sub>2</sub>	Limits
Nitrogen Oxides Concentration	NO <sub>x</sub>	ppmvd	86.36	64.55	63.89	71.60	32.85	150.0
Carbon Monoxide Concentration	CO	ppmvd	832.59	751.51	749.74	777.95	356.92	610
Oxygen Concentration	O <sub>2</sub>	% <sub>dry</sub>	7.90	8.11	8.12	8.04	-	-
Total Hydrocarbons (as propane) Concentration	THC	ppmv	444.39	486.64	487.10	472.71	-	-
Total Hydrocarbons (as propane) Concentration	THC	ppmvd	505.44	553.30	555.51	538.09	-	-
Methane (as methane) Concentration	CH <sub>4</sub>	ppmv	1164.61	1282.17	1268.03	1,238.27	-	-
Methane (as methane) Concentration	CH <sub>4</sub>	ppmvd	1324.62	1457.81	1446.12	1,409.52	-	-
Methane (as propane) Concentration	CH <sub>4</sub>	ppmvd	552.34	605.12	608.00	588.49	-	-
Non-Methane Organic Compounds Concentration	NMOC	ppmvd	<0.10	<0.10	<0.10	<0.10	-	-
<b>Reaction Factor for Methane Subtraction</b>								
Nitrogen Oxides Emission Rate	NO <sub>x</sub>	pph	2.83	2.11	2.07	2.33	-	3.0
Carbon Monoxide Emission Rate	CO	pph	16.59	14.95	14.79	15.44	-	16.3
Non-Methane Organic Compounds Emission Rate	NMOC	pph	<0.003	<0.003	<0.003	<0.003	-	-
<b>Reaction Factor for Methane Subtraction</b>								
Nitrogen Oxides Concentration	NO <sub>x</sub>	g/HP-hr	0.60	0.45	0.45	0.53	-	2.0
Carbon Monoxide Concentration	CO	g/HP-hr	3.52	3.22	3.19	3.37	-	5.0
Non-Methane Organic Compounds Concentration	NMOC	g/HP-hr	<0.0007	<0.0007	<0.0007	<0.0007	-	1.0

Reaction factor for methane subtraction: 2.40 2.41 2.38

For Tests 1, 2 and 3, NMOC numbers were negative after methane subtraction and are being reported as <0.10

## Table 4: EU-ICEENGINE 1 Flow Measurements

Blue Water Renewables

**Facility:** Blue Water Renewables

**City:** Smith's Creek, MI

**Source:** Engine #1

Parameter	Units	Test 1	Test 2	Test 3	Average
Stack Gas Temperature	°F	925.4	922.9	922.9	923.7
Stack Gas Moisture	%	12.08	12.05	12.31	12.15
Velocity	ft/sec	173.0	172.3	171.2	172.2
Actual Flowrate	acfm	13,603	13,550	13,462	13,538
Dry Reference Flowrate	dscfm	4,584	4,575	4,539	4,566
Dry Reference Flowrate	m <sup>3</sup> /s	2.16	2.16	2.14	2.15

# Table 5: EU-ICEENGINE 1 Process Data

Blue Water Renewables

Facility: Blue Water Renewables

City: Smith's Creek, MI

Source: Engine #1

Max Horspower: 2233

Max Kilowatt: 1665

Test	Time	Kilowatts (KW)	Brake Horse Power (BHP)	Load (%)
1	8:35	1,594	2,137.6	95.7%
	8:50	1,604	2,151.0	96.3%
	9:05	1,605	2,152.3	96.4%
	9:20	1,605	2,152.3	96.4%
	9:35	1,573	2,109.4	94.5%
	<b>Average</b>	<b>1,596</b>	<b>2,140.5</b>	<b>95.9%</b>
2	10:15	1,565	2098.7	94.0%
	10:30	1,577	2114.8	94.7%
	10:45	1,569	2104.0	94.2%
	11:00	1,568	2102.7	94.2%
	11:15	1,560	2092.0	93.7%
	<b>Average</b>	<b>1,568</b>	<b>2102.4</b>	<b>94.2%</b>
3	11:50	1,564	2097.3	93.9%
	12:05	1,566	2100.0	94.0%
	12:20	1,568	2102.7	94.2%
	12:35	1,570	2105.4	94.3%
	12:50	1,572	2108.1	94.4%
	<b>Average</b>	<b>1,568</b>	<b>2,102.7</b>	<b>94.2%</b>

KW to BHP Conversion Factor: 1.341

**Table 6: Summary of Emissions - EU-ICEENGINE 2**

Blue Water Renewables

**Facility:** Blue Water Renewables

**City:** Smith's Creek, MI

**Source:** Engine #2

**Date:** 4/25/2024

	Symbol	Units	Test 1	Test 2	Test 3	Average	Corrected to 15% O <sub>2</sub>	Limits
Nitrogen Oxides Concentration	NO <sub>x</sub>	ppmvd	78.49	76.48	76.07	77.01	35.23	150.0
Carbon Monoxide Concentration	CO	ppmvd	647.46	555.22	433.19	545.29	249.46	610
Oxygen Concentration	O <sub>2</sub>	% <sub>dry</sub>	8.01	8.01	7.99	8.00	-	-
Total Hydrocarbons (as propane) Concentration	THC	ppmv	401.72	408.96	417.38	409.35	-	-
Total Hydrocarbons (as propane) Concentration	THC	ppmvd	457.65	468.24	474.19	466.69	-	-
Methane (as methane) Concentration	CH <sub>4</sub>	ppmv	1071.39	1097.41	1114.13	1,094.31	-	-
Methane (as methane) Concentration	CH <sub>4</sub>	ppmvd	1220.54	1256.48	1265.77	1,247.59	-	-
Methane (as propane) Concentration	CH <sub>4</sub>	ppmvd	507.08	540.01	533.25	526.78	-	-
Non-Methane Organic Compounds Concentration	NMOC	ppmvd	<0.10	<0.10	<0.10	<0.10	-	-
<b>Emission Rates</b>								
Nitrogen Oxides Emission Rate	NO <sub>x</sub>	pph	2.59	2.51	2.49	2.53	-	3.0
Carbon Monoxide Emission Rate	CO	pph	13.01	11.09	8.62	10.91	-	16.3
Non-Methane Organic Compounds Emission Rate	NMOC	pph	<0.003	<0.003	<0.003	<0.003	-	-
<b>Reaction Factors</b>								
Nitrogen Oxides Concentration	NO <sub>x</sub>	g/HP-hr	0.56	0.54	0.53	0.55	-	2.0
Carbon Monoxide Concentration	CO	g/HP-hr	2.79	2.39	1.85	2.59	-	5.0
Non-Methane Organic Compounds Concentration	NMOC	g/HP-hr	<0.0007	<0.0007	<0.0007	<0.0007	-	1.0
<i>Reaction factor for methane subtraction:</i>			2.41	2.33	2.37			

For Tests 1, 2 and 3, NMOC numbers were negative after methane subtraction and are being reported as <0.10.

## Table 7: EU-ICEENGINE 2 Flow Measurements

Blue Water Renewables

**Facility:** Blue Water Renewables

**City:** Smith's Creek, MI

**Source:** Engine #2

Parameter	Units	Test 1	Test 2	Test 3	Average
Stack Gas Temperature	°F	928	927	929	928
Stack Gas Moisture	%	12.22	12.66	11.98	12.29
Velocity	ft/sec	174.7	173.9	173.3	174.0
Actual Flowrate	acfm	13,734	13,676	13,629	13,679
Dry Reference Flowrate	dscfm	4,625	4,594	4,579	4,599
Dry Reference Flowrate	m <sup>3</sup> /s	2.19	2.17	2.16	2.17

## Table 8: EU-ICEENGINE 2 Process Data

Blue Water Renewables

Facility: Blue Water Renewables

City: Smith's Creek, MI

Source: Engine #2

Max Horspower: 2233

Max Kilowatt: 1665

Test	Time	Kilowatts (KW)	Brake Horse Power (BHP)	Load (%)
1	13:35	1,577	2,114.8	94.7%
	13:50	1,578	2,116.1	94.8%
	14:05	1,579	2,117.4	94.8%
	14:20	1,577	2,114.8	94.7%
	14:35	1,571	2,106.7	94.3%
	<b>Average</b>	<b>1,576</b>	<b>2,114.0</b>	<b>94.7%</b>
2	15:05	1,567	2101.3	94.1%
	15:20	1,571	2106.7	94.3%
	15:35	1,575	2112.1	94.6%
	15:50	1,570	2105.4	94.3%
	16:05	1,578	2116.1	94.8%
	<b>Average</b>	<b>1,572</b>	<b>2108.3</b>	<b>94.4%</b>
3	16:29	1,581	2120.1	94.9%
	16:44	1,579	2117.4	94.8%
	16:59	1,571	2106.7	94.3%
	17:14	1,571	2106.7	94.3%
	17:29	1,583	2122.8	95.1%
	<b>Average</b>	<b>1,577</b>	<b>2,114.8</b>	<b>94.7%</b>

KW to BHP Conversion Factor: 1.341



# FIGURES







Figure No. 1




Engine #1 & #2  
Bluewater Renewables  
Smiths Creek, Michigan

Date:  
25-Apr-24

RWDI USA LLC  
2239 Star Court  
Rochester Hills, MI 48309



Figure No. 2




**USEPA Method 4**  
**Bluewater Renewables**  
Smiths Creek, Michigan

**RWDI USA LLC**  
2239 Star Court  
Rochester Hills, MI 48309  
**April 25th, 2024**





Figure No. 3




**USEPA Method 3A,7E,10**  
**Bluewater Renewables**  
Smiths Creek, Michigan

**RWDI USA LLC**  
2239 Star Court  
Rochester Hills, MI 48309  
**April 25th, 2024**





Figure No. 4



### USEPA Method 25A

Bluewater Renewables  
Smiths Creek, Michigan

Date: April 25, 2024

RWDI USA LLC  
2239 Star Court  
Rochester Hills, MI 48309

